

Scaled data based on original data using
LM-79-2019 Approved Method: Electrical and Photometric Measurements of Solid-
State Lighting Products

Test Report Prepared for
Cooper Lighting Solutions

Brand: IRiS

Report Number: P1286095

Luminaire Tested: P3AS02R309030D2WDE010 E3DL1LI

Issue Date: 1/30/2026

Test Information

Test Method: LM-79-2019
Report Number: P1286095
TEST IS SCALED FROM IESNA LM-79-08 TEST DATA (G1-2601-647-15)
Test Lab: INNOVATION CENTER
Issue Date: 1/30/2026
Manufacturer: COOPER LIGHTING SOLUTIONS
Product Line: IRiS
Catalog Number: P3AS02R309030D2WDE010 E3DL1LI
Description: 3in Adjustable Dim to Warm LED luminaire with, R30 optic, 3000K CCT AND, 90CRI , E3DL1LI TRIM
Light Source: -
Ballast/Driver: -

Summary


Lumens per Lamp: N/A
Luminaire Lumens: 345.1 lumens
Efficiency: N/A
Efficacy: 47.9 lumens/watt
Spacing Criteria (0/90/45): 0.54 / 0.54 / 0.54
Luminous Opening: Circular (Dia: 0.25' x H: 0')
CIE Type: Direct

Input Watts (W): 7.2
Input Voltage (V): NR
Input Current (Ain): NR
Voltage Rise (V): NR
Power Factor: NR
Total Harmonic Distortion (THDi): NR
Frequency (hertz): 60
Stabilization Time: NR
Operation Time: NR
Ambient Temperature (°C): NR
Test Distance: 24 FT

TEST NUMBER: P1286095

CATALOG NUMBER: P3AS02R309030D2WDE010 E3DL1LI

Luminous Intensity Polar Plot



TEST NUMBER: P1286095

CATALOG NUMBER: P3AS02R309030D2WDE010 E3DL1LI

COEFFICIENT OF UTILIZATION - ZONAL CAVITY METHOD:

RF	20				20				20				20				20
RC	80				70				50				30				10
RW	70	50	30	10	70	50	30	10	50	30	10		50	30	10		50
RCR																	
0	119	119	119	119	116	116	116	116	111	111	111		106	106	106		102
1	114	112	110	108	112	110	108	106	106	104	103		102	101	100		99
2	110	105	102	99	107	104	101	98	101	98	96		98	96	94		95
3	105	100	96	92	103	98	95	91	96	93	90		94	91	89		91
4	101	95	90	86	99	94	89	86	92	88	85		90	87	84		88
5	97	90	85	82	96	89	85	81	88	84	81		86	83	80		85
6	94	86	81	78	92	85	81	77	84	80	77		83	79	76		81
7	90	82	77	74	89	82	77	74	81	76	73		80	76	73		78
8	87	79	74	71	86	79	74	71	78	73	70		77	73	70		76
9	84	76	71	68	83	75	71	68	75	70	67		74	70	67		73
10	81	73	68	65	80	73	68	65	72	68	65		71	67	65		71

AVERAGE LUMINANCE (cd/sqm):

	0°
0°	201322
5°	191613
10°	161164
15°	116232
20°	72106
25°	41010
30°	22788
35°	12394
40°	6527
45°	3535
50°	1876
55°	1262
60°	1140
65°	1193
70°	1026
75°	847
80°	884
85°	755

MAXIMUM LUMINANCE 45°-90°:

Horizontal Angle: 0°

Vertical Angle: 45°

Luminance: 3535 cd/sqm

TEST NUMBER: P1286095

CATALOG NUMBER: P3AS02R309030D2WDE010 E3DL1LI

ZONAL LUMENS:

Zone	Lumens	% Fixture
0°-10°	78.4	22.7
10°-20°	139.3	40.4
20°-30°	80.5	23.3
30°-40°	30.6	8.9
40°-50°	9.4	2.7
50°-60°	3.2	0.9
60°-70°	2.2	0.6
70°-80°	1.2	0.3
80°-90°	0.4	0.1
90°-100°	0.0	0.0
100°-110°	0.0	0.0
110°-120°	0.0	0.0
120°-130°	0.0	0.0
130°-140°	0.0	0.0
140°-150°	0.0	0.0
150°-160°	0.0	0.0
160°-170°	0.0	0.0
170°-180°	0.0	0.0
0°-30°	298.3	86.4
0°-40°	328.8	95.3
0°-60°	341.4	98.9
0°-90°	345.1	100.0
90°-120°	0.0	0.0
90°-150°	0.0	0.0
90°-180°	0.0	0.0
0°-180°	345.1	100.0

CANDELA DISTRIBUTION:

	0°	Flux
0°	918	
5°	870	78
15°	512	139
25°	170	81
35°	46	31
45°	11	9
55°	3	3
65°	2	2
75°	1	1
85°	0	0
90°	0	

TEST NUMBER: P1286095

CATALOG NUMBER: P3AS02R309030D2WDE010 E3DL1LI

CANDELA DISTRIBUTION (FULL):

0°	
0°	918.1
1°	917.4
2°	911.9
3°	901.5
4°	888.4
5°	870.5
6°	847.7
7°	822.3
8°	793.9
9°	760.0
10°	723.8
11°	684.7
12°	643.3
13°	600.0
14°	556.0
15°	512.0
17.5°	403.8
20°	309.0
22.5°	229.1
25°	169.5
27.5°	123.2
30°	90.0
32.5°	64.9
35°	46.3
37.5°	32.3
40°	22.8
42.5°	16.0
45°	11.4
47.5°	7.8
50°	5.5
52.5°	3.9
55°	3.3
57.5°	2.9
60°	2.6
62.5°	2.3
65°	2.3
67.5°	2.0
70°	1.6
72.5°	1.3
75°	1.0
77.5°	1.0
80°	0.7
82.5°	0.7
85°	0.3
87.5°	0.0



TEST NUMBER: P1286095

CATALOG NUMBER: P3AS02R309030D2WDE010 E3DL1LI

CANDELA DISTRIBUTION (continued):



(END OF REPORT)