

Scaled data based on original data using  
LM-79-2019 Approved Method: Electrical and Photometric Measurements of Solid-  
State Lighting Products

Test Report Prepared for  
Cooper Lighting Solutions

Brand: IRiS

Report Number: P1291815

Luminaire Tested: P3AS09R15W2N902765DE010 E3DLP1GPH\_6500K

Issue Date: 1/30/2026

**Test Information**


Test Method: LM-79-2019  
Report Number: P1291815  
TEST IS SCALED FROM IESNA LM-79-08 TEST DATA (G1-2601-647-1)  
Test Lab: INNOVATION CENTER  
Issue Date: 1/30/2026  
Manufacturer: COOPER LIGHTING SOLUTIONS  
Product Line: IRiS  
Catalog Number: P3AS09R15W2N902765DE010 E3DLP1GPH\_6500K  
Description: 3in Adjustable Tunable White LED luminaire with, R15 optic, 6500K CCT AND, 90CRI ,  
E3DLP1GPH TRIM  
Light Source: -  
Ballast/Driver: -

**Summary**

Lumens per Lamp: N/A  
Luminaire Lumens: 178.0 lumens  
Efficiency: N/A  
Efficacy: 19.8 lumens/watt  
Spacing Criteria (0/90/45): 0.52 / 0.52 / 0.61  
Luminous Opening: Circular (Dia: 0.25' x H: 0')  
CIE Type: Direct  
  
Input Watts (W): 9  
Input Voltage (V): NR  
Input Current (Ain): NR  
Voltage Rise (V): NR  
Power Factor: NR  
Total Harmonic Distortion (THDi): NR  
Frequency (hertz): 60  
Stabilization Time: NR  
Operation Time: NR  
Ambient Temperature (°C): NR  
Test Distance: 24 FT

TEST NUMBER: P1291815  
CATALOG NUMBER: P3AS09R15W2N902765DE010 E3DLP1GPH\_6500K

### Luminous Intensity Polar Plot





TEST NUMBER: P1291815  
 CATALOG NUMBER: P3AS09R15W2N902765DE010 E3DLP1GPH\_6500K

**COEFFICIENT OF UTILIZATION - ZONAL CAVITY METHOD:**

|     |     |     |     |     |     |     |     |     |     |     |     |     |     |     |     |     |     |     |     |     |     |
|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|
| RF  | 20  |     |     |     | 20  |     |     |     | 20  |     |     |     | 20  |     |     |     | 20  |     |     |     |     |
| RC  | 80  |     |     |     | 70  |     |     |     | 50  |     |     |     | 30  |     |     |     | 10  |     |     | 0   |     |
| RW  | 70  | 50  | 30  | 10  | 70  | 50  | 30  | 10  | 50  | 30  | 10  | 50  | 30  | 10  | 50  | 30  | 10  | 50  | 30  | 10  | 0   |
| RCR |     |     |     |     |     |     |     |     |     |     |     |     |     |     |     |     |     |     |     |     |     |
| 0   | 119 | 119 | 119 | 119 | 116 | 116 | 116 | 116 | 111 | 111 | 111 | 106 | 106 | 106 | 102 | 102 | 102 | 100 | 100 | 100 | 100 |
| 1   | 113 | 110 | 108 | 106 | 111 | 108 | 106 | 104 | 104 | 102 | 101 | 100 | 99  | 98  | 97  | 96  | 95  | 93  | 93  | 93  | 93  |
| 2   | 108 | 103 | 98  | 95  | 105 | 101 | 97  | 94  | 98  | 95  | 92  | 95  | 92  | 90  | 92  | 90  | 88  | 86  | 86  | 86  | 86  |
| 3   | 102 | 96  | 91  | 87  | 100 | 94  | 90  | 86  | 92  | 88  | 85  | 89  | 86  | 83  | 87  | 84  | 82  | 80  | 80  | 80  | 80  |
| 4   | 97  | 90  | 84  | 80  | 95  | 88  | 83  | 79  | 86  | 82  | 78  | 84  | 81  | 78  | 82  | 79  | 77  | 75  | 75  | 75  | 75  |
| 5   | 93  | 84  | 78  | 74  | 91  | 83  | 78  | 74  | 81  | 77  | 73  | 80  | 76  | 72  | 78  | 75  | 72  | 70  | 70  | 70  | 70  |
| 6   | 88  | 79  | 73  | 69  | 87  | 79  | 73  | 69  | 77  | 72  | 69  | 76  | 71  | 68  | 74  | 71  | 68  | 66  | 66  | 66  | 66  |
| 7   | 84  | 75  | 69  | 65  | 83  | 74  | 69  | 65  | 73  | 68  | 64  | 72  | 67  | 64  | 71  | 67  | 64  | 62  | 62  | 62  | 62  |
| 8   | 80  | 71  | 65  | 61  | 79  | 71  | 65  | 61  | 69  | 64  | 61  | 68  | 64  | 61  | 67  | 63  | 60  | 59  | 59  | 59  | 59  |
| 9   | 77  | 68  | 62  | 58  | 76  | 67  | 62  | 58  | 66  | 61  | 58  | 65  | 61  | 57  | 64  | 60  | 57  | 56  | 56  | 56  | 56  |
| 10  | 74  | 64  | 59  | 55  | 73  | 64  | 59  | 55  | 63  | 58  | 55  | 62  | 58  | 55  | 62  | 57  | 54  | 53  | 53  | 53  | 53  |

**AVERAGE LUMINANCE (cd/sqm):**

|     |       |
|-----|-------|
|     | 0°    |
| 0°  | 76748 |
| 5°  | 70944 |
| 10° | 56646 |
| 15° | 42793 |
| 20° | 32576 |
| 25° | 24824 |
| 30° | 17775 |
| 35° | 11618 |
| 40° | 7128  |
| 45° | 4311  |
| 50° | 2866  |
| 55° | 2217  |
| 60° | 1886  |
| 65° | 1660  |
| 70° | 1475  |
| 75° | 1440  |
| 80° | 1137  |
| 85° | 755   |

**MAXIMUM LUMINANCE 45°-90°:**

Horizontal Angle: 0°  
 Vertical Angle: 45°  
 Luminance: 4311 cd/sqm



TEST NUMBER: P1291815  
 CATALOG NUMBER: P3AS09R15W2N902765DE010 E3DLP1GPH\_6500K

**ZONAL LUMENS:**

| Zone      | Lumens | % Fixture |
|-----------|--------|-----------|
| 0°-10°    | 28.5   | 16.0      |
| 10°-20°   | 52.7   | 29.6      |
| 20°-30°   | 46.9   | 26.3      |
| 30°-40°   | 27.8   | 15.6      |
| 40°-50°   | 11.4   | 6.4       |
| 50°-60°   | 5.3    | 3.0       |
| 60°-70°   | 3.3    | 1.8       |
| 70°-80°   | 1.7    | 1.0       |
| 80°-90°   | 0.4    | 0.3       |
| 90°-100°  | 0.0    | 0.0       |
| 100°-110° | 0.0    | 0.0       |
| 110°-120° | 0.0    | 0.0       |
| 120°-130° | 0.0    | 0.0       |
| 130°-140° | 0.0    | 0.0       |
| 140°-150° | 0.0    | 0.0       |
| 150°-160° | 0.0    | 0.0       |
| 160°-170° | 0.0    | 0.0       |
| 170°-180° | 0.0    | 0.0       |
| 0°-30°    | 128.1  | 72.0      |
| 0°-40°    | 155.9  | 87.6      |
| 0°-60°    | 172.6  | 97.0      |
| 0°-90°    | 178.0  | 100.0     |
| 90°-120°  | 0.0    | 0.0       |
| 90°-150°  | 0.0    | 0.0       |
| 90°-180°  | 0.0    | 0.0       |
| 0°-180°   | 178.0  | 100.0     |

**CANDELA DISTRIBUTION:**

|     | 0°  | Flux |
|-----|-----|------|
| 0°  | 350 |      |
| 5°  | 322 | 29   |
| 15° | 188 | 53   |
| 25° | 103 | 47   |
| 35° | 43  | 28   |
| 45° | 14  | 11   |
| 55° | 6   | 5    |
| 65° | 3   | 3    |
| 75° | 2   | 2    |
| 85° | 0   | 0    |
| 90° | 0   |      |



TEST NUMBER: P1291815  
CATALOG NUMBER: P3AS09R15W2N902765DE010 E3DLP1GPH\_6500K

**CANDELA DISTRIBUTION (FULL):**

| 0°    |       |
|-------|-------|
| 0°    | 350.0 |
| 1°    | 349.2 |
| 2°    | 346.6 |
| 3°    | 341.4 |
| 4°    | 332.7 |
| 5°    | 322.3 |
| 6°    | 311.0 |
| 7°    | 297.7 |
| 8°    | 283.8 |
| 9°    | 269.7 |
| 10°   | 254.4 |
| 12.5° | 219.4 |
| 15°   | 188.5 |
| 17.5° | 161.9 |
| 20°   | 139.6 |
| 22.5° | 120.0 |
| 25°   | 102.6 |
| 27.5° | 85.8  |
| 30°   | 70.2  |
| 32.5° | 56.1  |
| 35°   | 43.4  |
| 37.5° | 33.2  |
| 40°   | 24.9  |
| 42.5° | 18.5  |
| 45°   | 13.9  |
| 47.5° | 10.7  |
| 50°   | 8.4   |
| 52.5° | 6.9   |
| 55°   | 5.8   |
| 57.5° | 4.9   |
| 60°   | 4.3   |
| 62.5° | 3.8   |
| 65°   | 3.2   |
| 67.5° | 2.9   |
| 70°   | 2.3   |
| 72.5° | 2.0   |
| 75°   | 1.7   |
| 77.5° | 1.2   |
| 80°   | 0.9   |
| 82.5° | 0.6   |
| 85°   | 0.3   |
| 87.5° | 0.3   |
| 90°   | 0.0   |

(END OF REPORT)