

Scaled data based on original data using
LM-79-2019 Approved Method: Electrical and Photometric Measurements of Solid-
State Lighting Products

Test Report Prepared for
Cooper Lighting Solutions

Brand: IRiS

Report Number: P1301370

Luminaire Tested: P3AS17R50W2N902750DE010 E3CD1MMS_5000K

Issue Date: 1/30/2026

Test Information

Test Method: LM-79-2019
Report Number: P1301370
TEST IS SCALED FROM IESNA LM-79-08 TEST DATA (G1-2601-647-32)
Test Lab: INNOVATION CENTER
Issue Date: 1/30/2026
Manufacturer: COOPER LIGHTING SOLUTIONS
Product Line: IRiS
Catalog Number: P3AS17R50W2N902750DE010 E3CD1MMS_5000K
Description: 3in Adjustable Tunable White LED luminaire with, R50 optic, 5000K CCT AND, 90CRI , E3CD1MMS TRIM
Light Source: -
Ballast/Driver: -


Summary

Lumens per Lamp: N/A
Luminaire Lumens: 1649.9 lumens
Efficiency: N/A
Efficacy: 85.0 lumens/watt
Spacing Criteria (0/90/45): 0.84 / 0.84 / 0.76
Luminous Opening: Circular (Dia: 0.25' x H: 0')
CIE Type: Direct

Input Watts (W): 19.4
Input Voltage (V): NR
Input Current (Ain): NR
Voltage Rise (V): NR
Power Factor: NR
Total Harmonic Distortion (THDi): NR
Frequency (hertz): 60
Stabilization Time: NR
Operation Time: NR
Ambient Temperature (°C): NR
Test Distance: 24 FT

TEST NUMBER: P1301370
CATALOG NUMBER: P3AS17R50W2N902750DE010 E3CD1MMS_5000K

Luminous Intensity Polar Plot





TEST NUMBER: P1301370

CATALOG NUMBER: P3AS17R50W2N902750DE010 E3CD1MMS_5000K

ZONAL LUMENS:

Zone	Lumens	% Fixture
0°-10°	240.6	14.6
10°-20°	608.4	36.9
20°-30°	609.4	36.9
30°-40°	171.3	10.4
40°-50°	10.3	0.6
50°-60°	3.9	0.2
60°-70°	3.1	0.2
70°-80°	2.1	0.1
80°-90°	0.8	0.0
90°-100°	0.0	0.0
100°-110°	0.0	0.0
110°-120°	0.0	0.0
120°-130°	0.0	0.0
130°-140°	0.0	0.0
140°-150°	0.0	0.0
150°-160°	0.0	0.0
160°-170°	0.0	0.0
170°-180°	0.0	0.0
0°-30°	1458.4	88.4
0°-40°	1629.7	98.8
0°-60°	1644.0	99.6
0°-90°	1649.9	100.0
90°-120°	0.0	0.0
90°-150°	0.0	0.0
90°-180°	0.0	0.0
0°-180°	1649.9	100.0

CANDELA DISTRIBUTION:

	0°	Flux
0°	2621	
5°	2564	241
15°	2189	608
25°	1388	609
35°	220	171
45°	6	10
55°	5	4
65°	4	3
75°	2	2
85°	1	1
90°	0	



TEST NUMBER: P1301370
CATALOG NUMBER: P3AS17R50W2N902750DE010 E3CD1MMS_5000K

CANDELA DISTRIBUTION (FULL):

	0°
0°	2620.6
2.5°	2607.3
5°	2563.9
7.5°	2504.8
10°	2433.7
12.5°	2326.3
15°	2188.9
17.5°	2030.9
20°	1877.7
22.5°	1687.2
25°	1388.1
27.5°	1033.5
30°	721.2
32.5°	435.4
35°	219.5
37.5°	103.7
40°	48.2
42.5°	18.1
45°	6.0
47.5°	4.8
50°	4.8
52.5°	4.8
55°	4.8
57.5°	3.6
60°	3.6
62.5°	3.6
65°	3.6
67.5°	2.4
70°	2.4
72.5°	2.4
75°	2.4
77.5°	1.2
80°	1.2
82.5°	1.2
85°	1.2
87.5°	0.0
90°	0.0

(END OF REPORT)