

Scaled data based on original data using
LM-79-2019 Approved Method: Electrical and Photometric Measurements of Solid-
State Lighting Products

Test Report Prepared for
Cooper Lighting Solutions

Brand: IRiS

Report Number: P1301407

Luminaire Tested: P3AS17R50W2N902750DE010 E3DL1H_3000K

Issue Date: 1/30/2026

Test Information

Test Method: LM-79-2019
Report Number: P1301407
TEST IS SCALED FROM IESNA LM-79-08 TEST DATA (G1-2601-647-31)
Test Lab: INNOVATION CENTER
Issue Date: 1/30/2026
Manufacturer: COOPER LIGHTING SOLUTIONS
Product Line: IRiS
Catalog Number: P3AS17R50W2N902750DE010 E3DL1H_3000K
Description: 3in Adjustable Tunable White LED luminaire with, R50 optic, 3000K CCT AND, 90CRI ,
E3DL1H TRIM
Light Source: -
Ballast/Driver: -


Summary

Lumens per Lamp: N/A
Luminaire Lumens: 1343.0 lumens
Efficiency: N/A
Efficacy: 69.2 lumens/watt
Spacing Criteria (0/90/45): 0.77 / 0.77 / 0.75
Luminous Opening: Circular (Dia: 0.25' x H: 0')
CIE Type: Direct

Input Watts (W): 19.4
Input Voltage (V): NR
Input Current (Ain): NR
Voltage Rise (V): NR
Power Factor: NR
Total Harmonic Distortion (THDi): NR
Frequency (hertz): 60
Stabilization Time: NR
Operation Time: NR
Ambient Temperature (°C): NR
Test Distance: 24 FT

TEST NUMBER: P1301407
CATALOG NUMBER: P3AS17R50W2N902750DE010 E3DL1H_3000K

Luminous Intensity Polar Plot





TEST NUMBER: P1301407

CATALOG NUMBER: P3AS17R50W2N902750DE010 E3DL1H_3000K

ZONAL LUMENS:

Zone	Lumens	% Fixture
0°-10°	177.1	13.2
10°-20°	428.0	31.9
20°-30°	419.9	31.3
30°-40°	211.5	15.7
40°-50°	66.8	5.0
50°-60°	17.3	1.3
60°-70°	12.2	0.9
70°-80°	7.6	0.6
80°-90°	2.6	0.2
90°-100°	0.0	0.0
100°-110°	0.0	0.0
110°-120°	0.0	0.0
120°-130°	0.0	0.0
130°-140°	0.0	0.0
140°-150°	0.0	0.0
150°-160°	0.0	0.0
160°-170°	0.0	0.0
170°-180°	0.0	0.0
0°-30°	1024.9	76.3
0°-40°	1236.4	92.1
0°-60°	1320.6	98.3
0°-90°	1343.0	100.0
90°-120°	0.0	0.0
90°-150°	0.0	0.0
90°-180°	0.0	0.0
0°-180°	1343.0	100.0

CANDELA DISTRIBUTION:

	0°	Flux
0°	1950	
5°	1903	177
15°	1548	428
25°	933	420
35°	325	212
45°	81	67
55°	19	17
65°	12	12
75°	7	8
85°	2	3
90°	0	



TEST NUMBER: P1301407
CATALOG NUMBER: P3AS17R50W2N902750DE010 E3DL1H_3000K

CANDELA DISTRIBUTION (FULL):

0°	
0°	1950.0
2.5°	1938.0
5°	1903.4
7.5°	1841.3
10°	1762.5
12.5°	1661.0
15°	1547.5
17.5°	1416.2
20°	1266.9
22.5°	1105.7
25°	932.6
27.5°	748.7
30°	579.1
32.5°	435.8
35°	324.8
37.5°	240.0
40°	175.5
42.5°	124.2
45°	81.2
47.5°	46.6
50°	27.5
52.5°	20.3
55°	19.1
57.5°	16.7
60°	15.5
62.5°	14.3
65°	11.9
67.5°	10.7
70°	9.6
72.5°	8.4
75°	7.2
77.5°	6.0
80°	4.8
82.5°	3.6
85°	2.4
87.5°	1.2
90°	0.0

(END OF REPORT)