

Scaled data based on original data using
LM-79-2019 Approved Method: Electrical and Photometric Measurements of Solid-
State Lighting Products

Test Report Prepared for
Cooper Lighting Solutions

Brand: IRiS

Report Number: P1246577

Luminaire Tested: P3A09R459024DE010 E3DLP1LI

Issue Date: 1/30/2026

Test Information

Test Method: LM-79-2019
Report Number: P1246577
TEST IS SCALED FROM IESNA LM-79-08 TEST DATA (G1-2601-647-25)
Test Lab: INNOVATION CENTER
Issue Date: 1/30/2026
Manufacturer: COOPER LIGHTING SOLUTIONS
Product Line: IRiS
Catalog Number: P3A09R459024DE010 E3DLP1LI
Description: 3in Adjustable LED luminaire with, R45 optic, 2400K CCT AND, 90CRI , E3DLP1LI TRIM
Light Source: -
Ballast/Driver: -

Summary


Lumens per Lamp: N/A
Luminaire Lumens: 466.0 lumens
Efficiency: N/A
Efficacy: 42.0 lumens/watt
Spacing Criteria (0/90/45): 0.73 / 0.73 / 0.76
Luminous Opening: Circular (Dia: 0.25' x H: 0')
CIE Type: Direct

Input Watts (W): 11.1
Input Voltage (V): NR
Input Current (Ain): NR
Voltage Rise (V): NR
Power Factor: NR
Total Harmonic Distortion (THDi): NR
Frequency (hertz): 60
Stabilization Time: NR
Operation Time: NR
Ambient Temperature (°C): NR
Test Distance: 24 FT

TEST NUMBER: P1246577

CATALOG NUMBER: P3A09R459024DE010 E3DLP1LI

Luminous Intensity Polar Plot



TEST NUMBER: P1246577

CATALOG NUMBER: P3A09R459024DE010 E3DLP1LI

COEFFICIENT OF UTILIZATION - ZONAL CAVITY METHOD:

RF	20				20				20				20				20
RC	80				70				50				30				10
RW	70	50	30	10	70	50	30	10	50	30	10		50	30	10		50
RCR																	
0	119	119	119	119	116	116	116	116	111	111	111		106	106	106		102
1	113	110	107	105	111	108	106	103	104	102	100		100	99	97		97
2	107	102	98	94	105	100	96	93	97	94	91		94	91	89		91
3	102	95	90	85	100	93	89	85	91	87	83		88	85	82		86
4	96	88	83	78	94	87	82	78	85	81	77		83	79	76		81
5	91	83	77	72	90	82	76	72	80	75	71		78	74	71		77
6	87	78	72	67	85	77	71	67	75	70	66		74	69	66		73
7	83	73	67	63	81	72	67	63	71	66	62		70	65	62		69
8	79	69	63	59	77	68	63	59	67	62	58		66	62	58		65
9	75	65	59	55	74	65	59	55	64	59	55		63	58	55		62
10	72	62	56	52	71	61	56	52	61	55	52		60	55	52		59

AVERAGE LUMINANCE (cd/sqm):

	0°
0°	138805
5°	135637
10°	125115
15°	108809
20°	89374
25°	69536
30°	51350
35°	36138
40°	22557
45°	12218
50°	6618
55°	5696
60°	5087
65°	4358
70°	3719
75°	3813
80°	3283
85°	3271

MAXIMUM LUMINANCE 45°-90°:

Horizontal Angle: 0°

Vertical Angle: 45°

Luminance: 12218 cd/sqm

TEST NUMBER: P1246577

CATALOG NUMBER: P3A09R459024DE010 E3DLP1LI

ZONAL LUMENS:

Zone	Lumens	% Fixture
0°-10°	57.1	12.2
10°-20°	132.5	28.4
20°-30°	131.5	28.2
30°-40°	84.7	18.2
40°-50°	32.6	7.0
50°-60°	13.3	2.8
60°-70°	8.4	1.8
70°-80°	4.5	1.0
80°-90°	1.4	0.3
90°-100°	0.0	0.0
100°-110°	0.0	0.0
110°-120°	0.0	0.0
120°-130°	0.0	0.0
130°-140°	0.0	0.0
140°-150°	0.0	0.0
150°-160°	0.0	0.0
160°-170°	0.0	0.0
170°-180°	0.0	0.0
0°-30°	321.1	68.9
0°-40°	405.8	87.1
0°-60°	451.7	96.9
0°-90°	466.0	100.0
90°-120°	0.0	0.0
90°-150°	0.0	0.0
90°-180°	0.0	0.0
0°-180°	466.0	100.0

CANDELA DISTRIBUTION:

	0°	Flux
0°	633	
5°	616	57
15°	479	132
25°	287	132
35°	135	85
45°	39	33
55°	15	13
65°	8	8
75°	4	5
85°	1	1
90°	0	

TEST NUMBER: P1246577

CATALOG NUMBER: P3A09R459024DE010 E3DLP1LI

CANDELA DISTRIBUTION (FULL):

0°	
0°	633.0
2.5°	629.8
5°	616.2
7.5°	592.9
10°	561.9
12.5°	523.2
15°	479.3
17.5°	431.5
20°	383.0
22.5°	333.9
25°	287.4
27.5°	243.5
30°	202.8
32.5°	167.3
35°	135.0
37.5°	105.9
40°	78.8
42.5°	56.8
45°	39.4
47.5°	26.5
50°	19.4
52.5°	16.1
55°	14.9
57.5°	12.9
60°	11.6
62.5°	9.7
65°	8.4
67.5°	7.1
70°	5.8
72.5°	5.2
75°	4.5
77.5°	3.2
80°	2.6
82.5°	1.9
85°	1.3
87.5°	0.6
90°	0.0

(END OF REPORT)