

Scaled data based on original data using  
LM-79-2019 Approved Method: Electrical and Photometric Measurements of Solid-  
State Lighting Products

Test Report Prepared for  
Cooper Lighting Solutions

Brand: IRiS

Report Number: P1266584

Luminaire Tested: P3A05R209735DE010 E3CD1MB

Issue Date: 1/30/2026

**Test Information**

Test Method: LM-79-2019  
Report Number: P1266584  
TEST IS SCALED FROM IESNA LM-79-08 TEST DATA (G1-2601-647-8)  
Test Lab: INNOVATION CENTER  
Issue Date: 1/30/2026  
Manufacturer: COOPER LIGHTING SOLUTIONS  
Product Line: IRiS  
Catalog Number: P3A05R209735DE010 E3CD1MB  
Description: 3in Adjustable LED luminaire with, R20 optic, 3500K CCT AND, 97CRI , E3CD1MB TRIM  
Light Source: -  
Ballast/Driver: -

**Summary**


Lumens per Lamp: N/A  
Luminaire Lumens: 589.0 lumens  
Efficiency: N/A  
Efficacy: 81.8 lumens/watt  
Spacing Criteria (0/90/45): 0.35 / 0.35 / 0.34  
Luminous Opening: Circular (Dia: 0.25' x H: 0')  
CIE Type: Direct

Input Watts (W): 7.2  
Input Voltage (V): NR  
Input Current (Ain): NR  
Voltage Rise (V): NR  
Power Factor: NR  
Total Harmonic Distortion (THDi): NR  
Frequency (hertz): 60  
Stabilization Time: NR  
Operation Time: NR  
Ambient Temperature (°C): NR  
Test Distance: 24 FT

TEST NUMBER: P1266584

CATALOG NUMBER: P3A05R209735DE010 E3CD1MB

### Luminous Intensity Polar Plot



TEST NUMBER: P1266584

CATALOG NUMBER: P3A05R209735DE010 E3CD1MB

**COEFFICIENT OF UTILIZATION - ZONAL CAVITY METHOD:**

|     |     |     |     |     |     |     |     |     |     |     |     |     |     |     |     |     |     |     |    |    |
|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|----|----|
| RF  | 20  |     |     |     | 20  |     |     |     |     | 20  |     |     |     |     | 20  |     |     |     |    | 20 |
| RC  | 80  |     |     |     | 70  |     |     |     |     | 50  |     |     |     |     | 30  |     |     |     |    | 10 |
| RW  | 70  | 50  | 30  | 10  | 70  | 50  | 30  | 10  | 50  | 30  | 10  | 50  | 30  | 10  | 50  | 30  | 10  | 50  | 30 | 10 |
| RCR |     |     |     |     |     |     |     |     |     |     |     |     |     |     |     |     |     |     |    |    |
| 0   | 119 | 119 | 119 | 119 | 116 | 116 | 116 | 116 | 111 | 111 | 111 | 106 | 106 | 106 | 102 | 102 | 102 | 100 |    |    |
| 1   | 116 | 114 | 112 | 110 | 113 | 112 | 110 | 109 | 108 | 106 | 105 | 104 | 103 | 102 | 101 | 100 | 99  | 98  |    |    |
| 2   | 112 | 109 | 106 | 104 | 110 | 108 | 105 | 103 | 104 | 103 | 101 | 102 | 100 | 99  | 99  | 98  | 97  | 95  |    |    |
| 3   | 109 | 105 | 102 | 100 | 108 | 104 | 101 | 99  | 102 | 99  | 97  | 99  | 98  | 96  | 97  | 96  | 95  | 93  |    |    |
| 4   | 107 | 102 | 99  | 96  | 105 | 101 | 98  | 96  | 99  | 97  | 94  | 97  | 95  | 93  | 96  | 94  | 92  | 91  |    |    |
| 5   | 104 | 99  | 96  | 93  | 103 | 98  | 95  | 93  | 97  | 94  | 92  | 95  | 93  | 91  | 94  | 92  | 91  | 90  |    |    |
| 6   | 102 | 97  | 93  | 91  | 101 | 96  | 93  | 90  | 95  | 92  | 90  | 94  | 91  | 89  | 93  | 90  | 89  | 88  |    |    |
| 7   | 100 | 94  | 91  | 88  | 99  | 94  | 91  | 88  | 93  | 90  | 88  | 92  | 89  | 87  | 91  | 89  | 87  | 86  |    |    |
| 8   | 98  | 92  | 89  | 86  | 97  | 92  | 89  | 86  | 91  | 88  | 86  | 90  | 88  | 86  | 89  | 87  | 85  | 85  |    |    |
| 9   | 96  | 90  | 87  | 85  | 95  | 90  | 87  | 85  | 89  | 86  | 84  | 89  | 86  | 84  | 88  | 86  | 84  | 83  |    |    |
| 10  | 94  | 89  | 85  | 83  | 93  | 88  | 85  | 83  | 88  | 85  | 83  | 87  | 84  | 83  | 86  | 84  | 82  | 82  |    |    |

**AVERAGE LUMINANCE (cd/sqm):**

|     |        |
|-----|--------|
|     | 0°     |
| 0°  | 914773 |
| 5°  | 794011 |
| 10° | 490617 |
| 15° | 170398 |
| 20° | 52341  |
| 25° | 18509  |
| 30° | 6836   |
| 35° | 2757   |
| 40° | 1460   |
| 45° | 589    |
| 50° | 307    |
| 55° | 344    |
| 60° | 395    |
| 65° | 259    |
| 70° | 321    |
| 75° | 424    |
| 80° | 0      |
| 85° | 0      |

**MAXIMUM LUMINANCE 45°-90°:**

Horizontal Angle: 0°

Vertical Angle: 45°

Luminance: 589 cd/sqm

TEST NUMBER: P1266584

CATALOG NUMBER: P3A05R209735DE010 E3CD1MB

**ZONAL LUMENS:**

| Zone      | Lumens | % Fixture |
|-----------|--------|-----------|
| 0°-10°    | 299.4  | 50.8      |
| 10°-20°   | 237.5  | 40.3      |
| 20°-30°   | 41.1   | 7.0       |
| 30°-40°   | 7.5    | 1.3       |
| 40°-50°   | 1.7    | 0.3       |
| 50°-60°   | 0.8    | 0.1       |
| 60°-70°   | 0.5    | 0.1       |
| 70°-80°   | 0.5    | 0.1       |
| 80°-90°   | 0.0    | 0.0       |
| 90°-100°  | 0.0    | 0.0       |
| 100°-110° | 0.0    | 0.0       |
| 110°-120° | 0.0    | 0.0       |
| 120°-130° | 0.0    | 0.0       |
| 130°-140° | 0.0    | 0.0       |
| 140°-150° | 0.0    | 0.0       |
| 150°-160° | 0.0    | 0.0       |
| 160°-170° | 0.0    | 0.0       |
| 170°-180° | 0.0    | 0.0       |
| <hr/>     |        |           |
| 0°-30°    | 578.0  | 98.1      |
| 0°-40°    | 585.5  | 99.4      |
| 0°-60°    | 588.0  | 99.8      |
| 0°-90°    | 589.0  | 100.0     |
| 90°-120°  | 0.0    | 0.0       |
| 90°-150°  | 0.0    | 0.0       |
| 90°-180°  | 0.0    | 0.0       |
| 0°-180°   | 589.0  | 100.0     |

**CANDELA DISTRIBUTION:**

|     | 0°   | Flux |
|-----|------|------|
| 0°  | 4172 |      |
| 5°  | 3607 | 299  |
| 15° | 751  | 238  |
| 25° | 76   | 41   |
| 35° | 10   | 7    |
| 45° | 2    | 2    |
| 55° | 1    | 1    |
| 65° | 0    | 1    |
| 75° | 0    | 0    |
| 85° | 0    | 0    |
| 90° | 0    |      |

TEST NUMBER: P1266584

CATALOG NUMBER: P3A05R209735DE010 E3CD1MB

**CANDELA DISTRIBUTION (FULL):**

| 0°    |        |
|-------|--------|
| 0°    | 4171.7 |
| 1°    | 4151.7 |
| 2°    | 4072.4 |
| 3°    | 3945.2 |
| 4°    | 3796.0 |
| 5°    | 3607.2 |
| 6°    | 3390.8 |
| 7°    | 3139.1 |
| 8°    | 2852.3 |
| 9°    | 2530.2 |
| 10°   | 2203.4 |
| 12.5° | 1389.8 |
| 15°   | 750.6  |
| 17.5° | 401.0  |
| 20°   | 224.3  |
| 22.5° | 128.2  |
| 25°   | 76.5   |
| 27.5° | 46.6   |
| 30°   | 27.0   |
| 32.5° | 15.9   |
| 35°   | 10.3   |
| 37.5° | 7.0    |
| 40°   | 5.1    |
| 42.5° | 3.3    |
| 45°   | 1.9    |
| 47.5° | 0.9    |
| 50°   | 0.9    |
| 52.5° | 0.9    |
| 55°   | 0.9    |
| 57.5° | 0.9    |
| 60°   | 0.9    |
| 62.5° | 0.5    |
| 65°   | 0.5    |
| 67.5° | 0.5    |
| 70°   | 0.5    |
| 72.5° | 0.5    |
| 75°   | 0.5    |
| 77.5° | 0.5    |
| 80°   | 0.0    |
| 82.5° | 0.0    |
| 85°   | 0.0    |
| 87.5° | 0.0    |
| 90°   | 0.0    |

(END OF REPORT)