

Scaled data based on original data using
LM-79-2019 Approved Method: Electrical and Photometric Measurements of Solid-
State Lighting Products

Test Report Prepared for
Cooper Lighting Solutions

Brand: IRiS

Report Number: P1273334

Luminaire Tested: P3A05R309830DE010 E3DLD1GPH

Issue Date: 1/30/2026

Test Information

Test Method: LM-79-2019
Report Number: P1273334
TEST IS SCALED FROM IESNA LM-79-08 TEST DATA (G1-2601-647-14)
Test Lab: INNOVATION CENTER
Issue Date: 1/30/2026
Manufacturer: COOPER LIGHTING SOLUTIONS
Product Line: IRiS
Catalog Number: P3A05R309830DE010 E3DLD1GPH
Description: 3in Adjustable LED luminaire with, R30 optic, 3000K CCT AND, 98CRI , E3DLD1GPH TRIM
Light Source: -
Ballast/Driver: -

Summary


Lumens per Lamp: N/A
Luminaire Lumens: 148.0 lumens
Efficiency: N/A
Efficacy: 20.6 lumens/watt
Spacing Criteria (0/90/45): 0.78 / 0.78 / 0.85
Luminous Opening: Circular (Dia: 0.25' x H: 0')
CIE Type: Direct

Input Watts (W): 7.2
Input Voltage (V): NR
Input Current (Ain): NR
Voltage Rise (V): NR
Power Factor: NR
Total Harmonic Distortion (THDi): NR
Frequency (hertz): 60
Stabilization Time: NR
Operation Time: NR
Ambient Temperature (°C): NR
Test Distance: 24 FT

TEST NUMBER: P1273334

CATALOG NUMBER: P3A05R309830DE010 E3DLD1GPH

Luminous Intensity Polar Plot



TEST NUMBER: P1273334

CATALOG NUMBER: P3A05R309830DE010 E3DLD1GPH

COEFFICIENT OF UTILIZATION - ZONAL CAVITY METHOD:

RF	20				20					20					20					20
RC	80				70					50					30					10
RW	70	50	30	10	70	50	30	10	50	30	10	50	30	10	50	30	10	50	30	10
RCR																				
0	119	119	119	119	116	116	116	116	111	111	111	106	106	106	102	102	102	100		
1	112	109	106	104	110	107	105	102	103	101	99	99	98	96	96	94	93	91		
2	106	100	96	92	104	99	94	91	95	92	89	92	89	87	89	87	85	83		
3	100	92	87	82	98	91	86	82	88	84	80	86	82	79	84	80	78	76		
4	94	85	79	74	92	84	79	74	82	77	73	80	76	72	78	74	71	70		
5	89	79	73	68	87	78	72	68	76	71	67	75	70	66	73	69	66	64		
6	84	74	67	62	82	73	67	62	71	66	62	70	65	61	69	64	61	59		
7	79	69	62	58	78	68	62	58	67	61	57	66	61	57	65	60	57	55		
8	75	65	58	54	74	64	58	53	63	57	53	62	57	53	61	56	53	51		
9	71	61	54	50	70	60	54	50	59	54	50	58	53	50	57	53	49	48		
10	68	57	51	47	67	57	51	47	56	50	47	55	50	46	54	50	46	45		

AVERAGE LUMINANCE (cd/sqm):

	0°
0°	34975
5°	34184
10°	31774
15°	28286
20°	24315
25°	20614
30°	17117
35°	13411
40°	9618
45°	6295
50°	3582
55°	2370
60°	2237
65°	2075
70°	1859
75°	1694
80°	1642
85°	1258

MAXIMUM LUMINANCE 45°-90°:

Horizontal Angle: 0°

Vertical Angle: 45°

Luminance: 6295 cd/sqm

TEST NUMBER: P1273334

CATALOG NUMBER: P3A05R309830DE010 E3DLD1GPH

ZONAL LUMENS:

Zone	Lumens	% Fixture
0°-10°	14.4	9.7
10°-20°	34.6	23.4
20°-30°	39.0	26.4
30°-40°	31.2	21.1
40°-50°	16.0	10.8
50°-60°	6.0	4.1
60°-70°	4.0	2.7
70°-80°	2.1	1.4
80°-90°	0.6	0.4
90°-100°	0.0	0.0
100°-110°	0.0	0.0
110°-120°	0.0	0.0
120°-130°	0.0	0.0
130°-140°	0.0	0.0
140°-150°	0.0	0.0
150°-160°	0.0	0.0
160°-170°	0.0	0.0
170°-180°	0.0	0.0
0°-30°	88.1	59.5
0°-40°	119.2	80.6
0°-60°	141.3	95.5
0°-90°	148.0	100.0
90°-120°	0.0	0.0
90°-150°	0.0	0.0
90°-180°	0.0	0.0
0°-180°	148.0	100.0

CANDELA DISTRIBUTION:

	0°	Flux
0°	160	
5°	155	14
15°	125	35
25°	85	39
35°	50	31
45°	20	16
55°	6	6
65°	4	4
75°	2	2
85°	0	1
90°	0	

TEST NUMBER: P1273334

CATALOG NUMBER: P3A05R309830DE010 E3DLD1GPH

CANDELA DISTRIBUTION (FULL):

0°	
0°	159.5
1°	159.5
2°	158.9
3°	158.0
4°	156.7
5°	155.3
6°	153.5
7°	151.1
8°	148.6
9°	145.7
10°	142.7
11°	139.5
12°	136.0
13°	132.4
14°	128.6
15°	124.6
17.5°	114.4
20°	104.2
22.5°	94.4
25°	85.2
27.5°	76.1
30°	67.6
32.5°	58.8
35°	50.1
37.5°	41.6
40°	33.6
42.5°	26.5
45°	20.3
47.5°	15.1
50°	10.5
52.5°	7.4
55°	6.2
57.5°	5.6
60°	5.1
62.5°	4.5
65°	4.0
67.5°	3.5
70°	2.9
72.5°	2.4
75°	2.0
77.5°	1.6
80°	1.3
82.5°	0.9
85°	0.5
87.5°	0.2



TEST NUMBER: P1273334

CATALOG NUMBER: P3A05R309830DE010 E3DLD1GPH

CANDELA DISTRIBUTION (continued):



(END OF REPORT)