

Scaled data based on original data using  
LM-79-2019 Approved Method: Electrical and Photometric Measurements of Solid-  
State Lighting Products

Test Report Prepared for  
Cooper Lighting Solutions

Brand: IRiS

Report Number: P1299417

Luminaire Tested: P3A17R15W2N902765DE010 E3DLP1LI\_6500K

Issue Date: 1/30/2026

**Test Information**

Test Method: LM-79-2019  
Report Number: P1299417  
TEST IS SCALED FROM IESNA LM-79-08 TEST DATA (G1-2601-647-1)  
Test Lab: INNOVATION CENTER  
Issue Date: 1/30/2026  
Manufacturer: COOPER LIGHTING SOLUTIONS  
Product Line: IRiS  
Catalog Number: P3A17R15W2N902765DE010 E3DLP1LI\_6500K  
Description: 3in Adjustable Tunable White LED luminaire with, R15 optic, 6500K CCT AND, 90CRI ,  
E3DLP1LI TRIM  
Light Source: -  
Ballast/Driver: -

**Summary**


Lumens per Lamp: N/A  
Luminaire Lumens: 742.0 lumens  
Efficiency: N/A  
Efficacy: 38.2 lumens/watt  
Spacing Criteria (0/90/45): 0.52 / 0.52 / 0.61  
Luminous Opening: Circular (Dia: 0.25' x H: 0')  
CIE Type: Direct

Input Watts (W): 19.4  
Input Voltage (V): NR  
Input Current (Ain): NR  
Voltage Rise (V): NR  
Power Factor: NR  
Total Harmonic Distortion (THDi): NR  
Frequency (hertz): 60  
Stabilization Time: NR  
Operation Time: NR  
Ambient Temperature (°C): NR  
Test Distance: 24 FT

TEST NUMBER: P1299417

CATALOG NUMBER: P3A17R15W2N902765DE010 E3DLP1LI\_6500K

### Luminous Intensity Polar Plot



TEST NUMBER: P1299417

CATALOG NUMBER: P3A17R15W2N902765DE010 E3DLP1LI\_6500K

**COEFFICIENT OF UTILIZATION - ZONAL CAVITY METHOD:**

|     |     |     |     |     |     |     |     |     |     |     |     |     |     |     |     |     |     |     |    |    |
|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|----|----|
| RF  | 20  |     |     |     | 20  |     |     |     | 20  |     |     |     | 20  |     |     |     | 20  |     |    |    |
| RC  | 80  |     |     |     | 70  |     |     |     | 50  |     |     |     | 30  |     |     |     | 10  |     |    | 0  |
| RW  | 70  | 50  | 30  | 10  | 70  | 50  | 30  | 10  | 50  | 30  | 10  | 50  | 30  | 10  | 50  | 30  | 10  | 50  | 30 | 10 |
| RCR |     |     |     |     |     |     |     |     |     |     |     |     |     |     |     |     |     |     |    |    |
| 0   | 119 | 119 | 119 | 119 | 116 | 116 | 116 | 116 | 111 | 111 | 111 | 106 | 106 | 106 | 102 | 102 | 102 | 100 |    |    |
| 1   | 113 | 110 | 108 | 106 | 111 | 108 | 106 | 104 | 104 | 102 | 101 | 100 | 99  | 98  | 97  | 96  | 95  | 93  |    |    |
| 2   | 108 | 103 | 98  | 95  | 105 | 101 | 97  | 94  | 98  | 95  | 92  | 95  | 92  | 90  | 92  | 90  | 88  | 86  |    |    |
| 3   | 102 | 96  | 91  | 87  | 100 | 94  | 90  | 86  | 92  | 88  | 85  | 89  | 86  | 83  | 87  | 84  | 82  | 80  |    |    |
| 4   | 97  | 90  | 84  | 80  | 95  | 88  | 83  | 79  | 86  | 82  | 78  | 84  | 81  | 78  | 82  | 79  | 77  | 75  |    |    |
| 5   | 93  | 84  | 78  | 74  | 91  | 83  | 78  | 74  | 81  | 77  | 73  | 80  | 76  | 72  | 78  | 75  | 72  | 70  |    |    |
| 6   | 88  | 79  | 73  | 69  | 87  | 79  | 73  | 69  | 77  | 72  | 69  | 76  | 71  | 68  | 74  | 71  | 68  | 66  |    |    |
| 7   | 84  | 75  | 69  | 65  | 83  | 74  | 69  | 65  | 73  | 68  | 64  | 72  | 67  | 64  | 71  | 67  | 64  | 62  |    |    |
| 8   | 80  | 71  | 65  | 61  | 79  | 71  | 65  | 61  | 69  | 64  | 61  | 68  | 64  | 61  | 67  | 63  | 60  | 59  |    |    |
| 9   | 77  | 68  | 62  | 58  | 76  | 67  | 62  | 58  | 66  | 61  | 58  | 65  | 61  | 57  | 64  | 60  | 57  | 56  |    |    |
| 10  | 74  | 64  | 59  | 55  | 73  | 64  | 59  | 55  | 63  | 58  | 55  | 62  | 58  | 55  | 62  | 57  | 54  | 53  |    |    |

**AVERAGE LUMINANCE (cd/sqm):**

|     |        |
|-----|--------|
|     | 0°     |
| 0°  | 319974 |
| 5°  | 295729 |
| 10° | 236090 |
| 15° | 178344 |
| 20° | 135812 |
| 25° | 103482 |
| 30° | 74138  |
| 35° | 48372  |
| 40° | 29656  |
| 45° | 17924  |
| 50° | 11906  |
| 55° | 9214   |
| 60° | 7938   |
| 65° | 6901   |
| 70° | 6155   |
| 75° | 6100   |
| 80° | 4546   |
| 85° | 3019   |

**MAXIMUM LUMINANCE 45°-90°:**

Horizontal Angle: 0°

Vertical Angle: 45°

Luminance: 17924 cd/sqm

TEST NUMBER: P1299417

CATALOG NUMBER: P3A17R15W2N902765DE010 E3DLP1LI\_6500K

**ZONAL LUMENS:**

| Zone      | Lumens | % Fixture |
|-----------|--------|-----------|
| 0°-10°    | 119.0  | 16.0      |
| 10°-20°   | 219.6  | 29.6      |
| 20°-30°   | 195.5  | 26.3      |
| 30°-40°   | 115.7  | 15.6      |
| 40°-50°   | 47.4   | 6.4       |
| 50°-60°   | 22.3   | 3.0       |
| 60°-70°   | 13.6   | 1.8       |
| 70°-80°   | 7.1    | 1.0       |
| 80°-90°   | 1.8    | 0.2       |
| 90°-100°  | 0.0    | 0.0       |
| 100°-110° | 0.0    | 0.0       |
| 110°-120° | 0.0    | 0.0       |
| 120°-130° | 0.0    | 0.0       |
| 130°-140° | 0.0    | 0.0       |
| 140°-150° | 0.0    | 0.0       |
| 150°-160° | 0.0    | 0.0       |
| 160°-170° | 0.0    | 0.0       |
| 170°-180° | 0.0    | 0.0       |
| <hr/>     |        |           |
| 0°-30°    | 534.1  | 72.0      |
| 0°-40°    | 649.7  | 87.6      |
| 0°-60°    | 719.5  | 97.0      |
| 0°-90°    | 742.0  | 100.0     |
| 90°-120°  | 0.0    | 0.0       |
| 90°-150°  | 0.0    | 0.0       |
| 90°-180°  | 0.0    | 0.0       |
| 0°-180°   | 742.0  | 100.0     |

**CANDELA DISTRIBUTION:**

|     | 0°   | Flux |
|-----|------|------|
| 0°  | 1459 |      |
| 5°  | 1344 | 119  |
| 15° | 786  | 220  |
| 25° | 428  | 195  |
| 35° | 181  | 116  |
| 45° | 58   | 47   |
| 55° | 24   | 22   |
| 65° | 13   | 14   |
| 75° | 7    | 7    |
| 85° | 1    | 2    |
| 90° | 0    |      |



TEST NUMBER: P1299417

CATALOG NUMBER: P3A17R15W2N902765DE010 E3DLP1LI\_6500K

**CANDELA DISTRIBUTION (FULL):**

| 0°    |        |
|-------|--------|
| 0°    | 1459.2 |
| 1°    | 1455.6 |
| 2°    | 1444.7 |
| 3°    | 1423.0 |
| 4°    | 1386.9 |
| 5°    | 1343.5 |
| 6°    | 1296.5 |
| 7°    | 1241.1 |
| 8°    | 1183.2 |
| 9°    | 1124.2 |
| 10°   | 1060.3 |
| 12.5° | 914.5  |
| 15°   | 785.6  |
| 17.5° | 674.8  |
| 20°   | 582.0  |
| 22.5° | 500.0  |
| 25°   | 427.7  |
| 27.5° | 357.9  |
| 30°   | 292.8  |
| 32.5° | 233.8  |
| 35°   | 180.7  |
| 37.5° | 138.6  |
| 40°   | 103.6  |
| 42.5° | 77.1   |
| 45°   | 57.8   |
| 47.5° | 44.6   |
| 50°   | 34.9   |
| 52.5° | 28.9   |
| 55°   | 24.1   |
| 57.5° | 20.5   |
| 60°   | 18.1   |
| 62.5° | 15.7   |
| 65°   | 13.3   |
| 67.5° | 12.0   |
| 70°   | 9.6    |
| 72.5° | 8.4    |
| 75°   | 7.2    |
| 77.5° | 4.8    |
| 80°   | 3.6    |
| 82.5° | 2.4    |
| 85°   | 1.2    |
| 87.5° | 1.2    |
| 90°   | 0.0    |

(END OF REPORT)