

Scaled data based on original data using
LM-79-2019 Approved Method: Electrical and Photometric Measurements of Solid-
State Lighting Products

Test Report Prepared for
Cooper Lighting Solutions

Brand: IRiS

Report Number: P1305530

Luminaire Tested: P3SQAS05R129024DE010 E3SQCB1MW

Issue Date: 1/30/2026

Test Information

Test Method: LM-79-2019
Report Number: P1305530
TEST IS SCALED FROM IESNA LM-79-08 TEST DATA (G1-2501-338-24)
Test Lab: INNOVATION CENTER
Issue Date: 1/30/2026
Manufacturer: COOPER LIGHTING SOLUTIONS
Product Line: IRiS
Catalog Number: P3SQAS05R129024DE010 E3SQCB1MW
Description: 3in Adjustable LED luminaire with, R12 optic, 2400K CCT AND, 90CRI , E3SQCB1MW TRIM
Light Source: -
Ballast/Driver: -

Summary

Lumens per Lamp: N/A
Luminaire Lumens: 537.0 lumens
Efficiency: N/A
Efficacy: 70.7 lumens/watt
Spacing Criteria (0/90/45): 0.22 / 0.22 / 0.22
Luminous Opening: Rectangular (W 0.25' x L: 0.25' x H: 0')
CIE Type: Direct

Input Watts (W): 7.6
Input Voltage (V): NR
Input Current (Ain): NR
Voltage Rise (V): NR
Power Factor: NR
Total Harmonic Distortion (THDi): NR
Frequency (hertz): 60
Stabilization Time: NR
Operation Time: NR
Ambient Temperature (°C): NR
Test Distance: 24 FT

TEST NUMBER: P1305530

CATALOG NUMBER: P3SQAS05R129024DE010 E3SQCB1MW

Luminous Intensity Polar Plot



TEST NUMBER: P1305530

CATALOG NUMBER: P3SQAS05R129024DE010 E3SQCB1MW

COEFFICIENT OF UTILIZATION - ZONAL CAVITY METHOD:

RF	20				20				20				20				20
RC	80				70				50				30				10
RW	70	50	30	10	70	50	30	10	50	30	10		50	30	10		50
RCR																	
0	119	119	119	119	116	116	116	116	111	111	111		106	106	106		102
1	116	114	113	111	114	112	111	109	108	107	106		104	104	103		101
2	113	110	108	106	111	108	106	104	105	104	102		103	101	100		100
3	110	107	104	102	109	105	103	101	103	101	99		101	99	98		99
4	108	104	101	98	107	103	100	98	101	99	97		99	97	96		98
5	106	102	98	96	105	101	98	96	99	97	95		98	96	94		96
6	104	99	96	94	103	99	96	94	98	95	93		96	94	93		95
7	102	98	94	92	101	97	94	92	96	93	92		95	93	91		94
8	101	96	93	91	100	95	93	90	95	92	90		94	92	90		93
9	99	94	91	89	98	94	91	89	93	91	89		93	90	89		92
10	98	93	90	88	97	93	90	88	92	90	88		91	89	88		91

AVERAGE LUMINANCE (cd/sqm):

	0°
0°	1362505
5°	880359
10°	248399
15°	70232
20°	29361
25°	12998
30°	6642
35°	3511
40°	1506
45°	414
50°	455
55°	0
60°	0
65°	0
70°	0
75°	0
80°	0
85°	0

MAXIMUM LUMINANCE 45°-90°:

Horizontal Angle: 0°

Vertical Angle: 50°

Luminance: 455 cd/sqm

TEST NUMBER: P1305530

CATALOG NUMBER: P3SQAS05R129024DE010 E3SQCB1MW

ZONAL LUMENS:

Zone	Lumens	% Fixture
0°-10°	358.8	66.8
10°-20°	130.2	24.2
20°-30°	34.8	6.5
30°-40°	11.0	2.0
40°-50°	2.1	0.4
50°-60°	0.2	0.0
60°-70°	0.0	0.0
70°-80°	0.0	0.0
80°-90°	0.0	0.0
90°-100°	0.0	0.0
100°-110°	0.0	0.0
110°-120°	0.0	0.0
120°-130°	0.0	0.0
130°-140°	0.0	0.0
140°-150°	0.0	0.0
150°-160°	0.0	0.0
160°-170°	0.0	0.0
170°-180°	0.0	0.0
0°-30°	523.8	97.5
0°-40°	534.8	99.6
0°-60°	537.0	100.0
0°-90°	537.0	100.0
90°-120°	0.0	0.0
90°-150°	0.0	0.0
90°-180°	0.0	0.0
0°-180°	537.0	100.0

CANDELA DISTRIBUTION:

	0°	Flux
0°	7911	
5°	5092	359
15°	394	130
25°	68	35
35°	17	11
45°	2	2
55°	0	0
65°	0	0
75°	0	0
85°	0	0
90°	0	

TEST NUMBER: P1305530

CATALOG NUMBER: P3SQAS05R129024DE010 E3SQCB1MW

CANDELA DISTRIBUTION (FULL):

0°	
0°	7911.3
1°	7777.8
2°	7402.2
3°	6759.6
4°	5961.8
5°	5092.3
6°	4186.0
7°	3374.8
8°	2597.0
9°	1932.8
10°	1420.4
11°	1046.5
12°	787.8
13°	610.9
14°	484.0
15°	393.9
17.5°	250.4
20°	160.2
22.5°	103.5
25°	68.4
27.5°	46.7
30°	33.4
32.5°	23.4
35°	16.7
37.5°	11.7
40°	6.7
42.5°	3.3
45°	1.7
47.5°	1.7
50°	1.7
52.5°	0.0
55°	0.0
57.5°	0.0
60°	0.0
62.5°	0.0
65°	0.0
67.5°	0.0
70°	0.0
72.5°	0.0
75°	0.0
77.5°	0.0
80°	0.0
82.5°	0.0
85°	0.0
87.5°	0.0



TEST NUMBER: P1305530

CATALOG NUMBER: P3SQAS05R129024DE010 E3SQCB1MW

CANDELA DISTRIBUTION (continued):

0°
90° | 0.0

(END OF REPORT)