

Scaled data based on original data using
LM-79-2019 Approved Method: Electrical and Photometric Measurements of Solid-
State Lighting Products

Test Report Prepared for
Cooper Lighting Solutions

Brand: IRiS

Report Number: P1317703

Luminaire Tested: P3SQAS05R309835DE010 E3SQCD1MMS

Issue Date: 1/29/2026

Test Information

Test Method: LM-79-2019
Report Number: P1317703
TEST IS SCALED FROM IESNA LM-79-08 TEST DATA (G1-2510-583-24)
Test Lab: INNOVATION CENTER
Issue Date: 1/29/2026
Manufacturer: COOPER LIGHTING SOLUTIONS
Product Line: IRiS
Catalog Number: P3SQAS05R309835DE010 E3SQCD1MMS
Description: 3in Adjustable LED luminaire with, R30 optic, 3500K CCT AND, 98CRI , E3SQCD1MMS TRIM
Light Source: -
Ballast/Driver: -

Summary


Lumens per Lamp: N/A
Luminaire Lumens: 497.0 lumens
Efficiency: N/A
Efficacy: 69.0 lumens/watt
Spacing Criteria (0/90/45): 0.51 / 0.51 / 0.46
Luminous Opening: Rectangular (W 0.25' x L: 0.25' x H: 0')
CIE Type: Direct

Input Watts (W): 7.2
Input Voltage (V): NR
Input Current (Ain): NR
Voltage Rise (V): NR
Power Factor: NR
Total Harmonic Distortion (THDi): NR
Frequency (hertz): 60
Stabilization Time: NR
Operation Time: NR
Ambient Temperature (°C): NR
Test Distance: 24 FT

TEST NUMBER: P1317703

CATALOG NUMBER: P3SQAS05R309835DE010 E3SQCD1MMS

Luminous Intensity Polar Plot



TEST NUMBER: P1317703

CATALOG NUMBER: P3SQAS05R309835DE010 E3SQCD1MMS

COEFFICIENT OF UTILIZATION - ZONAL CAVITY METHOD:

RF	20				20				20				20				20
RC	80				70				50				30				10
RW	70	50	30	10	70	50	30	10	50	30	10		50	30	10		50
RCR																	
0	119	119	119	119	116	116	116	116	111	111	111		106	106	106		102
1	115	113	111	110	113	111	109	108	107	106	105		103	102	101		100
2	112	108	105	103	109	106	104	102	103	101	99		100	99	97		98
3	108	104	100	97	106	102	99	97	100	97	95		98	95	94		95
4	105	100	96	93	103	99	95	92	97	94	91		95	92	90		93
5	102	96	92	89	101	95	92	89	94	91	88		92	90	87		91
6	99	93	89	86	98	92	89	86	91	88	85		90	87	85		89
7	96	90	86	83	95	90	86	83	89	85	83		87	85	82		87
8	94	88	84	81	93	87	83	81	86	83	80		85	82	80		84
9	91	85	81	78	91	85	81	78	84	80	78		83	80	78		82
10	89	83	79	76	88	82	79	76	82	78	76		81	78	76		80

AVERAGE LUMINANCE (cd/sqm):

	0°	45°	90°
0°	331718	331718	331718
5°	323632	324030	325828
10°	276397	275120	273494
15°	170578	168581	169187
20°	64458	64825	64751
25°	19839	21739	20713
30°	7994	10142	8293
35°	2355	4310	2439
40°	967	1731	967
45°	195	560	195
50°	0	107	0
55°	0	0	0
60°	0	0	0
65°	0	0	0
70°	0	0	0
75°	0	0	0
80°	0	0	0
85°	0	0	0

MAXIMUM LUMINANCE 45°-90°:

Horizontal Angle: 45°

Vertical Angle: 45°

Luminance: 560 cd/sqm

TEST NUMBER: P1317703

CATALOG NUMBER: P3SQAS05R309835DE010 E3SQCD1MMS

ZONAL LUMENS:

Zone	Lumens	% Fixture
0°-10°	169.9	34.2
10°-20°	251.5	50.6
20°-30°	62.4	12.6
30°-40°	11.7	2.4
40°-50°	1.5	0.3
50°-60°	0.0	0.0
60°-70°	0.0	0.0
70°-80°	0.0	0.0
80°-90°	0.0	0.0
90°-100°	0.0	0.0
100°-110°	0.0	0.0
110°-120°	0.0	0.0
120°-130°	0.0	0.0
130°-140°	0.0	0.0
140°-150°	0.0	0.0
150°-160°	0.0	0.0
160°-170°	0.0	0.0
170°-180°	0.0	0.0
0°-30°	483.8	97.3
0°-40°	495.5	99.7
0°-60°	497.0	100.0
0°-90°	497.0	100.0
90°-120°	0.0	0.0
90°-150°	0.0	0.0
90°-180°	0.0	0.0
0°-180°	497.0	100.0

CANDELA DISTRIBUTION:

	0°	22.5°	45°	67.5°	90°	Flux
0°	1926	1926	1926	1926	1926	
5°	1872	1871	1874	1877	1885	170
15°	957	947	946	953	949	253
25°	104	111	114	114	109	60
35°	11	15	20	15	12	9
45°	1	1	2	2	1	1
55°	0	0	0	0	0	0
65°	0	0	0	0	0	0
75°	0	0	0	0	0	0
85°	0	0	0	0	0	0
90°	0	0	0	0	0	

TEST NUMBER: P1317703

CATALOG NUMBER: P3SQAS05R309835DE010 E3SQCD1MMS

CANDELA DISTRIBUTION (FULL):

	0°	22.5°	45°	67.5°	90°
0°	1926.1	1926.1	1926.1	1926.1	1926.1
1°	1926.9	1925.3	1925.3	1923.0	1927.3
2°	1919.9	1918.4	1921.1	1919.2	1924.6
3°	1909.5	1907.6	1911.4	1912.6	1915.3
4°	1894.0	1892.5	1896.7	1899.1	1906.4
5°	1872.0	1871.2	1874.3	1877.4	1884.7
6°	1841.8	1840.7	1842.6	1846.5	1851.1
7°	1798.2	1795.8	1797.4	1798.2	1799.3
8°	1742.9	1739.4	1737.5	1741.7	1744.1
9°	1671.8	1667.9	1663.7	1662.1	1667.5
10°	1580.5	1574.7	1573.2	1569.3	1563.9
11°	1474.6	1470.0	1468.8	1461.9	1458.8
12°	1353.3	1350.9	1353.6	1349.4	1347.9
13°	1236.9	1222.2	1220.3	1212.2	1207.9
14°	1099.3	1085.8	1085.4	1081.1	1086.9
15°	956.7	947.4	945.5	952.8	948.9
17.5°	610.0	616.1	614.6	610.7	604.2
20°	351.7	347.5	353.7	355.2	353.3
22.5°	187.5	189.0	190.2	194.8	197.9
25°	104.4	111.3	114.4	114.0	109.0
27.5°	64.9	69.2	75.0	71.1	66.9
30°	40.2	43.7	51.0	44.1	41.7
32.5°	21.6	27.4	32.9	27.4	22.4
35°	11.2	14.7	20.5	15.1	11.6
37.5°	7.3	8.5	13.1	8.5	7.3
40°	4.3	5.4	7.7	5.4	4.3
42.5°	1.9	3.1	4.3	3.1	1.9
45°	0.8	1.2	2.3	1.5	0.8
47.5°	0.0	0.4	1.2	0.4	0.0
50°	0.0	0.0	0.4	0.0	0.0
52.5°	0.0	0.0	0.0	0.0	0.0
55°	0.0	0.0	0.0	0.0	0.0
57.5°	0.0	0.0	0.0	0.0	0.0
60°	0.0	0.0	0.0	0.0	0.0
62.5°	0.0	0.0	0.0	0.0	0.0
65°	0.0	0.0	0.0	0.0	0.0
67.5°	0.0	0.0	0.0	0.0	0.0
70°	0.0	0.0	0.0	0.0	0.0
72.5°	0.0	0.0	0.0	0.0	0.0
75°	0.0	0.0	0.0	0.0	0.0
77.5°	0.0	0.0	0.0	0.0	0.0
80°	0.0	0.0	0.0	0.0	0.0
82.5°	0.0	0.0	0.0	0.0	0.0
85°	0.0	0.0	0.0	0.0	0.0
87.5°	0.0	0.0	0.0	0.0	0.0



TEST NUMBER: P1317703

CATALOG NUMBER: P3SQAS05R309835DE010 E3SQCD1MMS

CANDELA DISTRIBUTION (continued):

	0°	22.5°	45°	67.5°	90°
90°	0.0	0.0	0.0	0.0	0.0

(END OF REPORT)