

Cooper Lighting Solutions Photometric Lab  
1121 Highway 74 South  
Peachtree City, GA 30269



Scaled data based on original data using  
LM-79-2019 Approved Method: Electrical and Photometric Measurements of Solid-  
State Lighting Products

Test Report Prepared for  
Cooper Lighting Solutions

Brand: METALUX

Report Number: P1432538

Luminaire Tested: EHBR1-60-UNV-N-L830

Issue Date: 3/13/2026

**Test Information**

Test Method: LM-79-2019  
Report Number: P1432538  
TEST IS SCALED FROM IESNA LM-79-08 TEST DATA (G3-2601-654-3)  
Test Lab: INNOVATION CENTER  
Issue Date: 3/13/2026  
Manufacturer: COOPER LIGHTING SOLUTIONS  
Product Line: METALUX  
Catalog Number: EHBR1-60-UNV-N-L830  
Description: Elevate Round Highbay at, 60000 lumens, 3000K 80CRI LEDs with N lens  
Light Source: -  
Ballast/Driver: -


**Summary**

Lumens per Lamp: N/A  
Luminaire Lumens: 56386.1 lumens  
Efficiency: N/A  
Efficacy: 170.7 lumens/watt  
Spacing Criteria (0/90/45): 0.82 / 0.82 / 0.8  
Luminous Opening: Circular (Dia: 1.71' x H: 0')  
CIE Type: Direct

Input Watts (W): 330.4  
Input Voltage (V): NR  
Input Current (Ain): NR  
Voltage Rise (V): NR  
Power Factor: NR  
Total Harmonic Distortion (THDi): NR  
Frequency (hertz): 60  
Stabilization Time: NR  
Operation Time: NR  
Ambient Temperature (°C): NR  
Test Distance: 24 FT

TEST NUMBER: P1432538  
CATALOG NUMBER: EHBR1-60-UNV-N-L830

### Luminous Intensity Polar Plot





TEST NUMBER: P1432538  
 CATALOG NUMBER: EHBR1-60-UNV-N-L830

**COEFFICIENT OF UTILIZATION - ZONAL CAVITY METHOD:**

RF	20				20				20				20				20			
RC	80				70				50				30				10		0	
RW	70	50	30	10	70	50	30	10	50	30	10	50	30	10	50	30	10	50	30	10
RCR																				
0	119	119	119	119	116	116	116	116	111	111	111	106	106	106	102	102	102	100	100	100
1	112	109	106	104	110	107	104	102	103	101	99	99	97	96	96	94	93	91	91	91
2	106	100	96	92	104	98	94	91	95	92	89	92	89	87	89	87	85	83	83	83
3	100	92	87	82	98	91	86	82	88	84	80	86	82	79	84	80	78	76	76	76
4	94	86	80	75	92	85	79	74	82	77	74	80	76	73	78	75	72	70	70	70
5	89	80	74	69	87	79	73	68	77	72	68	75	71	67	74	70	67	65	65	65
6	85	75	68	64	83	74	68	63	72	67	63	71	66	63	70	65	62	61	61	61
7	80	70	64	59	79	70	63	59	68	63	59	67	62	58	66	61	58	57	57	57
8	76	66	60	55	75	66	59	55	64	59	55	63	58	55	62	58	55	53	53	53
9	73	62	56	52	72	62	56	52	61	56	52	60	55	52	59	55	51	50	50	50
10	69	59	53	49	68	59	53	49	58	52	49	57	52	49	56	52	48	47	47	47

**AVERAGE LUMINANCE (cd/sqm):**

	0°	45°	90°
0°	309005	309005	309005
5°	304982	304982	304982
10°	291369	291369	291369
15°	266894	266894	266894
20°	230543	230543	230543
25°	182705	182705	182705
30°	126385	126385	126385
35°	75736	75736	75736
40°	45252	45252	45252
45°	32851	32851	32851
50°	27362	27362	27362
55°	25270	25270	25270
60°	24685	24685	24685
65°	24186	24186	24186
70°	23364	23364	23364
75°	22408	22408	22408
80°	20705	20705	20705
85°	17064	17064	17064

**MAXIMUM LUMINANCE 45°-90°:**

Horizontal Angle: 0°  
 Vertical Angle: 45°  
 Luminance: 32851 cd/sqm



TEST NUMBER: P1432538  
 CATALOG NUMBER: EHBR1-60-UNV-N-L830

**ZONAL LUMENS:**

Zone	Lumens	% Fixture
0°-10°	6061.3	10.7
10°-20°	15214.8	27.0
20°-30°	15908.7	28.2
30°-40°	8619.8	15.3
40°-50°	3965.5	7.0
50°-60°	2794.6	5.0
60°-70°	2150.7	3.8
70°-80°	1303.8	2.3
80°-90°	367.1	0.7
90°-100°	0.0	0.0
100°-110°	0.0	0.0
110°-120°	0.0	0.0
120°-130°	0.0	0.0
130°-140°	0.0	0.0
140°-150°	0.0	0.0
150°-160°	0.0	0.0
160°-170°	0.0	0.0
170°-180°	0.0	0.0
0°-30°	37184.7	65.9
0°-40°	45804.5	81.2
0°-60°	52564.6	93.2
0°-90°	56386.1	100.0
90°-120°	0.0	0.0
90°-150°	0.0	0.0
90°-180°	0.0	0.0
0°-180°	56386.1	100.0

**CANDELA DISTRIBUTION:**

	0°	22.5°	45°	67.5°	90°	Flux
0°	65800	65800	65800	65800	65800	
5°	64697	64697	64697	64697	64697	6061
15°	54897	54897	54897	54897	54897	15215
25°	35261	35261	35261	35261	35261	15909
35°	13211	13211	13211	13211	13211	8620
45°	4946	4946	4946	4946	4946	3966
55°	3086	3086	3086	3086	3086	2795
65°	2177	2177	2177	2177	2177	2151
75°	1235	1235	1235	1235	1235	1304
85°	317	317	317	317	317	367
90°	2	2	2	2	2	



TEST NUMBER: P1432538  
 CATALOG NUMBER: EHBR1-60-UNV-N-L830

**CANDELA DISTRIBUTION (FULL):**

	0°	22.5°	45°	67.5°	90°
0°	65800.5	65800.5	65800.5	65800.5	65800.5
2.5°	65567.2	65567.2	65567.2	65567.2	65567.2
5°	64696.7	64696.7	64696.7	64696.7	64696.7
7.5°	63210.6	63210.6	63210.6	63210.6	63210.6
10°	61102.4	61102.4	61102.4	61102.4	61102.4
12.5°	58377.6	58377.6	58377.6	58377.6	58377.6
15°	54896.6	54896.6	54896.6	54896.6	54896.6
17.5°	50858.1	50858.1	50858.1	50858.1	50858.1
20°	46131.8	46131.8	46131.8	46131.8	46131.8
22.5°	40869.6	40869.6	40869.6	40869.6	40869.6
25°	35260.6	35260.6	35260.6	35260.6	35260.6
27.5°	29314.3	29314.3	29314.3	29314.3	29314.3
30°	23307.2	23307.2	23307.2	23307.2	23307.2
32.5°	17887.5	17887.5	17887.5	17887.5	17887.5
35°	13210.9	13210.9	13210.9	13210.9	13210.9
37.5°	9699.9	9699.9	9699.9	9699.9	9699.9
40°	7381.7	7381.7	7381.7	7381.7	7381.7
42.5°	5919.1	5919.1	5919.1	5919.1	5919.1
45°	4946.5	4946.5	4946.5	4946.5	4946.5
47.5°	4245.6	4245.6	4245.6	4245.6	4245.6
50°	3745.2	3745.2	3745.2	3745.2	3745.2
52.5°	3379.8	3379.8	3379.8	3379.8	3379.8
55°	3086.5	3086.5	3086.5	3086.5	3086.5
57.5°	2848.5	2848.5	2848.5	2848.5	2848.5
60°	2628.3	2628.3	2628.3	2628.3	2628.3
62.5°	2408.1	2408.1	2408.1	2408.1	2408.1
65°	2176.6	2176.6	2176.6	2176.6	2176.6
67.5°	1940.6	1940.6	1940.6	1940.6	1940.6
70°	1701.6	1701.6	1701.6	1701.6	1701.6
72.5°	1469.2	1469.2	1469.2	1469.2	1469.2
75°	1235.0	1235.0	1235.0	1235.0	1235.0
77.5°	1005.4	1005.4	1005.4	1005.4	1005.4
80°	765.6	765.6	765.6	765.6	765.6
82.5°	536.0	536.0	536.0	536.0	536.0
85°	316.7	316.7	316.7	316.7	316.7
87.5°	113.3	113.3	113.3	113.3	113.3
90°	1.9	1.9	1.9	1.9	1.9



TEST NUMBER: P1432538  
 CATALOG NUMBER: EHBR1-60-UNV-N-L830

**CIE UGR TABLE:**

Reflectances:											
Ceiling		0.7	0.7	0.5	0.5	0.3	0.7	0.7	0.5	0.5	0.3
Wall		0.5	0.3	0.5	0.3	0.3	0.5	0.3	0.5	0.3	0.3
Reference plane		0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2
Room dimensions		Viewed crosswise					Viewed endwise				
X=2H	Y=2H	19.83	20.99	20.20	21.31	21.62	19.83	20.99	20.20	21.31	21.62
	3H	21.71	22.74	22.09	23.07	23.44	21.71	22.74	22.09	23.07	23.44
	4H	22.44	23.40	22.84	23.75	24.14	22.44	23.40	22.84	23.75	24.14
	6H	22.98	23.86	23.40	24.24	24.63	22.98	23.86	23.40	24.24	24.63
	8H	23.15	23.99	23.58	24.38	24.78	23.15	23.99	23.58	24.38	24.78
	12H	23.25	24.04	23.68	24.43	24.86	23.25	24.04	23.68	24.43	24.86
4H	2H	20.43	21.39	20.83	21.74	22.13	20.43	21.39	20.83	21.74	22.13
	3H	22.51	23.30	22.92	23.71	24.11	22.51	23.30	22.92	23.71	24.11
	4H	23.36	24.07	23.80	24.50	24.94	23.36	24.07	23.80	24.50	24.94
	6H	24.04	24.65	24.50	25.10	25.57	24.04	24.65	24.50	25.10	25.57
	8H	24.25	24.82	24.72	25.27	25.74	24.25	24.82	24.72	25.27	25.74
	12H	24.38	24.88	24.87	25.37	25.84	24.38	24.88	24.87	25.37	25.84
8H	4H	23.65	24.22	24.12	24.67	25.14	23.65	24.22	24.12	24.67	25.14
	6H	24.45	24.91	24.96	25.41	25.90	24.45	24.91	24.96	25.41	25.90
	8H	24.75	25.16	25.27	25.67	26.17	24.75	25.16	25.27	25.67	26.17
	12H	24.96	25.32	25.48	25.81	26.39	24.96	25.32	25.48	25.81	26.39
12H	4H	23.66	24.16	24.15	24.65	25.12	23.66	24.16	24.15	24.65	25.12
	6H	24.50	24.91	25.03	25.43	25.92	24.50	24.91	25.03	25.43	25.92
	8H	24.85	25.21	25.37	25.70	26.28	24.85	25.21	25.37	25.70	26.28

Cooper Lighting Solutions Photometric Lab  
1121 Highway 74 South  
Peachtree City, GA 30269



LM-79-2019: Approved Method: Electrical and Photometric Measurements of Solid-State Lighting Products

Report Prepared for

Cooper Lighting Solutions

Metalux

Report Number: SP1-2506-472-2

Test Date: 07/31/2025

Luminaire Tested: EHBR-60-L830-N

Data in this report applies to families of products including EHBR-60-L830-N


**Test Information**

Test Method: LM-79-2019  
 Report Number: SP1-2506-472-2  
 Test Lab: COOPER LIGHTING SOLUTIONS  
 Photometer: SP1 - 76IN SPHERE  
 Measurement Geometry: 4π  
 Issue Date: 08/05/2025  
 Manufacturer: COOPER LIGHTING SOLUTIONS  
 Product Line: Metalux  
 Catalog Number: **EHBR-60-L830-N**  
 Description: Elevate Round Highbay at, 60000 lumens, 3000K 80CRI LEDs with N lens

**Spectral Parameters**

CCT (K): 2983  
 CIE u': 0.2516  
 CIE v': 0.5201  
 Duv: -0.0012  
 CIE x: 0.4364  
 CIE y: 0.4010  
 CIE z: 0.1626  
 Peak Wavelength (nm): 630  
 Dominant Wavelength (nm): 583  
 Purity: 51.34918  
 Rf: 81.2  
 Rg: 101.5

CRI (Ra):	83.4		
R1:	84.0	R9:	29.4
R2:	87.5	R10:	68.6
R3:	88.9	R11:	82.2
R4:	83.8	R12:	61.6
R5:	81.9	R13:	83.9
R6:	83.1	R14:	92.5
R7:	87.1	R15:	79.8
R8:	70.9		



**Test Conditions**


Stabilization Time: 38M  
 Operation Time: 1H 38M  
 Sphere Temperature (°C): 25.0

REPORT NUMBER: SP1-2506-472-2


Measurement and Test Equipment			
Instrument	Identification Number	Calibration Date	Calibration Due Date
Photometer	76INCH SPHERE IN0058	6/16/2025	12/16/2025
Power Meter	XITRON INXT2011004	1/21/2025	1/21/2026
AC Power Source	CHROMA 61603 IN0063	10/22/2024	10/22/2025
DC Power Source	AGILENT E3634A IN0208	10/22/2024	10/22/2025
Sphere Thermometer	ONSET IN0085	10/22/2024	10/22/2025
Room Thermometer	ONSET IN0046	10/22/2024	10/22/2025

REPORT NUMBER: SP1-2506-472-2

CIE 1931 Chromaticity Diagram



CIE 1931 Chromaticity Diagram with 2017 ANSI 7-Step and 4-Step Quadrangles




CCT = 2983K  
 CIE x = 0.4364  
 CIE y = 0.4010  
 Duv = -0.0012

Point lies inside the ANSI 3000K 4-step quadrangle

REPORT NUMBER: SP1-2506-472-2

**Photopic Flux vs. Wavelength**




**Photopic Lumens: NR**

λ (nm)	Power W <sup>^</sup> /nm	Lumens (φ/nm)	λ (nm)	Power W <sup>^</sup> /nm	Lumens (φ/nm)	λ (nm)	Power W <sup>^</sup> /nm	Lumens (φ/nm)	λ (nm)	Power W <sup>^</sup> /nm	Lumens (φ/nm)	λ (nm)	Power W <sup>^</sup> /nm	Lumens (φ/nm)
360	0	NR	490	43	NR	620	294	NR	750	6	NR	880	0	NR
365	0	NR	495	59	NR	625	294	NR	755	5	NR	885	0	NR
370	0	NR	500	81	NR	630	1000	NR	760	4	NR	890	0	NR
375	0	NR	505	109	NR	635	637	NR	765	4	NR	895	0	NR
380	0	NR	510	135	NR	640	175	NR	770	3	NR	900	0	NR
385	0	NR	515	160	NR	645	171	NR	775	3	NR	905	0	NR
390	1	NR	520	180	NR	650	146	NR	780	2	NR	910	0	NR
395	1	NR	525	195	NR	655	119	NR	785	2	NR	915	0	NR
400	2	NR	530	207	NR	660	99	NR	790	2	NR	920	0	NR
405	3	NR	535	218	NR	665	82	NR	795	2	NR	925	0	NR
410	5	NR	540	227	NR	670	76	NR	800	1	NR	930	0	NR
415	10	NR	545	237	NR	675	61	NR	805	1	NR	935	0	NR
420	20	NR	550	247	NR	680	52	NR	810	1	NR	940	0	NR
425	35	NR	555	259	NR	685	44	NR	815	1	NR	945	0	NR
430	58	NR	560	271	NR	690	38	NR	820	1	NR	950	0	NR
435	90	NR	565	283	NR	695	33	NR	825	1	NR	955	0	NR
440	135	NR	570	293	NR	700	27	NR	830	1	NR	960	0	NR
445	204	NR	575	303	NR	705	24	NR	835	1	NR	965	0	NR
450	233	NR	580	310	NR	710	20	NR	840	0	NR	970	0	NR
455	153	NR	585	313	NR	715	17	NR	845	0	NR	975	0	NR
460	98	NR	590	314	NR	720	15	NR	850	0	NR	980	0	NR
465	76	NR	595	310	NR	725	13	NR	855	0	NR	985	0	NR
470	53	NR	600	307	NR	730	11	NR	860	0	NR	990	0	NR
475	39	NR	605	303	NR	735	9	NR	865	0	NR	995	0	NR
480	35	NR	610	331	NR	740	8	NR	870	0	NR	1000	0	NR
485	36	NR	615	353	NR	745	7	NR	875	0	NR			

REPORT NUMBER: SP1-2506-472-2

**Scotopic Flux vs. Wavelength**




**Scotopic Lumens: NR**

**S/P: 1.27**

λ (nm)	Power W <sup>^</sup> /nm	Lumens (φ/nm)	λ (nm)	Power W <sup>^</sup> /nm	Lumens (φ/nm)	λ (nm)	Power W <sup>^</sup> /nm	Lumens (φ/nm)	λ (nm)	Power W <sup>^</sup> /nm	Lumens (φ/nm)	λ (nm)	Power W <sup>^</sup> /nm	Lumens (φ/nm)
360	0	NR	490	43	NR	620	294	NR	750	6	NR	880	0	NR
365	0	NR	495	59	NR	625	294	NR	755	5	NR	885	0	NR
370	0	NR	500	81	NR	630	1000	NR	760	4	NR	890	0	NR
375	0	NR	505	109	NR	635	637	NR	765	4	NR	895	0	NR
380	0	NR	510	135	NR	640	175	NR	770	3	NR	900	0	NR
385	0	NR	515	160	NR	645	171	NR	775	3	NR	905	0	NR
390	1	NR	520	180	NR	650	146	NR	780	2	NR	910	0	NR
395	1	NR	525	195	NR	655	119	NR	785	2	NR	915	0	NR
400	2	NR	530	207	NR	660	99	NR	790	2	NR	920	0	NR
405	3	NR	535	218	NR	665	82	NR	795	2	NR	925	0	NR
410	5	NR	540	227	NR	670	76	NR	800	1	NR	930	0	NR
415	10	NR	545	237	NR	675	61	NR	805	1	NR	935	0	NR
420	20	NR	550	247	NR	680	52	NR	810	1	NR	940	0	NR
425	35	NR	555	259	NR	685	44	NR	815	1	NR	945	0	NR
430	58	NR	560	271	NR	690	38	NR	820	1	NR	950	0	NR
435	90	NR	565	283	NR	695	33	NR	825	1	NR	955	0	NR
440	135	NR	570	293	NR	700	27	NR	830	1	NR	960	0	NR
445	204	NR	575	303	NR	705	24	NR	835	1	NR	965	0	NR
450	233	NR	580	310	NR	710	20	NR	840	0	NR	970	0	NR
455	153	NR	585	313	NR	715	17	NR	845	0	NR	975	0	NR
460	98	NR	590	314	NR	720	15	NR	850	0	NR	980	0	NR
465	76	NR	595	310	NR	725	13	NR	855	0	NR	985	0	NR
470	53	NR	600	307	NR	730	11	NR	860	0	NR	990	0	NR
475	39	NR	605	303	NR	735	9	NR	865	0	NR	995	0	NR
480	35	NR	610	331	NR	740	8	NR	870	0	NR	1000	0	NR
485	36	NR	615	353	NR	745	7	NR	875	0	NR			

REPORT NUMBER: SP1-2506-472-2

**Melanopic Flux vs. Wavelength**




**Melanopic Lumens: NR**

**M/P: 2.34**





λ (nm)	Power W <sup>^</sup> /nm	Lumens (φ/nm)	λ (nm)	Power W <sup>^</sup> /nm	Lumens (φ/nm)	λ (nm)	Power W <sup>^</sup> /nm	Lumens (φ/nm)	λ (nm)	Power W <sup>^</sup> /nm	Lumens (φ/nm)	λ (nm)	Power W <sup>^</sup> /nm	Lumens (φ/nm)
360	0	NR	490	43	NR	620	294	NR	750	6	NR	880	0	NR
365	0	NR	495	59	NR	625	294	NR	755	5	NR	885	0	NR
370	0	NR	500	81	NR	630	1000	NR	760	4	NR	890	0	NR
375	0	NR	505	109	NR	635	637	NR	765	4	NR	895	0	NR
380	0	NR	510	135	NR	640	175	NR	770	3	NR	900	0	NR
385	0	NR	515	160	NR	645	171	NR	775	3	NR	905	0	NR
390	1	NR	520	180	NR	650	146	NR	780	2	NR	910	0	NR
395	1	NR	525	195	NR	655	119	NR	785	2	NR	915	0	NR
400	2	NR	530	207	NR	660	99	NR	790	2	NR	920	0	NR
405	3	NR	535	218	NR	665	82	NR	795	2	NR	925	0	NR
410	5	NR	540	227	NR	670	76	NR	800	1	NR	930	0	NR
415	10	NR	545	237	NR	675	61	NR	805	1	NR	935	0	NR
420	20	NR	550	247	NR	680	52	NR	810	1	NR	940	0	NR
425	35	NR	555	259	NR	685	44	NR	815	1	NR	945	0	NR
430	58	NR	560	271	NR	690	38	NR	820	1	NR	950	0	NR
435	90	NR	565	283	NR	695	33	NR	825	1	NR	955	0	NR
440	135	NR	570	293	NR	700	27	NR	830	1	NR	960	0	NR
445	204	NR	575	303	NR	705	24	NR	835	1	NR	965	0	NR
450	233	NR	580	310	NR	710	20	NR	840	0	NR	970	0	NR
455	153	NR	585	313	NR	715	17	NR	845	0	NR	975	0	NR
460	98	NR	590	314	NR	720	15	NR	850	0	NR	980	0	NR
465	76	NR	595	310	NR	725	13	NR	855	0	NR	985	0	NR
470	53	NR	600	307	NR	730	11	NR	860	0	NR	990	0	NR
475	39	NR	605	303	NR	735	9	NR	865	0	NR	995	0	NR
480	35	NR	610	331	NR	740	8	NR	870	0	NR	1000	0	NR
485	36	NR	615	353	NR	745	7	NR	875	0	NR			

**Summary**

$R_f = 81.2$   
 $R_g = 101.5$   
 CIE  $R_a = 83.4$   
 $R_9 = 29.4$




**Color Vector Graphics**






**Individual Sample Fidelity Index ( $R_{f,i}$ )**



CES01 = 86	CES26 = 71	CES51 = 89	CES76 = 65
CES02 = 63	CES27 = 89	CES52 = 89	CES77 = 82
CES03 = 31	CES28 = 86	CES53 = 80	CES78 = 67
CES04 = 70	CES29 = 68	CES54 = 92	CES79 = 89
CES05 = 50	CES30 = 77	CES55 = 90	CES80 = 85
CES06 = 51	CES31 = 70	CES56 = 81	CES81 = 75
CES07 = 43	CES32 = 64	CES57 = 79	CES82 = 93
CES08 = 41	CES33 = 74	CES58 = 81	CES83 = 89
CES09 = 29	CES34 = 76	CES59 = 92	CES84 = 91
CES10 = 76	CES35 = 87	CES60 = 96	CES85 = 81
CES11 = 59	CES36 = 99	CES61 = 91	CES86 = 74
CES12 = 65	CES37 = 81	CES62 = 93	CES87 = 83
CES13 = 44	CES38 = 83	CES63 = 79	CES88 = 86
CES14 = 74	CES39 = 94	CES64 = 81	CES89 = 74
CES15 = 72	CES40 = 89	CES65 = 78	CES90 = 85
CES16 = 48	CES41 = 88	CES66 = 76	CES91 = 87
CES17 = 50	CES42 = 80	CES67 = 74	CES92 = 73
CES18 = 57	CES43 = 75	CES68 = 79	CES93 = 84
CES19 = 72	CES44 = 99	CES69 = 83	CES94 = 64
CES20 = 67	CES45 = 83	CES70 = 72	CES95 = 80
CES21 = 87	CES46 = 82	CES71 = 70	CES96 = 86
CES22 = 79	CES47 = 79	CES72 = 90	CES97 = 85
CES23 = 92	CES48 = 78	CES73 = 65	CES98 = 83
CES24 = 91	CES49 = 79	CES74 = 94	CES99 = 82
CES25 = 72	CES50 = 88	CES75 = 70	



Color Rendition by Hue-Angle Bin



Measure Comparisons



(END OF REPORT)