

Cooper Lighting Solutions Photometric Lab
1121 Highway 74 South
Peachtree City, GA 30269



Scaled data based on original data using
LM-79-2019 Approved Method: Electrical and Photometric Measurements of Solid-
State Lighting Products

Test Report Prepared for
Cooper Lighting Solutions

Brand: METALUX

Report Number: P1432578

Luminaire Tested: EHBR1-12-UNV-W-L835

Issue Date: 3/13/2026

Test Information

Test Method: LM-79-2019
Report Number: P1432578
TEST IS SCALED FROM IESNA LM-79-08 TEST DATA (G3-2601-654-2)
Test Lab: INNOVATION CENTER
Issue Date: 3/13/2026
Manufacturer: COOPER LIGHTING SOLUTIONS
Product Line: METALUX
Catalog Number: EHBR1-12-UNV-W-L835
Description: Elevate Round Highbay at, 12000 lumens, 3500K 80CRI LEDs with W lens
Light Source: -
Ballast/Driver: -


Summary

Lumens per Lamp: N/A
Luminaire Lumens: 11878.1 lumens
Efficiency: N/A
Efficacy: 183.6 lumens/watt
Spacing Criteria (0/90/45): 1.54 / 1.54 / 1.31
Luminous Opening: Circular (Dia: 1.71' x H: 0')
CIE Type: Direct

Input Watts (W): 64.7
Input Voltage (V): NR
Input Current (A_{in}): NR
Voltage Rise (V): NR
Power Factor: NR
Total Harmonic Distortion (THDi): NR
Frequency (hertz): 60
Stabilization Time: NR
Operation Time: NR
Ambient Temperature (°C): NR
Test Distance: 24 FT

TEST NUMBER: P1432578
CATALOG NUMBER: EHBR1-12-UNV-W-L835

Luminous Intensity Polar Plot



— 0°-180° - - 45°-225° - · - · 90°-270°



TEST NUMBER: P1432578
 CATALOG NUMBER: EHBR1-12-UNV-W-L835

COEFFICIENT OF UTILIZATION - ZONAL CAVITY METHOD:

RF	20				20				20				20				20	
RC	80				70				50				30				10	0
RW	70	50	30	10	70	50	30	10	50	30	10	50	30	10	50	30	10	0
RCR																		
0	119	119	119	119	116	116	116	116	111	111	111	106	106	106	102	102	102	100
1	111	108	104	101	109	105	102	100	101	99	96	97	95	94	94	92	91	89
2	103	97	91	87	101	95	90	86	92	88	84	89	85	82	86	83	80	78
3	96	88	81	76	94	86	80	75	83	78	74	81	76	72	78	74	71	69
4	89	79	72	67	87	78	71	66	76	70	65	74	69	64	72	67	64	62
5	83	72	65	59	81	71	64	59	69	63	58	67	62	58	66	61	57	55
6	78	66	58	53	76	65	58	53	64	57	52	62	56	52	60	55	51	50
7	72	61	53	48	71	60	53	47	58	52	47	57	51	47	56	51	47	45
8	68	56	48	43	66	55	48	43	54	47	43	53	47	43	52	46	42	41
9	64	52	44	39	62	51	44	39	50	43	39	49	43	39	48	43	39	37
10	60	48	41	36	59	47	40	36	46	40	36	45	40	35	45	39	35	34

AVERAGE LUMINANCE (cd/sqm):

	0°	45°	90°
0°	23322	23322	23322
5°	23630	23630	23630
10°	24612	24612	24612
15°	26348	26348	26348
20°	28762	28762	28762
25°	31500	31500	31500
30°	33281	33281	33281
35°	31956	31956	31956
40°	25606	25606	25606
45°	16005	16005	16005
50°	9391	9391	9391
55°	7221	7221	7221
60°	6321	6321	6321
65°	5864	5864	5864
70°	5605	5605	5605
75°	5253	5253	5253
80°	4765	4765	4765
85°	3659	3659	3659

MAXIMUM LUMINANCE 45°-90°:

Horizontal Angle: 0°
 Vertical Angle: 45°
 Luminance: 16005 cd/sqm



TEST NUMBER: P1432578
 CATALOG NUMBER: EHBR1-12-UNV-W-L835

ZONAL LUMENS:

Zone	Lumens	% Fixture
0°-10°	483.2	4.1
10°-20°	1549.1	13.0
20°-30°	2796.1	23.5
30°-40°	3378.8	28.4
40°-50°	1930.4	16.3
50°-60°	817.6	6.9
60°-70°	527.4	4.4
70°-80°	306.6	2.6
80°-90°	81.1	0.7
90°-100°	0.4	0.0
100°-110°	0.4	0.0
110°-120°	0.6	0.0
120°-130°	0.7	0.0
130°-140°	1.2	0.0
140°-150°	1.6	0.0
150°-160°	1.4	0.0
160°-170°	1.0	0.0
170°-180°	0.3	0.0
0°-30°	4828.4	40.6
0°-40°	8207.3	69.1
0°-60°	10955.3	92.2
0°-90°	11870.5	99.9
90°-120°	1.4	0.0
90°-150°	4.9	0.0
90°-180°	8.0	0.1
0°-180°	11878.1	100.0

CANDELA DISTRIBUTION:

	0°	22.5°	45°	67.5°	90°	Flux
0°	4966	4966	4966	4966	4966	
5°	5013	5013	5013	5013	5013	483
15°	5420	5420	5420	5420	5420	1549
25°	6079	6079	6079	6079	6079	2796
35°	5574	5574	5574	5574	5574	3379
45°	2410	2410	2410	2410	2410	1930
55°	882	882	882	882	882	818
65°	528	528	528	528	528	527
75°	290	290	290	290	290	307
85°	68	68	68	68	68	78
90°	0	0	0	0	0	3
95°	0	0	0	0	0	0
105°	0	0	0	0	0	0
115°	1	1	1	1	1	1
125°	1	1	1	1	1	1
135°	2	2	2	2	2	1
145°	3	3	3	3	3	2
155°	3	3	3	3	3	1
165°	3	3	3	3	3	1
175°	4	4	4	4	4	0
180°	4	4	4	4	4	



TEST NUMBER: P1432578
 CATALOG NUMBER: EHBR1-12-UNV-W-L835

CANDELA DISTRIBUTION (FULL):

	0°	22.5°	45°	67.5°	90°
0°	4966.3	4966.3	4966.3	4966.3	4966.3
2.5°	4983.0	4983.0	4983.0	4983.0	4983.0
5°	5012.7	5012.7	5012.7	5012.7	5012.7
7.5°	5071.3	5071.3	5071.3	5071.3	5071.3
10°	5161.4	5161.4	5161.4	5161.4	5161.4
12.5°	5278.4	5278.4	5278.4	5278.4	5278.4
15°	5419.5	5419.5	5419.5	5419.5	5419.5
17.5°	5581.0	5581.0	5581.0	5581.0	5581.0
20°	5755.3	5755.3	5755.3	5755.3	5755.3
22.5°	5930.9	5930.9	5930.9	5930.9	5930.9
25°	6079.2	6079.2	6079.2	6079.2	6079.2
27.5°	6158.9	6158.9	6158.9	6158.9	6158.9
30°	6137.5	6137.5	6137.5	6137.5	6137.5
32.5°	5955.6	5955.6	5955.6	5955.6	5955.6
35°	5574.2	5574.2	5574.2	5574.2	5574.2
37.5°	4979.6	4979.6	4979.6	4979.6	4979.6
40°	4177.0	4177.0	4177.0	4177.0	4177.0
42.5°	3269.4	3269.4	3269.4	3269.4	3269.4
45°	2410.0	2410.0	2410.0	2410.0	2410.0
47.5°	1722.6	1722.6	1722.6	1722.6	1722.6
50°	1285.4	1285.4	1285.4	1285.4	1285.4
52.5°	1040.9	1040.9	1040.9	1040.9	1040.9
55°	882.0	882.0	882.0	882.0	882.0
57.5°	765.9	765.9	765.9	765.9	765.9
60°	673.0	673.0	673.0	673.0	673.0
62.5°	595.6	595.6	595.6	595.6	595.6
65°	527.7	527.7	527.7	527.7	527.7
67.5°	467.9	467.9	467.9	467.9	467.9
70°	408.2	408.2	408.2	408.2	408.2
72.5°	348.6	348.6	348.6	348.6	348.6
75°	289.5	289.5	289.5	289.5	289.5
77.5°	232.5	232.5	232.5	232.5	232.5
80°	176.2	176.2	176.2	176.2	176.2
82.5°	120.8	120.8	120.8	120.8	120.8
85°	67.9	67.9	67.9	67.9	67.9
87.5°	21.4	21.4	21.4	21.4	21.4
90°	0.4	0.4	0.4	0.4	0.4
92.5°	0.2	0.2	0.2	0.2	0.2
95°	0.4	0.4	0.4	0.4	0.4
97.5°	0.4	0.4	0.4	0.4	0.4
100°	0.4	0.4	0.4	0.4	0.4
102.5°	0.4	0.4	0.4	0.4	0.4
105°	0.4	0.4	0.4	0.4	0.4
107.5°	0.4	0.4	0.4	0.4	0.4
110°	0.6	0.6	0.6	0.6	0.6



TEST NUMBER: P1432578
 CATALOG NUMBER: EHBR1-12-UNV-W-L835

CANDELA DISTRIBUTION (continued):

	0°	22.5°	45°	67.5°	90°
112.5°	0.6	0.6	0.6	0.6	0.6
115°	0.6	0.6	0.6	0.6	0.6
117.5°	0.6	0.6	0.6	0.6	0.6
120°	0.6	0.6	0.6	0.6	0.6
122.5°	0.6	0.6	0.6	0.6	0.6
125°	0.8	0.8	0.8	0.8	0.8
127.5°	0.8	0.8	0.8	0.8	0.8
130°	1.0	1.0	1.0	1.0	1.0
132.5°	1.4	1.4	1.4	1.4	1.4
135°	1.6	1.6	1.6	1.6	1.6
137.5°	1.7	1.7	1.7	1.7	1.7
140°	2.2	2.2	2.2	2.2	2.2
142.5°	2.4	2.4	2.4	2.4	2.4
145°	2.6	2.6	2.6	2.6	2.6
147.5°	2.8	2.8	2.8	2.8	2.8
150°	2.8	2.8	2.8	2.8	2.8
152.5°	2.8	2.8	2.8	2.8	2.8
155°	3.0	3.0	3.0	3.0	3.0
157.5°	3.0	3.0	3.0	3.0	3.0
160°	3.2	3.2	3.2	3.2	3.2
162.5°	3.4	3.4	3.4	3.4	3.4
165°	3.4	3.4	3.4	3.4	3.4
167.5°	3.4	3.4	3.4	3.4	3.4
170°	3.4	3.4	3.4	3.4	3.4
172.5°	3.6	3.6	3.6	3.6	3.6
175°	3.8	3.8	3.8	3.8	3.8
177.5°	3.8	3.8	3.8	3.8	3.8
180°	4.0	4.0	4.0	4.0	4.0



TEST NUMBER: P1432578
 CATALOG NUMBER: EHBR1-12-UNV-W-L835

CIE UGR TABLE:

Reflectances:											
Ceiling		0.7	0.7	0.5	0.5	0.3	0.7	0.7	0.5	0.5	0.3
Wall		0.5	0.3	0.5	0.3	0.3	0.5	0.3	0.5	0.3	0.3
Reference plane		0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2
Room dimensions		Viewed crosswise					Viewed endwise				
X=2H	Y=2H	15.90	17.21	16.27	17.53	17.84	15.90	17.21	16.27	17.53	17.84
	3H	17.49	18.66	17.87	18.99	19.35	17.49	18.66	17.87	18.99	19.35
	4H	18.11	19.20	18.52	19.55	19.94	18.11	19.20	18.52	19.55	19.94
	6H	18.58	19.58	18.99	19.95	20.34	18.58	19.58	18.99	19.95	20.34
	8H	18.72	19.66	19.15	20.06	20.46	18.72	19.66	19.15	20.06	20.46
	12H	18.79	19.70	19.22	20.08	20.51	18.79	19.70	19.22	20.08	20.51
4H	2H	16.39	17.48	16.80	17.83	18.22	16.39	17.48	16.80	17.83	18.22
	3H	18.23	19.12	18.64	19.52	19.93	18.23	19.12	18.64	19.52	19.93
	4H	18.98	19.78	19.42	20.20	20.64	18.98	19.78	19.42	20.20	20.64
	6H	19.57	20.26	20.03	20.71	21.18	19.57	20.26	20.03	20.71	21.18
	8H	19.75	20.40	20.22	20.84	21.32	19.75	20.40	20.22	20.84	21.32
	12H	19.86	20.43	20.35	20.91	21.39	19.86	20.43	20.35	20.91	21.39
8H	4H	19.24	19.88	19.71	20.33	20.80	19.24	19.88	19.71	20.33	20.80
	6H	19.95	20.48	20.45	20.97	21.46	19.95	20.48	20.45	20.97	21.46
	8H	20.20	20.67	20.72	21.19	21.68	20.20	20.67	20.72	21.19	21.68
	12H	20.37	20.79	20.89	21.29	21.86	20.37	20.79	20.89	21.29	21.86
12H	4H	19.25	19.82	19.74	20.30	20.78	19.25	19.82	19.74	20.30	20.78
	6H	19.99	20.46	20.51	20.97	21.47	19.99	20.46	20.51	20.97	21.47
	8H	20.29	20.71	20.80	21.20	21.77	20.29	20.71	20.80	21.20	21.77

Cooper Lighting Solutions Photometric Lab
1121 Highway 74 South
Peachtree City, GA 30269



LM-79-2019: Approved Method: Electrical and Photometric Measurements of Solid-State Lighting Products

Report Prepared for

Cooper Lighting Solutions

Metalux

Report Number: SP1-2506-472-3

Test Date: 07/31/2025

Luminaire Tested: EHBR-60-L835-N

Data in this report applies to families of products including EHBR-60-L835-N

Test Information

Test Method: LM-79-2019
 Report Number: SP1-2506-472-3
 Test Lab: COOPER LIGHTING SOLUTIONS
 Photometer: SP1 - 76IN SPHERE
 Measurement Geometry: 4π
 Issue Date: 08/05/2025
 Manufacturer: COOPER LIGHTING SOLUTIONS
 Product Line: Metalux
 Catalog Number: **EHBR-60-L835-N**
 Description: Elevate Round Highbay at, 60000 lumens, 3500K 80CRI LEDs with N lens

Spectral Parameters

CCT (K): 3468
 CIE u': 0.2375
 CIE v': 0.5091
 Duv: -0.0021
 CIE x: 0.4049
 CIE y: 0.3856
 CIE z: 0.2095
 Peak Wavelength (nm): 630
 Dominant Wavelength (nm): 581
 Purity: 37.24544
 R_f: 80.1
 R_g: 101

CRI (Ra):	82.1		
R1:	82.9	R9:	27.6
R2:	85.6	R10:	63.8
R3:	85.9	R11:	81.2
R4:	82.8	R12:	57.2
R5:	81.0	R13:	82.6
R6:	79.7	R14:	91.0
R7:	86.5	R15:	79.4
R8:	72.1		



Test Conditions

Stabilization Time: 39M
 Operation Time: 1H 39M
 Sphere Temperature (°C): 25.0

REPORT NUMBER: SP1-2506-472-3

Measurement and Test Equipment			
Instrument	Identification Number	Calibration Date	Calibration Due Date
Photometer	76INCH SPHERE IN0058	6/16/2025	12/16/2025
Power Meter	XITRON INXT2011004	1/21/2025	1/21/2026
AC Power Source	CHROMA 61603 IN0063	10/22/2024	10/22/2025
DC Power Source	AGILENT E3634A IN0208	10/22/2024	10/22/2025
Sphere Thermometer	ONSET IN0085	10/22/2024	10/22/2025
Room Thermometer	ONSET IN0046	10/22/2024	10/22/2025

REPORT NUMBER: SP1-2506-472-3

CIE 1931 Chromaticity Diagram



CIE 1931 Chromaticity Diagram with 2017 ANSI 7-Step and 4-Step Quadrangles



CCT = 3468K
 CIE x = 0.4049
 CIE y = 0.3856
 Duv = -0.0021

Point lies inside the ANSI 3500K 4-step quadrangle

REPORT NUMBER: SP1-2506-472-3

Photopic Flux vs. Wavelength



Photopic Lumens: NR

λ (nm)	Power W [^] /nm	Lumens (ϕ /nm)	λ (nm)	Power W [^] /nm	Lumens (ϕ /nm)	λ (nm)	Power W [^] /nm	Lumens (ϕ /nm)	λ (nm)	Power W [^] /nm	Lumens (ϕ /nm)	λ (nm)	Power W [^] /nm	Lumens (ϕ /nm)
360	0	NR	490	60	NR	620	327	NR	750	7	NR	880	0	NR
365	0	NR	495	82	NR	625	322	NR	755	6	NR	885	0	NR
370	0	NR	500	114	NR	630	1000	NR	760	5	NR	890	0	NR
375	0	NR	505	152	NR	635	645	NR	765	4	NR	895	0	NR
380	0	NR	510	189	NR	640	197	NR	770	4	NR	900	0	NR
385	1	NR	515	222	NR	645	189	NR	775	3	NR	905	0	NR
390	2	NR	520	248	NR	650	163	NR	780	3	NR	910	0	NR
395	3	NR	525	268	NR	655	134	NR	785	2	NR	915	0	NR
400	4	NR	530	283	NR	660	113	NR	790	2	NR	920	0	NR
405	6	NR	535	294	NR	665	94	NR	795	2	NR	925	0	NR
410	9	NR	540	305	NR	670	87	NR	800	2	NR	930	0	NR
415	18	NR	545	314	NR	675	70	NR	805	1	NR	935	0	NR
420	34	NR	550	323	NR	680	60	NR	810	1	NR	940	0	NR
425	62	NR	555	335	NR	685	51	NR	815	1	NR	945	0	NR
430	102	NR	560	346	NR	690	44	NR	820	1	NR	950	0	NR
435	159	NR	565	356	NR	695	38	NR	825	1	NR	955	0	NR
440	241	NR	570	364	NR	700	32	NR	830	1	NR	960	0	NR
445	363	NR	575	371	NR	705	28	NR	835	1	NR	965	0	NR
450	389	NR	580	375	NR	710	24	NR	840	1	NR	970	0	NR
455	245	NR	585	375	NR	715	20	NR	845	0	NR	975	0	NR
460	158	NR	590	373	NR	720	17	NR	850	0	NR	980	0	NR
465	120	NR	595	364	NR	725	15	NR	855	0	NR	985	0	NR
470	79	NR	600	357	NR	730	13	NR	860	0	NR	990	0	NR
475	57	NR	605	349	NR	735	11	NR	865	0	NR	995	0	NR
480	51	NR	610	371	NR	740	9	NR	870	0	NR	1000	0	NR
485	51	NR	615	387	NR	745	8	NR	875	0	NR			

REPORT NUMBER: SP1-2506-472-3

Scotopic Flux vs. Wavelength



Scotopic Lumens: NR

S/P: 1.43

λ (nm)	Power W [^] /nm	Lumens (φ/nm)	λ (nm)	Power W [^] /nm	Lumens (φ/nm)	λ (nm)	Power W [^] /nm	Lumens (φ/nm)	λ (nm)	Power W [^] /nm	Lumens (φ/nm)	λ (nm)	Power W [^] /nm	Lumens (φ/nm)
360	0	NR	490	60	NR	620	327	NR	750	7	NR	880	0	NR
365	0	NR	495	82	NR	625	322	NR	755	6	NR	885	0	NR
370	0	NR	500	114	NR	630	1000	NR	760	5	NR	890	0	NR
375	0	NR	505	152	NR	635	645	NR	765	4	NR	895	0	NR
380	0	NR	510	189	NR	640	197	NR	770	4	NR	900	0	NR
385	1	NR	515	222	NR	645	189	NR	775	3	NR	905	0	NR
390	2	NR	520	248	NR	650	163	NR	780	3	NR	910	0	NR
395	3	NR	525	268	NR	655	134	NR	785	2	NR	915	0	NR
400	4	NR	530	283	NR	660	113	NR	790	2	NR	920	0	NR
405	6	NR	535	294	NR	665	94	NR	795	2	NR	925	0	NR
410	9	NR	540	305	NR	670	87	NR	800	2	NR	930	0	NR
415	18	NR	545	314	NR	675	70	NR	805	1	NR	935	0	NR
420	34	NR	550	323	NR	680	60	NR	810	1	NR	940	0	NR
425	62	NR	555	335	NR	685	51	NR	815	1	NR	945	0	NR
430	102	NR	560	346	NR	690	44	NR	820	1	NR	950	0	NR
435	159	NR	565	356	NR	695	38	NR	825	1	NR	955	0	NR
440	241	NR	570	364	NR	700	32	NR	830	1	NR	960	0	NR
445	363	NR	575	371	NR	705	28	NR	835	1	NR	965	0	NR
450	389	NR	580	375	NR	710	24	NR	840	1	NR	970	0	NR
455	245	NR	585	375	NR	715	20	NR	845	0	NR	975	0	NR
460	158	NR	590	373	NR	720	17	NR	850	0	NR	980	0	NR
465	120	NR	595	364	NR	725	15	NR	855	0	NR	985	0	NR
470	79	NR	600	357	NR	730	13	NR	860	0	NR	990	0	NR
475	57	NR	605	349	NR	735	11	NR	865	0	NR	995	0	NR
480	51	NR	610	371	NR	740	9	NR	870	0	NR	1000	0	NR
485	51	NR	615	387	NR	745	8	NR	875	0	NR			

REPORT NUMBER: SP1-2506-472-3

Melanopic Flux vs. Wavelength



Melanopic Lumens: NR

M/P: 2.75

λ (nm)	Power W [^] /nm	Lumens (φ/nm)	λ (nm)	Power W [^] /nm	Lumens (φ/nm)	λ (nm)	Power W [^] /nm	Lumens (φ/nm)	λ (nm)	Power W [^] /nm	Lumens (φ/nm)	λ (nm)	Power W [^] /nm	Lumens (φ/nm)
360	0	NR	490	60	NR	620	327	NR	750	7	NR	880	0	NR
365	0	NR	495	82	NR	625	322	NR	755	6	NR	885	0	NR
370	0	NR	500	114	NR	630	1000	NR	760	5	NR	890	0	NR
375	0	NR	505	152	NR	635	645	NR	765	4	NR	895	0	NR
380	0	NR	510	189	NR	640	197	NR	770	4	NR	900	0	NR
385	1	NR	515	222	NR	645	189	NR	775	3	NR	905	0	NR
390	2	NR	520	248	NR	650	163	NR	780	3	NR	910	0	NR
395	3	NR	525	268	NR	655	134	NR	785	2	NR	915	0	NR
400	4	NR	530	283	NR	660	113	NR	790	2	NR	920	0	NR
405	6	NR	535	294	NR	665	94	NR	795	2	NR	925	0	NR
410	9	NR	540	305	NR	670	87	NR	800	2	NR	930	0	NR
415	18	NR	545	314	NR	675	70	NR	805	1	NR	935	0	NR
420	34	NR	550	323	NR	680	60	NR	810	1	NR	940	0	NR
425	62	NR	555	335	NR	685	51	NR	815	1	NR	945	0	NR
430	102	NR	560	346	NR	690	44	NR	820	1	NR	950	0	NR
435	159	NR	565	356	NR	695	38	NR	825	1	NR	955	0	NR
440	241	NR	570	364	NR	700	32	NR	830	1	NR	960	0	NR
445	363	NR	575	371	NR	705	28	NR	835	1	NR	965	0	NR
450	389	NR	580	375	NR	710	24	NR	840	1	NR	970	0	NR
455	245	NR	585	375	NR	715	20	NR	845	0	NR	975	0	NR
460	158	NR	590	373	NR	720	17	NR	850	0	NR	980	0	NR
465	120	NR	595	364	NR	725	15	NR	855	0	NR	985	0	NR
470	79	NR	600	357	NR	730	13	NR	860	0	NR	990	0	NR
475	57	NR	605	349	NR	735	11	NR	865	0	NR	995	0	NR
480	51	NR	610	371	NR	740	9	NR	870	0	NR	1000	0	NR
485	51	NR	615	387	NR	745	8	NR	875	0	NR			

Summary

$R_f = 80.1$
 $R_g = 101$
 $CIE R_a = 82.1$
 $R_9 = 27.6$



Color Vector Graphics



Individual Sample Fidelity Index ($R_{f,i}$)

CES01 = 86	CES26 = 68	CES51 = 90	CES76 = 59
CES02 = 62	CES27 = 89	CES52 = 90	CES77 = 78
CES03 = 31	CES28 = 84	CES53 = 81	CES78 = 61
CES04 = 70	CES29 = 66	CES54 = 91	CES79 = 86
CES05 = 49	CES30 = 77	CES55 = 90	CES80 = 82
CES06 = 51	CES31 = 69	CES56 = 80	CES81 = 79
CES07 = 42	CES32 = 62	CES57 = 79	CES82 = 92
CES08 = 41	CES33 = 74	CES58 = 81	CES83 = 89
CES09 = 29	CES34 = 72	CES59 = 92	CES84 = 89
CES10 = 75	CES35 = 85	CES60 = 94	CES85 = 82
CES11 = 58	CES36 = 97	CES61 = 90	CES86 = 78
CES12 = 64	CES37 = 79	CES62 = 92	CES87 = 82
CES13 = 43	CES38 = 85	CES63 = 78	CES88 = 86
CES14 = 74	CES39 = 94	CES64 = 79	CES89 = 76
CES15 = 71	CES40 = 89	CES65 = 76	CES90 = 85
CES16 = 47	CES41 = 89	CES66 = 73	CES91 = 83
CES17 = 49	CES42 = 77	CES67 = 70	CES92 = 73
CES18 = 56	CES43 = 74	CES68 = 76	CES93 = 84
CES19 = 72	CES44 = 99	CES69 = 81	CES94 = 65
CES20 = 66	CES45 = 83	CES70 = 68	CES95 = 79
CES21 = 86	CES46 = 82	CES71 = 64	CES96 = 85
CES22 = 78	CES47 = 81	CES72 = 88	CES97 = 85
CES23 = 92	CES48 = 80	CES73 = 60	CES98 = 82
CES24 = 91	CES49 = 80	CES74 = 97	CES99 = 81
CES25 = 72	CES50 = 89	CES75 = 64	



Color Rendition by Hue-Angle Bin



Measure Comparisons



(END OF REPORT)