

Cooper Lighting Solutions Photometric Lab
1121 Highway 74 South
Peachtree City, GA 30269



Scaled data based on original data using
LM-79-2019 Approved Method: Electrical and Photometric Measurements of Solid-
State Lighting Products

Test Report Prepared for
Cooper Lighting Solutions

Brand: METALUX

Report Number: P1432569

Luminaire Tested: EHBR1-12-UNV-N-L835-UPL40

Issue Date: 3/20/2026

Test Information

Test Method: LM-79-2019
Report Number: P1432569
REPORT IS A COMBINATION OF REPORTS P1431658 AND P1431635
Test Lab: INNOVATION CENTER
Issue Date: 3/20/2026
Manufacturer: COOPER LIGHTING SOLUTIONS
Product Line: METALUX
Catalog Number: EHBR1-12-UNV-N-L835-UPL40
Description: Elevate Round Highbay at, 12000 lumens, 3500K 80CRI LEDs with N lens
Light Source: -
Ballast/Driver: -


Summary

Lumens per Lamp: N/A
Luminaire Lumens: 15740.5 lumens
Efficiency: N/A
Efficacy: 165.2 lumens/watt
Spacing Criteria (0/90/45): 0.82 / 0.82 / 0.8
Luminous Opening: Vertical Cylinder (Dia: 1.71' x H: 0.1')
CIE Type: Semi-Direct

Input Watts (W): 95.3
Input Voltage (V): NR
Input Current (Ain): NR
Voltage Rise (V): NR
Power Factor: NR
Total Harmonic Distortion (THDi): NR
Frequency (hertz): 60
Stabilization Time: NR
Operation Time: NR
Ambient Temperature (°C): NR
Test Distance: 24 FT

TEST NUMBER: P1432569
CATALOG NUMBER: EHBR1-12-UNV-N-L835-UPL40

Luminous Intensity Polar Plot





TEST NUMBER: P1432569

CATALOG NUMBER: EHBR1-12-UNV-N-L835-UPL40

COEFFICIENT OF UTILIZATION - ZONAL CAVITY METHOD:

RF	20				20				20				20				20	
RC	80				70				50				30				10	0
RW	70	50	30	10	70	50	30	10	50	30	10	50	30	10	50	30	10	0
RCR																		
0	114	114	114	114	108	108	108	108	98	98	98	89	89	89	81	81	81	77
1	106	103	100	97	101	98	96	93	90	88	86	82	81	80	75	74	73	70
2	100	94	89	85	95	90	86	82	83	79	77	76	74	72	70	68	67	64
3	93	86	80	75	89	82	77	73	76	72	69	71	68	65	66	63	61	58
4	88	79	72	67	84	76	70	66	71	66	63	66	62	59	62	59	56	54
5	82	73	66	61	79	70	64	60	66	61	57	62	58	55	58	55	52	50
6	78	68	61	56	75	66	59	55	62	57	53	58	54	51	55	51	49	46
7	73	63	56	52	70	61	55	51	58	53	49	55	50	47	52	48	45	43
8	69	59	52	48	67	57	51	47	54	49	46	51	47	44	49	45	43	41
9	66	55	49	45	63	54	48	44	51	46	43	49	44	41	46	43	40	38
10	63	52	46	42	60	51	45	41	48	43	40	46	42	39	44	40	38	36

AVERAGE LUMINANCE (cd/sqm):

	0°	45°	90°
0°	66220	66220	66220
5°	64934	64934	64934
10°	61631	61631	61631
15°	56075	56075	56075
20°	48100	48100	48100
25°	37839	37839	37839
30°	25967	25967	25967
35°	15425	15425	15425
40°	9127	9127	9127
45°	6551	6551	6551
50°	5385	5385	5385
55°	4894	4894	4894
60°	4685	4685	4685
65°	4468	4468	4468
70°	4155	4155	4155
75°	3756	3756	3756
80°	3119	3119	3119
85°	1976	1976	1976

MAXIMUM LUMINANCE 45°-90°:

Horizontal Angle: 0°
 Vertical Angle: 45°
 Luminance: 6551 cd/sqm



TEST NUMBER: P1432569
 CATALOG NUMBER: EHBR1-12-UNV-N-L835-UPL40

ZONAL LUMENS:

Zone	Lumens	% Fixture
0°-10°	1298.9	8.3
10°-20°	3260.5	20.7
20°-30°	3409.2	21.7
30°-40°	1847.2	11.7
40°-50°	849.8	5.4
50°-60°	598.9	3.8
60°-70°	460.9	2.9
70°-80°	279.4	1.8
80°-90°	85.3	0.5
90°-100°	104.1	0.7
100°-110°	652.2	4.1
110°-120°	1166.3	7.4
120°-130°	684.3	4.3
130°-140°	419.8	2.7
140°-150°	291.2	1.8
150°-160°	189.2	1.2
160°-170°	107.8	0.7
170°-180°	35.6	0.2
0°-30°	7968.7	50.6
0°-40°	9815.9	62.4
0°-60°	11264.6	71.6
0°-90°	12090.2	76.8
90°-120°	1922.5	12.2
90°-150°	3317.8	21.1
90°-180°	3650.0	23.2
0°-180°	15740.5	100.0

CANDELA DISTRIBUTION:

	0°	22.5°	45°	67.5°	90°	Flux
0°	14101	14101	14101	14101	14101	
5°	13864	13864	13864	13864	13864	1299
15°	11764	11764	11764	11764	11764	3261
25°	7556	7556	7556	7556	7556	3409
35°	2831	2831	2831	2831	2831	1847
45°	1060	1060	1060	1060	1060	850
55°	661	661	661	661	661	599
65°	466	466	466	466	466	461
75°	265	265	265	265	265	279
85°	68	68	68	68	68	75
90°	28	44	76	48	28	16
95°	46	77	169	84	52	44
105°	228	449	1147	495	301	305
115°	1049	1103	1356	1300	1291	966
125°	756	706	725	736	825	690
135°	552	535	554	520	518	432
145°	453	447	474	468	466	287
155°	397	393	412	412	412	185
165°	372	372	382	382	380	106
175°	368	368	374	374	374	35
180°	372	372	372	372	372	



TEST NUMBER: P1432569

CATALOG NUMBER: EHBR1-12-UNV-N-L835-UPL40

CANDELA DISTRIBUTION (FULL):

	0°	22.5°	45°	67.5°	90°
0°	14101.0	14101.0	14101.0	14101.0	14101.0
2.5°	14051.1	14051.1	14051.1	14051.1	14051.1
5°	13864.5	13864.5	13864.5	13864.5	13864.5
7.5°	13546.1	13546.1	13546.1	13546.1	13546.1
10°	13094.3	13094.3	13094.3	13094.3	13094.3
12.5°	12510.3	12510.3	12510.3	12510.3	12510.3
15°	11764.3	11764.3	11764.3	11764.3	11764.3
17.5°	10898.9	10898.9	10898.9	10898.9	10898.9
20°	9886.0	9886.0	9886.0	9886.0	9886.0
22.5°	8758.3	8758.3	8758.3	8758.3	8758.3
25°	7556.4	7556.4	7556.4	7556.4	7556.4
27.5°	6282.1	6282.1	6282.1	6282.1	6282.1
30°	4994.7	4994.7	4994.7	4994.7	4994.7
32.5°	3833.3	3833.3	3833.3	3833.3	3833.3
35°	2831.1	2831.1	2831.1	2831.1	2831.1
37.5°	2078.7	2078.7	2078.7	2078.7	2078.7
40°	1581.9	1581.9	1581.9	1581.9	1581.9
42.5°	1268.5	1268.5	1268.5	1268.5	1268.5
45°	1060.0	1060.0	1060.0	1060.0	1060.0
47.5°	909.9	909.9	909.9	909.9	909.9
50°	802.6	802.6	802.6	802.6	802.6
52.5°	724.3	724.3	724.3	724.3	724.3
55°	661.4	661.4	661.4	661.4	661.4
57.5°	610.4	610.4	610.4	610.4	610.4
60°	563.2	563.2	563.2	563.2	563.2
62.5°	516.1	516.1	516.1	516.1	516.1
65°	466.4	466.4	466.4	466.4	466.4
67.5°	415.8	415.8	415.8	415.8	415.8
70°	364.6	364.6	364.6	364.6	364.6
72.5°	314.9	314.9	314.9	314.9	314.9
75°	264.6	264.6	264.6	264.6	264.6
77.5°	215.5	215.5	215.5	215.5	215.5
80°	164.1	164.1	164.1	164.1	164.1
82.5°	114.8	114.8	114.8	114.8	114.8
85°	67.9	67.9	67.9	67.9	67.9
87.5°	24.3	24.3	24.3	24.3	24.3
90°	27.5	44.3	75.6	48.5	27.5
92.5°	39.7	66.9	121.2	62.6	35.5
95°	46.0	77.3	169.2	83.6	52.3
97.5°	58.5	85.6	194.3	102.4	81.5
100°	77.3	100.3	303.0	125.4	108.7
102.5°	131.7	213.1	643.6	236.1	165.0
105°	227.8	449.3	1147.2	495.2	300.9
107.5°	395.0	804.5	1512.8	877.6	570.5
110°	737.7	1067.7	1586.0	1205.6	913.2



TEST NUMBER: P1432569

CATALOG NUMBER: EHBR1-12-UNV-N-L835-UPL40

CANDELA DISTRIBUTION (continued):

	0°	22.5°	45°	67.5°	90°
112.5°	996.8	1147.2	1519.1	1331.0	1189.0
115°	1048.9	1103.3	1356.1	1299.7	1291.4
117.5°	1013.4	1007.1	1151.3	1168.1	1247.4
120°	938.2	896.4	961.2	1019.7	1126.3
122.5°	844.2	794.0	823.3	867.2	973.8
125°	756.4	706.2	725.1	735.5	825.4
127.5°	679.1	645.6	656.1	643.6	700.0
130°	626.9	597.6	612.3	583.0	610.1
132.5°	583.0	564.2	580.9	545.4	553.7
135°	551.7	534.9	553.7	520.3	518.2
137.5°	524.5	509.9	528.7	503.6	497.4
140°	499.4	486.9	507.7	488.9	484.8
142.5°	472.2	463.9	488.9	476.4	472.2
145°	453.4	447.1	474.3	468.1	465.9
147.5°	436.8	432.6	457.6	455.6	455.6
150°	422.1	417.9	443.0	440.9	443.0
152.5°	407.5	403.3	426.3	424.2	426.3
155°	397.0	392.8	411.6	411.6	411.6
157.5°	388.7	386.5	401.2	401.2	401.2
160°	382.4	380.3	392.8	392.8	390.8
162.5°	376.2	374.0	388.7	386.5	386.5
165°	372.0	372.0	382.4	382.4	380.3
167.5°	372.0	369.8	380.3	380.3	378.2
170°	369.8	369.8	378.2	376.2	374.0
172.5°	369.8	369.8	378.2	376.2	374.0
175°	367.8	367.8	374.0	374.0	374.0
177.5°	369.8	369.8	374.0	374.0	372.0
180°	372.0	372.0	372.0	372.0	372.0



TEST NUMBER: P1432569
 CATALOG NUMBER: EHBR1-12-UNV-N-L835-UPL40

CIE UGR TABLE:

Reflectances:											
Ceiling		0.7	0.7	0.5	0.5	0.3	0.7	0.7	0.5	0.5	0.3
Wall		0.5	0.3	0.5	0.3	0.3	0.5	0.3	0.5	0.3	0.3
Reference plane		0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2
Room dimensions		Viewed crosswise					Viewed endwise				
X=2H	Y=2H	12.12	13.01	12.85	13.73	14.57	12.12	13.01	12.85	13.73	14.57
	3H	13.90	14.69	14.63	15.41	16.29	13.90	14.69	14.63	15.41	16.29
	4H	14.55	15.29	15.30	16.03	16.91	14.55	15.29	15.30	16.03	16.91
	6H	15.00	15.68	15.77	16.43	17.33	15.00	15.68	15.77	16.43	17.33
	8H	15.12	15.77	15.90	16.53	17.43	15.12	15.77	15.90	16.53	17.43
	12H	15.17	15.79	15.95	16.54	17.47	15.17	15.79	15.95	16.54	17.47
4H	2H	12.65	13.40	13.41	14.13	15.02	12.65	13.40	13.41	14.13	15.02
	3H	14.62	15.23	15.38	16.00	16.91	14.62	15.23	15.38	16.00	16.91
	4H	15.39	15.94	16.16	16.72	17.65	15.39	15.94	16.16	16.72	17.65
	6H	15.95	16.43	16.75	17.23	18.17	15.95	16.43	16.75	17.23	18.17
	8H	16.11	16.56	16.91	17.35	18.30	16.11	16.56	16.91	17.35	18.30
	12H	16.18	16.58	17.00	17.40	18.35	16.18	16.58	17.00	17.40	18.35
8H	4H	15.61	16.06	16.41	16.85	17.80	15.61	16.06	16.41	16.85	17.80
	6H	16.29	16.65	17.12	17.49	18.44	16.29	16.65	17.12	17.49	18.44
	8H	16.52	16.84	17.36	17.67	18.64	16.52	16.84	17.36	17.67	18.64
	12H	16.65	16.93	17.49	17.75	18.78	16.65	16.93	17.49	17.75	18.78
12H	4H	15.60	16.00	16.42	16.81	17.77	15.60	16.00	16.42	16.81	17.77
	6H	16.32	16.64	17.16	17.47	18.44	16.32	16.64	17.16	17.47	18.44
	8H	16.57	16.85	17.41	17.68	18.71	16.57	16.85	17.41	17.68	18.71

Cooper Lighting Solutions Photometric Lab
1121 Highway 74 South
Peachtree City, GA 30269



LM-79-2019: Approved Method: Electrical and Photometric Measurements of Solid-
State Lighting Products

Report Prepared for

Cooper Lighting Solutions

Metalux

Report Number: SP1-2506-472-3

Test Date: 07/31/2025

Luminaire Tested: EHBR-60-L835-N

Data in this report applies to families of products including EHBR-60-L835-N

Test Information

Test Method: LM-79-2019
 Report Number: SP1-2506-472-3
 Test Lab: COOPER LIGHTING SOLUTIONS
 Photometer: SP1 - 76IN SPHERE
 Measurement Geometry: 4π
 Issue Date: 08/05/2025
 Manufacturer: COOPER LIGHTING SOLUTIONS
 Product Line: Metalux
 Catalog Number: **EHBR-60-L835-N**
 Description: Elevate Round Highbay at, 60000 lumens, 3500K 80CRI LEDs with N lens

Spectral Parameters

CCT (K): 3468
 CIE u': 0.2375
 CIE v': 0.5091
 Duv: -0.0021
 CIE x: 0.4049
 CIE y: 0.3856
 CIE z: 0.2095
 Peak Wavelength (nm): 630
 Dominant Wavelength (nm): 581
 Purity: 37.24544
 Rf: 80.1
 Rg: 101

CRI (Ra):	82.1		
R1:	82.9	R9:	27.6
R2:	85.6	R10:	63.8
R3:	85.9	R11:	81.2
R4:	82.8	R12:	57.2
R5:	81.0	R13:	82.6
R6:	79.7	R14:	91.0
R7:	86.5	R15:	79.4
R8:	72.1		



Test Conditions

Stabilization Time: 39M
 Operation Time: 1H 39M
 Sphere Temperature (°C): 25.0

REPORT NUMBER: SP1-2506-472-3

Measurement and Test Equipment			
Instrument	Identification Number	Calibration Date	Calibration Due Date
Photometer	76INCH SPHERE IN0058	6/16/2025	12/16/2025
Power Meter	XITRON INXT2011004	1/21/2025	1/21/2026
AC Power Source	CHROMA 61603 IN0063	10/22/2024	10/22/2025
DC Power Source	AGILENT E3634A IN0208	10/22/2024	10/22/2025
Sphere Thermometer	ONSET IN0085	10/22/2024	10/22/2025
Room Thermometer	ONSET IN0046	10/22/2024	10/22/2025

REPORT NUMBER: SP1-2506-472-3

CIE 1931 Chromaticity Diagram



CIE 1931 Chromaticity Diagram with 2017 ANSI 7-Step and 4-Step Quadrangles



Point lies inside the ANSI 3500K 4-step quadrangle

REPORT NUMBER: SP1-2506-472-3

Photopic Flux vs. Wavelength



Photopic Lumens: NR

λ (nm)	Power W [^] /nm	Lumens (φ/nm)	λ (nm)	Power W [^] /nm	Lumens (φ/nm)	λ (nm)	Power W [^] /nm	Lumens (φ/nm)	λ (nm)	Power W [^] /nm	Lumens (φ/nm)	λ (nm)	Power W [^] /nm	Lumens (φ/nm)
360	0	NR	490	60	NR	620	327	NR	750	7	NR	880	0	NR
365	0	NR	495	82	NR	625	322	NR	755	6	NR	885	0	NR
370	0	NR	500	114	NR	630	1000	NR	760	5	NR	890	0	NR
375	0	NR	505	152	NR	635	645	NR	765	4	NR	895	0	NR
380	0	NR	510	189	NR	640	197	NR	770	4	NR	900	0	NR
385	1	NR	515	222	NR	645	189	NR	775	3	NR	905	0	NR
390	2	NR	520	248	NR	650	163	NR	780	3	NR	910	0	NR
395	3	NR	525	268	NR	655	134	NR	785	2	NR	915	0	NR
400	4	NR	530	283	NR	660	113	NR	790	2	NR	920	0	NR
405	6	NR	535	294	NR	665	94	NR	795	2	NR	925	0	NR
410	9	NR	540	305	NR	670	87	NR	800	2	NR	930	0	NR
415	18	NR	545	314	NR	675	70	NR	805	1	NR	935	0	NR
420	34	NR	550	323	NR	680	60	NR	810	1	NR	940	0	NR
425	62	NR	555	335	NR	685	51	NR	815	1	NR	945	0	NR
430	102	NR	560	346	NR	690	44	NR	820	1	NR	950	0	NR
435	159	NR	565	356	NR	695	38	NR	825	1	NR	955	0	NR
440	241	NR	570	364	NR	700	32	NR	830	1	NR	960	0	NR
445	363	NR	575	371	NR	705	28	NR	835	1	NR	965	0	NR
450	389	NR	580	375	NR	710	24	NR	840	1	NR	970	0	NR
455	245	NR	585	375	NR	715	20	NR	845	0	NR	975	0	NR
460	158	NR	590	373	NR	720	17	NR	850	0	NR	980	0	NR
465	120	NR	595	364	NR	725	15	NR	855	0	NR	985	0	NR
470	79	NR	600	357	NR	730	13	NR	860	0	NR	990	0	NR
475	57	NR	605	349	NR	735	11	NR	865	0	NR	995	0	NR
480	51	NR	610	371	NR	740	9	NR	870	0	NR	1000	0	NR
485	51	NR	615	387	NR	745	8	NR	875	0	NR			

REPORT NUMBER: SP1-2506-472-3

Scotopic Flux vs. Wavelength



Scotopic Lumens: NR

S/P: 1.43

λ (nm)	Power W [^] /nm	Lumens (φ/nm)	λ (nm)	Power W [^] /nm	Lumens (φ/nm)	λ (nm)	Power W [^] /nm	Lumens (φ/nm)	λ (nm)	Power W [^] /nm	Lumens (φ/nm)	λ (nm)	Power W [^] /nm	Lumens (φ/nm)
360	0	NR	490	60	NR	620	327	NR	750	7	NR	880	0	NR
365	0	NR	495	82	NR	625	322	NR	755	6	NR	885	0	NR
370	0	NR	500	114	NR	630	1000	NR	760	5	NR	890	0	NR
375	0	NR	505	152	NR	635	645	NR	765	4	NR	895	0	NR
380	0	NR	510	189	NR	640	197	NR	770	4	NR	900	0	NR
385	1	NR	515	222	NR	645	189	NR	775	3	NR	905	0	NR
390	2	NR	520	248	NR	650	163	NR	780	3	NR	910	0	NR
395	3	NR	525	268	NR	655	134	NR	785	2	NR	915	0	NR
400	4	NR	530	283	NR	660	113	NR	790	2	NR	920	0	NR
405	6	NR	535	294	NR	665	94	NR	795	2	NR	925	0	NR
410	9	NR	540	305	NR	670	87	NR	800	2	NR	930	0	NR
415	18	NR	545	314	NR	675	70	NR	805	1	NR	935	0	NR
420	34	NR	550	323	NR	680	60	NR	810	1	NR	940	0	NR
425	62	NR	555	335	NR	685	51	NR	815	1	NR	945	0	NR
430	102	NR	560	346	NR	690	44	NR	820	1	NR	950	0	NR
435	159	NR	565	356	NR	695	38	NR	825	1	NR	955	0	NR
440	241	NR	570	364	NR	700	32	NR	830	1	NR	960	0	NR
445	363	NR	575	371	NR	705	28	NR	835	1	NR	965	0	NR
450	389	NR	580	375	NR	710	24	NR	840	1	NR	970	0	NR
455	245	NR	585	375	NR	715	20	NR	845	0	NR	975	0	NR
460	158	NR	590	373	NR	720	17	NR	850	0	NR	980	0	NR
465	120	NR	595	364	NR	725	15	NR	855	0	NR	985	0	NR
470	79	NR	600	357	NR	730	13	NR	860	0	NR	990	0	NR
475	57	NR	605	349	NR	735	11	NR	865	0	NR	995	0	NR
480	51	NR	610	371	NR	740	9	NR	870	0	NR	1000	0	NR
485	51	NR	615	387	NR	745	8	NR	875	0	NR			

REPORT NUMBER: SP1-2506-472-3

Melanopic Flux vs. Wavelength



Melanopic Lumens: NR

M/P: 2.75

λ (nm)	Power W [^] /nm	Lumens (φ/nm)	λ (nm)	Power W [^] /nm	Lumens (φ/nm)	λ (nm)	Power W [^] /nm	Lumens (φ/nm)	λ (nm)	Power W [^] /nm	Lumens (φ/nm)	λ (nm)	Power W [^] /nm	Lumens (φ/nm)
360	0	NR	490	60	NR	620	327	NR	750	7	NR	880	0	NR
365	0	NR	495	82	NR	625	322	NR	755	6	NR	885	0	NR
370	0	NR	500	114	NR	630	1000	NR	760	5	NR	890	0	NR
375	0	NR	505	152	NR	635	645	NR	765	4	NR	895	0	NR
380	0	NR	510	189	NR	640	197	NR	770	4	NR	900	0	NR
385	1	NR	515	222	NR	645	189	NR	775	3	NR	905	0	NR
390	2	NR	520	248	NR	650	163	NR	780	3	NR	910	0	NR
395	3	NR	525	268	NR	655	134	NR	785	2	NR	915	0	NR
400	4	NR	530	283	NR	660	113	NR	790	2	NR	920	0	NR
405	6	NR	535	294	NR	665	94	NR	795	2	NR	925	0	NR
410	9	NR	540	305	NR	670	87	NR	800	2	NR	930	0	NR
415	18	NR	545	314	NR	675	70	NR	805	1	NR	935	0	NR
420	34	NR	550	323	NR	680	60	NR	810	1	NR	940	0	NR
425	62	NR	555	335	NR	685	51	NR	815	1	NR	945	0	NR
430	102	NR	560	346	NR	690	44	NR	820	1	NR	950	0	NR
435	159	NR	565	356	NR	695	38	NR	825	1	NR	955	0	NR
440	241	NR	570	364	NR	700	32	NR	830	1	NR	960	0	NR
445	363	NR	575	371	NR	705	28	NR	835	1	NR	965	0	NR
450	389	NR	580	375	NR	710	24	NR	840	1	NR	970	0	NR
455	245	NR	585	375	NR	715	20	NR	845	0	NR	975	0	NR
460	158	NR	590	373	NR	720	17	NR	850	0	NR	980	0	NR
465	120	NR	595	364	NR	725	15	NR	855	0	NR	985	0	NR
470	79	NR	600	357	NR	730	13	NR	860	0	NR	990	0	NR
475	57	NR	605	349	NR	735	11	NR	865	0	NR	995	0	NR
480	51	NR	610	371	NR	740	9	NR	870	0	NR	1000	0	NR
485	51	NR	615	387	NR	745	8	NR	875	0	NR			

Summary

$R_f = 80.1$
 $R_g = 101$
 CIE $R_a = 82.1$
 $R_9 = 27.6$



Color Vector Graphics



Individual Sample Fidelity Index ($R_{f,i}$)


CES01 = 86	CES26 = 68	CES51 = 90	CES76 = 59
CES02 = 62	CES27 = 89	CES52 = 90	CES77 = 78
CES03 = 31	CES28 = 84	CES53 = 81	CES78 = 61
CES04 = 70	CES29 = 66	CES54 = 91	CES79 = 86
CES05 = 49	CES30 = 77	CES55 = 90	CES80 = 82
CES06 = 51	CES31 = 69	CES56 = 80	CES81 = 79
CES07 = 42	CES32 = 62	CES57 = 79	CES82 = 92
CES08 = 41	CES33 = 74	CES58 = 81	CES83 = 89
CES09 = 29	CES34 = 72	CES59 = 92	CES84 = 89
CES10 = 75	CES35 = 85	CES60 = 94	CES85 = 82
CES11 = 58	CES36 = 97	CES61 = 90	CES86 = 78
CES12 = 64	CES37 = 79	CES62 = 92	CES87 = 82
CES13 = 43	CES38 = 85	CES63 = 78	CES88 = 86
CES14 = 74	CES39 = 94	CES64 = 79	CES89 = 76
CES15 = 71	CES40 = 89	CES65 = 76	CES90 = 85
CES16 = 47	CES41 = 89	CES66 = 73	CES91 = 83
CES17 = 49	CES42 = 77	CES67 = 70	CES92 = 73
CES18 = 56	CES43 = 74	CES68 = 76	CES93 = 84
CES19 = 72	CES44 = 99	CES69 = 81	CES94 = 65
CES20 = 66	CES45 = 83	CES70 = 68	CES95 = 79
CES21 = 86	CES46 = 82	CES71 = 64	CES96 = 85
CES22 = 78	CES47 = 81	CES72 = 88	CES97 = 85
CES23 = 92	CES48 = 80	CES73 = 60	CES98 = 82
CES24 = 91	CES49 = 80	CES74 = 97	CES99 = 81
CES25 = 72	CES50 = 89	CES75 = 64	



Color Rendition by Hue-Angle Bin



Measure Comparisons



(END OF REPORT)