

Cooper Lighting Solutions Photometric Lab
1121 Highway 74 South
Peachtree City, GA 30269



Scaled data based on original data using
LM-79-2019 Approved Method: Electrical and Photometric Measurements of Solid-
State Lighting Products

Test Report Prepared for
Cooper Lighting Solutions

Brand: METALUX

Report Number: P1432633

Luminaire Tested: EHBR1-24-UNV-N-L835-UPL40

Issue Date: 3/20/2026

Test Information

Test Method: LM-79-2019
Report Number: P1432633
REPORT IS A COMBINATION OF REPORTS P1431722 AND P1431635
Test Lab: INNOVATION CENTER
Issue Date: 3/20/2026
Manufacturer: COOPER LIGHTING SOLUTIONS
Product Line: METALUX
Catalog Number: EHBR1-24-UNV-N-L835-UPL40
Description: Elevate Round Highbay at, 24000 lumens, 3500K 80CRI LEDs with N lens
Light Source: -
Ballast/Driver: -


Summary

Lumens per Lamp: N/A
Luminaire Lumens: 28006.5 lumens
Efficiency: N/A
Efficacy: 176.3 lumens/watt
Spacing Criteria (0/90/45): 0.82 / 0.82 / 0.8
Luminous Opening: Vertical Cylinder (Dia: 1.71' x H: 0.1')
CIE Type: Semi-Direct

Input Watts (W): 158.9
Input Voltage (V): NR
Input Current (Ain): NR
Voltage Rise (V): NR
Power Factor: NR
Total Harmonic Distortion (THDi): NR
Frequency (hertz): 60
Stabilization Time: NR
Operation Time: NR
Ambient Temperature (°C): NR
Test Distance: 24 FT

TEST NUMBER: P1432633
CATALOG NUMBER: EHBR1-24-UNV-N-L835-UPL40

Luminous Intensity Polar Plot





TEST NUMBER: P1432633

CATALOG NUMBER: EHBR1-24-UNV-N-L835-UPL40

COEFFICIENT OF UTILIZATION - ZONAL CAVITY METHOD:

RF	20				20				20				20				20	
RC	80				70				50				30				10	0
RW	70	50	30	10	70	50	30	10	50	30	10	50	30	10	50	30	10	0
RCR																		
0	116	116	116	116	112	112	112	112	104	104	104	97	97	97	90	90	90	87
1	109	106	103	100	105	102	99	97	96	94	92	90	88	87	84	83	82	79
2	102	96	92	88	99	94	89	86	88	85	82	83	81	78	79	77	75	72
3	96	89	83	78	93	86	81	77	82	77	74	77	74	71	74	71	68	66
4	91	82	76	71	88	80	74	70	76	71	67	72	68	65	69	66	63	61
5	85	76	69	65	83	74	68	64	71	66	62	68	64	60	65	61	58	57
6	81	71	64	59	78	69	63	59	66	61	57	64	59	56	61	57	54	53
7	76	66	60	55	74	65	59	54	62	57	53	60	55	52	58	54	51	49
8	72	62	56	51	70	61	55	51	59	53	50	57	52	49	55	51	48	46
9	69	58	52	48	67	57	52	47	56	50	47	54	49	46	52	48	45	43
10	65	55	49	45	64	54	48	45	53	47	44	51	46	43	49	45	42	41

AVERAGE LUMINANCE (cd/sqm):

	0°	45°	90°
0°	133439	133439	133439
5°	130848	130848	130848
10°	124191	124191	124191
15°	112997	112997	112997
20°	96926	96926	96926
25°	76248	76248	76248
30°	52326	52326	52326
35°	31083	31083	31083
40°	18391	18391	18391
45°	13202	13202	13202
50°	10852	10852	10852
55°	9863	9863	9863
60°	9441	9441	9441
65°	9005	9005	9005
70°	8374	8374	8374
75°	7571	7571	7571
80°	6284	6284	6284
85°	3977	3977	3977

MAXIMUM LUMINANCE 45°-90°:

Horizontal Angle: 0°
 Vertical Angle: 45°
 Luminance: 13202 cd/sqm



TEST NUMBER: P1432633

CATALOG NUMBER: EHBR1-24-UNV-N-L835-UPL40

ZONAL LUMENS:

Zone	Lumens	% Fixture
0°-10°	2617.5	9.3
10°-20°	6570.3	23.5
20°-30°	6869.9	24.5
30°-40°	3722.3	13.3
40°-50°	1712.5	6.1
50°-60°	1206.8	4.3
60°-70°	928.7	3.3
70°-80°	563.0	2.0
80°-90°	165.2	0.6
90°-100°	104.2	0.4
100°-110°	652.2	2.3
110°-120°	1166.3	4.2
120°-130°	684.3	2.4
130°-140°	419.8	1.5
140°-150°	291.2	1.0
150°-160°	189.2	0.7
160°-170°	107.8	0.4
170°-180°	35.6	0.1
0°-30°	16057.6	57.3
0°-40°	19779.9	70.6
0°-60°	22699.2	81.0
0°-90°	24356.1	87.0
90°-120°	1922.6	6.9
90°-150°	3317.8	11.8
90°-180°	3650.0	13.0
0°-180°	28006.5	100.0

CANDELA DISTRIBUTION:

	0°	22.5°	45°	67.5°	90°	Flux
0°	28415	28415	28415	28415	28415	
5°	27938	27938	27938	27938	27938	2617
15°	23706	23706	23706	23706	23706	6570
25°	15227	15227	15227	15227	15227	6870
35°	5705	5705	5705	5705	5705	3722
45°	2136	2136	2136	2136	2136	1712
55°	1333	1333	1333	1333	1333	1207
65°	940	940	940	940	940	929
75°	533	533	533	533	533	563
85°	137	137	137	137	137	152
90°	28	45	76	49	28	20
95°	46	77	169	84	52	44
105°	228	449	1147	495	301	305
115°	1049	1103	1356	1300	1291	966
125°	756	706	725	736	825	690
135°	552	535	554	520	518	432
145°	453	447	474	468	466	287
155°	397	393	412	412	412	185
165°	372	372	382	382	380	106
175°	368	368	374	374	374	35
180°	372	372	372	372	372	



TEST NUMBER: P1432633

CATALOG NUMBER: EHBR1-24-UNV-N-L835-UPL40

CANDELA DISTRIBUTION (FULL):

	0°	22.5°	45°	67.5°	90°
0°	28414.8	28414.8	28414.8	28414.8	28414.8
2.5°	28314.1	28314.1	28314.1	28314.1	28314.1
5°	27938.2	27938.2	27938.2	27938.2	27938.2
7.5°	27296.5	27296.5	27296.5	27296.5	27296.5
10°	26386.0	26386.0	26386.0	26386.0	26386.0
12.5°	25209.4	25209.4	25209.4	25209.4	25209.4
15°	23706.2	23706.2	23706.2	23706.2	23706.2
17.5°	21962.2	21962.2	21962.2	21962.2	21962.2
20°	19921.2	19921.2	19921.2	19921.2	19921.2
22.5°	17648.8	17648.8	17648.8	17648.8	17648.8
25°	15226.7	15226.7	15226.7	15226.7	15226.7
27.5°	12658.9	12658.9	12658.9	12658.9	12658.9
30°	10064.8	10064.8	10064.8	10064.8	10064.8
32.5°	7724.4	7724.4	7724.4	7724.4	7724.4
35°	5704.9	5704.9	5704.9	5704.9	5704.9
37.5°	4188.8	4188.8	4188.8	4188.8	4188.8
40°	3187.7	3187.7	3187.7	3187.7	3187.7
42.5°	2556.1	2556.1	2556.1	2556.1	2556.1
45°	2136.1	2136.1	2136.1	2136.1	2136.1
47.5°	1833.4	1833.4	1833.4	1833.4	1833.4
50°	1617.3	1617.3	1617.3	1617.3	1617.3
52.5°	1459.5	1459.5	1459.5	1459.5	1459.5
55°	1332.9	1332.9	1332.9	1332.9	1332.9
57.5°	1230.1	1230.1	1230.1	1230.1	1230.1
60°	1134.9	1134.9	1134.9	1134.9	1134.9
62.5°	1039.9	1039.9	1039.9	1039.9	1039.9
65°	939.9	939.9	939.9	939.9	939.9
67.5°	838.0	838.0	838.0	838.0	838.0
70°	734.8	734.8	734.8	734.8	734.8
72.5°	634.5	634.5	634.5	634.5	634.5
75°	533.3	533.3	533.3	533.3	533.3
77.5°	434.1	434.1	434.1	434.1	434.1
80°	330.6	330.6	330.6	330.6	330.6
82.5°	231.5	231.5	231.5	231.5	231.5
85°	136.7	136.7	136.7	136.7	136.7
87.5°	49.0	49.0	49.0	49.0	49.0
90°	27.9	44.7	76.0	48.9	27.9
92.5°	39.7	66.9	121.2	62.6	35.5
95°	46.0	77.3	169.2	83.6	52.3
97.5°	58.5	85.6	194.3	102.4	81.5
100°	77.3	100.3	303.0	125.4	108.7
102.5°	131.7	213.1	643.6	236.1	165.0
105°	227.8	449.3	1147.2	495.2	300.9
107.5°	395.0	804.5	1512.8	877.6	570.5
110°	737.7	1067.7	1586.0	1205.6	913.2



TEST NUMBER: P1432633

CATALOG NUMBER: EHBR1-24-UNV-N-L835-UPL40

CANDELA DISTRIBUTION (continued):

	0°	22.5°	45°	67.5°	90°
112.5°	996.8	1147.2	1519.1	1331.0	1189.0
115°	1048.9	1103.3	1356.1	1299.7	1291.4
117.5°	1013.4	1007.1	1151.3	1168.1	1247.4
120°	938.2	896.4	961.2	1019.7	1126.3
122.5°	844.2	794.0	823.3	867.2	973.8
125°	756.4	706.2	725.1	735.5	825.4
127.5°	679.1	645.6	656.1	643.6	700.0
130°	626.9	597.6	612.3	583.0	610.1
132.5°	583.0	564.2	580.9	545.4	553.7
135°	551.7	534.9	553.7	520.3	518.2
137.5°	524.5	509.9	528.7	503.6	497.4
140°	499.4	486.9	507.7	488.9	484.8
142.5°	472.2	463.9	488.9	476.4	472.2
145°	453.4	447.1	474.3	468.1	465.9
147.5°	436.8	432.6	457.6	455.6	455.6
150°	422.1	417.9	443.0	440.9	443.0
152.5°	407.5	403.3	426.3	424.2	426.3
155°	397.0	392.8	411.6	411.6	411.6
157.5°	388.7	386.5	401.2	401.2	401.2
160°	382.4	380.3	392.8	392.8	390.8
162.5°	376.2	374.0	388.7	386.5	386.5
165°	372.0	372.0	382.4	382.4	380.3
167.5°	372.0	369.8	380.3	380.3	378.2
170°	369.8	369.8	378.2	376.2	374.0
172.5°	369.8	369.8	378.2	376.2	374.0
175°	367.8	367.8	374.0	374.0	374.0
177.5°	369.8	369.8	374.0	374.0	372.0
180°	372.0	372.0	372.0	372.0	372.0



TEST NUMBER: P1432633
 CATALOG NUMBER: EHBR1-24-UNV-N-L835-UPL40

CIE UGR TABLE:

Reflectances:											
Ceiling		0.7	0.7	0.5	0.5	0.3	0.7	0.7	0.5	0.5	0.3
Wall		0.5	0.3	0.5	0.3	0.3	0.5	0.3	0.5	0.3	0.3
Reference plane		0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2
Room dimensions		Viewed crosswise					Viewed endwise				
X=2H	Y=2H	15.38	16.37	15.96	16.93	17.56	15.38	16.37	15.96	16.93	17.56
	3H	17.15	18.03	17.75	18.61	19.29	17.15	18.03	17.75	18.61	19.29
	4H	17.81	18.63	18.43	19.22	19.91	17.81	18.63	18.43	19.22	19.91
	6H	18.26	19.02	18.90	19.63	20.33	18.26	19.02	18.90	19.63	20.33
	8H	18.39	19.10	19.03	19.73	20.43	18.39	19.10	19.03	19.73	20.43
	12H	18.44	19.12	19.08	19.74	20.46	18.44	19.12	19.08	19.74	20.46
4H	2H	15.91	16.74	16.53	17.33	18.02	15.91	16.74	16.53	17.33	18.02
	3H	17.88	18.56	18.51	19.20	19.90	17.88	18.56	18.51	19.20	19.90
	4H	18.65	19.27	19.30	19.91	20.65	18.65	19.27	19.30	19.91	20.65
	6H	19.22	19.75	19.89	20.41	21.17	19.22	19.75	19.89	20.41	21.17
	8H	19.38	19.87	20.05	20.53	21.29	19.38	19.87	20.05	20.53	21.29
	12H	19.46	19.89	20.15	20.58	21.34	19.46	19.89	20.15	20.58	21.34
8H	4H	18.88	19.37	19.55	20.03	20.79	18.88	19.37	19.55	20.03	20.79
	6H	19.56	19.96	20.26	20.67	21.43	19.56	19.96	20.26	20.67	21.43
	8H	19.78	20.14	20.50	20.85	21.63	19.78	20.14	20.50	20.85	21.63
	12H	19.92	20.23	20.64	20.93	21.77	19.92	20.23	20.64	20.93	21.77
12H	4H	18.87	19.31	19.56	20.00	20.76	18.87	19.31	19.56	20.00	20.76
	6H	19.59	19.94	20.31	20.66	21.43	19.59	19.94	20.31	20.66	21.43
	8H	19.85	20.15	20.56	20.85	21.70	19.85	20.15	20.56	20.85	21.70

LM-79-2019: Approved Method: Electrical and Photometric Measurements of Solid-State Lighting Products

Report Prepared for

Cooper Lighting Solutions

Metalux

Report Number: SP1-2506-472-3

Test Date: 07/31/2025

Luminaire Tested: EHBR-60-L835-N

Data in this report applies to families of products including EHBR-60-L835-N

Test Information

Test Method: LM-79-2019
 Report Number: SP1-2506-472-3
 Test Lab: COOPER LIGHTING SOLUTIONS
 Photometer: SP1 - 76IN SPHERE
 Measurement Geometry: 4π
 Issue Date: 08/05/2025
 Manufacturer: COOPER LIGHTING SOLUTIONS
 Product Line: Metalux
 Catalog Number: **EHBR-60-L835-N**
 Description: Elevate Round Highbay at, 60000 lumens, 3500K 80CRI LEDs with N lens

Spectral Parameters

CCT (K): 3468
 CIE u': 0.2375
 CIE v': 0.5091
 Duv: -0.0021
 CIE x: 0.4049
 CIE y: 0.3856
 CIE z: 0.2095
 Peak Wavelength (nm): 630
 Dominant Wavelength (nm): 581
 Purity: 37.24544
 Rf: 80.1
 Rg: 101

CRI (Ra):	82.1		
R1:	82.9	R9:	27.6
R2:	85.6	R10:	63.8
R3:	85.9	R11:	81.2
R4:	82.8	R12:	57.2
R5:	81.0	R13:	82.6
R6:	79.7	R14:	91.0
R7:	86.5	R15:	79.4
R8:	72.1		



Test Conditions

Stabilization Time: 39M
 Operation Time: 1H 39M
 Sphere Temperature (°C): 25.0

REPORT NUMBER: SP1-2506-472-3

Measurement and Test Equipment			
Instrument	Identification Number	Calibration Date	Calibration Due Date
Photometer	76INCH SPHERE IN0058	6/16/2025	12/16/2025
Power Meter	XITRON INXT2011004	1/21/2025	1/21/2026
AC Power Source	CHROMA 61603 IN0063	10/22/2024	10/22/2025
DC Power Source	AGILENT E3634A IN0208	10/22/2024	10/22/2025
Sphere Thermometer	ONSET IN0085	10/22/2024	10/22/2025
Room Thermometer	ONSET IN0046	10/22/2024	10/22/2025

REPORT NUMBER: SP1-2506-472-3

CIE 1931 Chromaticity Diagram



CIE 1931 Chromaticity Diagram with 2017 ANSI 7-Step and 4-Step Quadrangles



Point lies inside the ANSI 3500K 4-step quadrangle

REPORT NUMBER: SP1-2506-472-3

Photopic Flux vs. Wavelength



Photopic Lumens: NR

λ (nm)	Power W [^] /nm	Lumens (ϕ /nm)	λ (nm)	Power W [^] /nm	Lumens (ϕ /nm)	λ (nm)	Power W [^] /nm	Lumens (ϕ /nm)	λ (nm)	Power W [^] /nm	Lumens (ϕ /nm)	λ (nm)	Power W [^] /nm	Lumens (ϕ /nm)
360	0	NR	490	60	NR	620	327	NR	750	7	NR	880	0	NR
365	0	NR	495	82	NR	625	322	NR	755	6	NR	885	0	NR
370	0	NR	500	114	NR	630	1000	NR	760	5	NR	890	0	NR
375	0	NR	505	152	NR	635	645	NR	765	4	NR	895	0	NR
380	0	NR	510	189	NR	640	197	NR	770	4	NR	900	0	NR
385	1	NR	515	222	NR	645	189	NR	775	3	NR	905	0	NR
390	2	NR	520	248	NR	650	163	NR	780	3	NR	910	0	NR
395	3	NR	525	268	NR	655	134	NR	785	2	NR	915	0	NR
400	4	NR	530	283	NR	660	113	NR	790	2	NR	920	0	NR
405	6	NR	535	294	NR	665	94	NR	795	2	NR	925	0	NR
410	9	NR	540	305	NR	670	87	NR	800	2	NR	930	0	NR
415	18	NR	545	314	NR	675	70	NR	805	1	NR	935	0	NR
420	34	NR	550	323	NR	680	60	NR	810	1	NR	940	0	NR
425	62	NR	555	335	NR	685	51	NR	815	1	NR	945	0	NR
430	102	NR	560	346	NR	690	44	NR	820	1	NR	950	0	NR
435	159	NR	565	356	NR	695	38	NR	825	1	NR	955	0	NR
440	241	NR	570	364	NR	700	32	NR	830	1	NR	960	0	NR
445	363	NR	575	371	NR	705	28	NR	835	1	NR	965	0	NR
450	389	NR	580	375	NR	710	24	NR	840	1	NR	970	0	NR
455	245	NR	585	375	NR	715	20	NR	845	0	NR	975	0	NR
460	158	NR	590	373	NR	720	17	NR	850	0	NR	980	0	NR
465	120	NR	595	364	NR	725	15	NR	855	0	NR	985	0	NR
470	79	NR	600	357	NR	730	13	NR	860	0	NR	990	0	NR
475	57	NR	605	349	NR	735	11	NR	865	0	NR	995	0	NR
480	51	NR	610	371	NR	740	9	NR	870	0	NR	1000	0	NR
485	51	NR	615	387	NR	745	8	NR	875	0	NR			

REPORT NUMBER: SP1-2506-472-3

Scotopic Flux vs. Wavelength



Scotopic Lumens: NR

S/P: 1.43

λ (nm)	Power W [^] /nm	Lumens (φ/nm)	λ (nm)	Power W [^] /nm	Lumens (φ/nm)	λ (nm)	Power W [^] /nm	Lumens (φ/nm)	λ (nm)	Power W [^] /nm	Lumens (φ/nm)	λ (nm)	Power W [^] /nm	Lumens (φ/nm)
360	0	NR	490	60	NR	620	327	NR	750	7	NR	880	0	NR
365	0	NR	495	82	NR	625	322	NR	755	6	NR	885	0	NR
370	0	NR	500	114	NR	630	1000	NR	760	5	NR	890	0	NR
375	0	NR	505	152	NR	635	645	NR	765	4	NR	895	0	NR
380	0	NR	510	189	NR	640	197	NR	770	4	NR	900	0	NR
385	1	NR	515	222	NR	645	189	NR	775	3	NR	905	0	NR
390	2	NR	520	248	NR	650	163	NR	780	3	NR	910	0	NR
395	3	NR	525	268	NR	655	134	NR	785	2	NR	915	0	NR
400	4	NR	530	283	NR	660	113	NR	790	2	NR	920	0	NR
405	6	NR	535	294	NR	665	94	NR	795	2	NR	925	0	NR
410	9	NR	540	305	NR	670	87	NR	800	2	NR	930	0	NR
415	18	NR	545	314	NR	675	70	NR	805	1	NR	935	0	NR
420	34	NR	550	323	NR	680	60	NR	810	1	NR	940	0	NR
425	62	NR	555	335	NR	685	51	NR	815	1	NR	945	0	NR
430	102	NR	560	346	NR	690	44	NR	820	1	NR	950	0	NR
435	159	NR	565	356	NR	695	38	NR	825	1	NR	955	0	NR
440	241	NR	570	364	NR	700	32	NR	830	1	NR	960	0	NR
445	363	NR	575	371	NR	705	28	NR	835	1	NR	965	0	NR
450	389	NR	580	375	NR	710	24	NR	840	1	NR	970	0	NR
455	245	NR	585	375	NR	715	20	NR	845	0	NR	975	0	NR
460	158	NR	590	373	NR	720	17	NR	850	0	NR	980	0	NR
465	120	NR	595	364	NR	725	15	NR	855	0	NR	985	0	NR
470	79	NR	600	357	NR	730	13	NR	860	0	NR	990	0	NR
475	57	NR	605	349	NR	735	11	NR	865	0	NR	995	0	NR
480	51	NR	610	371	NR	740	9	NR	870	0	NR	1000	0	NR
485	51	NR	615	387	NR	745	8	NR	875	0	NR			

REPORT NUMBER: SP1-2506-472-3

Melanopic Flux vs. Wavelength



Melanopic Lumens: NR

M/P: 2.75

λ (nm)	Power W [^] /nm	Lumens (φ/nm)	λ (nm)	Power W [^] /nm	Lumens (φ/nm)	λ (nm)	Power W [^] /nm	Lumens (φ/nm)	λ (nm)	Power W [^] /nm	Lumens (φ/nm)	λ (nm)	Power W [^] /nm	Lumens (φ/nm)
360	0	NR	490	60	NR	620	327	NR	750	7	NR	880	0	NR
365	0	NR	495	82	NR	625	322	NR	755	6	NR	885	0	NR
370	0	NR	500	114	NR	630	1000	NR	760	5	NR	890	0	NR
375	0	NR	505	152	NR	635	645	NR	765	4	NR	895	0	NR
380	0	NR	510	189	NR	640	197	NR	770	4	NR	900	0	NR
385	1	NR	515	222	NR	645	189	NR	775	3	NR	905	0	NR
390	2	NR	520	248	NR	650	163	NR	780	3	NR	910	0	NR
395	3	NR	525	268	NR	655	134	NR	785	2	NR	915	0	NR
400	4	NR	530	283	NR	660	113	NR	790	2	NR	920	0	NR
405	6	NR	535	294	NR	665	94	NR	795	2	NR	925	0	NR
410	9	NR	540	305	NR	670	87	NR	800	2	NR	930	0	NR
415	18	NR	545	314	NR	675	70	NR	805	1	NR	935	0	NR
420	34	NR	550	323	NR	680	60	NR	810	1	NR	940	0	NR
425	62	NR	555	335	NR	685	51	NR	815	1	NR	945	0	NR
430	102	NR	560	346	NR	690	44	NR	820	1	NR	950	0	NR
435	159	NR	565	356	NR	695	38	NR	825	1	NR	955	0	NR
440	241	NR	570	364	NR	700	32	NR	830	1	NR	960	0	NR
445	363	NR	575	371	NR	705	28	NR	835	1	NR	965	0	NR
450	389	NR	580	375	NR	710	24	NR	840	1	NR	970	0	NR
455	245	NR	585	375	NR	715	20	NR	845	0	NR	975	0	NR
460	158	NR	590	373	NR	720	17	NR	850	0	NR	980	0	NR
465	120	NR	595	364	NR	725	15	NR	855	0	NR	985	0	NR
470	79	NR	600	357	NR	730	13	NR	860	0	NR	990	0	NR
475	57	NR	605	349	NR	735	11	NR	865	0	NR	995	0	NR
480	51	NR	610	371	NR	740	9	NR	870	0	NR	1000	0	NR
485	51	NR	615	387	NR	745	8	NR	875	0	NR			

Summary

$R_f = 80.1$
 $R_g = 101$
 $CIE R_a = 82.1$
 $R_9 = 27.6$



Color Vector Graphics



Individual Sample Fidelity Index ($R_{f,i}$)

CES01 = 86	CES26 = 68	CES51 = 90	CES76 = 59
CES02 = 62	CES27 = 89	CES52 = 90	CES77 = 78
CES03 = 31	CES28 = 84	CES53 = 81	CES78 = 61
CES04 = 70	CES29 = 66	CES54 = 91	CES79 = 86
CES05 = 49	CES30 = 77	CES55 = 90	CES80 = 82
CES06 = 51	CES31 = 69	CES56 = 80	CES81 = 79
CES07 = 42	CES32 = 62	CES57 = 79	CES82 = 92
CES08 = 41	CES33 = 74	CES58 = 81	CES83 = 89
CES09 = 29	CES34 = 72	CES59 = 92	CES84 = 89
CES10 = 75	CES35 = 85	CES60 = 94	CES85 = 82
CES11 = 58	CES36 = 97	CES61 = 90	CES86 = 78
CES12 = 64	CES37 = 79	CES62 = 92	CES87 = 82
CES13 = 43	CES38 = 85	CES63 = 78	CES88 = 86
CES14 = 74	CES39 = 94	CES64 = 79	CES89 = 76
CES15 = 71	CES40 = 89	CES65 = 76	CES90 = 85
CES16 = 47	CES41 = 89	CES66 = 73	CES91 = 83
CES17 = 49	CES42 = 77	CES67 = 70	CES92 = 73
CES18 = 56	CES43 = 74	CES68 = 76	CES93 = 84
CES19 = 72	CES44 = 99	CES69 = 81	CES94 = 65
CES20 = 66	CES45 = 83	CES70 = 68	CES95 = 79
CES21 = 86	CES46 = 82	CES71 = 64	CES96 = 85
CES22 = 78	CES47 = 81	CES72 = 88	CES97 = 85
CES23 = 92	CES48 = 80	CES73 = 60	CES98 = 82
CES24 = 91	CES49 = 80	CES74 = 97	CES99 = 81
CES25 = 72	CES50 = 89	CES75 = 64	



Color Rendition by Hue-Angle Bin



Measure Comparisons



(END OF REPORT)