

Cooper Lighting Solutions Photometric Lab
1121 Highway 74 South
Peachtree City, GA 30269



Scaled data based on original data using
LM-79-2019 Approved Method: Electrical and Photometric Measurements of Solid-
State Lighting Products

Test Report Prepared for
Cooper Lighting Solutions

Brand: METALUX

Report Number: P1436381

Luminaire Tested: EHBR1-42-UNV-M-L850-UPL18

Issue Date: 3/25/2026

Test Information

Test Method: LM-79-2019
Report Number: P1436381
REPORT IS A COMBINATION OF REPORTS P1436093 AND P1431635
Test Lab: INNOVATION CENTER
Issue Date: 3/25/2026
Manufacturer: COOPER LIGHTING SOLUTIONS
Product Line: METALUX
Catalog Number: EHBR1-42-UNV-M-L850-UPL18
Description: Elevate Round Highbay at, 42000 lumens, 5000K 80CRI LEDs with M lens
Light Source: -
Ballast/Driver: -


Summary

Lumens per Lamp: N/A
Luminaire Lumens: 42714.3 lumens
Efficiency: N/A
Efficacy: 180.8 lumens/watt
Spacing Criteria (0/90/45): 1.21 / 1.21 / 1.15
Luminous Opening: Vertical Cylinder (Dia: 1.71' x H: 0.1')
CIE Type: Direct

Input Watts (W): 236.3
Input Voltage (V): NR
Input Current (Ain): NR
Voltage Rise (V): NR
Power Factor: NR
Total Harmonic Distortion (THDi): NR
Frequency (hertz): 60
Stabilization Time: NR
Operation Time: NR
Ambient Temperature (°C): NR
Test Distance: 24 FT

TEST NUMBER: P1436381
CATALOG NUMBER: EHBR1-42-UNV-M-L850-UPL18

Luminous Intensity Polar Plot



— 0°-180° - - 45°-225° - - - 90°-270°



TEST NUMBER: P1436381
 CATALOG NUMBER: EHBR1-42-UNV-M-L850-UPL18

COEFFICIENT OF UTILIZATION - ZONAL CAVITY METHOD:

RF	20				20				20				20				20				
RC	80				70				50				30				10			0	
RW	70	50	30	10	70	50	30	10	50	30	10	50	30	10	50	30	10	50	30	10	0
RCR																					
0	118	118	118	118	115	115	115	115	109	109	109	103	103	103	98	98	98	98	98	98	96
1	111	107	104	101	108	104	101	99	100	97	95	95	93	91	91	89	88	88	88	88	86
2	103	97	92	87	100	95	90	86	91	87	83	87	84	81	83	81	79	79	79	79	76
3	96	88	81	76	94	86	80	76	83	78	74	80	75	72	77	73	70	70	70	70	68
4	90	80	73	68	87	79	72	67	76	70	66	73	68	65	71	67	63	63	63	63	61
5	84	73	66	61	82	72	65	60	70	64	59	67	62	58	65	61	57	57	57	57	55
6	78	67	60	55	76	66	59	54	64	58	54	62	57	53	60	56	52	52	52	52	50
7	73	62	55	50	72	61	54	49	59	53	49	58	52	48	56	51	48	48	48	48	46
8	69	57	50	45	67	57	50	45	55	49	45	54	48	44	52	47	44	44	44	44	42
9	65	53	46	42	63	53	46	41	51	45	41	50	45	41	49	44	40	40	40	40	39
10	61	50	43	38	60	49	43	38	48	42	38	47	41	37	46	41	37	37	37	37	36

AVERAGE LUMINANCE (cd/sqm):

	0°	45°	90°
0°	113625	113625	113625
5°	113430	113430	113430
10°	113963	113963	113963
15°	114617	114617	114617
20°	114271	114271	114271
25°	111603	111603	111603
30°	104356	104356	104356
35°	90885	90885	90885
40°	69652	69652	69652
45°	45502	45502	45502
50°	28685	28685	28685
55°	21383	21383	21383
60°	18003	18003	18003
65°	16370	16370	16370
70°	14913	14913	14913
75°	12766	12766	12766
80°	9831	9831	9831
85°	5156	5156	5156

MAXIMUM LUMINANCE 45°-90°:

Horizontal Angle: 0°
 Vertical Angle: 45°
 Luminance: 45502 cd/sqm



TEST NUMBER: P1436381
 CATALOG NUMBER: EHBR1-42-UNV-M-L850-UPL18

ZONAL LUMENS:

Zone	Lumens	% Fixture
0°-10°	2310.9	5.4
10°-20°	6786.4	15.9
20°-30°	10182.8	23.8
30°-40°	10245.0	24.0
40°-50°	5864.5	13.7
50°-60°	2682.3	6.3
60°-70°	1701.9	4.0
70°-80°	954.7	2.2
80°-90°	227.1	0.5
90°-100°	50.1	0.1
100°-110°	314.2	0.7
110°-120°	561.9	1.3
120°-130°	329.7	0.8
130°-140°	202.3	0.5
140°-150°	140.3	0.3
150°-160°	91.1	0.2
160°-170°	51.9	0.1
170°-180°	17.2	0.0
0°-30°	19280.2	45.1
0°-40°	29525.1	69.1
0°-60°	38071.9	89.1
0°-90°	40955.5	95.9
90°-120°	926.2	2.2
90°-150°	1598.5	3.7
90°-180°	1759.0	4.1
0°-180°	42714.3	100.0

CANDELA DISTRIBUTION:

	0°	22.5°	45°	67.5°	90°	Flux
0°	24196	24196	24196	24196	24196	
5°	24219	24219	24219	24219	24219	2311
15°	24046	24046	24046	24046	24046	6786
25°	22287	22287	22287	22287	22287	10183
35°	16681	16681	16681	16681	16681	10245
45°	7362	7362	7362	7362	7362	5864
55°	2890	2890	2890	2890	2890	2682
65°	1709	1709	1709	1709	1709	1702
75°	899	899	899	899	899	955
85°	177	177	177	177	177	217
90°	13	21	36	23	13	13
95°	22	37	82	40	25	21
105°	110	216	553	239	145	147
115°	505	532	653	626	622	466
125°	364	340	349	354	398	332
135°	266	258	267	251	250	208
145°	218	215	229	226	224	138
155°	191	189	198	198	198	89
165°	179	179	184	184	183	51
175°	177	177	180	180	180	17
180°	179	179	179	179	179	



TEST NUMBER: P1436381

CATALOG NUMBER: EHBR1-42-UNV-M-L850-UPL18

CANDELA DISTRIBUTION (FULL):

	0°	22.5°	45°	67.5°	90°
0°	24195.6	24195.6	24195.6	24195.6	24195.6
2.5°	24207.4	24207.4	24207.4	24207.4	24207.4
5°	24219.2	24219.2	24219.2	24219.2	24219.2
7.5°	24202.6	24202.6	24202.6	24202.6	24202.6
10°	24213.0	24213.0	24213.0	24213.0	24213.0
12.5°	24171.5	24171.5	24171.5	24171.5	24171.5
15°	24046.1	24046.1	24046.1	24046.1	24046.1
17.5°	23839.1	23839.1	23839.1	23839.1	23839.1
20°	23486.0	23486.0	23486.0	23486.0	23486.0
22.5°	23000.8	23000.8	23000.8	23000.8	23000.8
25°	22287.0	22287.0	22287.0	22287.0	22287.0
27.5°	21326.7	21326.7	21326.7	21326.7	21326.7
30°	20072.9	20072.9	20072.9	20072.9	20072.9
32.5°	18588.6	18588.6	18588.6	18588.6	18588.6
35°	16680.6	16680.6	16680.6	16680.6	16680.6
37.5°	14519.2	14519.2	14519.2	14519.2	14519.2
40°	12072.5	12072.5	12072.5	12072.5	12072.5
42.5°	9647.4	9647.4	9647.4	9647.4	9647.4
45°	7362.1	7362.1	7362.1	7362.1	7362.1
47.5°	5541.9	5541.9	5541.9	5541.9	5541.9
50°	4275.1	4275.1	4275.1	4275.1	4275.1
52.5°	3454.0	3454.0	3454.0	3454.0	3454.0
55°	2889.7	2889.7	2889.7	2889.7	2889.7
57.5°	2474.4	2474.4	2474.4	2474.4	2474.4
60°	2164.2	2164.2	2164.2	2164.2	2164.2
62.5°	1924.7	1924.7	1924.7	1924.7	1924.7
65°	1708.7	1708.7	1708.7	1708.7	1708.7
67.5°	1510.0	1510.0	1510.0	1510.0	1510.0
70°	1308.5	1308.5	1308.5	1308.5	1308.5
72.5°	1105.7	1105.7	1105.7	1105.7	1105.7
75°	899.3	899.3	899.3	899.3	899.3
77.5°	703.4	703.4	703.4	703.4	703.4
80°	517.2	517.2	517.2	517.2	517.2
82.5°	337.1	337.1	337.1	337.1	337.1
85°	177.2	177.2	177.2	177.2	177.2
87.5°	50.6	50.6	50.6	50.6	50.6
90°	13.1	21.1	36.2	23.2	13.1
92.5°	19.2	32.2	58.3	30.2	17.1
95°	22.1	37.2	81.5	40.3	25.1
97.5°	28.2	41.3	93.6	49.3	39.3
100°	37.2	48.3	146.0	60.4	52.4
102.5°	63.5	102.6	310.1	113.7	79.6
105°	109.7	216.5	552.7	238.6	145.0
107.5°	190.3	387.6	728.9	422.9	274.8
110°	355.4	514.4	764.1	580.9	440.0



TEST NUMBER: P1436381

CATALOG NUMBER: EHBR1-42-UNV-M-L850-UPL18

CANDELA DISTRIBUTION (continued):

	0°	22.5°	45°	67.5°	90°
112.5°	480.2	552.7	731.9	641.3	572.9
115°	505.4	531.6	653.4	626.2	622.2
117.5°	488.3	485.2	554.7	562.7	601.1
120°	452.0	431.9	463.1	491.3	542.6
122.5°	406.8	382.6	396.6	417.8	469.1
125°	364.4	340.3	349.3	354.4	397.6
127.5°	327.2	311.1	316.1	310.1	337.2
130°	302.1	287.9	295.0	280.9	294.0
132.5°	280.9	271.8	279.9	262.8	266.8
135°	265.8	257.8	266.8	250.7	249.7
137.5°	252.7	245.7	254.7	242.6	239.6
140°	240.7	234.6	244.7	235.6	233.6
142.5°	227.5	223.5	235.6	229.6	227.5
145°	218.5	215.4	228.6	225.5	224.5
147.5°	210.4	208.4	220.5	219.4	219.4
150°	203.3	201.4	213.4	212.5	213.4
152.5°	196.4	194.3	205.4	204.4	205.4
155°	191.2	189.3	198.3	198.3	198.3
157.5°	187.2	186.2	193.3	193.3	193.3
160°	184.3	183.2	189.3	189.3	188.3
162.5°	181.2	180.2	187.2	186.2	186.2
165°	179.2	179.2	184.3	184.3	183.2
167.5°	179.2	178.2	183.2	183.2	182.2
170°	178.2	178.2	182.2	181.2	180.2
172.5°	178.2	178.2	182.2	181.2	180.2
175°	177.2	177.2	180.2	180.2	180.2
177.5°	178.2	178.2	180.2	180.2	179.2
180°	179.2	179.2	179.2	179.2	179.2



TEST NUMBER: P1436381
 CATALOG NUMBER: EHBR1-42-UNV-M-L850-UPL18

CIE UGR TABLE:

Reflectances:											
Ceiling		0.7	0.7	0.5	0.5	0.3	0.7	0.7	0.5	0.5	0.3
Wall		0.5	0.3	0.5	0.3	0.3	0.5	0.3	0.5	0.3	0.3
Reference plane		0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2
Room dimensions		Viewed crosswise					Viewed endwise				
X=2H	Y=2H	18.99	20.19	19.43	20.60	21.02	18.99	20.19	19.43	20.60	21.02
	3H	20.48	21.55	20.93	21.96	22.43	20.48	21.55	20.93	21.96	22.43
	4H	21.00	22.00	21.48	22.44	22.92	21.00	22.00	21.48	22.44	22.92
	6H	21.33	22.24	21.82	22.70	23.19	21.33	22.24	21.82	22.70	23.19
	8H	21.40	22.27	21.90	22.74	23.24	21.40	22.27	21.90	22.74	23.24
	12H	21.41	22.24	21.92	22.71	23.24	21.41	22.24	21.92	22.71	23.24
4H	2H	19.43	20.43	19.91	20.87	21.35	19.43	20.43	19.91	20.87	21.35
	3H	21.13	21.95	21.62	22.44	22.94	21.13	21.95	21.62	22.44	22.94
	4H	21.76	22.50	22.27	22.99	23.54	21.76	22.50	22.27	22.99	23.54
	6H	22.19	22.82	22.72	23.34	23.91	22.19	22.82	22.72	23.34	23.91
	8H	22.28	22.87	22.82	23.40	23.96	22.28	22.87	22.82	23.40	23.96
	12H	22.31	22.83	22.87	23.39	23.96	22.31	22.83	22.87	23.39	23.96
8H	4H	21.94	22.53	22.48	23.05	23.62	21.94	22.53	22.48	23.05	23.62
	6H	22.45	22.93	23.02	23.50	24.08	22.45	22.93	23.02	23.50	24.08
	8H	22.59	23.02	23.18	23.61	24.19	22.59	23.02	23.18	23.61	24.19
	12H	22.66	23.04	23.24	23.60	24.27	22.66	23.04	23.24	23.60	24.27
12H	4H	21.93	22.45	22.49	23.01	23.58	21.93	22.45	22.49	23.01	23.58
	6H	22.45	22.88	23.04	23.47	24.06	22.45	22.88	23.04	23.47	24.06
	8H	22.63	23.00	23.21	23.57	24.24	22.63	23.00	23.21	23.57	24.24

Cooper Lighting Solutions Photometric Lab
1121 Highway 74 South
Peachtree City, GA 30269



LM-79-2019: Approved Method: Electrical and Photometric Measurements of Solid-State Lighting Products

Report Prepared for

Cooper Lighting Solutions

Metalux

Report Number: SP1-2506-472-4

Test Date: 07/31/2025

Luminaire Tested: EHBR-60-L850-N

Data in this report applies to families of products including EHBR-60-L850-N

Test Information

Test Method: LM-79-2019
 Report Number: SP1-2506-472-4
 Test Lab: COOPER LIGHTING SOLUTIONS
 Photometer: SP1 - 76IN SPHERE
 Measurement Geometry: 4π
 Issue Date: 08/05/2025
 Manufacturer: COOPER LIGHTING SOLUTIONS
 Product Line: Metalux
 Catalog Number: **EHBR-60-L850-N**
 Description: Elevate Round Highbay at, 60000 lumens, 5000K 80CRI LEDs with N lens

Spectral Parameters

CCT (K): 4875
 CIE u': 0.2124
 CIE v': 0.4871
 Duv: 0.0005
 CIE x: 0.3488
 CIE y: 0.3555
 CIE z: 0.2957
 Peak Wavelength (nm): 630
 Dominant Wavelength (nm): 573
 Purity: 11.33556
 Rf: 80
 Rg: 102.3

CRI (Ra):	82.3		
R1:	85.0	R9:	43.9
R2:	83.1	R10:	57.4
R3:	78.8	R11:	83.1
R4:	84.0	R12:	51.0
R5:	83.0	R13:	83.4
R6:	76.3	R14:	87.4
R7:	86.8	R15:	83.4
R8:	81.7		



Test Conditions

Stabilization Time: 39M
 Operation Time: 1H 39M
 Sphere Temperature (°C): 25.0

REPORT NUMBER: SP1-2506-472-4

Measurement and Test Equipment			
Instrument	Identification Number	Calibration Date	Calibration Due Date
Photometer	76INCH SPHERE IN0058	6/16/2025	12/16/2025
Power Meter	XITRON INXT2011004	1/21/2025	1/21/2026
AC Power Source	CHROMA 61603 IN0063	10/22/2024	10/22/2025
DC Power Source	AGILENT E3634A IN0208	10/22/2024	10/22/2025
Sphere Thermometer	ONSET IN0085	10/22/2024	10/22/2025
Room Thermometer	ONSET IN0046	10/22/2024	10/22/2025

REPORT NUMBER: SP1-2506-472-4

CIE 1931 Chromaticity Diagram



CIE 1931 Chromaticity Diagram with 2017 ANSI 7-Step and 4-Step Quadrangles



Point lies inside the ANSI 5000K 4-step quadrangle

REPORT NUMBER: SP1-2506-472-4

Photopic Flux vs. Wavelength



Photopic Lumens: NR

λ (nm)	Power W [^] /nm	Lumens (ϕ /nm)	λ (nm)	Power W [^] /nm	Lumens (ϕ /nm)	λ (nm)	Power W [^] /nm	Lumens (ϕ /nm)	λ (nm)	Power W [^] /nm	Lumens (ϕ /nm)	λ (nm)	Power W [^] /nm	Lumens (ϕ /nm)
360	0	NR	490	89	NR	620	280	NR	750	6	NR	880	0	NR
365	0	NR	495	121	NR	625	280	NR	755	5	NR	885	0	NR
370	0	NR	500	168	NR	630	1000	NR	760	5	NR	890	0	NR
375	0	NR	505	224	NR	635	626	NR	765	4	NR	895	0	NR
380	1	NR	510	275	NR	640	163	NR	770	4	NR	900	0	NR
385	2	NR	515	321	NR	645	160	NR	775	3	NR	905	0	NR
390	3	NR	520	354	NR	650	136	NR	780	3	NR	910	0	NR
395	5	NR	525	375	NR	655	111	NR	785	2	NR	915	0	NR
400	7	NR	530	388	NR	660	93	NR	790	2	NR	920	0	NR
405	10	NR	535	395	NR	665	76	NR	795	2	NR	925	0	NR
410	15	NR	540	397	NR	670	72	NR	800	2	NR	930	0	NR
415	28	NR	545	398	NR	675	57	NR	805	1	NR	935	0	NR
420	53	NR	550	396	NR	680	49	NR	810	1	NR	940	0	NR
425	97	NR	555	395	NR	685	42	NR	815	1	NR	945	0	NR
430	163	NR	560	392	NR	690	37	NR	820	1	NR	950	0	NR
435	261	NR	565	388	NR	695	32	NR	825	1	NR	955	0	NR
440	409	NR	570	381	NR	700	27	NR	830	1	NR	960	0	NR
445	637	NR	575	374	NR	705	23	NR	835	1	NR	965	0	NR
450	699	NR	580	365	NR	710	20	NR	840	1	NR	970	0	NR
455	436	NR	585	354	NR	715	17	NR	845	0	NR	975	0	NR
460	274	NR	590	342	NR	720	15	NR	850	0	NR	980	0	NR
465	205	NR	595	325	NR	725	13	NR	855	0	NR	985	0	NR
470	130	NR	600	313	NR	730	11	NR	860	0	NR	990	0	NR
475	90	NR	605	301	NR	735	10	NR	865	0	NR	995	0	NR
480	78	NR	610	323	NR	740	8	NR	870	0	NR	1000	0	NR
485	77	NR	615	340	NR	745	7	NR	875	0	NR			

REPORT NUMBER: SP1-2506-472-4

Scotopic Flux vs. Wavelength



Scotopic Lumens: NR

S/P: 1.82

λ (nm)	Power W [^] /nm	Lumens (φ/nm)	λ (nm)	Power W [^] /nm	Lumens (φ/nm)	λ (nm)	Power W [^] /nm	Lumens (φ/nm)	λ (nm)	Power W [^] /nm	Lumens (φ/nm)	λ (nm)	Power W [^] /nm	Lumens (φ/nm)
360	0	NR	490	89	NR	620	280	NR	750	6	NR	880	0	NR
365	0	NR	495	121	NR	625	280	NR	755	5	NR	885	0	NR
370	0	NR	500	168	NR	630	1000	NR	760	5	NR	890	0	NR
375	0	NR	505	224	NR	635	626	NR	765	4	NR	895	0	NR
380	1	NR	510	275	NR	640	163	NR	770	4	NR	900	0	NR
385	2	NR	515	321	NR	645	160	NR	775	3	NR	905	0	NR
390	3	NR	520	354	NR	650	136	NR	780	3	NR	910	0	NR
395	5	NR	525	375	NR	655	111	NR	785	2	NR	915	0	NR
400	7	NR	530	388	NR	660	93	NR	790	2	NR	920	0	NR
405	10	NR	535	395	NR	665	76	NR	795	2	NR	925	0	NR
410	15	NR	540	397	NR	670	72	NR	800	2	NR	930	0	NR
415	28	NR	545	398	NR	675	57	NR	805	1	NR	935	0	NR
420	53	NR	550	396	NR	680	49	NR	810	1	NR	940	0	NR
425	97	NR	555	395	NR	685	42	NR	815	1	NR	945	0	NR
430	163	NR	560	392	NR	690	37	NR	820	1	NR	950	0	NR
435	261	NR	565	388	NR	695	32	NR	825	1	NR	955	0	NR
440	409	NR	570	381	NR	700	27	NR	830	1	NR	960	0	NR
445	637	NR	575	374	NR	705	23	NR	835	1	NR	965	0	NR
450	699	NR	580	365	NR	710	20	NR	840	1	NR	970	0	NR
455	436	NR	585	354	NR	715	17	NR	845	0	NR	975	0	NR
460	274	NR	590	342	NR	720	15	NR	850	0	NR	980	0	NR
465	205	NR	595	325	NR	725	13	NR	855	0	NR	985	0	NR
470	130	NR	600	313	NR	730	11	NR	860	0	NR	990	0	NR
475	90	NR	605	301	NR	735	10	NR	865	0	NR	995	0	NR
480	78	NR	610	323	NR	740	8	NR	870	0	NR	1000	0	NR
485	77	NR	615	340	NR	745	7	NR	875	0	NR			

REPORT NUMBER: SP1-2506-472-4

Melanopic Flux vs. Wavelength



Melanopic Lumens: NR

M/P: 3.71

λ (nm)	Power W [^] /nm	Lumens (φ/nm)	λ (nm)	Power W [^] /nm	Lumens (φ/nm)	λ (nm)	Power W [^] /nm	Lumens (φ/nm)	λ (nm)	Power W [^] /nm	Lumens (φ/nm)	λ (nm)	Power W [^] /nm	Lumens (φ/nm)
360	0	NR	490	89	NR	620	280	NR	750	6	NR	880	0	NR
365	0	NR	495	121	NR	625	280	NR	755	5	NR	885	0	NR
370	0	NR	500	168	NR	630	1000	NR	760	5	NR	890	0	NR
375	0	NR	505	224	NR	635	626	NR	765	4	NR	895	0	NR
380	1	NR	510	275	NR	640	163	NR	770	4	NR	900	0	NR
385	2	NR	515	321	NR	645	160	NR	775	3	NR	905	0	NR
390	3	NR	520	354	NR	650	136	NR	780	3	NR	910	0	NR
395	5	NR	525	375	NR	655	111	NR	785	2	NR	915	0	NR
400	7	NR	530	388	NR	660	93	NR	790	2	NR	920	0	NR
405	10	NR	535	395	NR	665	76	NR	795	2	NR	925	0	NR
410	15	NR	540	397	NR	670	72	NR	800	2	NR	930	0	NR
415	28	NR	545	398	NR	675	57	NR	805	1	NR	935	0	NR
420	53	NR	550	396	NR	680	49	NR	810	1	NR	940	0	NR
425	97	NR	555	395	NR	685	42	NR	815	1	NR	945	0	NR
430	163	NR	560	392	NR	690	37	NR	820	1	NR	950	0	NR
435	261	NR	565	388	NR	695	32	NR	825	1	NR	955	0	NR
440	409	NR	570	381	NR	700	27	NR	830	1	NR	960	0	NR
445	637	NR	575	374	NR	705	23	NR	835	1	NR	965	0	NR
450	699	NR	580	365	NR	710	20	NR	840	1	NR	970	0	NR
455	436	NR	585	354	NR	715	17	NR	845	0	NR	975	0	NR
460	274	NR	590	342	NR	720	15	NR	850	0	NR	980	0	NR
465	205	NR	595	325	NR	725	13	NR	855	0	NR	985	0	NR
470	130	NR	600	313	NR	730	11	NR	860	0	NR	990	0	NR
475	90	NR	605	301	NR	735	10	NR	865	0	NR	995	0	NR
480	78	NR	610	323	NR	740	8	NR	870	0	NR	1000	0	NR
485	77	NR	615	340	NR	745	7	NR	875	0	NR			

Summary

$R_f = 80$
 $R_g = 102.3$
 CIE $R_a = 82.3$
 $R_9 = 43.9$



Color Vector Graphics



Individual Sample Fidelity Index ($R_{f,i}$)

CES01 = 85	CES26 = 67	CES51 = 92	CES76 = 54
CES02 = 60	CES27 = 88	CES52 = 91	CES77 = 71
CES03 = 31	CES28 = 81	CES53 = 82	CES78 = 55
CES04 = 69	CES29 = 66	CES54 = 92	CES79 = 81
CES05 = 47	CES30 = 80	CES55 = 90	CES80 = 75
CES06 = 50	CES31 = 69	CES56 = 81	CES81 = 79
CES07 = 40	CES32 = 61	CES57 = 80	CES82 = 90
CES08 = 39	CES33 = 76	CES58 = 81	CES83 = 87
CES09 = 29	CES34 = 68	CES59 = 93	CES84 = 87
CES10 = 73	CES35 = 82	CES60 = 94	CES85 = 82
CES11 = 56	CES36 = 95	CES61 = 91	CES86 = 83
CES12 = 62	CES37 = 75	CES62 = 89	CES87 = 78
CES13 = 42	CES38 = 87	CES63 = 80	CES88 = 85
CES14 = 74	CES39 = 94	CES64 = 79	CES89 = 81
CES15 = 71	CES40 = 87	CES65 = 75	CES90 = 86
CES16 = 46	CES41 = 91	CES66 = 72	CES91 = 80
CES17 = 48	CES42 = 71	CES67 = 69	CES92 = 77
CES18 = 56	CES43 = 72	CES68 = 75	CES93 = 86
CES19 = 70	CES44 = 99	CES69 = 80	CES94 = 71
CES20 = 65	CES45 = 81	CES70 = 66	CES95 = 79
CES21 = 85	CES46 = 83	CES71 = 59	CES96 = 86
CES22 = 77	CES47 = 83	CES72 = 87	CES97 = 85
CES23 = 91	CES48 = 83	CES73 = 56	CES98 = 82
CES24 = 90	CES49 = 82	CES74 = 95	CES99 = 84
CES25 = 71	CES50 = 91	CES75 = 58	



Color Rendition by Hue-Angle Bin



Measure Comparisons



(END OF REPORT)