

Cooper Lighting Solutions Photometric Lab
1121 Highway 74 South
Peachtree City, GA 30269



Scaled data based on original data using
LM-79-2019 Approved Method: Electrical and Photometric Measurements of Solid-
State Lighting Products

Test Report Prepared for
Cooper Lighting Solutions

Brand: METALUX

Report Number: P1433227

Luminaire Tested: EHBR1-36-UNV-N-L930-UPL15

Issue Date: 3/20/2026

Test Information

Test Method: LM-79-2019
Report Number: P1433227
REPORT IS A COMBINATION OF REPORTS P1431781 AND P1431635
Test Lab: INNOVATION CENTER
Issue Date: 3/20/2026
Manufacturer: COOPER LIGHTING SOLUTIONS
Product Line: METALUX
Catalog Number: EHBR1-36-UNV-N-L930-UPL15
Description: Elevate Round Highbay at, 36000 lumens, 3000K 90CRI LEDs with N lens
Light Source: -
Ballast/Driver: -


Summary

Lumens per Lamp: N/A
Luminaire Lumens: 33867.6 lumens
Efficiency: N/A
Efficacy: 168.7 lumens/watt
Spacing Criteria (0/90/45): 0.82 / 0.82 / 0.8
Luminous Opening: Vertical Cylinder (Dia: 1.71' x H: 0.1')
CIE Type: Direct

Input Watts (W): 200.7
Input Voltage (V): NR
Input Current (Ain): NR
Voltage Rise (V): NR
Power Factor: NR
Total Harmonic Distortion (THDi): NR
Frequency (hertz): 60
Stabilization Time: NR
Operation Time: NR
Ambient Temperature (°C): NR
Test Distance: 24 FT

TEST NUMBER: P1433227
CATALOG NUMBER: EHBR1-36-UNV-N-L930-UPL15

Luminous Intensity Polar Plot



— 0°-180° - - 45°-225° - - - 90°-270°



TEST NUMBER: P1433227

CATALOG NUMBER: EHBR1-36-UNV-N-L930-UPL15

COEFFICIENT OF UTILIZATION - ZONAL CAVITY METHOD:

RF	20				20				20				20				20				
RC	80				70				50				30				10			0	
RW	70	50	30	10	70	50	30	10	50	30	10	50	30	10	50	30	10	50	30	10	0
RCR																					
0	118	118	118	118	115	115	115	115	109	109	109	104	104	104	99	99	99	99	99	99	96
1	111	108	105	102	108	106	103	100	101	99	97	96	95	93	92	91	90	92	91	90	88
2	105	99	94	90	102	97	93	89	93	90	87	89	87	84	86	84	82	86	84	82	80
3	99	91	86	81	96	90	84	80	86	82	78	83	80	77	81	78	75	81	78	75	73
4	93	85	78	74	91	83	77	73	81	76	72	78	74	70	76	72	69	76	72	69	67
5	88	79	72	68	86	78	72	67	75	70	66	73	69	65	71	67	64	71	67	64	63
6	83	74	67	62	82	73	66	62	71	65	61	69	64	61	67	63	60	67	63	60	58
7	79	69	63	58	77	68	62	58	67	61	57	65	60	57	63	59	56	63	59	56	54
8	75	65	59	54	74	64	58	54	63	57	53	61	57	53	60	56	53	60	56	53	51
9	72	61	55	51	70	61	55	51	59	54	50	58	53	50	57	53	49	57	53	49	48
10	68	58	52	48	67	57	52	48	56	51	47	55	50	47	54	50	47	54	50	47	45

AVERAGE LUMINANCE (cd/sqm):

	0°	45°	90°
0°	178534	178534	178534
5°	175069	175069	175069
10°	166161	166161	166161
15°	151184	151184	151184
20°	129683	129683	129683
25°	102016	102016	102016
30°	70009	70009	70009
35°	41588	41588	41588
40°	24607	24607	24607
45°	17664	17664	17664
50°	14519	14519	14519
55°	13196	13196	13196
60°	12632	12632	12632
65°	12049	12049	12049
70°	11204	11204	11204
75°	10129	10129	10129
80°	8408	8408	8408
85°	5324	5324	5324

MAXIMUM LUMINANCE 45°-90°:

Horizontal Angle: 0°
 Vertical Angle: 45°
 Luminance: 17664 cd/sqm



TEST NUMBER: P1433227
 CATALOG NUMBER: EHBR1-36-UNV-N-L930-UPL15

ZONAL LUMENS:

Zone	Lumens	% Fixture
0°-10°	3502.0	10.3
10°-20°	8790.7	26.0
20°-30°	9191.6	27.1
30°-40°	4980.3	14.7
40°-50°	2291.2	6.8
50°-60°	1614.6	4.8
60°-70°	1242.6	3.7
70°-80°	753.3	2.2
80°-90°	214.5	0.6
90°-100°	36.8	0.1
100°-110°	229.9	0.7
110°-120°	411.1	1.2
120°-130°	241.2	0.7
130°-140°	148.0	0.4
140°-150°	102.6	0.3
150°-160°	66.7	0.2
160°-170°	38.0	0.1
170°-180°	12.6	0.0
0°-30°	21484.2	63.4
0°-40°	26464.5	78.1
0°-60°	30370.3	89.7
0°-90°	32580.6	96.2
90°-120°	677.9	2.0
90°-150°	1169.7	3.5
90°-180°	1287.0	3.8
0°-180°	33867.6	100.0

CANDELA DISTRIBUTION:

	0°	22.5°	45°	67.5°	90°	Flux
0°	38018	38018	38018	38018	38018	
5°	37380	37380	37380	37380	37380	3502
15°	31718	31718	31718	31718	31718	8791
25°	20372	20372	20372	20372	20372	9192
35°	7633	7633	7633	7633	7633	4980
45°	2858	2858	2858	2858	2858	2291
55°	1783	1783	1783	1783	1783	1615
65°	1258	1258	1258	1258	1258	1243
75°	714	714	714	714	714	753
85°	183	183	183	183	183	203
90°	11	17	28	18	11	14
95°	16	27	60	30	18	16
105°	80	158	404	175	106	107
115°	370	389	478	458	455	341
125°	267	249	256	259	291	243
135°	194	189	195	183	183	152
145°	160	158	167	165	164	101
155°	140	138	145	145	145	65
165°	131	131	135	135	134	37
175°	130	130	132	132	132	12
180°	131	131	131	131	131	



TEST NUMBER: P1433227

CATALOG NUMBER: EHBR1-36-UNV-N-L930-UPL15

CANDELA DISTRIBUTION (FULL):

	0°	22.5°	45°	67.5°	90°
0°	38017.6	38017.6	38017.6	38017.6	38017.6
2.5°	37882.9	37882.9	37882.9	37882.9	37882.9
5°	37379.9	37379.9	37379.9	37379.9	37379.9
7.5°	36521.3	36521.3	36521.3	36521.3	36521.3
10°	35303.2	35303.2	35303.2	35303.2	35303.2
12.5°	33728.8	33728.8	33728.8	33728.8	33728.8
15°	31717.6	31717.6	31717.6	31717.6	31717.6
17.5°	29384.4	29384.4	29384.4	29384.4	29384.4
20°	26653.6	26653.6	26653.6	26653.6	26653.6
22.5°	23613.2	23613.2	23613.2	23613.2	23613.2
25°	20372.5	20372.5	20372.5	20372.5	20372.5
27.5°	16937.0	16937.0	16937.0	16937.0	16937.0
30°	13466.2	13466.2	13466.2	13466.2	13466.2
32.5°	10334.9	10334.9	10334.9	10334.9	10334.9
35°	7632.9	7632.9	7632.9	7632.9	7632.9
37.5°	5604.4	5604.4	5604.4	5604.4	5604.4
40°	4265.0	4265.0	4265.0	4265.0	4265.0
42.5°	3419.8	3419.8	3419.8	3419.8	3419.8
45°	2857.9	2857.9	2857.9	2857.9	2857.9
47.5°	2453.0	2453.0	2453.0	2453.0	2453.0
50°	2163.9	2163.9	2163.9	2163.9	2163.9
52.5°	1952.8	1952.8	1952.8	1952.8	1952.8
55°	1783.3	1783.3	1783.3	1783.3	1783.3
57.5°	1645.8	1645.8	1645.8	1645.8	1645.8
60°	1518.6	1518.6	1518.6	1518.6	1518.6
62.5°	1391.3	1391.3	1391.3	1391.3	1391.3
65°	1257.6	1257.6	1257.6	1257.6	1257.6
67.5°	1121.2	1121.2	1121.2	1121.2	1121.2
70°	983.1	983.1	983.1	983.1	983.1
72.5°	848.9	848.9	848.9	848.9	848.9
75°	713.5	713.5	713.5	713.5	713.5
77.5°	580.9	580.9	580.9	580.9	580.9
80°	442.3	442.3	442.3	442.3	442.3
82.5°	309.7	309.7	309.7	309.7	309.7
85°	183.0	183.0	183.0	183.0	183.0
87.5°	65.5	65.5	65.5	65.5	65.5
90°	10.6	16.6	27.6	18.0	10.6
92.5°	14.0	23.6	42.7	22.1	12.6
95°	16.2	27.3	59.7	29.5	18.4
97.5°	20.6	30.2	68.5	36.1	28.7
100°	27.3	35.4	106.8	44.2	38.3
102.5°	46.4	75.1	226.9	83.2	58.2
105°	80.3	158.4	404.4	174.6	106.0
107.5°	139.2	283.6	533.3	309.4	201.1
110°	260.0	376.4	559.1	425.0	321.9



TEST NUMBER: P1433227

CATALOG NUMBER: EHBR1-36-UNV-N-L930-UPL15

CANDELA DISTRIBUTION (continued):

	0°	22.5°	45°	67.5°	90°
112.5°	351.4	404.4	535.5	469.2	419.1
115°	369.8	388.9	478.1	458.1	455.2
117.5°	357.3	355.0	405.9	411.8	439.8
120°	330.7	316.0	338.8	359.5	397.0
122.5°	297.6	279.9	290.2	305.7	343.3
125°	266.6	249.0	255.6	259.3	291.0
127.5°	239.4	227.6	231.3	226.9	246.8
130°	221.0	210.7	215.8	205.5	215.1
132.5°	205.5	198.9	204.8	192.2	195.2
135°	194.4	188.6	195.2	183.4	182.7
137.5°	184.9	179.7	186.3	177.5	175.3
140°	176.1	171.6	179.0	172.3	170.9
142.5°	166.5	163.5	172.3	168.0	166.5
145°	159.9	157.6	167.2	165.0	164.2
147.5°	154.0	152.5	161.3	160.6	160.6
150°	148.8	147.3	156.1	155.4	156.1
152.5°	143.7	142.1	150.2	149.5	150.2
155°	140.0	138.5	145.1	145.1	145.1
157.5°	137.0	136.3	141.4	141.4	141.4
160°	134.8	134.0	138.5	138.5	137.8
162.5°	132.6	131.9	137.0	136.3	136.3
165°	131.1	131.1	134.8	134.8	134.0
167.5°	131.1	130.4	134.0	134.0	133.3
170°	130.4	130.4	133.3	132.6	131.9
172.5°	130.4	130.4	133.3	132.6	131.9
175°	129.7	129.7	131.9	131.9	131.9
177.5°	130.4	130.4	131.9	131.9	131.1
180°	131.1	131.1	131.1	131.1	131.1



TEST NUMBER: P1433227

CATALOG NUMBER: EHBR1-36-UNV-N-L930-UPL15

CIE UGR TABLE:

Reflectances:											
Ceiling		0.7	0.7	0.5	0.5	0.3	0.7	0.7	0.5	0.5	0.3
Wall		0.5	0.3	0.5	0.3	0.3	0.5	0.3	0.5	0.3	0.3
Reference plane		0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2
Room dimensions		Viewed crosswise					Viewed endwise				
X=2H	Y=2H	17.13	18.24	17.57	18.63	19.05	17.13	18.24	17.57	18.63	19.05
	3H	18.91	19.89	19.36	20.31	20.77	18.91	19.89	19.36	20.31	20.77
	4H	19.57	20.49	20.05	20.92	21.40	19.57	20.49	20.05	20.92	21.40
	6H	20.03	20.87	20.52	21.32	21.81	20.03	20.87	20.52	21.32	21.81
	8H	20.16	20.95	20.66	21.42	21.92	20.16	20.95	20.66	21.42	21.92
	12H	20.21	20.97	20.71	21.43	21.95	20.21	20.97	20.71	21.43	21.95
4H	2H	17.68	18.59	18.15	19.02	19.50	17.68	18.59	18.15	19.02	19.50
	3H	19.65	20.40	20.13	20.88	21.38	19.65	20.40	20.13	20.88	21.38
	4H	20.42	21.10	20.92	21.59	22.13	20.42	21.10	20.92	21.59	22.13
	6H	20.99	21.58	21.53	22.10	22.66	20.99	21.58	21.53	22.10	22.66
	8H	21.15	21.70	21.69	22.21	22.78	21.15	21.70	21.69	22.21	22.78
	12H	21.23	21.71	21.79	22.26	22.83	21.23	21.71	21.79	22.26	22.83
8H	4H	20.65	21.20	21.19	21.71	22.28	20.65	21.20	21.19	21.71	22.28
	6H	21.33	21.77	21.90	22.34	22.91	21.33	21.77	21.90	22.34	22.91
	8H	21.56	21.95	22.14	22.53	23.11	21.56	21.95	22.14	22.53	23.11
	12H	21.70	22.04	22.28	22.60	23.26	21.70	22.04	22.28	22.60	23.26
12H	4H	20.65	21.13	21.20	21.68	22.24	20.65	21.13	21.20	21.68	22.24
	6H	21.36	21.75	21.95	22.33	22.91	21.36	21.75	21.95	22.33	22.91
	8H	21.62	21.96	22.21	22.53	23.19	21.62	21.96	22.21	22.53	23.19

Cooper Lighting Solutions Photometric Lab
1121 Highway 74 South
Peachtree City, GA 30269



LM-79-2019: Approved Method: Electrical and Photometric Measurements of Solid-State Lighting Products

Report Prepared for

Cooper Lighting Solutions

Metalux

Report Number: SP1-2506-472-5

Test Date: 08/01/2025

Luminaire Tested: EHBR-60-L930-N

Data in this report applies to families of products including EHBR-60-L930-N

Test Information

Test Method: LM-79-2019
 Report Number: SP1-2506-472-5
 Test Lab: COOPER LIGHTING SOLUTIONS
 Photometer: SP1 - 76IN SPHERE
 Measurement Geometry: 4π
 Issue Date: 08/05/2025
 Manufacturer: COOPER LIGHTING SOLUTIONS
 Product Line: Metalux
 Catalog Number: **EHBR-60-L930-N**
 Description: Elevate Round Highbay at, 60000 lumens, 3000K 90CRI LEDs with N lens

Spectral Parameters

CCT (K): 2996
 CIE u': 0.2519
 CIE v': 0.5169
 Duv: -0.0033
 CIE x: 0.4325
 CIE y: 0.3945
 CIE z: 0.1730
 Peak Wavelength (nm): 630
 Dominant Wavelength (nm): 584
 Purity: 48.21818
 Rf: 91.3
 Rg: 102

CRI (Ra):	94.4		
R1:	96.8	R9:	61.4
R2:	98.1	R10:	94.4
R3:	97.8	R11:	95.7
R4:	95.6	R12:	88.5
R5:	96.9	R13:	97.3
R6:	95.7	R14:	97.8
R7:	90.9	R15:	92.3
R8:	83.0		



Test Conditions

Stabilization Time: 40M
 Operation Time: 1H 40M
 Sphere Temperature (°C): 25.0

REPORT NUMBER: SP1-2506-472-5

Measurement and Test Equipment			
Instrument	Identification Number	Calibration Date	Calibration Due Date
Photometer	76INCH SPHERE IN0058	6/16/2025	12/16/2025
Power Meter	XITRON INXT2011004	1/21/2025	1/21/2026
AC Power Source	CHROMA 61603 IN0063	10/22/2024	10/22/2025
DC Power Source	AGILENT E3634A IN0208	10/22/2024	10/22/2025
Sphere Thermometer	ONSET IN0085	10/22/2024	10/22/2025
Room Thermometer	ONSET IN0046	10/22/2024	10/22/2025

REPORT NUMBER: SP1-2506-472-5

CIE 1931 Chromaticity Diagram



CIE 1931 Chromaticity Diagram with 2017 ANSI 7-Step and 4-Step Quadrangles



Point lies inside the ANSI 3000K 7-step quadrangle

REPORT NUMBER: SP1-2506-472-5

Photopic Flux vs. Wavelength




Photopic Lumens: NR

λ (nm)	Power W [^] /nm	Lumens (ϕ /nm)	λ (nm)	Power W [^] /nm	Lumens (ϕ /nm)	λ (nm)	Power W [^] /nm	Lumens (ϕ /nm)	λ (nm)	Power W [^] /nm	Lumens (ϕ /nm)	λ (nm)	Power W [^] /nm	Lumens (ϕ /nm)
360	0	NR	490	101	NR	620	317	NR	750	7	NR	880	0	NR
365	0	NR	495	121	NR	625	320	NR	755	6	NR	885	0	NR
370	0	NR	500	141	NR	630	1000	NR	760	5	NR	890	0	NR
375	0	NR	505	158	NR	635	651	NR	765	4	NR	895	0	NR
380	0	NR	510	171	NR	640	207	NR	770	4	NR	900	0	NR
385	0	NR	515	182	NR	645	201	NR	775	3	NR	905	0	NR
390	0	NR	520	189	NR	650	174	NR	780	3	NR	910	0	NR
395	1	NR	525	194	NR	655	146	NR	785	2	NR	915	0	NR
400	1	NR	530	199	NR	660	124	NR	790	2	NR	920	0	NR
405	3	NR	535	205	NR	665	105	NR	795	2	NR	925	0	NR
410	4	NR	540	210	NR	670	96	NR	800	1	NR	930	0	NR
415	7	NR	545	216	NR	675	79	NR	805	1	NR	935	0	NR
420	13	NR	550	222	NR	680	67	NR	810	1	NR	940	0	NR
425	22	NR	555	230	NR	685	58	NR	815	1	NR	945	0	NR
430	37	NR	560	240	NR	690	49	NR	820	1	NR	950	0	NR
435	60	NR	565	248	NR	695	42	NR	825	1	NR	955	0	NR
440	101	NR	570	258	NR	700	36	NR	830	1	NR	960	0	NR
445	172	NR	575	268	NR	705	30	NR	835	1	NR	965	0	NR
450	223	NR	580	278	NR	710	26	NR	840	1	NR	970	0	NR
455	167	NR	585	287	NR	715	22	NR	845	0	NR	975	0	NR
460	126	NR	590	295	NR	720	19	NR	850	0	NR	980	0	NR
465	111	NR	595	298	NR	725	16	NR	855	0	NR	985	0	NR
470	86	NR	600	303	NR	730	14	NR	860	0	NR	990	0	NR
475	74	NR	605	307	NR	735	12	NR	865	0	NR	995	0	NR
480	77	NR	610	341	NR	740	10	NR	870	0	NR	1000	0	NR
485	86	NR	615	368	NR	745	8	NR	875	0	NR			

REPORT NUMBER: SP1-2506-472-5

Scotopic Flux vs. Wavelength



Scotopic Lumens: NR S/P: 1.44

λ (nm)	Power W [^] /nm	Lumens (φ/nm)	λ (nm)	Power W [^] /nm	Lumens (φ/nm)	λ (nm)	Power W [^] /nm	Lumens (φ/nm)	λ (nm)	Power W [^] /nm	Lumens (φ/nm)	λ (nm)	Power W [^] /nm	Lumens (φ/nm)
360	0	NR	490	101	NR	620	317	NR	750	7	NR	880	0	NR
365	0	NR	495	121	NR	625	320	NR	755	6	NR	885	0	NR
370	0	NR	500	141	NR	630	1000	NR	760	5	NR	890	0	NR
375	0	NR	505	158	NR	635	651	NR	765	4	NR	895	0	NR
380	0	NR	510	171	NR	640	207	NR	770	4	NR	900	0	NR
385	0	NR	515	182	NR	645	201	NR	775	3	NR	905	0	NR
390	0	NR	520	189	NR	650	174	NR	780	3	NR	910	0	NR
395	1	NR	525	194	NR	655	146	NR	785	2	NR	915	0	NR
400	1	NR	530	199	NR	660	124	NR	790	2	NR	920	0	NR
405	3	NR	535	205	NR	665	105	NR	795	2	NR	925	0	NR
410	4	NR	540	210	NR	670	96	NR	800	1	NR	930	0	NR
415	7	NR	545	216	NR	675	79	NR	805	1	NR	935	0	NR
420	13	NR	550	222	NR	680	67	NR	810	1	NR	940	0	NR
425	22	NR	555	230	NR	685	58	NR	815	1	NR	945	0	NR
430	37	NR	560	240	NR	690	49	NR	820	1	NR	950	0	NR
435	60	NR	565	248	NR	695	42	NR	825	1	NR	955	0	NR
440	101	NR	570	258	NR	700	36	NR	830	1	NR	960	0	NR
445	172	NR	575	268	NR	705	30	NR	835	1	NR	965	0	NR
450	223	NR	580	278	NR	710	26	NR	840	1	NR	970	0	NR
455	167	NR	585	287	NR	715	22	NR	845	0	NR	975	0	NR
460	126	NR	590	295	NR	720	19	NR	850	0	NR	980	0	NR
465	111	NR	595	298	NR	725	16	NR	855	0	NR	985	0	NR
470	86	NR	600	303	NR	730	14	NR	860	0	NR	990	0	NR
475	74	NR	605	307	NR	735	12	NR	865	0	NR	995	0	NR
480	77	NR	610	341	NR	740	10	NR	870	0	NR	1000	0	NR
485	86	NR	615	368	NR	745	8	NR	875	0	NR			

REPORT NUMBER: SP1-2506-472-5

Melanopic Flux vs. Wavelength



Melanopic Lumens: NR

M/P: 2.85

λ (nm)	Power W [^] /nm	Lumens (φ/nm)	λ (nm)	Power W [^] /nm	Lumens (φ/nm)	λ (nm)	Power W [^] /nm	Lumens (φ/nm)	λ (nm)	Power W [^] /nm	Lumens (φ/nm)	λ (nm)	Power W [^] /nm	Lumens (φ/nm)
360	0	NR	490	101	NR	620	317	NR	750	7	NR	880	0	NR
365	0	NR	495	121	NR	625	320	NR	755	6	NR	885	0	NR
370	0	NR	500	141	NR	630	1000	NR	760	5	NR	890	0	NR
375	0	NR	505	158	NR	635	651	NR	765	4	NR	895	0	NR
380	0	NR	510	171	NR	640	207	NR	770	4	NR	900	0	NR
385	0	NR	515	182	NR	645	201	NR	775	3	NR	905	0	NR
390	0	NR	520	189	NR	650	174	NR	780	3	NR	910	0	NR
395	1	NR	525	194	NR	655	146	NR	785	2	NR	915	0	NR
400	1	NR	530	199	NR	660	124	NR	790	2	NR	920	0	NR
405	3	NR	535	205	NR	665	105	NR	795	2	NR	925	0	NR
410	4	NR	540	210	NR	670	96	NR	800	1	NR	930	0	NR
415	7	NR	545	216	NR	675	79	NR	805	1	NR	935	0	NR
420	13	NR	550	222	NR	680	67	NR	810	1	NR	940	0	NR
425	22	NR	555	230	NR	685	58	NR	815	1	NR	945	0	NR
430	37	NR	560	240	NR	690	49	NR	820	1	NR	950	0	NR
435	60	NR	565	248	NR	695	42	NR	825	1	NR	955	0	NR
440	101	NR	570	258	NR	700	36	NR	830	1	NR	960	0	NR
445	172	NR	575	268	NR	705	30	NR	835	1	NR	965	0	NR
450	223	NR	580	278	NR	710	26	NR	840	1	NR	970	0	NR
455	167	NR	585	287	NR	715	22	NR	845	0	NR	975	0	NR
460	126	NR	590	295	NR	720	19	NR	850	0	NR	980	0	NR
465	111	NR	595	298	NR	725	16	NR	855	0	NR	985	0	NR
470	86	NR	600	303	NR	730	14	NR	860	0	NR	990	0	NR
475	74	NR	605	307	NR	735	12	NR	865	0	NR	995	0	NR
480	77	NR	610	341	NR	740	10	NR	870	0	NR	1000	0	NR
485	86	NR	615	368	NR	745	8	NR	875	0	NR			

Summary

$R_f = 91.3$
 $R_g = 102$
 $CIE R_a = 94.4$
 $R_9 = 61.4$



Color Vector Graphics



Individual Sample Fidelity Index ($R_{f,i}$)

CES01 = 86	CES26 = 91	CES51 = 96	CES76 = 89
CES02 = 63	CES27 = 96	CES52 = 95	CES77 = 85
CES03 = 32	CES28 = 96	CES53 = 93	CES78 = 86
CES04 = 70	CES29 = 90	CES54 = 98	CES79 = 89
CES05 = 51	CES30 = 96	CES55 = 98	CES80 = 91
CES06 = 51	CES31 = 90	CES56 = 95	CES81 = 72
CES07 = 44	CES32 = 84	CES57 = 95	CES82 = 95
CES08 = 42	CES33 = 91	CES58 = 95	CES83 = 93
CES09 = 29	CES34 = 92	CES59 = 99	CES84 = 96
CES10 = 76	CES35 = 96	CES60 = 96	CES85 = 80
CES11 = 59	CES36 = 90	CES61 = 96	CES86 = 77
CES12 = 65	CES37 = 94	CES62 = 95	CES87 = 91
CES13 = 44	CES38 = 99	CES63 = 94	CES88 = 96
CES14 = 74	CES39 = 97	CES64 = 96	CES89 = 82
CES15 = 72	CES40 = 94	CES65 = 92	CES90 = 97
CES16 = 48	CES41 = 94	CES66 = 95	CES91 = 82
CES17 = 50	CES42 = 91	CES67 = 94	CES92 = 78
CES18 = 57	CES43 = 88	CES68 = 93	CES93 = 87
CES19 = 72	CES44 = 99	CES69 = 94	CES94 = 73
CES20 = 67	CES45 = 93	CES70 = 90	CES95 = 85
CES21 = 86	CES46 = 93	CES71 = 90	CES96 = 92
CES22 = 79	CES47 = 86	CES72 = 96	CES97 = 93
CES23 = 92	CES48 = 95	CES73 = 85	CES98 = 94
CES24 = 91	CES49 = 91	CES74 = 90	CES99 = 93
CES25 = 72	CES50 = 96	CES75 = 90	



Color Rendition by Hue-Angle Bin



Measure Comparisons



(END OF REPORT)