

Cooper Lighting Solutions Photometric Lab
1121 Highway 74 South
Peachtree City, GA 30269



Scaled data based on original data using
LM-79-2019 Approved Method: Electrical and Photometric Measurements of Solid-
State Lighting Products

Test Report Prepared for
Cooper Lighting Solutions

Brand: METALUX

Report Number: P1433587

Luminaire Tested: EHBR1-42-UNV-N-L935-UPL12

Issue Date: 3/20/2026

Test Information

Test Method: LM-79-2019
Report Number: P1433587
REPORT IS A COMBINATION OF REPORTS P1431812 AND P1431635
Test Lab: INNOVATION CENTER
Issue Date: 3/20/2026
Manufacturer: COOPER LIGHTING SOLUTIONS
Product Line: METALUX
Catalog Number: EHBR1-42-UNV-N-L935-UPL12
Description: Elevate Round Highbay at, 42000 lumens, 3500K 90CRI LEDs with N lens
Light Source: -
Ballast/Driver: -


Summary

Lumens per Lamp: N/A
Luminaire Lumens: 39158.6 lumens
Efficiency: N/A
Efficacy: 168.9 lumens/watt
Spacing Criteria (0/90/45): 0.82 / 0.82 / 0.8
Luminous Opening: Vertical Cylinder (Dia: 1.71' x H: 0.1')
CIE Type: Direct

Input Watts (W): 231.8
Input Voltage (V): NR
Input Current (Ain): NR
Voltage Rise (V): NR
Power Factor: NR
Total Harmonic Distortion (THDi): NR
Frequency (hertz): 60
Stabilization Time: NR
Operation Time: NR
Ambient Temperature (°C): NR
Test Distance: 24 FT

TEST NUMBER: P1433587
CATALOG NUMBER: EHBR1-42-UNV-N-L935-UPL12

Luminous Intensity Polar Plot





TEST NUMBER: P1433587

CATALOG NUMBER: EHBR1-42-UNV-N-L935-UPL12

COEFFICIENT OF UTILIZATION - ZONAL CAVITY METHOD:

RF	20				20				20				20				20				20	
RC	80				70				50				30				10				0	
RW	70	50	30	10	70	50	30	10	50	30	10	50	30	10	50	30	10	50	30	10	0	
RCR																						
0	118	118	118	118	115	115	115	115	110	110	110	104	104	104	100	100	100	97				97
1	112	108	105	103	109	106	103	101	101	99	97	97	95	94	93	92	91	89				89
2	105	99	95	91	103	97	93	90	94	90	87	90	87	85	87	85	83	81				81
3	99	92	86	81	97	90	85	81	87	83	79	84	80	77	81	78	76	74				74
4	93	85	79	74	91	84	78	73	81	76	72	79	74	71	76	73	70	68				68
5	88	79	73	68	86	78	72	67	76	71	67	74	69	66	72	68	65	63				63
6	84	74	67	63	82	73	67	62	71	66	62	69	65	61	68	64	60	59				59
7	79	69	63	58	78	69	62	58	67	62	58	66	61	57	64	60	57	55				55
8	75	65	59	55	74	65	59	54	63	58	54	62	57	54	61	56	53	52				52
9	72	62	55	51	71	61	55	51	60	54	51	59	54	50	58	53	50	49				49
10	69	58	52	48	67	58	52	48	57	51	48	56	51	47	55	50	47	46				46

AVERAGE LUMINANCE (cd/sqm):

	0°	45°	90°
0°	208756	208756	208756
5°	204704	204704	204704
10°	194289	194289	194289
15°	176777	176777	176777
20°	151635	151635	151635
25°	119285	119285	119285
30°	81860	81860	81860
35°	48628	48628	48628
40°	28772	28772	28772
45°	20654	20654	20654
50°	16977	16977	16977
55°	15430	15430	15430
60°	14770	14770	14770
65°	14088	14088	14088
70°	13102	13102	13102
75°	11843	11843	11843
80°	9831	9831	9831
85°	6226	6226	6226

MAXIMUM LUMINANCE 45°-90°:

Horizontal Angle: 0°
 Vertical Angle: 45°
 Luminance: 20654 cd/sqm



TEST NUMBER: P1433587
 CATALOG NUMBER: EHBR1-42-UNV-N-L935-UPL12

ZONAL LUMENS:

Zone	Lumens	% Fixture
0°-10°	4094.8	10.5
10°-20°	10278.7	26.2
20°-30°	10747.5	27.4
30°-40°	5823.3	14.9
40°-50°	2679.0	6.8
50°-60°	1888.0	4.8
60°-70°	1452.9	3.7
70°-80°	880.8	2.2
80°-90°	250.0	0.6
90°-100°	30.5	0.1
100°-110°	190.0	0.5
110°-120°	339.7	0.9
120°-130°	199.3	0.5
130°-140°	122.3	0.3
140°-150°	84.8	0.2
150°-160°	55.1	0.1
160°-170°	31.4	0.1
170°-180°	10.4	0.0
0°-30°	25121.1	64.2
0°-40°	30944.4	79.0
0°-60°	35511.3	90.7
0°-90°	38095.0	97.3
90°-120°	560.2	1.4
90°-150°	966.6	2.5
90°-180°	1064.0	2.7
0°-180°	39158.6	100.0

CANDELA DISTRIBUTION:

	0°	22.5°	45°	67.5°	90°	Flux
0°	44453	44453	44453	44453	44453	
5°	43708	43708	43708	43708	43708	4095
15°	37087	37087	37087	37087	37087	10279
25°	23821	23821	23821	23821	23821	10747
35°	8925	8925	8925	8925	8925	5823
45°	3342	3342	3342	3342	3342	2679
55°	2085	2085	2085	2085	2085	1888
65°	1470	1470	1470	1470	1470	1453
75°	834	834	834	834	834	881
85°	214	214	214	214	214	237
90°	9	14	23	15	9	15
95°	13	22	49	24	15	13
105°	66	131	334	144	88	89
115°	306	321	395	379	376	281
125°	220	206	211	214	240	201
135°	161	156	161	152	151	126
145°	132	130	138	136	136	84
155°	116	114	120	120	120	54
165°	108	108	111	111	111	31
175°	107	107	109	109	109	10
180°	108	108	108	108	108	



TEST NUMBER: P1433587

CATALOG NUMBER: EHBR1-42-UNV-N-L935-UPL12

CANDELA DISTRIBUTION (FULL):

	0°	22.5°	45°	67.5°	90°
0°	44453.2	44453.2	44453.2	44453.2	44453.2
2.5°	44295.6	44295.6	44295.6	44295.6	44295.6
5°	43707.5	43707.5	43707.5	43707.5	43707.5
7.5°	42703.6	42703.6	42703.6	42703.6	42703.6
10°	41279.3	41279.3	41279.3	41279.3	41279.3
12.5°	39438.4	39438.4	39438.4	39438.4	39438.4
15°	37086.8	37086.8	37086.8	37086.8	37086.8
17.5°	34358.4	34358.4	34358.4	34358.4	34358.4
20°	31165.4	31165.4	31165.4	31165.4	31165.4
22.5°	27610.4	27610.4	27610.4	27610.4	27610.4
25°	23821.2	23821.2	23821.2	23821.2	23821.2
27.5°	19804.0	19804.0	19804.0	19804.0	19804.0
30°	15745.8	15745.8	15745.8	15745.8	15745.8
32.5°	12084.4	12084.4	12084.4	12084.4	12084.4
35°	8924.9	8924.9	8924.9	8924.9	8924.9
37.5°	6553.0	6553.0	6553.0	6553.0	6553.0
40°	4986.9	4986.9	4986.9	4986.9	4986.9
42.5°	3998.8	3998.8	3998.8	3998.8	3998.8
45°	3341.7	3341.7	3341.7	3341.7	3341.7
47.5°	2868.2	2868.2	2868.2	2868.2	2868.2
50°	2530.2	2530.2	2530.2	2530.2	2530.2
52.5°	2283.3	2283.3	2283.3	2283.3	2283.3
55°	2085.2	2085.2	2085.2	2085.2	2085.2
57.5°	1924.4	1924.4	1924.4	1924.4	1924.4
60°	1775.6	1775.6	1775.6	1775.6	1775.6
62.5°	1626.9	1626.9	1626.9	1626.9	1626.9
65°	1470.5	1470.5	1470.5	1470.5	1470.5
67.5°	1311.0	1311.0	1311.0	1311.0	1311.0
70°	1149.6	1149.6	1149.6	1149.6	1149.6
72.5°	992.6	992.6	992.6	992.6	992.6
75°	834.3	834.3	834.3	834.3	834.3
77.5°	679.2	679.2	679.2	679.2	679.2
80°	517.2	517.2	517.2	517.2	517.2
82.5°	362.1	362.1	362.1	362.1	362.1
85°	214.0	214.0	214.0	214.0	214.0
87.5°	76.6	76.6	76.6	76.6	76.6
90°	9.2	14.0	23.2	15.2	9.2
92.5°	11.6	19.5	35.3	18.2	10.3
95°	13.4	22.5	49.3	24.4	15.2
97.5°	17.0	24.9	56.6	29.8	23.7
100°	22.5	29.2	88.3	36.5	31.6
102.5°	38.3	62.1	187.5	68.8	48.1
105°	66.3	130.9	334.2	144.3	87.6
107.5°	115.0	234.4	440.7	255.7	166.2
110°	214.9	311.1	462.0	351.2	266.0



TEST NUMBER: P1433587

CATALOG NUMBER: EHBR1-42-UNV-N-L935-UPL12

CANDELA DISTRIBUTION (continued):

	0°	22.5°	45°	67.5°	90°
112.5°	290.4	334.2	442.6	387.7	346.3
115°	305.6	321.4	395.1	378.6	376.2
117.5°	295.2	293.4	335.4	340.2	363.4
120°	273.3	261.1	280.0	297.0	328.1
122.5°	245.9	231.3	239.8	252.6	283.7
125°	220.3	205.7	211.3	214.3	240.4
127.5°	197.9	188.1	191.1	187.5	203.9
130°	182.6	174.1	178.4	169.8	177.7
132.5°	169.8	164.3	169.2	158.9	161.3
135°	160.7	155.8	161.3	151.5	151.0
137.5°	152.8	148.5	154.0	146.7	144.8
140°	145.5	141.8	147.9	142.5	141.2
142.5°	137.6	135.1	142.5	138.8	137.6
145°	132.1	130.2	138.2	136.3	135.8
147.5°	127.2	126.0	133.3	132.7	132.7
150°	123.0	121.7	129.1	128.4	129.1
152.5°	118.7	117.5	124.2	123.5	124.2
155°	115.6	114.5	119.9	119.9	119.9
157.5°	113.2	112.6	116.9	116.9	116.9
160°	111.4	110.8	114.5	114.5	113.8
162.5°	109.6	108.9	113.2	112.6	112.6
165°	108.3	108.3	111.4	111.4	110.8
167.5°	108.3	107.8	110.8	110.8	110.2
170°	107.8	107.8	110.2	109.6	108.9
172.5°	107.8	107.8	110.2	109.6	108.9
175°	107.1	107.1	108.9	108.9	108.9
177.5°	107.8	107.8	108.9	108.9	108.3
180°	108.3	108.3	108.3	108.3	108.3



TEST NUMBER: P1433587
 CATALOG NUMBER: EHBR1-42-UNV-N-L935-UPL12

CIE UGR TABLE:

Reflectances:											
Ceiling		0.7	0.7	0.5	0.5	0.3	0.7	0.7	0.5	0.5	0.3
Wall		0.5	0.3	0.5	0.3	0.3	0.5	0.3	0.5	0.3	0.3
Reference plane		0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2
Room dimensions		Viewed crosswise					Viewed endwise				
X=2H	Y=2H	17.76	18.88	18.18	19.26	19.64	17.76	18.88	18.18	19.26	19.64
	3H	19.55	20.54	19.98	20.93	21.37	19.55	20.54	19.98	20.93	21.37
	4H	20.20	21.13	20.66	21.54	22.00	20.20	21.13	20.66	21.54	22.00
	6H	20.66	21.52	21.13	21.95	22.41	20.66	21.52	21.13	21.95	22.41
	8H	20.79	21.59	21.27	22.04	22.52	20.79	21.59	21.27	22.04	22.52
	12H	20.84	21.61	21.33	22.05	22.55	20.84	21.61	21.33	22.05	22.55
4H	2H	18.31	19.24	18.76	19.65	20.10	18.31	19.24	18.76	19.65	20.10
	3H	20.28	21.05	20.75	21.51	21.98	20.28	21.05	20.75	21.51	21.98
	4H	21.05	21.74	21.54	22.21	22.73	21.05	21.74	21.54	22.21	22.73
	6H	21.63	22.22	22.14	22.72	23.25	21.63	22.22	22.14	22.72	23.25
	8H	21.78	22.34	22.30	22.84	23.37	21.78	22.34	22.30	22.84	23.37
	12H	21.87	22.35	22.40	22.89	23.43	21.87	22.35	22.40	22.89	23.43
8H	4H	21.28	21.84	21.80	22.34	22.87	21.28	21.84	21.80	22.34	22.87
	6H	21.97	22.41	22.52	22.96	23.51	21.97	22.41	22.52	22.96	23.51
	8H	22.19	22.59	22.76	23.15	23.71	22.19	22.59	22.76	23.15	23.71
	12H	22.33	22.68	22.89	23.22	23.86	22.33	22.68	22.89	23.22	23.86
12H	4H	21.28	21.77	21.82	22.30	22.84	21.28	21.77	21.82	22.30	22.84
	6H	21.99	22.39	22.56	22.95	23.51	21.99	22.39	22.56	22.95	23.51
	8H	22.26	22.60	22.82	23.15	23.78	22.26	22.60	22.82	23.15	23.78

LM-79-2019: Approved Method: Electrical and Photometric Measurements of Solid-
State Lighting Products

Report Prepared for

Cooper Lighting Solutions

Metalux

Report Number: SP1-2506-472-6

Test Date: 08/01/2025

Luminaire Tested: EHBR-60-L935-N

Data in this report applies to families of products including EHBR-60-L935-N

Test Information

Test Method: LM-79-2019
 Report Number: SP1-2506-472-6
 Test Lab: COOPER LIGHTING SOLUTIONS
 Photometer: SP1 - 76IN SPHERE
 Measurement Geometry: 4π
 Issue Date: 08/05/2025
 Manufacturer: COOPER LIGHTING SOLUTIONS
 Product Line: Metalux
 Catalog Number: **EHBR-60-L935-N**
 Description: Elevate Round Highbay at, 60000 lumens, 3500K 90CRI LEDs with N lens

Spectral Parameters

CCT (K): 3406
 CIE u': 0.2394
 CIE v': 0.5094
 Duv: -0.0028
 CIE x: 0.4076
 CIE y: 0.3856
 CIE z: 0.2068
 Peak Wavelength (nm): 630
 Dominant Wavelength (nm): 582
 Purity: 38.0517
 Rf: 91.3
 Rg: 100

CRI (Ra):	94.6		
R1:	96.6	R9:	63.8
R2:	98.4	R10:	94.7
R3:	98.1	R11:	96.6
R4:	95.8	R12:	80.9
R5:	96.2	R13:	97.4
R6:	95.4	R14:	98.3
R7:	91.8	R15:	93.1
R8:	84.4		



Test Conditions

Stabilization Time: 35M
 Operation Time: 1H 35M
 Sphere Temperature (°C): 25.0

REPORT NUMBER: SP1-2506-472-6

Measurement and Test Equipment			
Instrument	Identification Number	Calibration Date	Calibration Due Date
Photometer	76INCH SPHERE IN0058	6/16/2025	12/16/2025
Power Meter	XITRON INXT2011004	1/21/2025	1/21/2026
AC Power Source	CHROMA 61603 IN0063	10/22/2024	10/22/2025
DC Power Source	AGILENT E3634A IN0208	10/22/2024	10/22/2025
Sphere Thermometer	ONSET IN0085	10/22/2024	10/22/2025
Room Thermometer	ONSET IN0046	10/22/2024	10/22/2025

REPORT NUMBER: SP1-2506-472-6

CIE 1931 Chromaticity Diagram



CIE 1931 Chromaticity Diagram with 2017 ANSI 7-Step and 4-Step Quadrangles



Point lies inside the ANSI 3500K 4-step quadrangle

REPORT NUMBER: SP1-2506-472-6

Photopic Flux vs. Wavelength



Photopic Lumens: NR

λ (nm)	Power W [^] /nm	Lumens (φ/nm)	λ (nm)	Power W [^] /nm	Lumens (φ/nm)	λ (nm)	Power W [^] /nm	Lumens (φ/nm)	λ (nm)	Power W [^] /nm	Lumens (φ/nm)	λ (nm)	Power W [^] /nm	Lumens (φ/nm)
360	0	NR	490	140	NR	620	338	NR	750	8	NR	880	0	NR
365	0	NR	495	159	NR	625	339	NR	755	7	NR	885	0	NR
370	0	NR	500	182	NR	630	1000	NR	760	5	NR	890	0	NR
375	0	NR	505	202	NR	635	653	NR	765	5	NR	895	0	NR
380	0	NR	510	216	NR	640	222	NR	770	4	NR	900	0	NR
385	0	NR	515	228	NR	645	214	NR	775	3	NR	905	0	NR
390	0	NR	520	236	NR	650	185	NR	780	3	NR	910	0	NR
395	1	NR	525	242	NR	655	157	NR	785	3	NR	915	0	NR
400	2	NR	530	248	NR	660	133	NR	790	2	NR	920	0	NR
405	3	NR	535	253	NR	665	113	NR	795	2	NR	925	0	NR
410	4	NR	540	258	NR	670	103	NR	800	2	NR	930	0	NR
415	7	NR	545	264	NR	675	85	NR	805	1	NR	935	0	NR
420	13	NR	550	270	NR	680	72	NR	810	1	NR	940	0	NR
425	22	NR	555	278	NR	685	62	NR	815	1	NR	945	0	NR
430	38	NR	560	286	NR	690	53	NR	820	1	NR	950	0	NR
435	65	NR	565	295	NR	695	45	NR	825	1	NR	955	0	NR
440	108	NR	570	303	NR	700	39	NR	830	1	NR	960	0	NR
445	193	NR	575	311	NR	705	33	NR	835	1	NR	965	0	NR
450	312	NR	580	319	NR	710	28	NR	840	1	NR	970	0	NR
455	300	NR	585	326	NR	715	24	NR	845	0	NR	975	0	NR
460	214	NR	590	332	NR	720	20	NR	850	0	NR	980	0	NR
465	184	NR	595	333	NR	725	17	NR	855	0	NR	985	0	NR
470	153	NR	600	336	NR	730	15	NR	860	0	NR	990	0	NR
475	122	NR	605	337	NR	735	12	NR	865	0	NR	995	0	NR
480	115	NR	610	367	NR	740	10	NR	870	0	NR	1000	0	NR
485	125	NR	615	390	NR	745	9	NR	875	0	NR			

REPORT NUMBER: SP1-2506-472-6

Scotopic Flux vs. Wavelength



Scotopic Lumens: NR

S/P: 1.62

λ (nm)	Power W [^] /nm	Lumens (ϕ /nm)	λ (nm)	Power W [^] /nm	Lumens (ϕ /nm)	λ (nm)	Power W [^] /nm	Lumens (ϕ /nm)	λ (nm)	Power W [^] /nm	Lumens (ϕ /nm)	λ (nm)	Power W [^] /nm	Lumens (ϕ /nm)
360	0	NR	490	140	NR	620	338	NR	750	8	NR	880	0	NR
365	0	NR	495	159	NR	625	339	NR	755	7	NR	885	0	NR
370	0	NR	500	182	NR	630	1000	NR	760	5	NR	890	0	NR
375	0	NR	505	202	NR	635	653	NR	765	5	NR	895	0	NR
380	0	NR	510	216	NR	640	222	NR	770	4	NR	900	0	NR
385	0	NR	515	228	NR	645	214	NR	775	3	NR	905	0	NR
390	0	NR	520	236	NR	650	185	NR	780	3	NR	910	0	NR
395	1	NR	525	242	NR	655	157	NR	785	3	NR	915	0	NR
400	2	NR	530	248	NR	660	133	NR	790	2	NR	920	0	NR
405	3	NR	535	253	NR	665	113	NR	795	2	NR	925	0	NR
410	4	NR	540	258	NR	670	103	NR	800	2	NR	930	0	NR
415	7	NR	545	264	NR	675	85	NR	805	1	NR	935	0	NR
420	13	NR	550	270	NR	680	72	NR	810	1	NR	940	0	NR
425	22	NR	555	278	NR	685	62	NR	815	1	NR	945	0	NR
430	38	NR	560	286	NR	690	53	NR	820	1	NR	950	0	NR
435	65	NR	565	295	NR	695	45	NR	825	1	NR	955	0	NR
440	108	NR	570	303	NR	700	39	NR	830	1	NR	960	0	NR
445	193	NR	575	311	NR	705	33	NR	835	1	NR	965	0	NR
450	312	NR	580	319	NR	710	28	NR	840	1	NR	970	0	NR
455	300	NR	585	326	NR	715	24	NR	845	0	NR	975	0	NR
460	214	NR	590	332	NR	720	20	NR	850	0	NR	980	0	NR
465	184	NR	595	333	NR	725	17	NR	855	0	NR	985	0	NR
470	153	NR	600	336	NR	730	15	NR	860	0	NR	990	0	NR
475	122	NR	605	337	NR	735	12	NR	865	0	NR	995	0	NR
480	115	NR	610	367	NR	740	10	NR	870	0	NR	1000	0	NR
485	125	NR	615	390	NR	745	9	NR	875	0	NR			

REPORT NUMBER: SP1-2506-472-6

Melanopic Flux vs. Wavelength



Melanopic Lumens: NR

M/P: 3.3


λ (nm)	Power W [^] /nm	Lumens (ϕ /nm)	λ (nm)	Power W [^] /nm	Lumens (ϕ /nm)	λ (nm)	Power W [^] /nm	Lumens (ϕ /nm)	λ (nm)	Power W [^] /nm	Lumens (ϕ /nm)	λ (nm)	Power W [^] /nm	Lumens (ϕ /nm)
360	0	NR	490	140	NR	620	338	NR	750	8	NR	880	0	NR
365	0	NR	495	159	NR	625	339	NR	755	7	NR	885	0	NR
370	0	NR	500	182	NR	630	1000	NR	760	5	NR	890	0	NR
375	0	NR	505	202	NR	635	653	NR	765	5	NR	895	0	NR
380	0	NR	510	216	NR	640	222	NR	770	4	NR	900	0	NR
385	0	NR	515	228	NR	645	214	NR	775	3	NR	905	0	NR
390	0	NR	520	236	NR	650	185	NR	780	3	NR	910	0	NR
395	1	NR	525	242	NR	655	157	NR	785	3	NR	915	0	NR
400	2	NR	530	248	NR	660	133	NR	790	2	NR	920	0	NR
405	3	NR	535	253	NR	665	113	NR	795	2	NR	925	0	NR
410	4	NR	540	258	NR	670	103	NR	800	2	NR	930	0	NR
415	7	NR	545	264	NR	675	85	NR	805	1	NR	935	0	NR
420	13	NR	550	270	NR	680	72	NR	810	1	NR	940	0	NR
425	22	NR	555	278	NR	685	62	NR	815	1	NR	945	0	NR
430	38	NR	560	286	NR	690	53	NR	820	1	NR	950	0	NR
435	65	NR	565	295	NR	695	45	NR	825	1	NR	955	0	NR
440	108	NR	570	303	NR	700	39	NR	830	1	NR	960	0	NR
445	193	NR	575	311	NR	705	33	NR	835	1	NR	965	0	NR
450	312	NR	580	319	NR	710	28	NR	840	1	NR	970	0	NR
455	300	NR	585	326	NR	715	24	NR	845	0	NR	975	0	NR
460	214	NR	590	332	NR	720	20	NR	850	0	NR	980	0	NR
465	184	NR	595	333	NR	725	17	NR	855	0	NR	985	0	NR
470	153	NR	600	336	NR	730	15	NR	860	0	NR	990	0	NR
475	122	NR	605	337	NR	735	12	NR	865	0	NR	995	0	NR
480	115	NR	610	367	NR	740	10	NR	870	0	NR	1000	0	NR
485	125	NR	615	390	NR	745	9	NR	875	0	NR			

Summary

$R_f = 91.3$
 $R_g = 100$
 $CIE R_a = 94.6$
 $R_9 = 63.8$



Color Vector Graphics



Individual Sample Fidelity Index ($R_{f,i}$)

CES01 = 86	CES26 = 94	CES51 = 97	CES76 = 90
CES02 = 63	CES27 = 92	CES52 = 98	CES77 = 86
CES03 = 31	CES28 = 97	CES53 = 98	CES78 = 86
CES04 = 70	CES29 = 97	CES54 = 93	CES79 = 90
CES05 = 50	CES30 = 92	CES55 = 92	CES80 = 91
CES06 = 51	CES31 = 97	CES56 = 96	CES81 = 74
CES07 = 43	CES32 = 89	CES57 = 94	CES82 = 96
CES08 = 41	CES33 = 99	CES58 = 95	CES83 = 94
CES09 = 29	CES34 = 94	CES59 = 98	CES84 = 95
CES10 = 75	CES35 = 97	CES60 = 92	CES85 = 79
CES11 = 58	CES36 = 81	CES61 = 93	CES86 = 79
CES12 = 64	CES37 = 96	CES62 = 86	CES87 = 92
CES13 = 44	CES38 = 87	CES63 = 94	CES88 = 98
CES14 = 74	CES39 = 99	CES64 = 91	CES89 = 84
CES15 = 72	CES40 = 97	CES65 = 90	CES90 = 96
CES16 = 48	CES41 = 96	CES66 = 89	CES91 = 75
CES17 = 49	CES42 = 94	CES67 = 88	CES92 = 76
CES18 = 56	CES43 = 93	CES68 = 89	CES93 = 86
CES19 = 71	CES44 = 99	CES69 = 90	CES94 = 74
CES20 = 67	CES45 = 97	CES70 = 88	CES95 = 83
CES21 = 86	CES46 = 97	CES71 = 83	CES96 = 92
CES22 = 78	CES47 = 91	CES72 = 94	CES97 = 96
CES23 = 91	CES48 = 91	CES73 = 83	CES98 = 95
CES24 = 90	CES49 = 96	CES74 = 90	CES99 = 92
CES25 = 71	CES50 = 98	CES75 = 85	



Color Rendition by Hue-Angle Bin



Measure Comparisons



(END OF REPORT)