Cooper Lighting Solutions Photometric Lab
1121 Highway 74 South
Peachtree City, GA 30269

Scaled data based on original data using

LM-79-2019 Approved Method: Electrical and Photometric Measurements of Solid-State Lighting Products

Test Report Prepared for

Cooper Lighting Solutions

Brand: METALUX

Report Number: P1594577

Luminaire Tested: FLXB-1224-N-MED-5700K

Issue Date: 10/2/2026

Cooper Lighting Solutions Photometric Lab
1121 Highway 74 South
Peachtree City, GA 30269

Scaled Data Report

Test Information

Test Method:	LM-79-2019
Report Number:	P1594577
	TEST IS SCALED FROM IESNA LM-79-08 TEST DATA (A2601782A001)
Test Lab:	INNOVATION CENTER
Issue Date:	10/2/2026
Manufacturer:	COOPER LIGHTING SOLUTIONS
Product Line:	METALUX
Catalog Number:	FLXB-1224-N-MED-5700K
Description:	1224 FlexBay Linear High bay at N beam, MED lumen, 5700K CCT settings
Light Source:	-
Ballast/Driver:	-

Summary

Lumens per Lamp:	N/A
Luminaire Lumens:	18645.0 lumens
Efficiency:	N/A
Efficacy:	160.7 lumens/watt
Spacing Criteria (0/90/45):	1.53 / 1 / 1.06
Luminous Opening:	Rectangular (W 1.04' x L: 1.19' x H: 0')
CIE Type:	Direct


Input Watts (W):	116
Input Voltage (V):	NR
Input Current (Ain):	NR
Voltage Rise (V):	NR
Power Factor:	NR
Total Harmonic Distortion (THDi):	NR
Frequency (hertz):	60
Stabilization Time:	NR
Operation Time:	NR
Ambient Temperature (°C):	NR
Test Distance:	28.75 FT

Cooper Lighting Solutions Photometric Lab
1121 Highway 74 South
Peachtree City, GA 30269

Scaled Data Report

TEST NUMBER: P1594577
CATALOG NUMBER: FLXB-1224-N-MED-5700K

Luminous Intensity Polar Plot



Cooper Lighting Solutions Photometric Lab
1121 Highway 74 South
Peachtree City, GA 30269

Scaled Data Report

TEST NUMBER: P1594577
CATALOG NUMBER: FLXB-1224-N-MED-5700K

COEFFICIENT OF UTILIZATION - ZONAL CAVITY METHOD:

RF	20				20				20			20			20			20
RC	80				70				50			30			10			0
RW	70	50	30	10	70	50	30	10	50	30	10	50	30	10	50	30	10	0
RCR																		
0	119	119	119	119	116	116	116	116	111	111	111	106	106	106	102	102	102	100
1	112	108	105	102	109	106	103	100	102	99	97	98	96	94	94	93	91	90
2	104	98	92	88	102	96	91	87	93	89	85	89	86	83	87	84	81	80
3	97	89	82	77	95	87	81	76	84	79	75	82	78	74	79	76	73	71
4	90	81	74	68	88	80	73	68	77	72	67	75	70	66	73	69	65	64
5	84	74	67	61	83	73	66	61	71	65	60	69	64	60	67	63	59	57
6	79	68	61	55	77	67	60	55	65	59	55	64	58	54	62	58	54	52
7	74	63	55	50	73	62	55	50	61	54	50	59	54	49	58	53	49	47
8	70	58	51	46	68	58	51	46	56	50	46	55	49	45	54	49	45	43
9	66	54	47	42	64	54	47	42	52	46	42	51	46	42	51	45	42	40
10	62	50	44	39	61	50	43	39	49	43	39	48	43	39	47	42	38	37

AVERAGE LUMINANCE (cd/sqm):

	0°	90°	180°	270°
0°	99643	99643	99643	99643
5°	100069	99593	100069	99593
10°	101221	99136	101221	99136
15°	103275	97421	103275	97421
20°	106136	93224	106136	93224
25°	110212	84568	110212	84568
30°	115559	63069	115559	63069
35°	122094	29272	122094	29272
40°	129256	9141	129256	9141
45°	133743	6335	133743	6335
50°	135791	6226	135791	6226
55°	126781	6137	126781	6137
60°	113692	6491	113692	6491
65°	88753	6290	88753	6290
70°	66819	6449	66819	6449
75°	40966	4996	40966	4996
80°	26964	3603	26964	3603
85°	12949	1647	12949	1647

MAXIMUM LUMINANCE 45°-90°:

Horizontal Angle: 0°
Vertical Angle: 50°
Luminance: 135791 cd/sqm

Cooper Lighting Solutions Photometric Lab
1121 Highway 74 South
Peachtree City, GA 30269

Scaled Data Report

TEST NUMBER: P1594577
CATALOG NUMBER: FLXB-1224-N-MED-5700K

ZONAL LUMENS:

Zone	Lumens	% Fixture
0°-10°	1086.3	5.8
10°-20°	3135.9	16.8
20°-30°	4643.0	24.9
30°-40°	4336.5	23.3
40°-50°	2454.4	13.2
50°-60°	1541.1	8.3
60°-70°	972.0	5.2
70°-80°	408.7	2.2
80°-90°	67.2	0.4
90°-100°	0.0	0.0
100°-110°	0.0	0.0
110°-120°	0.0	0.0
120°-130°	0.0	0.0
130°-140°	0.0	0.0
140°-150°	0.0	0.0
150°-160°	0.0	0.0
160°-170°	0.0	0.0
170°-180°	0.0	0.0
0°-30°	8865.2	47.5
0°-40°	13201.7	70.8
0°-60°	17197.1	92.2
0°-90°	18645.0	100.0
90°-120°	0.0	0.0
90°-150°	0.0	0.0
90°-180°	0.0	0.0
0°-180°	18645.0	100.0

CANDELA DISTRIBUTION:

	0°	90°	180°	270°	360°	Flux
0°	11451	11451	11451	11451	11451	
5°	11456	11402	11456	11402	11456	1094
15°	11464	10814	11464	10814	11464	3249
25°	11479	8808	11479	8808	11479	5315
35°	11494	2756	11494	2756	11494	7205
45°	10868	515	10868	515	10868	8351
55°	8357	404	8357	404	8357	7444
65°	4311	306	4311	306	4311	4346
75°	1218	149	1218	149	1218	1413
85°	130	16	130	16	130	201
90°	15	2	15	2	15	

Cooper Lighting Solutions Photometric Lab
1121 Highway 74 South
Peachtree City, GA 30269

Scaled Data Report

TEST NUMBER: P1594577
CATALOG NUMBER: FLXB-1224-N-MED-5700K

CANDELA DISTRIBUTION (FULL):

	0°	30°	60°	90°	120°	150°	180°	210°	240°	270°	300°
0°	11451.3	11451.3	11451.3	11451.3	11451.3	11451.3	11451.3	11451.3	11451.3	11451.3	11451.3
0.5°	11451.3	11451.3	11451.3	11451.3	11451.3	11451.3	11451.3	11451.3	11451.3	11451.3	11451.3
1°	11472.9	11462.7	11448.6	11489.4	11358.3	11448.2	11472.9	11462.7	11448.6	11489.4	11358.3
1.5°	11472.9	11468.1	11452.1	11461.3	11358.3	11467.1	11472.9	11468.1	11452.1	11461.3	11358.3
2°	11446.2	11475.8	11426.3	11461.3	11358.3	11462.7	11446.2	11475.8	11426.3	11461.3	11358.3
2.5°	11446.2	11475.8	11415.1	11450.1	11358.3	11462.7	11446.2	11475.8	11415.1	11450.1	11358.3
3°	11471.0	11464.7	11420.5	11450.1	11358.3	11463.2	11471.0	11464.7	11420.5	11450.1	11358.3
3.5°	11471.0	11459.3	11410.8	11436.5	11321.9	11463.2	11471.0	11459.3	11410.8	11436.5	11321.9
4°	11449.6	11475.8	11398.6	11436.5	11385.0	11448.6	11449.6	11475.8	11398.6	11436.5	11385.0
4.5°	11449.6	11469.5	11358.8	11410.8	11392.3	11462.3	11449.6	11469.5	11358.8	11410.8	11392.3
5°	11456.4	11453.5	11376.8	11402.0	11357.8	11443.8	11456.4	11453.5	11376.8	11402.0	11357.8
5.5°	11466.6	11433.6	11385.5	11394.7	11357.8	11414.2	11466.6	11433.6	11385.5	11394.7	11357.8
6°	11466.6	11438.5	11366.6	11386.5	11330.2	11436.0	11466.6	11438.5	11366.6	11386.5	11330.2
6.5°	11444.3	11443.3	11333.1	11363.7	11335.5	11450.1	11444.3	11443.3	11333.1	11363.7	11335.5
7°	11444.3	11444.8	11336.9	11331.1	11326.3	11438.5	11444.3	11444.8	11336.9	11331.1	11326.3
7.5°	11471.0	11412.7	11320.4	11331.1	11304.4	11414.7	11471.0	11412.7	11320.4	11331.1	11304.4
8°	11471.0	11412.7	11293.7	11306.8	11249.5	11414.7	11471.0	11412.7	11293.7	11306.8	11249.5
8.5°	11446.2	11424.9	11269.4	11306.8	11261.2	11404.0	11446.2	11424.9	11269.4	11306.8	11261.2
9°	11465.2	11425.3	11219.9	11244.7	11259.2	11415.1	11465.2	11425.3	11219.9	11244.7	11259.2
9.5°	11455.9	11400.1	11233.5	11231.1	11187.9	11391.3	11455.9	11400.1	11233.5	11231.1	11187.9
10°	11455.9	11374.3	11231.1	11219.9	11187.9	11356.4	11455.9	11374.3	11231.1	11219.9	11187.9
10.5°	11461.3	11390.4	11199.5	11181.1	11161.2	11376.8	11461.3	11390.4	11199.5	11181.1	11161.2
11°	11460.8	11401.1	11143.2	11143.7	11161.2	11376.8	11460.8	11401.1	11143.2	11143.7	11161.2
11.5°	11443.3	11391.8	11146.6	11103.8	11109.2	11362.7	11443.3	11391.8	11146.6	11103.8	11109.2
12°	11471.5	11366.6	11125.2	11103.8	11087.8	11343.7	11471.5	11366.6	11125.2	11103.8	11087.8
12.5°	11471.5	11356.4	11112.6	11029.5	11032.0	11343.7	11471.5	11356.4	11112.6	11029.5	11032.0
13°	11441.8	11352.5	11062.6	11029.5	11032.0	11324.3	11441.8	11352.5	11062.6	11029.5	11032.0
13.5°	11441.8	11352.5	11037.8	10946.5	11002.3	11324.3	11441.8	11352.5	11037.8	10946.5	11002.3
14°	11466.6	11326.3	10974.7	10946.5	10969.8	11310.7	11466.6	11326.3	10974.7	10946.5	10969.8
14.5°	11466.6	11299.6	10941.6	10873.2	10910.5	11276.7	11466.6	11299.6	10941.6	10873.2	10910.5
15°	11464.2	11316.5	10921.7	10814.4	10857.1	11286.5	11464.2	11316.5	10921.7	10814.4	10857.1
15.5°	11453.0	11313.2	10857.1	10766.3	10857.1	11286.5	11453.0	11313.2	10857.1	10766.3	10857.1
16°	11453.0	11290.8	10846.0	10712.9	10764.9	11260.7	11453.0	11290.8	10846.0	10712.9	10764.9
16.5°	11477.8	11259.7	10807.6	10684.2	10736.7	11227.7	11477.8	11259.7	10807.6	10684.2	10736.7
17°	11477.8	11249.0	10783.3	10627.9	10660.9	11238.9	11477.8	11249.0	10783.3	10627.9	10660.9
17.5°	11446.7	11261.2	10712.9	10554.6	10653.6	11212.2	11446.7	11261.2	10712.9	10554.6	10653.6
18°	11446.7	11261.2	10605.6	10429.3	10598.3	11212.2	11446.7	11261.2	10605.6	10429.3	10598.3
18.5°	11473.4	11211.6	10588.1	10429.3	10552.1	11170.9	11473.4	11211.6	10588.1	10429.3	10552.1
19°	11473.4	11181.5	10525.4	10352.1	10457.4	11170.9	11473.4	11181.5	10525.4	10352.1	10457.4
19.5°	11461.8	11201.5	10474.4	10255.9	10447.7	11139.8	11461.8	11201.5	10474.4	10255.9	10447.7
20°	11461.8	11195.1	10381.2	10067.5	10373.4	11123.3	11461.8	11195.1	10381.2	10067.5	10373.4
20.5°	11458.4	11168.9	10358.9	10067.5	10327.8	11102.9	11458.4	11168.9	10358.9	10067.5	10327.8
21°	11481.2	11123.3	10288.4	9909.6	10229.7	11054.3	11481.2	11123.3	10288.4	9909.6	10229.7
21.5°	11481.2	11114.0	10241.8	9773.7	10091.8	11065.5	11481.2	11114.0	10241.8	9773.7	10091.8
22°	11453.5	11099.0	10141.3	9665.4	10061.2	11036.3	11453.5	11099.0	10141.3	9665.4	10061.2

Cooper Lighting Solutions Photometric Lab
1121 Highway 74 South
Peachtree City, GA 30269

Scaled Data Report

TEST NUMBER: P1594577
CATALOG NUMBER: FLXB-1224-N-MED-5700K

CANDELA DISTRIBUTION (continued):

	0°	30°	60°	90°	120°	150°	180°	210°	240°	270°	300°
22.5°	11453.5	11091.2	10094.7	9539.6	9962.1	11018.9	11453.5	11091.2	10094.7	9539.6	9962.1
23°	11488.5	11043.6	9988.3	9441.5	9900.4	10968.3	11488.5	11043.6	9988.3	9441.5	9900.4
23.5°	11488.5	11043.6	9830.0	9260.8	9761.5	10968.3	11488.5	11043.6	9830.0	9260.8	9761.5
24°	11472.5	10998.9	9747.4	9154.5	9723.1	10909.6	11472.5	10998.9	9747.4	9154.5	9723.1
24.5°	11472.5	10972.2	9612.9	8949.0	9604.2	10883.9	11472.5	10972.2	9612.9	8949.0	9604.2
25°	11479.2	10940.7	9545.4	8808.2	9375.9	10856.6	11479.2	10940.7	9545.4	8808.2	9375.9
25.5°	11479.2	10884.8	9424.0	8447.8	9375.9	10795.0	11479.2	10884.8	9424.0	8447.8	9375.9
26°	11506.9	10868.8	9321.5	8447.8	9140.9	10793.0	11506.9	10868.8	9321.5	8447.8	9140.9
26.5°	11472.0	10844.0	9166.6	8008.3	9140.9	10739.1	11472.0	10844.0	9166.6	8008.3	9140.9
27°	11472.0	10812.5	9054.9	7747.0	8884.4	10719.2	11472.0	10812.5	9054.9	7747.0	8884.4
27.5°	11503.5	10759.5	8898.5	7589.7	8764.5	10645.4	11503.5	10759.5	8898.5	7589.7	8764.5
28°	11503.5	10715.3	8776.1	7294.9	8559.0	10563.3	11503.5	10715.3	8776.1	7294.9	8559.0
28.5°	11489.4	10620.1	8601.3	7119.6	8446.4	10544.4	11489.4	10620.1	8601.3	7119.6	8446.4
29°	11489.4	10620.1	8214.7	6816.1	8240.0	10544.4	11489.4	10620.1	8214.7	6816.1	8240.0
29.5°	11501.1	10493.9	8030.7	6603.8	8072.9	10439.0	11501.1	10493.9	8030.7	6603.8	8072.9
30°	11501.1	10424.4	7828.6	6277.0	7821.4	10350.1	11501.1	10424.4	7828.6	6277.0	7821.4
30.5°	11512.8	10357.4	7584.4	6067.7	7378.0	10327.3	11512.8	10357.4	7584.4	6067.7	7378.0
31°	11487.5	10309.3	7331.8	5450.4	7378.0	10256.4	11487.5	10309.3	7331.8	5450.4	7378.0
31.5°	11487.5	10207.8	7067.6	5450.4	6871.4	10196.2	11487.5	10207.8	7067.6	5450.4	6871.4
32°	11522.0	10130.1	6811.7	4814.7	6616.0	10101.0	11522.0	10130.1	6811.7	4814.7	6616.0
32.5°	11522.0	10007.3	6527.6	4400.9	6295.9	10043.7	11522.0	10007.3	6527.6	4400.9	6295.9
33°	11489.4	9780.0	6244.5	4124.6	6030.8	9867.4	11489.4	9780.0	6244.5	4124.6	6030.8
33.5°	11489.4	9780.0	5631.1	3718.1	5705.4	9867.4	11489.4	9780.0	5631.1	3718.1	5705.4
34°	11495.3	9532.8	5310.6	3419.0	5411.1	9672.6	11495.3	9532.8	5310.6	3419.0	5411.1
34.5°	11495.3	9429.8	4998.8	3419.0	5059.5	9672.6	11495.3	9429.8	4998.8	3419.0	5059.5
35°	11493.8	9234.1	4635.5	2755.6	4771.0	9451.7	11493.8	9234.1	4635.5	2755.6	4771.0
35.5°	11493.8	9149.1	4291.7	2179.1	4414.1	9325.9	11493.8	9149.1	4291.7	2179.1	4414.1
36°	11461.8	8881.0	3902.7	2179.1	3744.3	9175.8	11461.8	8881.0	3902.7	2179.1	3744.3
36.5°	11479.7	8765.0	3560.8	1713.4	3744.3	9018.0	11479.7	8765.0	3560.8	1713.4	3744.3
37°	11479.7	8456.1	3126.6	1628.9	3118.8	8867.4	11479.7	8456.1	3126.6	1628.9	3118.8
37.5°	11433.1	8355.1	2791.5	1318.5	2733.7	8692.6	11433.1	8355.1	2791.5	1318.5	2733.7
38°	11433.1	8003.5	2324.3	1294.2	2553.5	8503.7	11433.1	8003.5	2324.3	1294.2	2553.5
38.5°	11424.4	7458.1	1959.1	1013.1	2114.5	8073.4	11424.4	7458.1	1959.1	1013.1	2114.5
39°	11424.4	7458.1	1524.9	1007.7	2013.0	8073.4	11424.4	7458.1	1524.9	1007.7	2013.0
39.5°	11379.2	6883.6	1204.4	803.3	1571.5	7568.3	11379.2	6883.6	1204.4	803.3	1571.5
40°	11379.2	6723.8	1044.6	804.7	1124.8	7311.4	11379.2	6723.8	1044.6	804.7	1124.8
40.5°	11318.5	6251.7	741.6	675.5	1106.8	6964.2	11318.5	6251.7	741.6	675.5	1106.8
41°	11324.3	6056.5	741.6	610.5	1106.8	6644.1	11324.3	6056.5	741.6	610.5	1106.8
41.5°	11280.1	5575.7	576.5	610.5	815.4	6277.0	11280.1	5575.7	576.5	610.5	815.4
42°	11158.2	5364.9	576.5	578.9	815.4	5913.7	11158.2	5364.9	576.5	578.9	815.4
42.5°	11158.2	4907.5	515.8	575.0	631.8	5496.6	11158.2	4907.5	515.8	575.0	631.8
43°	11101.4	4654.0	515.8	558.0	530.3	4646.2	11101.4	4654.0	515.8	558.0	530.3
43.5°	11101.4	4253.3	502.2	547.8	523.5	4646.2	11101.4	4253.3	502.2	547.8	523.5
44°	10979.5	3668.6	494.9	528.9	494.9	3751.6	10979.5	3668.6	494.9	528.9	494.9
44.5°	10979.5	3668.6	491.5	514.8	491.5	3751.6	10979.5	3668.6	491.5	514.8	491.5

Cooper Lighting Solutions Photometric Lab
1121 Highway 74 South
Peachtree City, GA 30269

Scaled Data Report

TEST NUMBER: P1594577
CATALOG NUMBER: FLXB-1224-N-MED-5700K

CANDELA DISTRIBUTION (continued):

	0°	30°	60°	90°	120°	150°	180°	210°	240°	270°	300°
45°	10868.3	3155.3	482.3	514.8	484.2	2893.5	10868.3	3155.3	482.3	514.8	484.2
45.5°	10868.3	2755.6	482.3	497.3	481.3	2549.6	10868.3	2755.6	482.3	497.3	481.3
46°	10743.0	2642.9	473.0	497.3	472.5	2134.9	10743.0	2642.9	473.0	497.3	472.5
46.5°	10568.7	2223.3	473.0	481.8	472.5	1885.3	10568.7	2223.3	473.0	481.8	472.5
47°	10568.7	2147.5	463.8	481.8	466.7	1523.5	10568.7	2147.5	463.8	481.8	466.7
47.5°	10427.8	1737.2	463.8	476.4	459.9	1333.1	10427.8	1737.2	463.8	476.4	459.9
48°	10427.8	1686.2	458.0	471.6	453.6	1095.6	10427.8	1686.2	458.0	471.6	453.6
48.5°	10229.2	1294.7	458.0	473.0	450.7	800.8	10229.2	1294.7	458.0	473.0	450.7
49°	10229.2	1294.7	450.2	468.2	445.8	800.8	10229.2	1294.7	450.2	468.2	445.8
49.5°	10031.0	1004.8	453.1	465.2	445.3	606.1	10031.0	1004.8	453.1	465.2	445.3
50°	10031.0	794.5	453.1	459.9	443.9	571.1	10031.0	794.5	453.1	459.9	443.9
50.5°	9812.0	780.9	460.9	451.7	448.7	509.9	9812.0	780.9	460.9	451.7	448.7
51°	9812.0	612.9	460.9	438.0	449.7	494.9	9812.0	612.9	460.9	438.0	449.7
51.5°	9548.3	601.2	463.8	438.0	461.4	454.1	9548.3	601.2	463.8	438.0	461.4
52°	9303.5	482.3	463.8	435.6	461.4	443.9	9303.5	482.3	463.8	435.6	461.4
52.5°	9303.5	471.1	457.5	432.7	459.4	419.1	9303.5	471.1	457.5	432.7	459.4
53°	8979.1	416.2	457.5	428.8	453.1	411.8	8979.1	416.2	457.5	428.8	453.1
53.5°	8979.1	408.0	434.2	418.2	444.4	397.3	8979.1	408.0	434.2	418.2	444.4
54°	8684.3	375.4	424.5	417.6	427.4	378.8	8684.3	375.4	424.5	417.6	427.4
54.5°	8684.3	375.4	410.4	405.0	414.7	378.8	8684.3	375.4	410.4	405.0	414.7
55°	8357.0	355.5	389.5	404.5	399.7	361.3	8357.0	355.5	389.5	404.5	399.7
55.5°	8357.0	348.7	389.5	394.3	393.4	354.0	8357.0	348.7	389.5	394.3	393.4
56°	7998.1	342.9	376.9	390.9	378.3	343.8	7998.1	342.9	376.9	390.9	378.3
56.5°	7998.1	335.6	376.9	386.1	378.3	335.6	7998.1	335.6	376.9	386.1	378.3
57°	7660.1	331.7	371.0	386.1	369.6	327.3	7660.1	331.7	371.0	386.1	369.6
57.5°	7276.5	324.4	371.0	387.6	368.6	318.6	7276.5	324.4	371.0	387.6	368.6
58°	7276.5	324.4	364.7	384.1	364.7	311.8	7276.5	324.4	364.7	384.1	364.7
58.5°	6914.6	323.0	364.7	384.6	357.9	298.2	6914.6	323.0	364.7	384.6	357.9
59°	6914.6	323.0	355.5	378.3	354.0	298.2	6914.6	323.0	355.5	378.3	354.0
59.5°	6532.9	320.5	347.2	373.0	351.1	285.1	6532.9	320.5	347.2	373.0	351.1
60°	6532.9	320.5	347.2	373.0	349.7	285.1	6532.9	320.5	347.2	373.0	349.7
60.5°	6154.1	311.8	345.3	364.2	342.4	277.3	6154.1	311.8	345.3	364.2	342.4
61°	6154.1	303.5	345.3	354.5	340.4	271.0	6154.1	303.5	345.3	354.5	340.4
61.5°	5784.6	302.1	345.8	347.7	341.4	273.4	5784.6	302.1	345.8	347.7	341.4
62°	5395.5	294.3	345.8	345.8	341.4	268.6	5395.5	294.3	345.8	345.8	341.4
62.5°	5395.5	288.5	342.4	335.6	334.6	274.4	5395.5	288.5	342.4	335.6	334.6
63°	5030.8	281.7	342.4	323.4	334.1	272.0	5030.8	281.7	342.4	323.4	334.1
63.5°	5030.8	277.8	324.4	323.4	327.8	272.9	5030.8	277.8	324.4	323.4	327.8
64°	4663.2	272.0	324.4	314.7	321.0	265.7	4663.2	272.0	324.4	314.7	321.0
64.5°	4663.2	272.0	306.0	314.7	316.2	265.7	4663.2	272.0	306.0	314.7	316.2
65°	4310.6	274.4	291.9	305.5	302.1	267.1	4310.6	274.4	291.9	305.5	302.1
65.5°	4310.6	272.0	291.9	305.5	299.6	271.5	4310.6	272.0	291.9	305.5	299.6
66°	3970.2	290.9	286.5	298.7	289.0	266.1	3970.2	290.9	286.5	298.7	289.0
66.5°	3970.2	289.4	286.5	296.3	289.0	272.0	3970.2	289.4	286.5	296.3	289.0
67°	3608.9	324.4	282.2	290.9	277.3	268.1	3608.9	324.4	282.2	290.9	277.3

Cooper Lighting Solutions Photometric Lab
1121 Highway 74 South
Peachtree City, GA 30269

Scaled Data Report

TEST NUMBER: P1594577
CATALOG NUMBER: FLXB-1224-N-MED-5700K

CANDELA DISTRIBUTION (continued):

	0°	30°	60°	90°	120°	150°	180°	210°	240°	270°	300°
67.5°	3281.0	332.2	282.2	285.6	277.3	274.9	3281.0	332.2	282.2	285.6	277.3
68°	3281.0	364.7	273.4	280.7	268.1	276.8	3281.0	364.7	273.4	280.7	268.1
68.5°	2938.2	364.7	273.4	268.6	267.6	290.9	2938.2	364.7	273.4	268.6	267.6
69°	2938.2	343.3	261.8	268.6	263.2	290.9	2938.2	343.3	261.8	268.6	263.2
69.5°	2626.4	303.5	256.9	253.5	256.4	308.9	2626.4	303.5	256.9	253.5	256.4
70°	2626.4	303.5	251.6	253.5	245.7	308.9	2626.4	303.5	251.6	253.5	245.7
70.5°	2340.3	288.0	235.1	233.6	240.9	338.5	2340.3	288.0	235.1	233.6	240.9
71°	2340.3	291.9	235.1	233.6	229.2	352.6	2340.3	291.9	235.1	233.6	229.2
71.5°	2062.1	277.8	213.2	222.9	213.7	378.3	2062.1	277.8	213.2	222.9	213.7
72°	1989.2	280.7	213.2	218.5	213.7	381.2	1989.2	280.7	213.2	218.5	213.7
72.5°	1820.7	268.1	189.4	210.8	191.4	371.0	1820.7	268.1	189.4	210.8	191.4
73°	1598.3	269.5	189.4	198.6	191.4	374.4	1598.3	269.5	189.4	198.6	191.4
73.5°	1598.3	257.9	177.3	198.6	165.6	334.6	1598.3	257.9	177.3	198.6	165.6
74°	1401.6	260.8	177.3	187.5	153.5	294.3	1401.6	260.8	177.3	187.5	153.5
74.5°	1401.6	260.8	164.6	187.5	147.1	294.3	1401.6	260.8	164.6	187.5	147.1
75°	1218.5	261.8	143.3	148.6	143.8	264.2	1218.5	261.8	143.3	148.6	143.8
75.5°	1218.5	268.1	143.3	148.6	138.4	264.2	1218.5	268.1	143.3	148.6	138.4
76°	1053.4	254.5	131.1	120.0	135.0	240.9	1053.4	254.5	131.1	120.0	135.0
76.5°	941.7	243.8	131.1	112.2	129.2	227.3	941.7	243.8	131.1	112.2	129.2
77°	911.6	244.3	120.0	110.2	113.6	213.2	911.6	244.3	120.0	110.2	113.6
77.5°	774.1	225.8	120.0	101.0	113.6	204.0	774.1	225.8	120.0	101.0	113.6
78°	774.1	208.8	105.9	95.2	98.6	205.9	774.1	208.8	105.9	95.2	98.6
78.5°	651.3	193.3	105.9	80.1	92.8	196.7	651.3	193.3	105.9	80.1	92.8
79°	651.3	173.4	86.0	80.1	87.4	184.5	651.3	173.4	86.0	80.1	87.4
79.5°	538.1	160.3	86.0	71.9	80.1	161.7	538.1	160.3	86.0	71.9	80.1
80°	538.1	148.6	63.6	71.9	73.8	161.7	538.1	148.6	63.6	71.9	73.8
80.5°	443.4	130.6	52.4	55.4	62.2	149.6	443.4	130.6	52.4	55.4	62.2
81°	443.4	120.0	52.4	55.4	57.8	141.8	443.4	120.0	52.4	55.4	57.8
81.5°	361.3	109.8	40.3	43.7	46.1	129.2	361.3	109.8	40.3	43.7	46.1
82°	361.3	103.4	40.3	42.2	43.7	113.2	361.3	103.4	40.3	42.2	43.7
82.5°	288.0	98.6	28.7	38.9	36.9	91.8	288.0	98.6	28.7	38.9	36.9
83°	226.8	89.4	28.7	30.6	36.9	79.2	226.8	89.4	28.7	30.6	36.9
83.5°	226.8	86.9	24.3	28.7	25.7	66.5	226.8	86.9	24.3	28.7	25.7
84°	173.4	77.7	24.3	20.4	19.9	49.1	173.4	77.7	24.3	20.4	19.9
84.5°	173.4	75.8	19.9	20.4	17.0	49.1	173.4	75.8	19.9	20.4	17.0
85°	129.7	67.0	16.0	16.5	14.6	28.7	129.7	67.0	16.0	16.5	14.6
85.5°	129.7	51.0	13.1	16.5	14.1	28.7	129.7	51.0	13.1	16.5	14.1
86°	94.7	50.5	6.3	14.1	12.1	16.0	94.7	50.5	6.3	14.1	12.1
86.5°	94.7	37.9	6.3	14.1	11.2	12.1	94.7	37.9	6.3	14.1	11.2
87°	69.0	37.9	5.4	10.2	6.8	9.7	69.0	37.9	5.4	10.2	6.8
87.5°	69.0	28.7	5.4	4.8	6.8	5.8	69.0	28.7	5.4	4.8	6.8
88°	49.5	28.7	3.9	4.8	3.9	3.4	49.5	28.7	3.9	4.8	3.9
88.5°	35.0	18.9	3.9	3.4	3.4	2.9	35.0	18.9	3.9	3.4	3.4
89°	35.0	18.9	1.9	3.4	3.4	2.9	35.0	18.9	1.9	3.4	3.4
89.5°	24.3	10.7	1.9	2.9	2.4	1.9	24.3	10.7	1.9	2.9	2.4

Cooper Lighting Solutions Photometric Lab
1121 Highway 74 South
Peachtree City, GA 30269

Scaled Data Report

TEST NUMBER: P1594577
CATALOG NUMBER: FLXB-1224-N-MED-5700K

CANDELA DISTRIBUTION (continued):

	0°	30°	60°	90°	120°	150°	180°	210°	240°	270°	300°
90°	*15.0*	6.3	1.0	1.9	1.5	1.5	15.0	6.3	1.0	1.9	1.5

Cooper Lighting Solutions Photometric Lab
1121 Highway 74 South
Peachtree City, GA 30269

Scaled Data Report

TEST NUMBER: P1594577
CATALOG NUMBER: FLXB-1224-N-MED-5700K

CANDELA DISTRIBUTION (continued):

	330°	360°
0°	11451.3	11451.3
0.5°	11451.3	11451.3
1°	11448.2	11472.9
1.5°	11467.1	11472.9
2°	11462.7	11446.2
2.5°	11462.7	11446.2
3°	11463.2	11471.0
3.5°	11463.2	11471.0
4°	11448.6	11449.6
4.5°	11462.3	11449.6
5°	11443.8	11456.4
5.5°	11414.2	11466.6
6°	11436.0	11466.6
6.5°	11450.1	11444.3
7°	11438.5	11444.3
7.5°	11414.7	11471.0
8°	11414.7	11471.0
8.5°	11404.0	11446.2
9°	11415.1	11465.2
9.5°	11391.3	11455.9
10°	11356.4	11455.9
10.5°	11376.8	11461.3
11°	11376.8	11460.8
11.5°	11362.7	11443.3
12°	11343.7	11471.5
12.5°	11343.7	11471.5
13°	11324.3	11441.8
13.5°	11324.3	11441.8
14°	11310.7	11466.6
14.5°	11276.7	11466.6
15°	11286.5	11464.2
15.5°	11286.5	11453.0
16°	11260.7	11453.0
16.5°	11227.7	11477.8
17°	11238.9	11477.8
17.5°	11212.2	11446.7
18°	11212.2	11446.7
18.5°	11170.9	11473.4
19°	11170.9	11473.4
19.5°	11139.8	11461.8
20°	11123.3	11461.8
20.5°	11102.9	11458.4
21°	11054.3	11481.2
21.5°	11065.5	11481.2
22°	11036.3	11453.5

TEST NUMBER: P1594577
CATALOG NUMBER: FLXB-1224-N-MED-5700K

CANDELA DISTRIBUTION (continued):

	330°	360°
22.5°	11018.9	11453.5
23°	10968.3	11488.5
23.5°	10968.3	11488.5
24°	10909.6	11472.5
24.5°	10883.9	11472.5
25°	10856.6	11479.2
25.5°	10795.0	11479.2
26°	10793.0	11506.9
26.5°	10739.1	11472.0
27°	10719.2	11472.0
27.5°	10645.4	11503.5
28°	10563.3	11503.5
28.5°	10544.4	11489.4
29°	10544.4	11489.4
29.5°	10439.0	11501.1
30°	10350.1	11501.1
30.5°	10327.3	11512.8
31°	10256.4	11487.5
31.5°	10196.2	11487.5
32°	*10101.0*	*11522.0*
32.5°	10043.7	11522.0
33°	9867.4	11489.4
33.5°	9867.4	11489.4
34°	9672.6	11495.3
34.5°	9672.6	11495.3
35°	9451.7	11493.8
35.5°	9325.9	11493.8
36°	9175.8	11461.8
36.5°	9018.0	11479.7
37°	8867.4	11479.7
37.5°	8692.6	11433.1
38°	8503.7	11433.1
38.5°	8073.4	11424.4
39°	8073.4	11424.4
39.5°	7568.3	11379.2
40°	7311.4	11379.2
40.5°	6964.2	11318.5
41°	6644.1	11324.3
41.5°	6277.0	11280.1
42°	5913.7	11158.2
42.5°	5496.6	11158.2
43°	4646.2	11101.4
43.5°	4646.2	11101.4
44°	3751.6	10979.5
44.5°	3751.6	10979.5

Cooper Lighting Solutions Photometric Lab
1121 Highway 74 South
Peachtree City, GA 30269

Scaled Data Report

TEST NUMBER: P1594577
CATALOG NUMBER: FLXB-1224-N-MED-5700K

CANDELA DISTRIBUTION (continued):

	330°	360°
45°	2893.5	10868.3
45.5°	2549.6	10868.3
46°	2134.9	10743.0
46.5°	1885.3	10568.7
47°	1523.5	10568.7
47.5°	1333.1	10427.8
48°	1095.6	10427.8
48.5°	800.8	10229.2
49°	800.8	10229.2
49.5°	606.1	10031.0
50°	571.1	10031.0
50.5°	509.9	9812.0
51°	494.9	9812.0
51.5°	454.1	9548.3
52°	443.9	9303.5
52.5°	419.1	9303.5
53°	411.8	8979.1
53.5°	397.3	8979.1
54°	378.8	8684.3
54.5°	378.8	8684.3
55°	361.3	8357.0
55.5°	354.0	8357.0
56°	343.8	7998.1
56.5°	335.6	7998.1
57°	327.3	7660.1
57.5°	318.6	7276.5
58°	311.8	7276.5
58.5°	298.2	6914.6
59°	298.2	6914.6
59.5°	285.1	6532.9
60°	285.1	6532.9
60.5°	277.3	6154.1
61°	271.0	6154.1
61.5°	273.4	5784.6
62°	268.6	5395.5
62.5°	274.4	5395.5
63°	272.0	5030.8
63.5°	272.9	5030.8
64°	265.7	4663.2
64.5°	265.7	4663.2
65°	267.1	4310.6
65.5°	271.5	4310.6
66°	266.1	3970.2
66.5°	272.0	3970.2
67°	268.1	3608.9

TEST NUMBER: P1594577
CATALOG NUMBER: FLXB-1224-N-MED-5700K

CANDELA DISTRIBUTION (continued):

	330°	360°
67.5°	274.9	3281.0
68°	276.8	3281.0
68.5°	290.9	2938.2
69°	290.9	2938.2
69.5°	308.9	2626.4
70°	308.9	2626.4
70.5°	338.5	2340.3
71°	352.6	2340.3
71.5°	378.3	2062.1
72°	381.2	1989.2
72.5°	371.0	1820.7
73°	374.4	1598.3
73.5°	334.6	1598.3
74°	294.3	1401.6
74.5°	294.3	1401.6
75°	264.2	1218.5
75.5°	264.2	1218.5
76°	240.9	1053.4
76.5°	227.3	941.7
77°	213.2	911.6
77.5°	204.0	774.1
78°	205.9	774.1
78.5°	196.7	651.3
79°	184.5	651.3
79.5°	161.7	538.1
80°	161.7	538.1
80.5°	149.6	443.4
81°	141.8	443.4
81.5°	129.2	361.3
82°	113.2	361.3
82.5°	91.8	288.0
83°	79.2	226.8
83.5°	66.5	226.8
84°	49.1	173.4
84.5°	49.1	173.4
85°	28.7	129.7
85.5°	28.7	129.7
86°	16.0	94.7
86.5°	12.1	94.7
87°	9.7	69.0
87.5°	5.8	69.0
88°	3.4	49.5
88.5°	2.9	35.0
89°	2.9	35.0
89.5°	1.9	24.3

TEST NUMBER: P1594577
CATALOG NUMBER: FLXB-1224-N-MED-5700K

CANDELA DISTRIBUTION (continued):

	330°	360°
90°	1.5	15.0

Cooper Lighting Solutions Photometric Lab
1121 Highway 74 South
Peachtree City, GA 30269

Scaled Data Report

TEST NUMBER: P1594577
CATALOG NUMBER: FLXB-1224-N-MED-5700K

CIE UGR TABLE:

Reflectances:											
	Ceiling	0.7	0.7	0.5	0.5	0.3	0.7	0.7	0.5	0.5	0.3
	Wall	0.5	0.3	0.5	0.3	0.3	0.5	0.3	0.5	0.3	0.3
	Reference plane	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2
Room Dimensions		Viewed crosswise					Viewed endwise				
X=2H	Y=2H	26.1	27.4	26.4	27.7	28.0	11.6	12.9	12.0	13.2	13.5
	3H	28.0	29.1	28.4	29.5	29.8	13.8	15.0	14.2	15.3	15.7
	4H	28.4	29.5	28.8	29.8	30.2	14.6	15.6	15.0	16.0	16.4
	6H	28.6	29.6	29.0	30.0	30.3	14.8	15.8	15.2	16.2	16.6
	8H	28.6	29.6	29.1	29.9	30.4	14.8	15.8	15.3	16.2	16.6
	12H	28.6	29.5	29.0	29.9	30.3	14.8	15.7	15.3	16.1	16.5
4H	2H	25.8	26.9	26.2	27.3	27.6	12.2	13.3	12.6	13.6	14.0
	3H	27.8	28.6	28.2	29.0	29.5	14.7	15.6	15.1	16.0	16.4
	4H	28.3	29.1	28.7	29.5	29.9	15.4	16.2	15.9	16.7	17.1
	6H	28.5	29.2	29.0	29.6	30.1	15.8	16.5	16.2	16.9	17.4
	8H	28.6	29.2	29.0	29.6	30.1	15.8	16.4	16.3	16.9	17.4
	12H	28.6	29.1	29.1	29.6	30.1	15.8	16.4	16.3	16.8	17.3
8H	4H	28.1	28.8	28.6	29.2	29.7	16.1	16.7	16.5	17.2	17.6
	6H	28.4	28.9	28.9	29.4	29.9	16.4	16.9	16.9	17.4	17.9
	8H	28.5	28.9	29.0	29.4	29.9	16.5	16.9	17.0	17.4	17.9
	12H	28.5	28.9	29.0	29.4	30.0	16.5	16.9	17.0	17.4	18.0
12H	4H	28.1	28.7	28.6	29.1	29.6	16.2	16.8	16.7	17.3	17.7
	6H	28.4	28.8	28.9	29.3	29.8	16.6	17.1	17.1	17.5	18.1
	8H	28.4	28.8	28.9	29.3	29.9	16.7	17.1	17.2	17.6	18.1

Cooper Lighting Solutions Photometric Lab
1121 Highway 74 South
Peachtree City, GA 30269

LM-79-2019: Approved Method: Electrical and Photometric Measurements of Solid-State Lighting Products

Report Prepared for

Cooper Lighting Solutions

Metalux

Report Number: SP3-2602-684-5

Test Date: 02/20/2026

Luminaire Tested: HLBX-2436-W-HI-5700K

Data in this report applies to families of products including HLBX-2436*

Report Generated By FNC07603 / LDUCLS01DT01661
Version: v7.05


Test Information

Test Method:	LM-79-2019
Report Number:	SP3-2602-684-5
Test Lab:	COOPER LIGHTING SOLUTIONS
Photometer:	SP3 - 3M SPHERE
Measurement Geometry:	4π
Issue Date:	02/27/2026
Manufacturer:	COOPER LIGHTING SOLUTIONS
Product Line:	Metalux
Catalog Number:	**HLBX-2436-W-HI-5700K**
Description:	LDS HLBX 2436 W beam, HI lumen, 5700K CCT settings

Spectral Parameters

CCT (K):	5604
CIE u':	0.2066
CIE v':	0.4754
Duv:	-0.0007
CIE x:	0.3301
CIE y:	0.3376
CIE z:	0.3322
Peak Wavelength (nm):	453
Dominant Wavelength (nm):	510
Purity:	1.011411
Rf:	82.8
Rg:	95.3

CRI (Ra):	84.2				
R1:	83.7	R9:	14.9
R2:	89.9	R10:	73.8
R3:	91.8	R11:	82.3
R4:	83.5	R12:	58.7
R5:	83.4	R13:	85.8
R6:	83.6	R14:	95.6
R7:	87.5	R15:	79.8
R8:	70.3		



Test Conditions


Stabilization Time:	35M
Operation Time:	1H 35M
Sphere Temperature (°C):	25.0

REPORT NUMBER: SP3-2602-684-5


Measurement and Test Equipment			
Instrument	Identification Number	Calibration Date	Calibration Due Date
Photometer	3M SPHERE IN02505	1/10/2026	7/10/2026
Power Meter	XITRON INXT2011006	10/21/2025	10/21/2026
AC Power Source	CHROMA 61604 IN6064A	10/20/2025	10/20/2026
DC Power Source	EYSIGHT N5770A IN0534	10/20/2025	10/20/2026
Sphere Thermometer	TANDD IN4036E	10/21/2025	10/21/2026

REPORT NUMBER: SP3-2602-684-5

CIE 1931 Chromaticity Diagram



CIE 1931 Chromaticity Diagram with 2017 ANSI 7-Step and 4-Step Quadrangles




CCT = 5604K
CIE x = 0.3301
CIE y = 0.3376
Duv = -0.0007

Point lies inside the ANSI 5700K 4-step quadrangle

REPORT NUMBER: SP3-2602-684-5

Photopic Flux vs. Wavelength




Photopic Lumens: NR

λ (nm)	Power W^/nm	Lumens (ϕ/nm)	λ (nm)	Power W^/nm	Lumens (ϕ/nm)	λ (nm)	Power W^/nm	Lumens (ϕ/nm)	λ (nm)	Power W^/nm	Lumens (ϕ/nm)	λ (nm)	Power W^/nm	Lumens (ϕ/nm)
360	0	NR	490	219	NR	620	383	NR	750	11	NR	880	0	NR
365	0	NR	495	239	NR	625	355	NR	755	10	NR	885	1	NR
370	0	NR	500	277	NR	630	327	NR	760	8	NR	890	0	NR
375	0	NR	505	319	NR	635	297	NR	765	7	NR	895	0	NR
380	0	NR	510	356	NR	640	270	NR	770	6	NR	900	0	NR
385	1	NR	515	389	NR	645	241	NR	775	5	NR	905	0	NR
390	2	NR	520	413	NR	650	215	NR	780	5	NR	910	0	NR
395	4	NR	525	430	NR	655	191	NR	785	4	NR	915	0	NR
400	6	NR	530	442	NR	660	168	NR	790	3	NR	920	0	NR
405	8	NR	535	452	NR	665	147	NR	795	3	NR	925	0	NR
410	13	NR	540	457	NR	670	129	NR	800	3	NR	930	0	NR
415	22	NR	545	463	NR	675	112	NR	805	2	NR	935	0	NR
420	39	NR	550	467	NR	680	97	NR	810	2	NR	940	0	NR
425	69	NR	555	470	NR	685	84	NR	815	2	NR	945	0	NR
430	117	NR	560	475	NR	690	72	NR	820	2	NR	950	0	NR
435	199	NR	565	481	NR	695	62	NR	825	1	NR	955	0	NR
440	324	NR	570	483	NR	700	54	NR	830	1	NR	960	0	NR
445	548	NR	575	489	NR	705	46	NR	835	1	NR	965	0	NR
450	887	NR	580	491	NR	710	40	NR	840	1	NR	970	0	NR
455	983	NR	585	490	NR	715	34	NR	845	1	NR	975	0	NR
460	710	NR	590	488	NR	720	29	NR	850	1	NR	980	0	NR
465	510	NR	595	480	NR	725	25	NR	855	1	NR	985	0	NR
470	400	NR	600	467	NR	730	21	NR	860	1	NR	990	0	NR
475	287	NR	605	452	NR	735	18	NR	865	1	NR	995	0	NR
480	225	NR	610	433	NR	740	16	NR	870	1	NR	1000	0	NR
485	212	NR	615	409	NR	745	13	NR	875	0	NR			

REPORT NUMBER: SP3-2602-684-5

Scotopic Flux vs. Wavelength




Scotopic Lumens: NR **S/P: 2.09**

λ (nm)	Power W^/nm	Lumens (ϕ/nm)	λ (nm)	Power W^/nm	Lumens (ϕ/nm)	λ (nm)	Power W^/nm	Lumens (ϕ/nm)	λ (nm)	Power W^/nm	Lumens (ϕ/nm)	λ (nm)	Power W^/nm	Lumens (ϕ/nm)
360	0	NR	490	219	NR	620	383	NR	750	11	NR	880	0	NR
365	0	NR	495	239	NR	625	355	NR	755	10	NR	885	1	NR
370	0	NR	500	277	NR	630	327	NR	760	8	NR	890	0	NR
375	0	NR	505	319	NR	635	297	NR	765	7	NR	895	0	NR
380	0	NR	510	356	NR	640	270	NR	770	6	NR	900	0	NR
385	1	NR	515	389	NR	645	241	NR	775	5	NR	905	0	NR
390	2	NR	520	413	NR	650	215	NR	780	5	NR	910	0	NR
395	4	NR	525	430	NR	655	191	NR	785	4	NR	915	0	NR
400	6	NR	530	442	NR	660	168	NR	790	3	NR	920	0	NR
405	8	NR	535	452	NR	665	147	NR	795	3	NR	925	0	NR
410	13	NR	540	457	NR	670	129	NR	800	3	NR	930	0	NR
415	22	NR	545	463	NR	675	112	NR	805	2	NR	935	0	NR
420	39	NR	550	467	NR	680	97	NR	810	2	NR	940	0	NR
425	69	NR	555	470	NR	685	84	NR	815	2	NR	945	0	NR
430	117	NR	560	475	NR	690	72	NR	820	2	NR	950	0	NR
435	199	NR	565	481	NR	695	62	NR	825	1	NR	955	0	NR
440	324	NR	570	483	NR	700	54	NR	830	1	NR	960	0	NR
445	548	NR	575	489	NR	705	46	NR	835	1	NR	965	0	NR
450	887	NR	580	491	NR	710	40	NR	840	1	NR	970	0	NR
455	983	NR	585	490	NR	715	34	NR	845	1	NR	975	0	NR
460	710	NR	590	488	NR	720	29	NR	850	1	NR	980	0	NR
465	510	NR	595	480	NR	725	25	NR	855	1	NR	985	0	NR
470	400	NR	600	467	NR	730	21	NR	860	1	NR	990	0	NR
475	287	NR	605	452	NR	735	18	NR	865	1	NR	995	0	NR
480	225	NR	610	433	NR	740	16	NR	870	1	NR	1000	0	NR
485	212	NR	615	409	NR	745	13	NR	875	0	NR			

REPORT NUMBER: SP3-2602-684-5

Melanopic Flux vs. Wavelength



Melanopic Lumens: NR **M/P: 4.57**

λ (nm)	Power W^/nm	Lumens (ϕ/nm)	λ (nm)	Power W^/nm	Lumens (ϕ/nm)	λ (nm)	Power W^/nm	Lumens (ϕ/nm)	λ (nm)	Power W^/nm	Lumens (ϕ/nm)	λ (nm)	Power W^/nm	Lumens (ϕ/nm)
360	0	NR	490	219	NR	620	383	NR	750	11	NR	880	0	NR
365	0	NR	495	239	NR	625	355	NR	755	10	NR	885	1	NR
370	0	NR	500	277	NR	630	327	NR	760	8	NR	890	0	NR
375	0	NR	505	319	NR	635	297	NR	765	7	NR	895	0	NR
380	0	NR	510	356	NR	640	270	NR	770	6	NR	900	0	NR
385	1	NR	515	389	NR	645	241	NR	775	5	NR	905	0	NR
390	2	NR	520	413	NR	650	215	NR	780	5	NR	910	0	NR
395	4	NR	525	430	NR	655	191	NR	785	4	NR	915	0	NR
400	6	NR	530	442	NR	660	168	NR	790	3	NR	920	0	NR
405	8	NR	535	452	NR	665	147	NR	795	3	NR	925	0	NR
410	13	NR	540	457	NR	670	129	NR	800	3	NR	930	0	NR
415	22	NR	545	463	NR	675	112	NR	805	2	NR	935	0	NR
420	39	NR	550	467	NR	680	97	NR	810	2	NR	940	0	NR
425	69	NR	555	470	NR	685	84	NR	815	2	NR	945	0	NR
430	117	NR	560	475	NR	690	72	NR	820	2	NR	950	0	NR
435	199	NR	565	481	NR	695	62	NR	825	1	NR	955	0	NR
440	324	NR	570	483	NR	700	54	NR	830	1	NR	960	0	NR
445	548	NR	575	489	NR	705	46	NR	835	1	NR	965	0	NR
450	887	NR	580	491	NR	710	40	NR	840	1	NR	970	0	NR
455	983	NR	585	490	NR	715	34	NR	845	1	NR	975	0	NR
460	710	NR	590	488	NR	720	29	NR	850	1	NR	980	0	NR
465	510	NR	595	480	NR	725	25	NR	855	1	NR	985	0	NR
470	400	NR	600	467	NR	730	21	NR	860	1	NR	990	0	NR
475	287	NR	605	452	NR	735	18	NR	865	1	NR	995	0	NR
480	225	NR	610	433	NR	740	16	NR	870	1	NR	1000	0	NR
485	212	NR	615	409	NR	745	13	NR	875	0	NR			


REPORT NUMBER: SP3-2602-684-5

TM-30-18


Summary


R_f = 82.8
R_g = 95.3
CIE R_a = 84.2
R_9 = 14.9


Spectral Power Distribution Comparison




Color Vector Graphics










REPORT NUMBER: SP3-2602-684-5

TM-30-18

Individual Sample Fidelity Index ($R_{f,i}$)


CES01 = 85	CES26 = 80	CES51 = 92	CES76 = 71
CES02 = 60	CES27 = 92	CES52 = 94	CES77 = 78
CES03 = 30	CES28 = 89	CES53 = 89	CES78 = 70
CES04 = 69	CES29 = 88	CES54 = 88	CES79 = 90
CES05 = 46	CES30 = 91	CES55 = 85	CES80 = 87
CES06 = 50	CES31 = 90	CES56 = 84	CES81 = 85
CES07 = 39	CES32 = 80	CES57 = 82	CES82 = 94
CES08 = 38	CES33 = 97	CES58 = 82	CES83 = 96
CES09 = 29	CES34 = 83	CES59 = 91	CES84 = 89
CES10 = 73	CES35 = 90	CES60 = 88	CES85 = 79
CES11 = 56	CES36 = 78	CES61 = 85	CES86 = 80
CES12 = 61	CES37 = 88	CES62 = 78	CES87 = 85
CES13 = 42	CES38 = 85	CES63 = 82	CES88 = 90
CES14 = 74	CES39 = 98	CES64 = 74	CES89 = 81
CES15 = 70	CES40 = 96	CES65 = 73	CES90 = 91
CES16 = 46	CES41 = 95	CES66 = 68	CES91 = 67
CES17 = 48	CES42 = 89	CES67 = 66	CES92 = 66
CES18 = 55	CES43 = 89	CES68 = 74	CES93 = 79
CES19 = 70	CES44 = 99	CES69 = 78	CES94 = 66
CES20 = 64	CES45 = 94	CES70 = 70	CES95 = 72
CES21 = 85	CES46 = 92	CES71 = 60	CES96 = 85
CES22 = 77	CES47 = 94	CES72 = 87	CES97 = 92
CES23 = 91	CES48 = 86	CES73 = 63	CES98 = 87
CES24 = 90	CES49 = 91	CES74 = 89	CES99 = 78
CES25 = 71	CES50 = 93	CES75 = 64	





REPORT NUMBER: SP3-2602-684-5

TM-30-18

Color Rendition by Hue-Angle Bin









REPORT NUMBER: SP3-2602-684-5

TM-30-18

Measure Comparisons





(END OF REPORT)