

Cooper Lighting Solutions Photometric Lab
1121 Highway 74 South
Peachtree City, GA 30269



Scaled data based on original data using
LM-79-2019 Approved Method: Electrical and Photometric Measurements of Solid-
State Lighting Products

Test Report Prepared for
Cooper Lighting Solutions

Brand: METALUX

Report Number: P1588543

Luminaire Tested: 24CZSP-75VHE-L930

Issue Date: 9/3/2026

Test Information

Test Method: LM-79-2019
Report Number: P1588543
TEST IS SCALED FROM IESNA LM-79-08 TEST DATA (G3-2605-776-5)
Test Lab: INNOVATION CENTER
Issue Date: 9/3/2026
Manufacturer: COOPER LIGHTING SOLUTIONS
Product Line: METALUX
Catalog Number: 24CZSP-75VHE-L930
Description: 2x4 CZSP LED Luminaire, 3000K CCT and 8000 lumens, 90CRI, Ribbed Lens
Light Source: -
Ballast/Driver: -

Summary


Lumens per Lamp: N/A
Luminaire Lumens: 6958.0 lumens
Efficiency: N/A
Efficacy: 122.3 lumens/watt
Spacing Criteria (0/90/45): 1.24 / 1.27 / 1.39
Luminous Opening: Rectangular (W 1.83' x L: 3.83' x H: 0')
CIE Type: Direct

Input Watts (W): 56.9
Input Voltage (V): NR
Input Current (Ain): NR
Voltage Rise (V): NR
Power Factor: NR
Total Harmonic Distortion (THDi): NR
Frequency (hertz): 60
Stabilization Time: NR
Operation Time: NR
Ambient Temperature (°C): NR
Test Distance: 24 FT

TEST NUMBER: P1588543

CATALOG NUMBER: 24CZSP-75VHE-L930

Luminous Intensity Polar Plot



TEST NUMBER: P1588543

CATALOG NUMBER: 24CZSP-75VHE-L930

COEFFICIENT OF UTILIZATION - ZONAL CAVITY METHOD:

RF	20				20				20				20				20			
RC	80				70				50				30				10			0
RW	70	50	30	10	70	50	30	10	50	30	10		50	30	10		50	30	10	0
RCR																				
0	119	119	119	119	116	116	116	116	111	111	111		106	106	106		102	102	102	100
1	108	103	99	95	105	101	97	93	97	93	90		93	90	87		89	87	85	83
2	98	89	82	76	95	88	81	75	84	78	74		81	76	72		78	74	70	68
3	89	78	70	63	87	77	69	62	74	67	61		71	65	60		68	63	59	57
4	81	69	60	53	79	68	59	53	65	58	52		63	56	51		61	55	51	48
5	75	62	52	46	73	60	52	45	58	51	45		56	50	44		54	49	44	42
6	69	55	46	40	67	54	46	39	53	45	39		51	44	39		49	43	38	36
7	64	50	41	35	62	49	41	35	48	40	35		46	39	34		45	39	34	32
8	60	46	37	31	58	45	37	31	44	36	31		42	36	31		41	35	30	28
9	56	42	34	28	54	41	33	28	40	33	28		39	32	28		38	32	27	26
10	52	39	31	25	51	38	30	25	37	30	25		36	30	25		35	29	25	23

AVERAGE LUMINANCE (cd/sqm):

	0°	45°	90°
0°	3570	3570	3570
5°	3554	3518	3541
10°	3544	3553	3578
15°	3511	3540	3574
20°	3503	3509	3564
25°	3475	3465	3555
30°	3444	3518	3538
35°	3418	3466	3522
40°	3380	3446	3511
45°	3338	3428	3498
50°	3311	3415	3482
55°	3227	3445	3409
60°	3145	3371	3458
65°	3003	3299	3412
70°	2880	3270	3461
75°	2550	3173	3391
80°	2014	3099	3750
85°	1232	3313	4277

MAXIMUM LUMINANCE 45°-90°:

Horizontal Angle: 90°

Vertical Angle: 85°

Luminance: 4277 cd/sqm

TEST NUMBER: P1588543

CATALOG NUMBER: 24CZSP-75VHE-L930

ZONAL LUMENS:

Zone	Lumens	% Fixture
0°-10°	220.1	3.2
10°-20°	628.8	9.0
20°-30°	958.0	13.8
30°-40°	1166.1	16.8
40°-50°	1222.7	17.6
50°-60°	1132.6	16.3
60°-70°	893.2	12.8
70°-80°	552.5	7.9
80°-90°	184.0	2.6
90°-100°	0.0	0.0
100°-110°	0.0	0.0
110°-120°	0.0	0.0
120°-130°	0.0	0.0
130°-140°	0.0	0.0
140°-150°	0.0	0.0
150°-160°	0.0	0.0
160°-170°	0.0	0.0
170°-180°	0.0	0.0
0°-30°	1806.9	26.0
0°-40°	2973.0	42.7
0°-60°	5328.3	76.6
0°-90°	6958.0	100.0
90°-120°	0.0	0.0
90°-150°	0.0	0.0
90°-180°	0.0	0.0
0°-180°	6958.0	100.0

CANDELA DISTRIBUTION:

	0°	22.5°	45°	67.5°	90°	Flux
0°	2331	2331	2331	2331	2331	
5°	2312	2311	2288	2338	2303	218
15°	2214	2226	2232	2216	2254	625
25°	2056	2068	2050	2107	2104	945
35°	1828	1845	1854	1888	1884	1142
45°	1541	1569	1583	1601	1615	1191
55°	1208	1244	1290	1301	1277	1081
65°	829	861	910	944	941	825
75°	431	465	536	577	573	455
85°	70	119	188	229	243	94
90°	0	0	0	0	0	

TEST NUMBER: P1588543

CATALOG NUMBER: 24CZSP-75VHE-L930

CANDELA DISTRIBUTION (FULL):

	0°	22.5°	45°	67.5°	90°
0°	2330.8	2330.8	2330.8	2330.8	2330.8
2.5°	2324.2	2338.4	2320.4	2335.6	2335.6
5°	2311.9	2310.9	2288.2	2338.4	2303.4
7.5°	2255.0	2294.8	2278.7	2340.3	2319.5
10°	2278.7	2268.3	2284.4	2326.1	2300.5
12.5°	2255.0	2272.1	2246.5	2225.7	2252.2
15°	2214.3	2225.7	2232.3	2216.2	2254.1
17.5°	2166.0	2208.6	2185.9	2178.3	2221.9
20°	2149.0	2150.9	2152.8	2191.6	2186.9
22.5°	2078.9	2116.8	2112.0	2143.3	2147.1
25°	2056.2	2067.5	2050.5	2107.3	2103.5
27.5°	2004.1	2028.7	2025.8	2044.8	2055.2
30°	1947.2	1971.9	1988.9	1968.1	2000.3
32.5°	1888.5	1930.2	1911.3	1950.1	1943.5
35°	1827.9	1845.0	1853.5	1888.5	1883.8
37.5°	1757.8	1787.2	1791.9	1845.0	1822.2
40°	1690.6	1719.9	1723.7	1755.0	1755.9
42.5°	1619.5	1633.7	1653.6	1689.6	1686.8
45°	1540.9	1569.3	1582.6	1600.6	1614.8
47.5°	1465.2	1495.5	1512.5	1541.9	1508.7
50°	1389.4	1411.2	1433.0	1464.2	1461.4
52.5°	1293.7	1343.0	1353.4	1370.5	1381.8
55°	1208.5	1244.5	1290.0	1301.3	1276.7
57.5°	1122.3	1149.8	1182.9	1218.0	1215.1
60°	1026.7	1059.8	1100.5	1127.1	1128.9
62.5°	939.5	962.3	1001.1	1039.9	1020.0
65°	828.7	860.9	910.2	944.3	941.4
67.5°	730.2	765.3	815.5	860.0	861.9
70°	643.1	662.0	730.2	764.3	772.8
72.5°	536.1	569.2	629.8	667.7	671.5
75°	430.9	465.0	536.1	576.8	573.0
77.5°	323.9	373.2	442.3	490.6	506.7
80°	228.3	272.8	351.4	398.7	425.2
82.5°	144.0	190.4	267.1	325.8	341.9
85°	70.1	119.3	188.5	229.2	243.4
87.5°	18.0	49.2	87.1	107.0	115.5
90°	0.0	0.0	0.0	0.0	0.0

TEST NUMBER: P1588543

CATALOG NUMBER: 24CZSP-75VHE-L930

CIE UGR TABLE:

Reflectances:											
Ceiling		0.7	0.7	0.5	0.5	0.3	0.7	0.7	0.5	0.5	0.3
Wall		0.5	0.3	0.5	0.3	0.3	0.5	0.3	0.5	0.3	0.3
Reference plane		0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2
Room dimensions		Viewed crosswise					Viewed endwise				
X=2H	Y=2H	16.22	17.90	16.59	18.21	18.52	16.65	18.33	17.02	18.64	18.95
	3H	18.02	19.54	18.40	19.87	20.23	18.73	20.24	19.10	20.57	20.93
	4H	18.67	20.10	19.07	20.45	20.82	19.57	21.00	19.97	21.35	21.72
	6H	19.08	20.41	19.49	20.77	21.16	20.36	21.69	20.77	22.05	22.44
	8H	19.18	20.45	19.60	20.84	21.24	20.70	21.97	21.13	22.36	22.76
	12H	19.23	20.45	19.66	20.83	21.26	21.00	22.22	21.43	22.60	23.03
4H	2H	16.96	18.39	17.36	18.74	19.12	17.30	18.73	17.69	19.08	19.45
	3H	19.00	20.20	19.41	20.60	21.00	19.61	20.82	20.02	21.21	21.61
	4H	19.77	20.86	20.20	21.28	21.71	20.62	21.71	21.05	22.12	22.56
	6H	20.30	21.27	20.76	21.71	22.16	21.57	22.53	22.02	22.97	23.42
	8H	20.45	21.35	20.91	21.79	22.25	21.99	22.89	22.45	23.33	23.80
	12H	20.53	21.34	21.01	21.82	22.28	22.37	23.18	22.85	23.66	24.13
8H	4H	20.22	21.12	20.68	21.56	22.02	20.96	21.86	21.41	22.30	22.76
	6H	20.90	21.65	21.39	22.14	22.61	22.07	22.82	22.56	23.31	23.78
	8H	21.12	21.79	21.62	22.30	22.78	22.62	23.29	23.12	23.80	24.28
	12H	21.26	21.86	21.77	22.35	22.91	23.14	23.74	23.64	24.22	24.78
12H	4H	20.30	21.11	20.78	21.59	22.06	20.99	21.80	21.47	22.28	22.74
	6H	21.03	21.71	21.54	22.21	22.70	22.14	22.81	22.64	23.32	23.80
	8H	21.33	21.93	21.83	22.42	22.97	22.76	23.36	23.27	23.85	24.41