

Cooper Lighting Solutions Photometric Lab
1121 Highway 74 South
Peachtree City, GA 30269



Scaled data based on original data using
LM-79-2019 Approved Method: Electrical and Photometric Measurements of Solid-
State Lighting Products

Test Report Prepared for
Cooper Lighting Solutions

Brand: METALUX

Report Number: P1588542

Luminaire Tested: 24CZSP-75VHE-L930-S

Issue Date: 9/3/2026

Test Information

Test Method: LM-79-2019
Report Number: P1588542
TEST IS SCALED FROM IESNA LM-79-08 TEST DATA (G2-2608-884-6)
Test Lab: INNOVATION CENTER
Issue Date: 9/3/2026
Manufacturer: COOPER LIGHTING SOLUTIONS
Product Line: METALUX
Catalog Number: 24CZSP-75VHE-L930-S
Description: 2x4 CZSP LED Luminaire, 3000K CCT and 8000 lumens, 90CRI, Smooth Lens
Light Source: -
Ballast/Driver: -

Summary


Lumens per Lamp: N/A
Luminaire Lumens: 6819.0 lumens
Efficiency: N/A
Efficacy: 119.8 lumens/watt
Spacing Criteria (0/90/45): 1.22 / 1.27 / 1.37
Luminous Opening: Rectangular (W 1.83' x L: 3.83' x H: 0')
CIE Type: Direct

Input Watts (W): 56.9
Input Voltage (V): NR
Input Current (Ain): NR
Voltage Rise (V): NR
Power Factor: NR
Total Harmonic Distortion (THDi): NR
Frequency (hertz): 60
Stabilization Time: NR
Operation Time: NR
Ambient Temperature (°C): NR
Test Distance: 24 FT

TEST NUMBER: P1588542

CATALOG NUMBER: 24CZSP-75VHE-L930-S

Luminous Intensity Polar Plot



TEST NUMBER: P1588542

CATALOG NUMBER: 24CZSP-75VHE-L930-S

COEFFICIENT OF UTILIZATION - ZONAL CAVITY METHOD:

RF	20				20				20				20				20			
RC	80				70				50				30				10			0
RW	70	50	30	10	70	50	30	10	50	30	10		50	30	10		50	30	10	0
RCR																				
0	119	119	119	119	116	116	116	116	111	111	111		106	106	106		102	102	102	100
1	108	103	99	95	106	101	97	93	97	93	90		93	90	88		89	87	85	83
2	98	90	83	77	96	88	81	76	84	79	74		81	76	72		78	74	71	69
3	89	79	70	64	87	77	69	63	74	67	62		71	65	61		69	64	60	57
4	82	69	60	54	79	68	60	53	66	58	52		63	57	52		61	56	51	49
5	75	62	53	46	73	61	52	46	59	51	45		57	50	45		55	49	44	42
6	69	56	47	40	67	55	46	40	53	45	40		51	44	39		50	44	39	37
7	64	50	42	35	62	50	41	35	48	40	35		47	40	35		45	39	34	32
8	60	46	37	32	58	45	37	31	44	37	31		43	36	31		42	35	31	29
9	56	42	34	28	54	42	34	28	40	33	28		39	33	28		38	32	28	26
10	52	39	31	26	51	38	31	26	37	30	25		37	30	25		36	30	25	23

AVERAGE LUMINANCE (cd/sqm):

	0°	45°	90°
0°	3577	3577	3577
5°	3561	3575	3573
10°	3553	3570	3567
15°	3528	3556	3578
20°	3492	3534	3563
25°	3449	3497	3540
30°	3395	3467	3530
35°	3346	3433	3519
40°	3291	3399	3509
45°	3228	3364	3513
50°	3159	3323	3512
55°	3076	3276	3516
60°	2961	3241	3525
65°	2825	3178	3536
70°	2633	3089	3551
75°	2346	2967	3586
80°	1940	2824	3761
85°	1262	2550	3286

MAXIMUM LUMINANCE 45°-90°:

Horizontal Angle: 90°

Vertical Angle: 82.5°

Luminance: 3881 cd/sqm

TEST NUMBER: P1588542

CATALOG NUMBER: 24CZSP-75VHE-L930-S

ZONAL LUMENS:

Zone	Lumens	% Fixture
0°-10°	220.9	3.2
10°-20°	632.5	9.3
20°-30°	953.9	14.0
30°-40°	1149.0	16.8
40°-50°	1199.9	17.6
50°-60°	1102.0	16.2
60°-70°	868.0	12.7
70°-80°	532.5	7.8
80°-90°	160.2	2.3
90°-100°	0.0	0.0
100°-110°	0.0	0.0
110°-120°	0.0	0.0
120°-130°	0.0	0.0
130°-140°	0.0	0.0
140°-150°	0.0	0.0
150°-160°	0.0	0.0
160°-170°	0.0	0.0
170°-180°	0.0	0.0
0°-30°	1807.3	26.5
0°-40°	2956.3	43.4
0°-60°	5258.3	77.1
0°-90°	6819.0	100.0
90°-120°	0.0	0.0
90°-150°	0.0	0.0
90°-180°	0.0	0.0
0°-180°	6819.0	100.0

CANDELA DISTRIBUTION:

	0°	22.5°	45°	67.5°	90°	Flux
0°	2336	2336	2336	2336	2336	
5°	2316	2319	2325	2333	2324	220
15°	2225	2230	2243	2256	2256	627
25°	2041	2045	2069	2095	2095	939
35°	1790	1798	1836	1873	1882	1119
45°	1490	1507	1553	1607	1622	1149
55°	1152	1173	1227	1296	1317	1029
65°	780	806	877	950	976	771
75°	396	428	501	581	606	420
85°	72	99	145	184	187	94
90°	0	0	0	0	0	

TEST NUMBER: P1588542

CATALOG NUMBER: 24CZSP-75VHE-L930-S

CANDELA DISTRIBUTION (FULL):

	0°	22.5°	45°	67.5°	90°
0°	2335.7	2335.7	2335.7	2335.7	2335.7
2.5°	2326.7	2331.2	2332.7	2334.2	2323.7
5°	2316.2	2319.2	2325.2	2332.7	2323.7
7.5°	2301.3	2304.3	2311.7	2322.2	2317.7
10°	2284.8	2286.3	2295.3	2302.8	2293.8
12.5°	2257.9	2262.4	2272.8	2278.8	2275.8
15°	2225.0	2229.5	2242.9	2256.4	2256.4
17.5°	2186.1	2192.0	2208.5	2226.5	2228.0
20°	2142.7	2147.2	2168.1	2186.1	2186.1
22.5°	2093.3	2099.3	2120.2	2139.7	2142.7
25°	2040.9	2045.4	2069.4	2094.8	2094.8
27.5°	1979.6	1988.6	2018.5	2043.9	2049.9
30°	1919.7	1927.2	1960.1	1991.5	1996.0
32.5°	1856.9	1865.9	1900.3	1934.7	1942.2
35°	1789.5	1798.5	1835.9	1873.3	1882.3
37.5°	1719.2	1729.7	1768.6	1812.0	1821.0
40°	1645.9	1657.9	1699.8	1746.2	1755.1
42.5°	1568.1	1584.6	1629.4	1677.3	1690.8
45°	1490.3	1506.8	1553.1	1607.0	1622.0
47.5°	1408.0	1427.4	1475.3	1532.2	1548.6
50°	1325.7	1345.2	1394.5	1455.9	1473.8
52.5°	1241.9	1261.4	1312.2	1376.6	1396.0
55°	1152.1	1173.1	1226.9	1295.8	1316.7
57.5°	1059.4	1086.3	1143.2	1213.5	1234.4
60°	966.6	993.5	1057.9	1126.7	1150.6
62.5°	875.3	900.8	966.6	1039.9	1065.3
65°	779.6	806.5	876.8	950.1	975.6
67.5°	685.3	712.2	782.6	858.9	885.8
70°	588.0	618.0	689.8	766.1	793.0
72.5°	490.8	522.2	595.5	673.3	698.8
75°	396.5	427.9	501.3	580.6	606.0
77.5°	303.7	338.2	410.0	490.8	514.7
80°	220.0	252.9	320.2	399.5	426.4
82.5°	140.7	169.1	236.4	311.2	330.7
85°	71.8	98.8	145.1	184.0	187.0
87.5°	22.4	31.4	47.9	71.8	73.3
90°	0.0	0.0	0.0	0.0	0.0

TEST NUMBER: P1588542

CATALOG NUMBER: 24CZSP-75VHE-L930-S

CIE UGR TABLE:

Reflectances:											
Ceiling		0.7	0.7	0.5	0.5	0.3	0.7	0.7	0.5	0.5	0.3
Wall		0.5	0.3	0.5	0.3	0.3	0.5	0.3	0.5	0.3	0.3
Reference plane		0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2
Room dimensions		Viewed crosswise					Viewed endwise				
X=2H	Y=2H	15.91	17.57	16.27	17.88	18.20	16.74	18.40	17.10	18.71	19.03
	3H	17.66	19.17	18.04	19.50	19.86	18.85	20.36	19.23	20.69	21.05
	4H	18.28	19.70	18.68	20.05	20.43	19.74	21.16	20.14	21.51	21.89
	6H	18.69	20.01	19.10	20.38	20.77	20.52	21.84	20.93	22.21	22.60
	8H	18.80	20.06	19.22	20.45	20.85	20.84	22.11	21.27	22.49	22.89
	12H	18.85	20.06	19.28	20.44	20.87	21.05	22.27	21.48	22.65	23.08
4H	2H	16.68	18.10	17.08	18.45	18.82	17.32	18.75	17.72	19.09	19.47
	3H	18.66	19.85	19.06	20.25	20.65	19.68	20.88	20.09	21.27	21.67
	4H	19.39	20.48	19.82	20.89	21.33	20.73	21.82	21.16	22.23	22.67
	6H	19.92	20.87	20.37	21.31	21.77	21.68	22.64	22.14	23.08	23.53
	8H	20.07	20.96	20.53	21.40	21.86	22.08	22.97	22.54	23.41	23.88
	12H	20.15	20.95	20.63	21.43	21.90	22.36	23.16	22.84	23.64	24.10
8H	4H	19.85	20.74	20.31	21.18	21.65	21.02	21.91	21.48	22.35	22.82
	6H	20.51	21.26	21.00	21.74	22.22	22.13	22.88	22.62	23.36	23.84
	8H	20.72	21.39	21.23	21.90	22.38	22.64	23.31	23.15	23.82	24.30
	12H	20.86	21.45	21.37	21.94	22.50	23.03	23.62	23.54	24.11	24.67
12H	4H	19.94	20.74	20.42	21.22	21.69	21.05	21.85	21.52	22.32	22.79
	6H	20.64	21.31	21.15	21.82	22.30	22.18	22.85	22.69	23.35	23.84
	8H	20.92	21.51	21.43	22.00	22.56	22.76	23.35	23.26	23.84	24.40