

Cooper Lighting Solutions Photometric Lab
1121 Highway 74 South
Peachtree City, GA 30269



Scaled data based on original data using
LM-79-2019 Approved Method: Electrical and Photometric Measurements of Solid-
State Lighting Products

Test Report Prepared for
Cooper Lighting Solutions

Brand: METALUX

Report Number: P1588551

Luminaire Tested: 24CZSP-75VHE-L950

Issue Date: 9/3/2026

Test Information

Test Method: LM-79-2019
Report Number: P1588551
TEST IS SCALED FROM IESNA LM-79-08 TEST DATA (G3-2605-776-5)
Test Lab: INNOVATION CENTER
Issue Date: 9/3/2026
Manufacturer: COOPER LIGHTING SOLUTIONS
Product Line: METALUX
Catalog Number: 24CZSP-75VHE-L950
Description: 2x4 CZSP LED Luminaire, 5000K CCT and 8000 lumens, 90CRI, Ribbed Lens
Light Source: -
Ballast/Driver: -


Summary

Lumens per Lamp: N/A
Luminaire Lumens: 7261.0 lumens
Efficiency: N/A
Efficacy: 127.6 lumens/watt
Spacing Criteria (0/90/45): 1.24 / 1.27 / 1.39
Luminous Opening: Rectangular (W 1.83' x L: 3.83' x H: 0')
CIE Type: Direct

Input Watts (W): 56.9
Input Voltage (V): NR
Input Current (Ain): NR
Voltage Rise (V): NR
Power Factor: NR
Total Harmonic Distortion (THDi): NR
Frequency (hertz): 60
Stabilization Time: NR
Operation Time: NR
Ambient Temperature (°C): NR
Test Distance: 24 FT

TEST NUMBER: P1588551
CATALOG NUMBER: 24CZSP-75VHE-L950

Luminous Intensity Polar Plot



TEST NUMBER: P1588551

CATALOG NUMBER: 24CZSP-75VHE-L950

COEFFICIENT OF UTILIZATION - ZONAL CAVITY METHOD:

RF	20				20				20				20				20			
RC	80				70				50				30				10			0
RW	70	50	30	10	70	50	30	10	50	30	10		50	30	10		50	30	10	0
RCR																				
0	119	119	119	119	116	116	116	116	111	111	111		106	106	106		102	102	102	100
1	108	103	99	95	105	101	97	93	97	93	90		93	90	87		89	87	85	83
2	98	89	82	76	95	88	81	75	84	78	74		81	76	72		78	74	70	68
3	89	78	70	63	87	77	69	62	74	67	61		71	65	60		68	63	59	57
4	81	69	60	53	79	68	59	53	65	58	52		63	56	51		61	55	51	48
5	75	62	52	46	73	60	52	45	58	51	45		56	50	44		54	49	44	42
6	69	55	46	40	67	54	46	39	53	45	39		51	44	39		49	43	38	36
7	64	50	41	35	62	49	41	35	48	40	35		46	39	34		45	39	34	32
8	60	46	37	31	58	45	37	31	44	36	31		42	36	31		41	35	30	28
9	56	42	34	28	54	41	33	28	40	33	28		39	32	28		38	32	27	26
10	52	39	31	25	51	38	30	25	37	30	25		36	30	25		35	29	25	23

AVERAGE LUMINANCE (cd/sqm):

	0°	45°	90°
0°	3725	3725	3725
5°	3709	3671	3696
10°	3698	3708	3734
15°	3664	3694	3730
20°	3655	3662	3720
25°	3626	3616	3710
30°	3594	3671	3692
35°	3567	3617	3676
40°	3527	3597	3664
45°	3483	3577	3650
50°	3455	3563	3634
55°	3368	3595	3558
60°	3282	3518	3609
65°	3134	3442	3560
70°	3005	3412	3612
75°	2661	3310	3538
80°	2101	3234	3914
85°	1285	3457	4464

MAXIMUM LUMINANCE 45°-90°:

Horizontal Angle: 90°

Vertical Angle: 85°

Luminance: 4464 cd/sqm

TEST NUMBER: P1588551

CATALOG NUMBER: 24CZSP-75VHE-L950

ZONAL LUMENS:

Zone	Lumens	% Fixture
0°-10°	229.7	3.2
10°-20°	656.1	9.0
20°-30°	999.7	13.8
30°-40°	1216.9	16.8
40°-50°	1275.9	17.6
50°-60°	1182.0	16.3
60°-70°	932.1	12.8
70°-80°	576.6	7.9
80°-90°	192.0	2.6
90°-100°	0.0	0.0
100°-110°	0.0	0.0
110°-120°	0.0	0.0
120°-130°	0.0	0.0
130°-140°	0.0	0.0
140°-150°	0.0	0.0
150°-160°	0.0	0.0
160°-170°	0.0	0.0
170°-180°	0.0	0.0
0°-30°	1885.6	26.0
0°-40°	3102.4	42.7
0°-60°	5560.3	76.6
0°-90°	7261.0	100.0
90°-120°	0.0	0.0
90°-150°	0.0	0.0
90°-180°	0.0	0.0
0°-180°	7261.0	100.0

CANDELA DISTRIBUTION:

	0°	22.5°	45°	67.5°	90°	Flux
0°	2432	2432	2432	2432	2432	
5°	2412	2412	2388	2440	2404	228
15°	2311	2323	2330	2313	2352	652
25°	2146	2158	2140	2199	2195	986
35°	1908	1925	1934	1971	1966	1192
45°	1608	1638	1652	1670	1685	1242
55°	1261	1299	1346	1358	1332	1128
65°	865	898	950	985	982	861
75°	450	485	559	602	598	475
85°	73	124	197	239	254	98
90°	0	0	0	0	0	

TEST NUMBER: P1588551

CATALOG NUMBER: 24CZSP-75VHE-L950

CANDELA DISTRIBUTION (FULL):

	0°	22.5°	45°	67.5°	90°
0°	2432.3	2432.3	2432.3	2432.3	2432.3
2.5°	2425.4	2440.2	2421.4	2437.3	2437.3
5°	2412.5	2411.6	2387.8	2440.2	2403.7
7.5°	2353.2	2394.8	2378.0	2442.2	2420.5
10°	2378.0	2367.1	2383.9	2427.4	2400.7
12.5°	2353.2	2371.0	2344.4	2322.6	2350.3
15°	2310.8	2322.6	2329.5	2312.7	2352.3
17.5°	2260.3	2304.8	2281.1	2273.2	2318.7
20°	2242.6	2244.5	2246.5	2287.0	2282.1
22.5°	2169.4	2209.0	2204.0	2236.6	2240.6
25°	2145.7	2157.6	2139.8	2199.1	2195.1
27.5°	2091.3	2117.0	2114.1	2133.8	2144.7
30°	2032.0	2057.7	2075.5	2053.8	2087.4
32.5°	1970.8	2014.2	1994.5	2035.0	2028.1
35°	1907.5	1925.3	1934.2	1970.8	1965.8
37.5°	1834.4	1865.0	1869.9	1925.3	1901.6
40°	1764.2	1794.8	1798.8	1831.4	1832.4
42.5°	1690.1	1704.9	1725.7	1763.2	1760.2
45°	1608.0	1637.7	1651.5	1670.3	1685.1
47.5°	1529.0	1560.6	1578.4	1609.0	1574.4
50°	1449.9	1472.6	1495.4	1528.0	1525.0
52.5°	1350.1	1401.5	1412.3	1430.1	1442.0
55°	1261.1	1298.7	1346.1	1358.0	1332.3
57.5°	1171.2	1199.9	1234.4	1271.0	1268.0
60°	1071.4	1106.0	1148.5	1176.1	1178.1
62.5°	980.4	1004.2	1044.7	1085.2	1064.4
65°	864.8	898.4	949.8	985.4	982.4
67.5°	762.0	798.6	851.0	897.4	899.4
70°	671.1	690.9	762.0	797.6	806.5
72.5°	559.4	594.0	657.2	696.8	700.7
75°	449.7	485.3	559.4	601.9	597.9
77.5°	338.0	389.4	461.6	512.0	528.8
80°	238.2	284.6	366.7	416.1	443.8
82.5°	150.2	198.7	278.7	340.0	356.8
85°	73.1	124.5	196.7	239.2	254.0
87.5°	18.8	51.4	90.9	111.7	120.6
90°	0.0	0.0	0.0	0.0	0.0

TEST NUMBER: P1588551

CATALOG NUMBER: 24CZSP-75VHE-L950

CIE UGR TABLE:

Reflectances:											
Ceiling		0.7	0.7	0.5	0.5	0.3	0.7	0.7	0.5	0.5	0.3
Wall		0.5	0.3	0.5	0.3	0.3	0.5	0.3	0.5	0.3	0.3
Reference plane		0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2
Room dimensions		Viewed crosswise					Viewed endwise				
X=2H	Y=2H	16.37	18.04	16.74	18.36	18.67	16.80	18.47	17.17	18.79	19.10
	3H	18.17	19.69	18.55	20.01	20.37	18.88	20.39	19.25	20.72	21.08
	4H	18.82	20.25	19.21	20.60	20.97	19.72	21.15	20.12	21.50	21.87
	6H	19.23	20.56	19.64	20.92	21.31	20.51	21.84	20.92	22.20	22.59
	8H	19.33	20.60	19.75	20.99	21.39	20.85	22.12	21.27	22.51	22.91
	12H	19.37	20.59	19.80	20.98	21.40	21.15	22.37	21.58	22.75	23.18
4H	2H	17.11	18.54	17.51	18.89	19.26	17.44	18.88	17.84	19.22	19.60
	3H	19.15	20.35	19.55	20.75	21.15	19.76	20.97	20.17	21.36	21.76
	4H	19.92	21.01	20.35	21.42	21.86	20.76	21.86	21.19	22.27	22.71
	6H	20.45	21.41	20.91	21.85	22.31	21.72	22.68	22.17	23.12	23.57
	8H	20.60	21.50	21.06	21.94	22.40	22.14	23.04	22.60	23.48	23.95
	12H	20.68	21.49	21.16	21.96	22.43	22.52	23.33	23.00	23.81	24.27
8H	4H	20.37	21.27	20.83	21.71	22.17	21.10	22.00	21.56	22.45	22.91
	6H	21.05	21.80	21.54	22.29	22.76	22.22	22.97	22.71	23.46	23.93
	8H	21.26	21.94	21.77	22.45	22.93	22.77	23.44	23.27	23.95	24.43
	12H	21.41	22.01	21.92	22.50	23.06	23.28	23.88	23.79	24.37	24.93
12H	4H	20.45	21.26	20.93	21.74	22.20	21.14	21.95	21.62	22.42	22.89
	6H	21.18	21.86	21.69	22.36	22.85	22.28	22.96	22.79	23.47	23.95
	8H	21.48	22.07	21.98	22.56	23.12	22.91	23.51	23.41	24.00	24.56