

Cooper Lighting Solutions Photometric Lab  
1121 Highway 74 South  
Peachtree City, GA 30269



Scaled data based on original data using  
LM-79-2019 Approved Method: Electrical and Photometric Measurements of Solid-  
State Lighting Products

Test Report Prepared for  
Cooper Lighting Solutions

Brand: METALUX

Report Number: P976577

Luminaire Tested: 22SR-LD2-C-20-UNV-L830-CD1-PL-U

Issue Date: 03/18/2025

**Test Information**

Test Method: LM-79-2019  
Report Number: P976577  
Test Lab: INNOVATION CENTER(P3)  
Issue Date: 03/18/2025  
Manufacturer: COOPER LIGHTING SOLUTIONS  
Product Line: METALUX  
Catalog Number: 22SR-LD2-C-20-UNV-L830-CD1-PL-U  
Description: METALUX SKYRIDGE 2x2 2000LM PACKAGE 80CRI 3000K TROFFER with Pearl SKYTRIM  
Light Source: 3000K CCT, 80+ CRI LEDS  
Ballast/Driver: -


**Summary**

Lumens per Lamp: N/A  
Luminaire Lumens: 1784.0 lumens  
Efficiency: N/A  
Efficacy: 129.3 lumens/watt  
Spacing Criteria (0/90/45): 1.31 / 2 / 1.87  
Luminous Opening: Rectangular (W 2' x L: 2' x H: 0')  
CIE Type: Direct

Input Watts (W): 13.8  
Input Voltage (V): 120  
Input Current (A<sub>in</sub>): NR  
Voltage Rise (V): NR  
Power Factor: NR  
Total Harmonic Distortion (THDi): NR  
Frequency (hertz): 60  
Stabilization Time: NR  
Operation Time: NR  
Ambient Temperature (°C): NR  
Test Distance: 28.75 FT

TEST NUMBER: P976577  
CATALOG NUMBER: 22SR-LD2-C-20-UNV-L830-CD1-PL-U

### Luminous Intensity Polar Plot





TEST NUMBER: P976577

CATALOG NUMBER: 22SR-LD2-C-20-UNV-L830-CD1-PL-U

**COEFFICIENT OF UTILIZATION - ZONAL CAVITY METHOD:**

RF	20				20				20				20				20			
RC	80				70				50				30				10		0	
RW	70	50	30	10	70	50	30	10	50	30	10	50	30	10	50	30	10	50	30	10
RCR																				
0	119	119	119	119	116	116	116	116	111	111	111	106	106	106	102	102	102	100		
1	106	100	95	90	103	98	93	88	93	89	85	89	86	83	85	83	80	78		
2	95	85	77	70	92	83	76	69	79	73	68	76	71	66	73	68	64	62		
3	85	73	64	56	83	72	63	56	69	61	55	66	59	54	63	57	53	50		
4	78	64	54	47	75	63	53	46	60	52	46	58	51	45	55	49	44	42		
5	71	57	47	39	69	55	46	39	53	45	39	51	44	38	49	43	38	35		
6	65	51	41	34	63	50	40	34	48	39	33	46	39	33	44	38	33	30		
7	60	46	36	29	58	45	36	29	43	35	29	42	34	29	40	34	28	26		
8	56	41	32	26	54	41	32	26	39	31	26	38	31	25	37	30	25	23		
9	52	38	29	23	51	37	29	23	36	28	23	35	28	23	34	27	22	20		
10	49	35	26	21	47	34	26	21	33	26	20	32	25	20	31	25	20	18		

**AVERAGE LUMINANCE (cd/sqm):**

	0°	45°	90°
0°	865	865	865
5°	871	909	958
10°	873	1036	1141
15°	877	1161	1320
20°	878	1268	1469
25°	877	1358	1592
30°	878	1427	1675
35°	881	1473	1716
40°	882	1508	1732
45°	887	1539	1728
50°	887	1585	1728
55°	891	1657	1766
60°	890	1764	1856
65°	891	1917	2013
70°	901	2131	2228
75°	912	2453	2495
80°	956	2901	2868
85°	1059	3705	3788

**MAXIMUM LUMINANCE 45°-90°:**

Horizontal Angle: 85°  
 Vertical Angle: 87.5°  
 Luminance: 4948 cd/sqm



TEST NUMBER: P976577

CATALOG NUMBER: 22SR-LD2-C-20-UNV-L830-CD1-PL-U

**ZONAL LUMENS:**

Zone	Lumens	% Fixture
0°-10°	33.4	1.9
10°-20°	115.2	6.5
20°-30°	202.4	11.3
30°-40°	266.4	14.9
40°-50°	293.0	16.4
50°-60°	290.3	16.3
60°-70°	267.2	15.0
70°-80°	214.2	12.0
80°-90°	101.9	5.7
90°-100°	0.0	0.0
100°-110°	0.0	0.0
110°-120°	0.0	0.0
120°-130°	0.0	0.0
130°-140°	0.0	0.0
140°-150°	0.0	0.0
150°-160°	0.0	0.0
160°-170°	0.0	0.0
170°-180°	0.0	0.0
0°-30°	351.0	19.7
0°-40°	617.4	34.6
0°-60°	1200.7	67.3
0°-90°	1784.0	100.0
90°-120°	0.0	0.0
90°-150°	0.0	0.0
90°-180°	0.0	0.0
0°-180°	1784.0	100.0

**CANDELA DISTRIBUTION:**

	0°	22.5°	45°	67.5°	90°	Flux
0°	322	322	322	322	322	
5°	322	323	337	350	354	31
15°	315	356	417	458	474	89
25°	296	369	457	515	536	136
35°	268	357	448	504	522	168
45°	233	324	404	443	454	180
55°	190	282	353	374	376	170
65°	140	235	301	311	316	139
75°	88	177	236	239	240	93
85°	34	83	120	121	123	36
90°	0	0	0	0	0	



TEST NUMBER: P976577

CATALOG NUMBER: 22SR-LD2-C-20-UNV-L830-CD1-PL-U

**CANDELA DISTRIBUTION (FULL):**

	0°	5°	10°	15°	20°	25°	30°	35°	40°	45°	50°
0°	321.6	321.6	321.6	321.6	321.6	321.6	321.6	321.6	321.6	321.6	321.6
2.5°	322.3	323.0	322.3	322.3	322.3	322.3	322.3	322.3	322.3	322.3	323.0
5°	322.3	322.3	322.3	322.3	322.3	324.3	326.4	329.1	333.2	336.6	340.8
7.5°	321.6	321.6	321.6	322.3	326.4	331.8	338.7	345.6	353.1	359.3	364.8
10°	319.5	319.5	320.2	325.0	332.5	342.9	352.5	362.0	370.2	379.2	388.1
12.5°	318.2	318.2	320.2	329.1	340.8	353.8	365.4	377.2	388.8	399.0	409.3
15°	314.7	314.7	319.5	332.5	348.4	362.7	377.2	390.8	404.5	416.9	428.6
17.5°	311.3	311.3	318.8	335.9	353.1	369.5	386.1	402.5	417.6	431.3	444.3
20°	306.5	307.2	318.2	337.3	355.9	375.1	393.6	410.8	427.9	442.9	457.4
22.5°	301.7	302.3	316.8	338.0	357.9	378.5	398.4	417.6	435.4	451.2	466.9
25°	295.5	297.6	314.1	336.6	358.6	379.9	401.1	421.0	440.2	457.4	473.1
27.5°	289.3	292.1	310.6	333.9	357.2	379.2	401.1	422.4	441.5	460.1	475.8
30°	282.5	285.9	306.5	330.5	354.5	377.2	399.7	421.0	440.9	459.4	475.1
32.5°	275.7	279.1	301.0	325.7	349.7	373.0	395.6	417.6	436.8	455.3	471.7
35°	268.2	272.9	295.5	320.2	344.9	368.2	390.8	412.1	431.3	448.5	464.2
37.5°	259.2	265.3	288.0	313.4	338.0	361.3	383.3	404.5	423.1	439.5	454.6
40°	251.0	257.8	281.1	305.9	330.5	353.8	375.1	395.6	413.5	429.2	443.6
42.5°	242.8	250.3	272.9	297.6	321.6	344.9	366.1	385.4	402.5	416.9	430.6
45°	233.2	241.4	263.9	288.7	312.7	335.3	355.9	374.3	391.5	404.5	416.9
47.5°	222.8	232.5	255.1	279.8	303.0	325.0	345.6	362.7	378.5	392.2	403.2
50°	211.9	222.8	245.5	270.2	292.8	314.7	334.6	351.8	366.1	378.5	388.8
52.5°	201.6	212.6	235.2	259.2	282.5	304.5	323.6	340.1	353.8	366.1	375.1
55°	189.9	201.6	224.9	248.2	271.6	292.8	312.0	328.4	341.5	353.1	361.3
57.5°	178.3	190.6	213.2	237.3	259.8	281.8	301.0	316.8	329.8	340.1	347.7
60°	165.3	179.0	201.6	225.6	248.9	270.2	289.3	305.2	317.5	327.7	333.9
62.5°	152.9	166.7	190.6	213.9	236.6	258.5	277.7	292.8	305.2	314.7	320.2
65°	139.9	154.2	177.6	201.6	224.2	246.2	264.6	280.5	292.1	301.0	306.5
67.5°	127.6	141.9	164.6	187.9	210.5	233.2	251.0	266.0	277.7	286.6	291.4
70°	114.5	128.9	151.5	173.5	196.8	218.0	236.6	251.6	262.6	270.9	275.7
72.5°	101.5	116.5	137.2	159.7	181.7	203.7	220.8	235.9	246.9	254.4	258.5
75°	87.7	102.9	123.4	143.3	166.0	187.2	204.4	218.7	229.0	235.9	239.3
77.5°	74.7	88.4	108.3	128.3	148.1	168.7	185.1	199.6	207.8	213.9	217.4
80°	61.7	74.0	91.9	110.4	128.3	147.4	162.6	175.5	183.7	187.2	189.2
82.5°	48.6	59.7	73.4	89.9	105.6	121.3	135.1	146.0	152.2	157.0	158.3
85°	34.3	41.1	52.1	63.8	76.8	89.9	102.2	110.4	116.5	120.0	120.6
87.5°	17.9	20.6	26.1	32.9	42.5	51.4	58.3	63.8	68.6	72.0	75.4
90°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0



TEST NUMBER: P976577

CATALOG NUMBER: 22SR-LD2-C-20-UNV-L830-CD1-PL-U

**CANDELA DISTRIBUTION (continued):**

	55°	60°	65°	70°	75°	80°	85°	90°
0°	321.6	321.6	321.6	321.6	321.6	321.6	321.6	321.6
2.5°	323.0	323.0	324.3	324.3	325.0	325.0	324.3	325.0
5°	343.6	346.3	350.4	350.4	353.1	354.5	354.5	354.5
7.5°	368.9	373.0	377.9	380.6	384.0	386.1	386.7	386.7
10°	393.6	399.7	405.2	409.3	413.5	415.6	417.6	417.6
12.5°	416.9	424.4	431.3	436.8	441.5	444.3	446.4	447.1
15°	438.1	447.8	454.6	461.5	466.9	470.4	472.4	473.8
17.5°	456.0	466.3	474.5	481.3	487.6	491.7	495.1	495.8
20°	469.7	480.6	490.3	497.8	504.6	508.8	512.2	512.9
22.5°	479.9	492.3	502.6	510.8	517.7	522.5	525.3	526.6
25°	486.9	499.2	510.8	519.8	527.3	532.1	534.2	536.2
27.5°	490.3	503.3	514.9	523.9	531.4	536.2	538.9	539.6
30°	490.3	502.6	514.2	523.2	530.0	534.8	537.6	538.9
32.5°	485.5	497.8	508.8	517.7	523.9	528.7	531.4	532.8
35°	477.9	489.6	500.5	508.1	514.9	518.4	521.8	522.5
37.5°	467.6	478.6	488.9	495.8	501.9	505.3	508.1	508.8
40°	455.3	465.6	474.5	480.6	486.2	489.6	491.7	493.0
42.5°	441.5	450.5	458.1	463.5	467.6	471.0	472.4	473.8
45°	426.5	434.0	440.9	445.6	449.2	451.2	453.3	454.0
47.5°	411.5	418.3	423.8	427.9	429.2	431.3	432.0	432.7
50°	396.3	401.8	406.6	408.6	410.8	412.1	412.1	412.8
52.5°	381.3	386.7	388.8	391.5	392.9	393.6	393.6	393.6
55°	366.8	370.9	373.0	374.3	375.1	376.5	376.5	376.5
57.5°	353.1	355.9	356.6	357.9	358.6	360.0	360.0	360.0
60°	338.0	340.8	341.5	342.2	342.9	344.2	344.9	344.9
62.5°	324.3	326.4	325.7	327.1	327.7	329.1	330.5	331.2
65°	309.3	310.6	310.6	311.3	313.4	314.1	315.4	316.1
67.5°	294.1	294.8	294.8	296.2	297.6	298.9	299.6	300.3
70°	277.0	278.4	277.7	279.1	280.5	281.8	283.2	283.2
72.5°	259.2	259.8	260.5	259.8	261.2	262.6	263.3	263.9
75°	238.6	240.0	240.0	238.6	239.3	239.3	240.0	240.0
77.5°	214.6	213.9	211.9	210.5	210.5	211.2	211.2	211.9
80°	187.2	185.8	184.4	183.1	183.1	183.7	183.7	185.1
82.5°	157.0	155.6	154.2	153.6	154.2	154.2	154.9	155.6
85°	121.3	119.3	121.3	120.0	121.3	121.3	121.3	122.7
87.5°	75.4	76.1	78.1	77.5	76.8	77.5	80.2	78.8
90°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0



TEST NUMBER: P976577  
 CATALOG NUMBER: 22SR-LD2-C-20-UNV-L830-CD1-PL-U

**CIE UGR TABLE:**

Reflectances:											
Ceiling		0.7	0.7	0.5	0.5	0.3	0.7	0.7	0.5	0.5	0.3
Wall		0.5	0.3	0.5	0.3	0.3	0.5	0.3	0.5	0.3	0.3
Reference plane		0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2
Room Dimensions		Viewed crosswise					Viewed endwise				
X=2H	Y=2H	12.3	14.1	12.6	14.4	14.7	14.7	16.5	15.1	16.8	17.1
	3H	14.2	15.9	14.6	16.2	16.6	17.4	19.1	17.8	19.4	19.8
	4H	15.0	16.6	15.4	16.9	17.3	18.7	20.3	19.1	20.6	21.0
	6H	15.7	17.1	16.1	17.5	17.9	19.9	21.3	20.3	21.7	22.1
	8H	15.9	17.3	16.4	17.7	18.1	20.4	21.8	20.8	22.2	22.6
	12H	16.1	17.5	16.6	17.9	18.3	20.9	22.3	21.3	22.6	23.1
4H	2H	13.9	15.4	14.3	15.8	16.2	15.5	17.1	15.9	17.4	17.8
	3H	16.3	17.7	16.7	18.1	18.5	18.5	19.9	18.9	20.3	20.7
	4H	17.4	18.6	17.8	19.0	19.4	20.0	21.2	20.4	21.6	22.0
	6H	18.2	19.3	18.7	19.8	20.2	21.3	22.4	21.8	22.9	23.3
	8H	18.5	19.6	19.0	20.0	20.5	21.9	23.0	22.4	23.4	23.9
	12H	18.8	19.7	19.3	20.2	20.7	22.5	23.5	23.0	23.9	24.4
8H	4H	18.6	19.6	19.0	20.0	20.5	20.5	21.6	21.0	22.0	22.5
	6H	19.8	20.7	20.3	21.2	21.6	22.1	23.0	22.6	23.5	23.9
	8H	20.3	21.1	20.8	21.6	22.1	22.9	23.7	23.4	24.2	24.6
	12H	20.7	21.4	21.2	21.9	22.4	23.6	24.3	24.1	24.8	25.4
12H	4H	18.8	19.7	19.3	20.2	20.7	20.6	21.6	21.1	22.0	22.5
	6H	20.2	21.0	20.7	21.5	22.0	22.3	23.1	22.8	23.5	24.1
	8H	20.9	21.6	21.4	22.1	22.6	23.2	23.9	23.7	24.3	24.9

LM-79-2019: Approved Method: Electrical and Photometric Measurements of Solid-  
State Lighting Products

Report Prepared for

Cooper Lighting Solutions

Metalux

Report Number: SP1-2506-457-5

Test Date: 07/02/2025

Luminaire Tested: 24SR-LD2-64-C-UNV-L930-CD1-U

Data in this report applies to families of products including 24SR-LD2-64-C-UNV-L930-CD1-U

**Test Information**

Test Method: LM-79-2019  
 Report Number: SP1-2506-457-5  
 Test Lab: COOPER LIGHTING SOLUTIONS  
 Photometer: SP1 - 76IN SPHERE  
 Measurement Geometry: 4π  
 Issue Date: 07/02/2025  
 Manufacturer: COOPER LIGHTING SOLUTIONS  
 Product Line: Metalux  
 Catalog Number: **24SR-LD2-64-C-UNV-L930-CD1-U**  
 Description: 2X4 SKYRIDGE 6400LM Fixture with new LTN chip

**Spectral Parameters**

CCT (K): 2935  
 CIE u': 0.2530  
 CIE v': 0.5224  
 Duv: -0.0002  
 CIE x: 0.4413  
 CIE y: 0.4049  
 CIE z: 0.1538  
 Peak Wavelength (nm): 630  
 Dominant Wavelength (nm): 583  
 Purity: 53.99297  
 Rf: 91.8  
 Rg: 99.6

CRI (Ra):	93.5		
R1:	94.7	R9:	55.1
R2:	97.2	R10:	92.3
R3:	98.6	R11:	97.0
R4:	95.2	R12:	86.4
R5:	94.7	R13:	95.3
R6:	96.8	R14:	98.2
R7:	90.9	R15:	89.3
R8:	80.4		



**Test Conditions**

Stabilization Time: 40M  
 Operation Time: 1H 40M  
 Sphere Temperature (°C): 25.0

REPORT NUMBER: SP1-2506-457-5

Measurement and Test Equipment			
Instrument	Identification Number	Calibration Date	Calibration Due Date
Photometer	76INCH SPHERE IN0058	6/16/2025	12/16/2025
Power Meter	XITRON INXT2011004	1/21/2025	1/21/2026
AC Power Source	CHROMA 61603 IN0063	10/22/2024	10/22/2025
DC Power Source	AGILENT E3634A IN0208	10/22/2024	10/22/2025
Sphere Thermometer	ONSET IN0085	10/22/2024	10/22/2025
Room Thermometer	ONSET IN0046	10/22/2024	10/22/2025

REPORT NUMBER: SP1-2506-457-5

**CIE 1931 Chromaticity Diagram**




**CIE 1931 Chromaticity Diagram with 2017 ANSI 7-Step and 4-Step Quadrangles**



Point lies inside the ANSI 3000K 7-step quadrangle

REPORT NUMBER: SP1-2506-457-5

**Photopic Flux vs. Wavelength**



**Photopic Lumens: NR**

λ (nm)	Power W <sup>^</sup> /nm	Lumens (φ/nm)	λ (nm)	Power W <sup>^</sup> /nm	Lumens (φ/nm)	λ (nm)	Power W <sup>^</sup> /nm	Lumens (φ/nm)	λ (nm)	Power W <sup>^</sup> /nm	Lumens (φ/nm)	λ (nm)	Power W <sup>^</sup> /nm	Lumens (φ/nm)
360	0	NR	490	108	NR	620	338	NR	750	8	NR	880	0	NR
365	0	NR	495	129	NR	625	339	NR	755	7	NR	885	0	NR
370	0	NR	500	151	NR	630	1000	NR	760	6	NR	890	0	NR
375	0	NR	505	168	NR	635	695	NR	765	5	NR	895	0	NR
380	0	NR	510	179	NR	640	225	NR	770	4	NR	900	0	NR
385	0	NR	515	187	NR	645	214	NR	775	4	NR	905	0	NR
390	0	NR	520	194	NR	650	190	NR	780	3	NR	910	0	NR
395	1	NR	525	199	NR	655	160	NR	785	3	NR	915	0	NR
400	2	NR	530	205	NR	660	136	NR	790	2	NR	920	0	NR
405	2	NR	535	213	NR	665	115	NR	795	2	NR	925	0	NR
410	4	NR	540	219	NR	670	106	NR	800	2	NR	930	0	NR
415	7	NR	545	228	NR	675	87	NR	805	1	NR	935	0	NR
420	12	NR	550	236	NR	680	74	NR	810	1	NR	940	0	NR
425	20	NR	555	247	NR	685	64	NR	815	1	NR	945	0	NR
430	32	NR	560	257	NR	690	55	NR	820	1	NR	950	0	NR
435	50	NR	565	267	NR	695	47	NR	825	1	NR	955	0	NR
440	79	NR	570	277	NR	700	40	NR	830	1	NR	960	0	NR
445	133	NR	575	287	NR	705	34	NR	835	1	NR	965	0	NR
450	194	NR	580	297	NR	710	29	NR	840	1	NR	970	0	NR
455	168	NR	585	308	NR	715	24	NR	845	0	NR	975	0	NR
460	117	NR	590	315	NR	720	20	NR	850	0	NR	980	0	NR
465	101	NR	595	320	NR	725	17	NR	855	0	NR	985	0	NR
470	85	NR	600	327	NR	730	14	NR	860	0	NR	990	0	NR
475	73	NR	605	331	NR	735	12	NR	865	0	NR	995	0	NR
480	77	NR	610	367	NR	740	10	NR	870	0	NR	1000	0	NR
485	91	NR	615	398	NR	745	9	NR	875	0	NR			

REPORT NUMBER: SP1-2506-457-5

**Scotopic Flux vs. Wavelength**



**Scotopic Lumens: NR**

**S/P: 1.4**

$\lambda$ (nm)	Power W <sup>^</sup> /nm	Lumens ( $\phi$ /nm)	$\lambda$ (nm)	Power W <sup>^</sup> /nm	Lumens ( $\phi$ /nm)	$\lambda$ (nm)	Power W <sup>^</sup> /nm	Lumens ( $\phi$ /nm)	$\lambda$ (nm)	Power W <sup>^</sup> /nm	Lumens ( $\phi$ /nm)	$\lambda$ (nm)	Power W <sup>^</sup> /nm	Lumens ( $\phi$ /nm)
360	0	NR	490	108	NR	620	338	NR	750	8	NR	880	0	NR
365	0	NR	495	129	NR	625	339	NR	755	7	NR	885	0	NR
370	0	NR	500	151	NR	630	1000	NR	760	6	NR	890	0	NR
375	0	NR	505	168	NR	635	695	NR	765	5	NR	895	0	NR
380	0	NR	510	179	NR	640	225	NR	770	4	NR	900	0	NR
385	0	NR	515	187	NR	645	214	NR	775	4	NR	905	0	NR
390	0	NR	520	194	NR	650	190	NR	780	3	NR	910	0	NR
395	1	NR	525	199	NR	655	160	NR	785	3	NR	915	0	NR
400	2	NR	530	205	NR	660	136	NR	790	2	NR	920	0	NR
405	2	NR	535	213	NR	665	115	NR	795	2	NR	925	0	NR
410	4	NR	540	219	NR	670	106	NR	800	2	NR	930	0	NR
415	7	NR	545	228	NR	675	87	NR	805	1	NR	935	0	NR
420	12	NR	550	236	NR	680	74	NR	810	1	NR	940	0	NR
425	20	NR	555	247	NR	685	64	NR	815	1	NR	945	0	NR
430	32	NR	560	257	NR	690	55	NR	820	1	NR	950	0	NR
435	50	NR	565	267	NR	695	47	NR	825	1	NR	955	0	NR
440	79	NR	570	277	NR	700	40	NR	830	1	NR	960	0	NR
445	133	NR	575	287	NR	705	34	NR	835	1	NR	965	0	NR
450	194	NR	580	297	NR	710	29	NR	840	1	NR	970	0	NR
455	168	NR	585	308	NR	715	24	NR	845	0	NR	975	0	NR
460	117	NR	590	315	NR	720	20	NR	850	0	NR	980	0	NR
465	101	NR	595	320	NR	725	17	NR	855	0	NR	985	0	NR
470	85	NR	600	327	NR	730	14	NR	860	0	NR	990	0	NR
475	73	NR	605	331	NR	735	12	NR	865	0	NR	995	0	NR
480	77	NR	610	367	NR	740	10	NR	870	0	NR	1000	0	NR
485	91	NR	615	398	NR	745	9	NR	875	0	NR			

REPORT NUMBER: SP1-2506-457-5

**Melanopic Flux vs. Wavelength**



**Melanopic Lumens: NR**

**M/P: 2.72**

λ (nm)	Power W <sup>^</sup> /nm	Lumens (φ/nm)	λ (nm)	Power W <sup>^</sup> /nm	Lumens (φ/nm)	λ (nm)	Power W <sup>^</sup> /nm	Lumens (φ/nm)	λ (nm)	Power W <sup>^</sup> /nm	Lumens (φ/nm)	λ (nm)	Power W <sup>^</sup> /nm	Lumens (φ/nm)
360	0	NR	490	108	NR	620	338	NR	750	8	NR	880	0	NR
365	0	NR	495	129	NR	625	339	NR	755	7	NR	885	0	NR
370	0	NR	500	151	NR	630	1000	NR	760	6	NR	890	0	NR
375	0	NR	505	168	NR	635	695	NR	765	5	NR	895	0	NR
380	0	NR	510	179	NR	640	225	NR	770	4	NR	900	0	NR
385	0	NR	515	187	NR	645	214	NR	775	4	NR	905	0	NR
390	0	NR	520	194	NR	650	190	NR	780	3	NR	910	0	NR
395	1	NR	525	199	NR	655	160	NR	785	3	NR	915	0	NR
400	2	NR	530	205	NR	660	136	NR	790	2	NR	920	0	NR
405	2	NR	535	213	NR	665	115	NR	795	2	NR	925	0	NR
410	4	NR	540	219	NR	670	106	NR	800	2	NR	930	0	NR
415	7	NR	545	228	NR	675	87	NR	805	1	NR	935	0	NR
420	12	NR	550	236	NR	680	74	NR	810	1	NR	940	0	NR
425	20	NR	555	247	NR	685	64	NR	815	1	NR	945	0	NR
430	32	NR	560	257	NR	690	55	NR	820	1	NR	950	0	NR
435	50	NR	565	267	NR	695	47	NR	825	1	NR	955	0	NR
440	79	NR	570	277	NR	700	40	NR	830	1	NR	960	0	NR
445	133	NR	575	287	NR	705	34	NR	835	1	NR	965	0	NR
450	194	NR	580	297	NR	710	29	NR	840	1	NR	970	0	NR
455	168	NR	585	308	NR	715	24	NR	845	0	NR	975	0	NR
460	117	NR	590	315	NR	720	20	NR	850	0	NR	980	0	NR
465	101	NR	595	320	NR	725	17	NR	855	0	NR	985	0	NR
470	85	NR	600	327	NR	730	14	NR	860	0	NR	990	0	NR
475	73	NR	605	331	NR	735	12	NR	865	0	NR	995	0	NR
480	77	NR	610	367	NR	740	10	NR	870	0	NR	1000	0	NR
485	91	NR	615	398	NR	745	9	NR	875	0	NR			

**Summary**

$R_f = 91.8$   
 $R_g = 99.6$   
 $CIE R_a = 93.5$   
 $R_9 = 55.1$



**Color Vector Graphics**






Individual Sample Fidelity Index ( $R_{f,i}$ )

CES01 = 86	CES26 = 94	CES51 = 97	CES76 = 91
CES02 = 63	CES27 = 95	CES52 = 98	CES77 = 84
CES03 = 32	CES28 = 97	CES53 = 97	CES78 = 88
CES04 = 70	CES29 = 94	CES54 = 96	CES79 = 88
CES05 = 51	CES30 = 98	CES55 = 96	CES80 = 90
CES06 = 51	CES31 = 95	CES56 = 97	CES81 = 70
CES07 = 44	CES32 = 87	CES57 = 96	CES82 = 96
CES08 = 42	CES33 = 96	CES58 = 97	CES83 = 93
CES09 = 29	CES34 = 95	CES59 = 98	CES84 = 96
CES10 = 76	CES35 = 97	CES60 = 95	CES85 = 79
CES11 = 59	CES36 = 88	CES61 = 95	CES86 = 75
CES12 = 65	CES37 = 96	CES62 = 93	CES87 = 92
CES13 = 44	CES38 = 95	CES63 = 95	CES88 = 96
CES14 = 74	CES39 = 98	CES64 = 95	CES89 = 82
CES15 = 72	CES40 = 96	CES65 = 91	CES90 = 97
CES16 = 48	CES41 = 96	CES66 = 94	CES91 = 82
CES17 = 50	CES42 = 95	CES67 = 93	CES92 = 77
CES18 = 57	CES43 = 94	CES68 = 92	CES93 = 86
CES19 = 72	CES44 = 99	CES69 = 93	CES94 = 72
CES20 = 67	CES45 = 97	CES70 = 91	CES95 = 85
CES21 = 86	CES46 = 95	CES71 = 89	CES96 = 92
CES22 = 79	CES47 = 88	CES72 = 96	CES97 = 95
CES23 = 92	CES48 = 94	CES73 = 86	CES98 = 94
CES24 = 91	CES49 = 95	CES74 = 89	CES99 = 91
CES25 = 72	CES50 = 98	CES75 = 90	



Color Rendition by Hue-Angle Bin



Measure Comparisons



(END OF REPORT)