

Cooper Lighting Solutions Photometric Lab
1121 Highway 74 South
Peachtree City, GA 30269



Scaled data based on original data using
LM-79-2019 Approved Method: Electrical and Photometric Measurements of Solid-
State Lighting Products

Test Report Prepared for
Cooper Lighting Solutions

Brand: METALUX

Report Number: P976683

Luminaire Tested: 24SR-LD2-C-39-UNV-L835-CD1-BR-U

Issue Date: 03/18/2025

Test Information

Test Method: LM-79-2019
Report Number: P976683
Test Lab: INNOVATION CENTER(P3)
Issue Date: 03/18/2025
Manufacturer: COOPER LIGHTING SOLUTIONS
Product Line: METALUX
Catalog Number: 24SR-LD2-C-39-UNV-L835-CD1-BR-U
Description: METALUX SKYRIDGE 2x4 3900LM PACKAGE 80CRI 3500K TROFFER with Belladonna Rose SKYT
Light Source: 3500K CCT, 80+ CRI LEDS
Ballast/Driver: -


Summary

Lumens per Lamp: N/A
Luminaire Lumens: 2229.0 lumens
Efficiency: N/A
Efficacy: 80.5 lumens/watt
Spacing Criteria (0/90/45): 1.29 / 2.29 / 2.08
Luminous Opening: Rectangular (W 2' x L: 4' x H: 0')
CIE Type: Direct

Input Watts (W): 27.7
Input Voltage (V): 120
Input Current (A_{in}): NR
Voltage Rise (V): NR
Power Factor: NR
Total Harmonic Distortion (THDi): NR
Frequency (hertz): 60
Stabilization Time: NR
Operation Time: NR
Ambient Temperature (°C): NR
Test Distance: 28.75 FT

TEST NUMBER: P976683
CATALOG NUMBER: 24SR-LD2-C-39-UNV-L835-CD1-BR-U

Luminous Intensity Polar Plot





TEST NUMBER: P976683

CATALOG NUMBER: 24SR-LD2-C-39-UNV-L835-CD1-BR-U

COEFFICIENT OF UTILIZATION - ZONAL CAVITY METHOD:

RF	20				20				20				20				20				
RC	80				70				50				30				10			0	
RW	70	50	30	10	70	50	30	10	50	30	10	50	30	10	50	30	10	50	30	10	0
RCR																					
0	119	119	119	119	116	116	116	116	111	111	111	106	106	106	102	102	102	102	102	102	100
1	106	100	94	90	103	97	93	88	93	89	85	89	86	83	85	83	80	85	83	80	78
2	95	85	77	70	92	83	75	69	79	73	67	76	70	66	73	68	64	73	68	64	62
3	85	73	64	56	83	71	63	56	68	61	55	65	59	54	63	57	53	63	57	53	50
4	77	64	54	46	75	62	53	46	60	52	45	57	50	45	55	49	44	55	49	44	41
5	71	56	46	39	68	55	46	39	53	45	38	51	44	38	49	42	37	49	42	37	35
6	65	50	40	33	63	49	40	33	47	39	33	46	38	33	44	37	32	44	37	32	30
7	60	45	36	29	58	44	35	29	43	35	29	41	34	28	40	33	28	40	33	28	26
8	56	41	32	25	54	40	31	25	39	31	25	38	30	25	36	30	25	36	30	25	23
9	52	37	29	23	50	37	28	22	36	28	22	34	27	22	33	27	22	33	27	22	20
10	48	34	26	20	47	34	26	20	33	25	20	32	25	20	31	24	20	31	24	20	18

AVERAGE LUMINANCE (cd/sqm):

	0°	45°	90°
0°	432	432	432
5°	435	480	526
10°	435	599	697
15°	435	713	843
20°	434	802	956
25°	432	870	1041
30°	432	920	1100
35°	432	950	1131
40°	431	971	1145
45°	432	990	1148
50°	431	1018	1154
55°	432	1059	1173
60°	436	1121	1217
65°	434	1209	1291
70°	436	1333	1415
75°	438	1527	1585
80°	454	1851	1752
85°	523	2388	2161

MAXIMUM LUMINANCE 45°-90°:

Horizontal Angle: 45°
 Vertical Angle: 87.5°
 Luminance: 2909 cd/sqm



TEST NUMBER: P976683
 CATALOG NUMBER: 24SR-LD2-C-39-UNV-L835-CD1-BR-U

ZONAL LUMENS:

Zone	Lumens	% Fixture
0°-10°	36.1	1.6
10°-20°	137.8	6.2
20°-30°	252.0	11.3
30°-40°	335.1	15.0
40°-50°	368.9	16.6
50°-60°	365.6	16.4
60°-70°	334.7	15.0
70°-80°	269.5	12.1
80°-90°	129.3	5.8
90°-100°	0.0	0.0
100°-110°	0.0	0.0
110°-120°	0.0	0.0
120°-130°	0.0	0.0
130°-140°	0.0	0.0
140°-150°	0.0	0.0
150°-160°	0.0	0.0
160°-170°	0.0	0.0
170°-180°	0.0	0.0
0°-30°	425.8	19.1
0°-40°	760.9	34.1
0°-60°	1495.5	67.1
0°-90°	2229.0	100.0
90°-120°	0.0	0.0
90°-150°	0.0	0.0
90°-180°	0.0	0.0
0°-180°	2229.0	100.0

CANDELA DISTRIBUTION:

	0°	22.5°	45°	67.5°	90°	Flux
0°	321	321	321	321	321	
5°	322	325	355	380	389	31
15°	312	393	512	580	605	88
25°	291	436	586	671	701	134
35°	263	429	579	660	688	165
45°	227	387	520	583	603	175
55°	184	341	451	489	500	165
65°	136	295	380	396	406	135
75°	84	230	294	302	305	89
85°	34	125	155	142	140	35
90°	0	0	0	0	0	



TEST NUMBER: P976683

CATALOG NUMBER: 24SR-LD2-C-39-UNV-L835-CD1-BR-U

CANDELA DISTRIBUTION (FULL):

	0°	5°	10°	15°	20°	25°	30°	35°	40°	45°	50°
0°	321.3	321.3	321.3	321.3	321.3	321.3	321.3	321.3	321.3	321.3	321.3
2.5°	323.1	323.1	322.3	322.3	322.3	322.3	322.3	322.3	323.1	325.0	326.0
5°	322.3	322.3	322.3	322.3	323.1	326.8	331.4	338.8	346.0	355.3	363.4
7.5°	320.4	320.4	320.4	323.1	331.4	344.2	356.1	369.8	383.6	397.3	408.4
10°	318.6	318.6	320.4	330.5	347.0	366.2	384.5	402.8	420.2	438.5	454.1
12.5°	315.9	315.9	321.3	339.6	363.4	387.3	411.1	433.0	455.0	477.9	495.3
15°	312.2	312.2	324.1	348.8	378.1	407.4	434.8	461.4	487.1	511.8	531.0
17.5°	307.6	309.5	326.8	358.0	390.9	424.9	455.0	485.2	512.7	538.3	561.2
20°	303.1	305.8	329.5	365.3	402.0	439.4	472.4	503.6	532.9	560.3	584.1
22.5°	297.5	301.2	331.4	370.8	410.2	449.5	484.3	517.2	548.4	575.8	600.6
25°	291.1	296.7	332.4	373.5	416.6	455.9	491.6	525.5	557.5	585.9	610.7
27.5°	285.6	293.0	331.4	375.4	419.3	459.6	496.2	530.0	563.0	591.5	617.1
30°	278.3	287.4	329.5	374.5	418.3	459.6	495.3	530.0	563.0	592.3	617.1
32.5°	271.1	282.0	325.0	370.8	415.6	455.0	491.6	526.5	558.5	587.8	611.6
35°	262.8	275.6	319.6	365.3	409.2	448.6	484.3	518.2	551.1	578.6	602.4
37.5°	254.5	268.2	312.2	358.0	401.0	439.4	474.2	508.1	539.3	567.6	589.6
40°	245.3	261.0	304.9	349.7	390.9	428.4	463.3	496.2	526.5	552.9	574.0
42.5°	236.2	252.7	296.7	340.6	380.9	416.6	451.3	482.5	511.8	537.4	556.6
45°	227.1	243.6	286.6	330.5	369.0	404.7	437.7	468.7	496.2	520.1	538.3
47.5°	216.0	234.4	277.5	319.6	357.0	392.7	424.9	454.1	481.5	502.6	520.1
50°	206.0	225.2	267.4	308.5	345.2	380.9	411.9	440.4	466.0	486.2	501.7
52.5°	195.1	215.1	257.3	298.5	335.1	369.0	400.1	426.6	449.5	468.7	483.4
55°	184.0	205.0	248.1	287.4	324.1	358.0	387.3	412.9	434.8	451.3	465.1
57.5°	173.0	195.1	238.0	278.3	314.0	347.0	375.4	398.3	419.3	434.0	445.8
60°	162.1	185.0	227.1	267.4	303.9	335.1	362.6	384.5	402.8	416.6	426.6
62.5°	149.3	174.0	217.0	256.4	292.1	322.3	348.8	369.0	386.3	398.3	406.5
65°	136.4	162.9	206.0	245.3	280.2	309.5	334.2	353.4	369.0	379.9	385.5
67.5°	123.6	152.0	195.1	234.4	267.4	294.8	318.6	336.9	350.6	359.8	364.4
70°	110.8	139.2	182.1	220.7	252.7	278.3	301.2	318.6	330.5	338.8	342.4
72.5°	97.0	126.4	168.5	206.0	236.2	261.8	282.9	299.4	310.3	316.7	319.6
75°	84.2	112.6	153.8	189.5	217.9	241.7	261.8	278.3	289.3	293.8	296.7
77.5°	70.4	98.9	138.3	171.2	197.8	219.7	238.9	254.5	264.6	269.2	271.9
80°	58.6	84.2	119.9	150.1	174.9	195.9	213.3	229.8	238.0	238.9	236.2
82.5°	45.8	69.6	100.7	127.2	148.3	168.5	185.0	195.9	199.6	199.6	196.8
85°	33.9	52.2	78.7	99.8	118.1	132.8	142.9	152.0	153.8	154.7	151.1
87.5°	19.2	29.3	46.7	60.5	71.4	81.5	88.8	93.3	93.3	94.3	92.5
90°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0



TEST NUMBER: P976683

CATALOG NUMBER: 24SR-LD2-C-39-UNV-L835-CD1-BR-U

CANDELA DISTRIBUTION (continued):

	55°	60°	65°	70°	75°	80°	85°	90°
0°	321.3	321.3	321.3	321.3	321.3	321.3	321.3	321.3
2.5°	326.0	327.7	327.7	329.5	330.5	330.5	331.4	331.4
5°	367.1	374.5	377.2	381.8	384.5	388.2	390.0	389.2
7.5°	416.6	427.6	433.0	439.4	446.8	448.6	451.3	451.3
10°	466.0	478.8	487.1	494.4	502.6	506.3	510.0	510.0
12.5°	510.8	523.6	534.7	543.8	552.1	557.5	561.2	562.2
15°	547.5	564.0	575.0	585.1	594.2	599.6	604.3	605.2
17.5°	577.7	593.2	607.9	618.9	627.1	635.3	638.2	640.0
20°	601.5	618.0	633.6	644.6	653.7	661.9	665.6	667.5
22.5°	618.9	636.3	651.8	663.8	672.9	681.1	685.7	687.5
25°	629.9	648.1	664.6	676.6	686.7	694.9	699.5	701.3
27.5°	637.2	655.5	671.0	683.0	693.1	701.3	705.9	708.6
30°	637.2	655.5	671.0	683.0	693.1	701.3	705.9	707.7
32.5°	631.8	650.0	665.6	676.6	686.7	694.9	699.5	701.3
35°	621.7	640.0	654.7	665.6	675.7	683.0	687.5	688.5
37.5°	607.9	625.4	639.0	650.0	659.2	666.5	671.0	672.0
40°	592.3	608.8	621.7	631.8	640.0	646.4	651.0	651.8
42.5°	574.0	589.6	600.6	610.7	618.0	624.4	628.9	628.1
45°	554.8	569.4	578.6	586.8	595.1	599.6	603.3	603.3
47.5°	535.6	547.5	555.8	563.0	569.4	574.0	576.8	576.8
50°	515.5	525.5	532.9	539.3	544.7	548.4	551.1	551.1
52.5°	495.3	504.4	510.0	515.5	520.1	522.8	525.5	524.6
55°	475.1	482.5	486.2	491.6	495.3	499.0	500.8	499.9
57.5°	455.0	459.6	463.3	467.8	471.5	475.1	476.1	477.0
60°	433.0	437.7	440.4	444.9	448.6	451.3	453.2	452.3
62.5°	411.9	414.8	417.5	421.2	423.9	427.6	428.4	428.4
65°	389.2	391.9	394.6	398.3	401.0	404.7	406.5	405.5
67.5°	367.1	369.8	372.6	375.4	379.1	382.7	383.6	383.6
70°	344.2	347.0	348.8	352.5	355.3	358.9	359.8	359.8
72.5°	322.3	324.1	326.0	329.5	331.4	334.2	336.0	336.0
75°	297.5	299.4	301.2	303.1	303.9	304.9	305.8	304.9
77.5°	270.1	268.2	266.4	266.4	264.6	265.5	266.4	265.5
80°	232.5	230.7	228.9	227.9	226.1	226.1	227.1	226.1
82.5°	193.2	189.5	187.7	186.8	185.0	185.0	185.0	185.0
85°	145.6	143.7	142.9	141.0	139.2	138.3	139.2	140.0
87.5°	90.6	88.8	86.9	85.1	84.2	83.4	85.1	82.4
90°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0



TEST NUMBER: P976683

CATALOG NUMBER: 24SR-LD2-C-39-UNV-L835-CD1-BR-U

CIE UGR TABLE:

Reflectances:											
Ceiling		0.7	0.7	0.5	0.5	0.3	0.7	0.7	0.5	0.5	0.3
Wall		0.5	0.3	0.5	0.3	0.3	0.5	0.3	0.5	0.3	0.3
Reference plane		0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2
Room Dimensions		Viewed crosswise					Viewed endwise				
X=2H	Y=2H	10.4	12.1	10.7	12.5	12.8	13.4	15.2	13.8	15.5	15.8
	3H	12.3	14.0	12.7	14.3	14.7	16.0	17.7	16.4	18.0	18.3
	4H	13.1	14.7	13.5	15.0	15.4	17.3	18.8	17.7	19.2	19.5
	6H	13.7	15.2	14.1	15.5	15.9	18.4	19.8	18.8	20.2	20.6
	8H	13.9	15.3	14.4	15.7	16.1	18.9	20.3	19.3	20.7	21.0
	12H	14.1	15.5	14.5	15.8	16.3	19.3	20.6	19.7	21.0	21.4
4H	2H	12.1	13.7	12.5	14.0	14.4	14.1	15.7	14.5	16.0	16.4
	3H	14.6	16.0	15.0	16.3	16.7	17.0	18.4	17.5	18.8	19.2
	4H	15.7	16.9	16.1	17.3	17.8	18.5	19.7	18.9	20.1	20.6
	6H	16.6	17.7	17.1	18.1	18.6	19.8	20.9	20.2	21.3	21.8
	8H	16.9	18.0	17.4	18.4	18.9	20.3	21.4	20.8	21.8	22.3
	12H	17.2	18.1	17.7	18.6	19.1	20.9	21.8	21.3	22.3	22.7
8H	4H	16.9	17.9	17.4	18.4	18.8	19.0	20.1	19.5	20.5	21.0
	6H	18.3	19.1	18.7	19.6	20.1	20.5	21.4	21.0	21.9	22.4
	8H	18.8	19.6	19.3	20.1	20.6	21.3	22.0	21.7	22.5	23.0
	12H	19.3	20.0	19.8	20.5	21.1	21.9	22.6	22.4	23.1	23.7
12H	4H	17.1	18.1	17.6	18.6	19.0	19.1	20.1	19.6	20.5	21.0
	6H	18.7	19.5	19.2	19.9	20.4	20.7	21.5	21.3	22.0	22.5
	8H	19.4	20.1	19.9	20.6	21.2	21.5	22.2	22.0	22.7	23.3

LM-79-2019: Approved Method: Electrical and Photometric Measurements of Solid-State Lighting Products

Report Prepared for

Cooper Lighting Solutions

Metalux

Report Number: SP1-2506-457-6

Test Date: 07/01/2025

Luminaire Tested: 24SR-LD2-64-C-UNV-L935-CD1-U

Data in this report applies to families of products including 24SR-LD2-64-C-UNV-L935-CD1-U

Test Information

Test Method: LM-79-2019
 Report Number: SP1-2506-457-6
 Test Lab: COOPER LIGHTING SOLUTIONS
 Photometer: SP1 - 76IN SPHERE
 Measurement Geometry: 4π
 Issue Date: 07/02/2025
 Manufacturer: COOPER LIGHTING SOLUTIONS
 Product Line: Metalux
 Catalog Number: **24SR-LD2-64-C-UNV-L935-CD1-U**
 Description: 2X4 SKYRIDGE 6400LM Fixture with new LTN chip

Spectral Parameters

CCT (K): 3329
 CIE u': 0.2411
 CIE v': 0.5118
 Duv: -0.0021
 CIE x: 0.4128
 CIE y: 0.3894
 CIE z: 0.1979
 Peak Wavelength (nm): 630
 Dominant Wavelength (nm): 582
 Purity: 40.74075
 Rf: 91.4
 Rg: 100.2

CRI (Ra):	93.9		
R1:	95.4	R9:	60.5
R2:	97.4	R10:	92.5
R3:	97.7	R11:	95.9
R4:	94.9	R12:	82.0
R5:	95.1	R13:	96.0
R6:	95.7	R14:	98.0
R7:	91.7	R15:	91.5
R8:	83.2		



Test Conditions

Stabilization Time: 48M
 Operation Time: 1H 48M
 Sphere Temperature (°C): 24.0

REPORT NUMBER: SP1-2506-457-6

Measurement and Test Equipment			
Instrument	Identification Number	Calibration Date	Calibration Due Date
Photometer	76INCH SPHERE IN0058	6/16/2025	12/16/2025
Power Meter	XITRON INXT2011004	1/21/2025	1/21/2026
AC Power Source	CHROMA 61603 IN0063	10/22/2024	10/22/2025
DC Power Source	AGILENT E3634A IN0208	10/22/2024	10/22/2025
Sphere Thermometer	ONSET IN0085	10/22/2024	10/22/2025
Room Thermometer	ONSET IN0046	10/22/2024	10/22/2025

REPORT NUMBER: SP1-2506-457-6

CIE 1931 Chromaticity Diagram



CIE 1931 Chromaticity Diagram with 2017 ANSI 7-Step and 4-Step Quadrangles



Point lies inside the ANSI 3500K 7-step quadrangle

REPORT NUMBER: SP1-2506-457-6

Photopic Flux vs. Wavelength



Photopic Lumens: NR

λ (nm)	Power W [^] /nm	Lumens (ϕ /nm)	λ (nm)	Power W [^] /nm	Lumens (ϕ /nm)	λ (nm)	Power W [^] /nm	Lumens (ϕ /nm)	λ (nm)	Power W [^] /nm	Lumens (ϕ /nm)	λ (nm)	Power W [^] /nm	Lumens (ϕ /nm)
360	0	NR	490	143	NR	620	358	NR	750	9	NR	880	0	NR
365	0	NR	495	166	NR	625	357	NR	755	7	NR	885	0	NR
370	0	NR	500	191	NR	630	1000	NR	760	6	NR	890	0	NR
375	0	NR	505	210	NR	635	705	NR	765	5	NR	895	0	NR
380	0	NR	510	223	NR	640	239	NR	770	5	NR	900	0	NR
385	0	NR	515	233	NR	645	226	NR	775	4	NR	905	0	NR
390	1	NR	520	240	NR	650	201	NR	780	3	NR	910	0	NR
395	2	NR	525	246	NR	655	170	NR	785	3	NR	915	0	NR
400	3	NR	530	251	NR	660	145	NR	790	2	NR	920	0	NR
405	4	NR	535	260	NR	665	123	NR	795	2	NR	925	0	NR
410	6	NR	540	267	NR	670	113	NR	800	2	NR	930	0	NR
415	9	NR	545	276	NR	675	93	NR	805	2	NR	935	0	NR
420	16	NR	550	284	NR	680	80	NR	810	1	NR	940	0	NR
425	28	NR	555	294	NR	685	69	NR	815	1	NR	945	0	NR
430	46	NR	560	303	NR	690	59	NR	820	1	NR	950	0	NR
435	75	NR	565	313	NR	695	51	NR	825	1	NR	955	0	NR
440	120	NR	570	319	NR	700	43	NR	830	1	NR	960	0	NR
445	203	NR	575	327	NR	705	37	NR	835	1	NR	965	0	NR
450	311	NR	580	336	NR	710	31	NR	840	1	NR	970	0	NR
455	290	NR	585	344	NR	715	26	NR	845	1	NR	975	0	NR
460	197	NR	590	349	NR	720	22	NR	850	0	NR	980	0	NR
465	163	NR	595	350	NR	725	18	NR	855	0	NR	985	0	NR
470	135	NR	600	355	NR	730	15	NR	860	0	NR	990	0	NR
475	110	NR	605	357	NR	735	13	NR	865	0	NR	995	0	NR
480	108	NR	610	391	NR	740	11	NR	870	0	NR	1000	0	NR
485	123	NR	615	421	NR	745	10	NR	875	0	NR			

REPORT NUMBER: SP1-2506-457-6

Scotopic Flux vs. Wavelength



Scotopic Lumens: NR

S/P: 1.57

λ (nm)	Power W [^] /nm	Lumens (φ/nm)	λ (nm)	Power W [^] /nm	Lumens (φ/nm)	λ (nm)	Power W [^] /nm	Lumens (φ/nm)	λ (nm)	Power W [^] /nm	Lumens (φ/nm)	λ (nm)	Power W [^] /nm	Lumens (φ/nm)
360	0	NR	490	143	NR	620	358	NR	750	9	NR	880	0	NR
365	0	NR	495	166	NR	625	357	NR	755	7	NR	885	0	NR
370	0	NR	500	191	NR	630	1000	NR	760	6	NR	890	0	NR
375	0	NR	505	210	NR	635	705	NR	765	5	NR	895	0	NR
380	0	NR	510	223	NR	640	239	NR	770	5	NR	900	0	NR
385	0	NR	515	233	NR	645	226	NR	775	4	NR	905	0	NR
390	1	NR	520	240	NR	650	201	NR	780	3	NR	910	0	NR
395	2	NR	525	246	NR	655	170	NR	785	3	NR	915	0	NR
400	3	NR	530	251	NR	660	145	NR	790	2	NR	920	0	NR
405	4	NR	535	260	NR	665	123	NR	795	2	NR	925	0	NR
410	6	NR	540	267	NR	670	113	NR	800	2	NR	930	0	NR
415	9	NR	545	276	NR	675	93	NR	805	2	NR	935	0	NR
420	16	NR	550	284	NR	680	80	NR	810	1	NR	940	0	NR
425	28	NR	555	294	NR	685	69	NR	815	1	NR	945	0	NR
430	46	NR	560	303	NR	690	59	NR	820	1	NR	950	0	NR
435	75	NR	565	313	NR	695	51	NR	825	1	NR	955	0	NR
440	120	NR	570	319	NR	700	43	NR	830	1	NR	960	0	NR
445	203	NR	575	327	NR	705	37	NR	835	1	NR	965	0	NR
450	311	NR	580	336	NR	710	31	NR	840	1	NR	970	0	NR
455	290	NR	585	344	NR	715	26	NR	845	1	NR	975	0	NR
460	197	NR	590	349	NR	720	22	NR	850	0	NR	980	0	NR
465	163	NR	595	350	NR	725	18	NR	855	0	NR	985	0	NR
470	135	NR	600	355	NR	730	15	NR	860	0	NR	990	0	NR
475	110	NR	605	357	NR	735	13	NR	865	0	NR	995	0	NR
480	108	NR	610	391	NR	740	11	NR	870	0	NR	1000	0	NR
485	123	NR	615	421	NR	745	10	NR	875	0	NR			

REPORT NUMBER: SP1-2506-457-6

Melanopic Flux vs. Wavelength



Melanopic Lumens: NR

M/P: 3.17

λ (nm)	Power W [^] /nm	Lumens (φ/nm)	λ (nm)	Power W [^] /nm	Lumens (φ/nm)	λ (nm)	Power W [^] /nm	Lumens (φ/nm)	λ (nm)	Power W [^] /nm	Lumens (φ/nm)	λ (nm)	Power W [^] /nm	Lumens (φ/nm)
360	0	NR	490	143	NR	620	358	NR	750	9	NR	880	0	NR
365	0	NR	495	166	NR	625	357	NR	755	7	NR	885	0	NR
370	0	NR	500	191	NR	630	1000	NR	760	6	NR	890	0	NR
375	0	NR	505	210	NR	635	705	NR	765	5	NR	895	0	NR
380	0	NR	510	223	NR	640	239	NR	770	5	NR	900	0	NR
385	0	NR	515	233	NR	645	226	NR	775	4	NR	905	0	NR
390	1	NR	520	240	NR	650	201	NR	780	3	NR	910	0	NR
395	2	NR	525	246	NR	655	170	NR	785	3	NR	915	0	NR
400	3	NR	530	251	NR	660	145	NR	790	2	NR	920	0	NR
405	4	NR	535	260	NR	665	123	NR	795	2	NR	925	0	NR
410	6	NR	540	267	NR	670	113	NR	800	2	NR	930	0	NR
415	9	NR	545	276	NR	675	93	NR	805	2	NR	935	0	NR
420	16	NR	550	284	NR	680	80	NR	810	1	NR	940	0	NR
425	28	NR	555	294	NR	685	69	NR	815	1	NR	945	0	NR
430	46	NR	560	303	NR	690	59	NR	820	1	NR	950	0	NR
435	75	NR	565	313	NR	695	51	NR	825	1	NR	955	0	NR
440	120	NR	570	319	NR	700	43	NR	830	1	NR	960	0	NR
445	203	NR	575	327	NR	705	37	NR	835	1	NR	965	0	NR
450	311	NR	580	336	NR	710	31	NR	840	1	NR	970	0	NR
455	290	NR	585	344	NR	715	26	NR	845	1	NR	975	0	NR
460	197	NR	590	349	NR	720	22	NR	850	0	NR	980	0	NR
465	163	NR	595	350	NR	725	18	NR	855	0	NR	985	0	NR
470	135	NR	600	355	NR	730	15	NR	860	0	NR	990	0	NR
475	110	NR	605	357	NR	735	13	NR	865	0	NR	995	0	NR
480	108	NR	610	391	NR	740	11	NR	870	0	NR	1000	0	NR
485	123	NR	615	421	NR	745	10	NR	875	0	NR			

Summary

$R_f = 91.4$
 $R_g = 100.2$
 $CIE R_a = 93.9$
 $R_9 = 60.5$




Color Vector Graphics



Individual Sample Fidelity Index ($R_{f,i}$)

CES01 = 86	CES26 = 93	CES51 = 98	CES76 = 88
CES02 = 63	CES27 = 93	CES52 = 98	CES77 = 87
CES03 = 31	CES28 = 96	CES53 = 97	CES78 = 85
CES04 = 70	CES29 = 95	CES54 = 95	CES79 = 91
CES05 = 50	CES30 = 96	CES55 = 94	CES80 = 92
CES06 = 51	CES31 = 95	CES56 = 96	CES81 = 75
CES07 = 43	CES32 = 87	CES57 = 95	CES82 = 96
CES08 = 42	CES33 = 97	CES58 = 96	CES83 = 94
CES09 = 29	CES34 = 94	CES59 = 98	CES84 = 95
CES10 = 75	CES35 = 96	CES60 = 94	CES85 = 80
CES11 = 58	CES36 = 84	CES61 = 93	CES86 = 79
CES12 = 64	CES37 = 95	CES62 = 89	CES87 = 91
CES13 = 44	CES38 = 91	CES63 = 94	CES88 = 97
CES14 = 74	CES39 = 99	CES64 = 92	CES89 = 83
CES15 = 72	CES40 = 97	CES65 = 90	CES90 = 98
CES16 = 48	CES41 = 97	CES66 = 90	CES91 = 77
CES17 = 49	CES42 = 93	CES67 = 89	CES92 = 77
CES18 = 56	CES43 = 92	CES68 = 89	CES93 = 86
CES19 = 71	CES44 = 99	CES69 = 91	CES94 = 74
CES20 = 67	CES45 = 96	CES70 = 88	CES95 = 84
CES21 = 86	CES46 = 96	CES71 = 84	CES96 = 92
CES22 = 78	CES47 = 91	CES72 = 94	CES97 = 95
CES23 = 91	CES48 = 94	CES73 = 83	CES98 = 94
CES24 = 90	CES49 = 94	CES74 = 91	CES99 = 92
CES25 = 71	CES50 = 98	CES75 = 86	



Color Rendition by Hue-Angle Bin



Measure Comparisons



(END OF REPORT)