Cooper Lighting Solutions Photometric Lab
1121 Highway 74 South
Peachtree City, GA 30269

Scaled data based on original data using

LM-79-08 Approved Method: Electrical and Photometric Measurements of Solid-State Lighting Products

Test Report Prepared for

Cooper Lighting Solutions

(formerly Eaton)

Brand: McGRAW-EDISON

Report Number: P1390194

Luminaire Tested: **GSS-SA3D-935-U-RBC**

Issue Date: 02/18/2026

This test was performed under the Supervised Manufacturer's Testing Program. The results of this test have not been influenced by sources from within Cooper Lighting Solutions or from external interests.

Report Generated By 670245763

Cooper Lighting Solutions Photometric Lab
1121 Highway 74 South
Peachtree City, GA 30269

Scaled Data Report

Test Information

Test Method:	LM-79-08
Report Number:	P1390194
Test Lab:	INNOVATION CENTER(G3)
Issue Date:	02/18/2026
Manufacturer:	COOPER LIGHTING SOLUTIONS (FORMERLY EATON)
Product Line:	McGRAW-EDISON
Catalog Number:	GSS-SA3D-935-U-RBC
Description:	GALLEON SLIM SITE LUMINAIRE 1200mA 3xLight Square PACKAGE 90CRI 3500K FIXTURE w/ RIGHT CORNER BACKLIGHT CONTROL
Light Source:	(42) 3500K CCT, 90 CRI LEDS
Ballast/Driver:	ELECTRONIC DRIVER

Luminaire Equipment:

Sample No.	Condition	Description
a	good	reflector
b	good	lens
c	good	housing
d	good	cord

Summary

Lumens per Lamp:	N/A
Luminaire Lumens:	10117.8 lumens
Efficiency:	N/A
Efficacy:	62.9 lumens/watt
Luminous Opening:	Rectangular (W 1.5' x L: 0.5' x H: 0')
IES Classification:	Type III - Short
BUG Rating:	B0 - U0 - G2


Input Watts (W):	160.9
Input Voltage (V):	120
Input Current (Ain):	NR
Voltage Rise (V):	NR
Power Factor:	0.97
Total Harmonic Distortion (THDi):	NR
Frequency (hertz):	60
Stabilization Time:	NR
Operation Time:	NR
Ambient Temperature (°C):	NR
Test Distance:	28.75 FT

Cooper Lighting Solutions Photometric Lab
1121 Highway 74 South
Peachtree City, GA 30269

Scaled Data Report

REPORT NUMBER: P1390194
CATALOG NUMBER: GSS-SA3D-935-U-RBC

Iso-Footcandle Lines of Horizontal Illumination




Based on 20 foot mounting height. Maximum calculated value = 0.5 fc
Type III - Short - N/A

Cooper Lighting Solutions Photometric Lab
1121 Highway 74 South
Peachtree City, GA 30269

Scaled Data Report

REPORT NUMBER: P1390194
CATALOG NUMBER: GSS-SA3D-935-U-RBC

Luminous Intensity Polar Plot



Cooper Lighting Solutions Photometric Lab
1121 Highway 74 South
Peachtree City, GA 30269

Scaled Data Report


REPORT NUMBER: P1390194
CATALOG NUMBER: GSS-SA3D-935-U-RBC

FLUX DISTRIBUTION:

		Downward	Upward	Total
House Side	Lumens	72.2	0.0	72.2
	% Fixture	0.7	0.0	0.7
Street Side	Lumens	10045.6	0.0	10045.6
	% Fixture	99.3	0.0	99.3
Total	Lumens	10117.8	0.0	10117.8
	% Fixture	100.0	0.0	100.0

ZONAL LUMENS:

Zone	Lumens	% Fixture
0°-10°	3.5	0.0
10°-20°	17.1	0.2
20°-30°	219.0	2.2
30°-40°	682.8	6.7
40°-50°	2230.2	22.0
50°-60°	3579.7	35.4
60°-70°	2748.5	27.2
70°-80°	625.9	6.2
80°-90°	11.1	0.1
90°-100°	0.0	0.0
100°-110°	0.0	0.0
110°-120°	0.0	0.0
120°-130°	0.0	0.0
130°-140°	0.0	0.0
140°-150°	0.0	0.0
150°-160°	0.0	0.0
160°-170°	0.0	0.0
170°-180°	0.0	0.0
0°-90°	10117.8	100.0
0°-180°	10117.8	100.0



Cooper Lighting Solutions Photometric Lab
1121 Highway 74 South
Peachtree City, GA 30269


Scaled Data Report

REPORT NUMBER: P1390194
CATALOG NUMBER: GSS-SA3D-935-U-RBC

LUMINAIRE CLASSIFICATION SYSTEM LUMEN TABLE AND BUG RATING:

Zone		Lumens	% Fixture	Zone Rating/Lumen Limit B	U	G
FL	(0°-30°)	229.2	2.3			
FM	(30°-60°)	6462.3	63.9			
FH	(60°-80°)	3346.3	33.1			G2/5000
FVH	(80°-90°)	7.9	0.1			G0/10
BL	(0°-30°)	10.4	0.1	B0/110		
BM	(30°-60°)	30.4	0.3	B0/220		
BH	(60°-80°)	28.2	0.3	B0/110		G0/110
BVH	(80°-90°)	3.2	0.0			G0/10
UL	(90°-100°)	0.0	0.0		U0/0	
UH	(100°-180°)	0.0	0.0		U0/0	

BUG Rating: B0-U0-G2
Type III Short



Cooper Lighting Solutions Photometric Lab
1121 Highway 74 South
Peachtree City, GA 30269

Scaled Data Report

REPORT NUMBER: P1390194
CATALOG NUMBER: GSS-SA3D-935-U-RBC

CANDELA DISTRIBUTION (FULL):

	0°	2.5°	5°	7.5°	10°	12.5°	15°	17.5°	20°	22.5°	25°
0°	37.3	37.3	37.3	37.3	37.3	37.3	37.3	37.3	37.3	37.3	37.3
2.5°	34.2	34.2	34.2	34.2	34.2	31.1	31.1	31.1	31.1	31.1	31.1
5°	37.3	37.3	37.3	37.3	37.3	34.2	34.2	34.2	34.2	31.1	31.1
7.5°	43.6	43.6	40.5	40.5	40.5	37.3	37.3	37.3	37.3	34.2	34.2
10°	49.8	49.8	46.7	46.7	43.6	43.6	40.5	40.5	37.3	37.3	34.2
12.5°	56.0	56.0	52.9	49.8	49.8	46.7	43.6	40.5	40.5	37.3	34.2
15°	62.2	59.1	56.0	52.9	52.9	49.8	46.7	43.6	43.6	40.5	37.3
17.5°	68.5	65.4	62.2	59.1	56.0	49.8	46.7	43.6	43.6	40.5	37.3
20°	74.7	68.5	62.2	59.1	56.0	49.8	46.7	43.6	43.6	40.5	37.3
22.5°	84.0	77.8	68.5	65.4	59.1	56.0	49.8	46.7	43.6	40.5	37.3
25°	96.5	84.0	74.7	68.5	62.2	56.0	49.8	46.7	43.6	40.5	37.3
27.5°	118.3	99.6	84.0	77.8	68.5	62.2	52.9	49.8	46.7	43.6	40.5
30°	158.7	124.5	90.3	80.9	74.7	65.4	56.0	52.9	46.7	43.6	37.3
32.5°	196.1	152.5	108.9	96.5	84.0	68.5	56.0	52.9	46.7	43.6	37.3
35°	196.1	155.6	115.2	99.6	87.1	71.6	56.0	52.9	46.7	43.6	37.3
37.5°	193.0	152.5	112.0	99.6	87.1	71.6	59.1	52.9	49.8	43.6	37.3
40°	202.3	149.4	99.6	90.3	80.9	68.5	59.1	52.9	49.8	43.6	37.3
42.5°	221.0	158.7	96.5	87.1	80.9	71.6	62.2	56.0	49.8	43.6	37.3
45°	277.0	186.7	99.6	90.3	80.9	68.5	59.1	56.0	49.8	46.7	40.5
47.5°	501.1	301.9	102.7	90.3	80.9	68.5	56.0	52.9	49.8	43.6	40.5
50°	784.3	445.1	105.8	93.4	80.9	68.5	56.0	52.9	49.8	46.7	43.6
52.5°	852.8	485.5	118.3	102.7	87.1	71.6	56.0	52.9	49.8	46.7	43.6
55°	768.7	451.3	136.9	118.3	96.5	77.8	56.0	52.9	49.8	46.7	43.6
57.5°	*650.5*	*401.5*	*152.5*	*130.7*	*105.8*	*84.0*	*59.1*	*56.0*	*52.9*	*49.8*	*46.7*
60°	488.6	333.0	177.4	149.4	124.5	96.5	68.5	65.4	62.2	56.0	52.9
62.5°	398.4	295.7	196.1	168.1	136.9	108.9	77.8	74.7	71.6	65.4	62.2
65°	351.7	280.1	208.5	177.4	146.3	112.0	80.9	77.8	74.7	71.6	68.5
67.5°	326.8	270.8	217.9	183.6	152.5	118.3	84.0	80.9	77.8	74.7	71.6
70°	314.3	264.5	214.7	183.6	152.5	121.4	90.3	87.1	80.9	77.8	71.6
72.5°	292.6	252.1	211.6	186.7	158.7	133.8	105.8	96.5	87.1	74.7	65.4
75°	261.4	224.1	186.7	171.2	155.6	136.9	121.4	105.8	90.3	71.6	56.0
77.5°	189.8	174.3	158.7	149.4	140.1	127.6	118.3	102.7	87.1	68.5	52.9
80°	74.7	84.0	90.3	90.3	93.4	93.4	93.4	80.9	68.5	56.0	43.6
82.5°	21.8	21.8	21.8	24.9	28.0	31.1	34.2	31.1	31.1	28.0	24.9
85°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
87.5°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
90°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
92.5°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
95°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
97.5°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
100°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
102.5°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
105°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
107.5°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
110°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0

Cooper Lighting Solutions Photometric Lab
1121 Highway 74 South
Peachtree City, GA 30269

Scaled Data Report

REPORT NUMBER: P1390194
CATALOG NUMBER: GSS-SA3D-935-U-RBC

CANDELA DISTRIBUTION (continued):

	0°	2.5°	5°	7.5°	10°	12.5°	15°	17.5°	20°	22.5°	25°
112.5°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
115°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
117.5°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
120°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
122.5°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
125°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
127.5°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
130°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
132.5°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
135°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
137.5°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
140°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
142.5°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
145°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
147.5°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
150°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
152.5°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
155°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
157.5°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
160°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
162.5°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
165°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
167.5°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
170°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
172.5°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
175°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
177.5°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
180°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0

Cooper Lighting Solutions Photometric Lab
1121 Highway 74 South
Peachtree City, GA 30269

Scaled Data Report

REPORT NUMBER: P1390194
CATALOG NUMBER: GSS-SA3D-935-U-RBC

CANDELA DISTRIBUTION (continued):

	27.5°	30°	32.5°	35°	37.5°	40°	42.5°	45°	47.5°	50°	52.5°
0°	37.3	37.3	37.3	37.3	37.3	37.3	37.3	37.3	37.3	37.3	37.3
2.5°	31.1	31.1	28.0	28.0	28.0	28.0	28.0	28.0	28.0	28.0	28.0
5°	31.1	31.1	28.0	28.0	28.0	28.0	24.9	24.9	24.9	24.9	24.9
7.5°	34.2	31.1	31.1	28.0	28.0	28.0	24.9	24.9	24.9	24.9	24.9
10°	34.2	31.1	31.1	28.0	28.0	28.0	24.9	24.9	24.9	24.9	21.8
12.5°	34.2	34.2	31.1	31.1	31.1	28.0	28.0	24.9	24.9	24.9	21.8
15°	34.2	34.2	31.1	28.0	28.0	28.0	24.9	24.9	24.9	24.9	21.8
17.5°	34.2	34.2	31.1	28.0	28.0	24.9	24.9	21.8	21.8	21.8	18.7
20°	34.2	34.2	31.1	28.0	28.0	24.9	24.9	21.8	21.8	21.8	18.7
22.5°	34.2	34.2	31.1	28.0	28.0	24.9	24.9	21.8	21.8	18.7	18.7
25°	34.2	34.2	31.1	28.0	24.9	24.9	21.8	18.7	18.7	15.6	15.6
27.5°	37.3	34.2	31.1	28.0	24.9	24.9	21.8	18.7	15.6	15.6	12.4
30°	34.2	34.2	31.1	28.0	24.9	21.8	18.7	15.6	12.4	12.4	9.3
32.5°	34.2	34.2	31.1	28.0	24.9	21.8	18.7	15.6	12.4	12.4	9.3
35°	34.2	31.1	28.0	24.9	21.8	18.7	15.6	12.4	9.3	9.3	6.2
37.5°	34.2	31.1	28.0	24.9	21.8	18.7	15.6	12.4	9.3	6.2	3.1
40°	34.2	31.1	28.0	24.9	21.8	18.7	12.4	9.3	6.2	6.2	3.1
42.5°	34.2	31.1	28.0	24.9	21.8	18.7	15.6	12.4	9.3	6.2	3.1
45°	37.3	34.2	28.0	24.9	21.8	21.8	18.7	15.6	12.4	9.3	3.1
47.5°	37.3	31.1	28.0	21.8	21.8	21.8	18.7	18.7	15.6	9.3	6.2
50°	40.5	34.2	31.1	24.9	21.8	21.8	18.7	15.6	12.4	9.3	3.1
52.5°	40.5	37.3	31.1	28.0	24.9	18.7	15.6	9.3	6.2	6.2	3.1
55°	40.5	40.5	37.3	34.2	28.0	21.8	12.4	6.2	6.2	3.1	3.1
57.5°	*43.6*	*43.6*	*40.5*	*37.3*	*28.0*	*18.7*	*9.3*	*0.0*	*0.0*	*0.0*	*0.0*
60°	49.8	46.7	43.6	40.5	31.1	21.8	9.3	0.0	0.0	0.0	0.0
62.5°	56.0	49.8	43.6	37.3	28.0	18.7	9.3	0.0	0.0	0.0	0.0
65°	59.1	49.8	40.5	31.1	24.9	15.6	9.3	0.0	0.0	0.0	0.0
67.5°	62.2	49.8	40.5	28.0	21.8	15.6	6.2	0.0	0.0	0.0	0.0
70°	59.1	46.7	34.2	21.8	15.6	12.4	6.2	0.0	0.0	0.0	0.0
72.5°	52.9	43.6	31.1	18.7	15.6	9.3	6.2	0.0	0.0	0.0	0.0
75°	46.7	37.3	24.9	15.6	12.4	9.3	3.1	0.0	0.0	0.0	0.0
77.5°	43.6	31.1	21.8	9.3	6.2	6.2	3.1	0.0	0.0	0.0	0.0
80°	34.2	24.9	12.4	3.1	3.1	3.1	0.0	0.0	0.0	0.0	0.0
82.5°	18.7	12.4	6.2	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
85°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
87.5°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
90°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
92.5°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
95°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
97.5°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
100°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
102.5°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
105°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
107.5°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
110°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0

Cooper Lighting Solutions Photometric Lab
1121 Highway 74 South
Peachtree City, GA 30269

Scaled Data Report

REPORT NUMBER: P1390194
CATALOG NUMBER: GSS-SA3D-935-U-RBC

CANDELA DISTRIBUTION (continued):

	27.5°	30°	32.5°	35°	37.5°	40°	42.5°	45°	47.5°	50°	52.5°
112.5°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
115°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
117.5°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
120°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
122.5°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
125°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
127.5°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
130°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
132.5°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
135°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
137.5°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
140°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
142.5°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
145°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
147.5°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
150°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
152.5°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
155°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
157.5°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
160°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
162.5°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
165°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
167.5°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
170°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
172.5°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
175°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
177.5°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
180°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0

Cooper Lighting Solutions Photometric Lab
1121 Highway 74 South
Peachtree City, GA 30269

Scaled Data Report

REPORT NUMBER: P1390194
CATALOG NUMBER: GSS-SA3D-935-U-RBC

CANDELA DISTRIBUTION (continued):

	55°	57.5°	60°	62.5°	65°	67.5°	70°	72.5°	75°	77.5°	80°
0°	37.3	37.3	37.3	37.3	37.3	37.3	37.3	37.3	37.3	37.3	37.3
2.5°	28.0	28.0	28.0	24.9	24.9	24.9	24.9	24.9	24.9	24.9	24.9
5°	24.9	24.9	24.9	21.8	21.8	21.8	21.8	21.8	21.8	21.8	21.8
7.5°	24.9	24.9	24.9	21.8	21.8	21.8	21.8	18.7	18.7	18.7	18.7
10°	21.8	21.8	21.8	18.7	18.7	18.7	18.7	15.6	15.6	15.6	15.6
12.5°	21.8	21.8	21.8	18.7	18.7	18.7	18.7	15.6	15.6	15.6	15.6
15°	21.8	21.8	21.8	18.7	18.7	18.7	15.6	15.6	12.4	12.4	12.4
17.5°	18.7	18.7	18.7	15.6	15.6	15.6	15.6	12.4	12.4	12.4	9.3
20°	18.7	18.7	18.7	15.6	15.6	12.4	12.4	9.3	6.2	6.2	6.2
22.5°	15.6	15.6	12.4	12.4	9.3	9.3	6.2	6.2	3.1	3.1	3.1
25°	12.4	12.4	9.3	9.3	6.2	6.2	3.1	3.1	0.0	0.0	0.0
27.5°	9.3	6.2	6.2	3.1	0.0	0.0	0.0	0.0	0.0	0.0	0.0
30°	6.2	6.2	3.1	3.1	0.0	0.0	0.0	0.0	0.0	0.0	0.0
32.5°	6.2	6.2	3.1	3.1	0.0	0.0	0.0	0.0	0.0	0.0	0.0
35°	3.1	3.1	3.1	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
37.5°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
40°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
42.5°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
45°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
47.5°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
50°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
52.5°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
55°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
57.5°	*0.0*	*0.0*	*0.0*	*0.0*	*0.0*	*0.0*	*0.0*	*0.0*	*0.0*	*0.0*	*0.0*
60°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
62.5°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
65°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
67.5°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
70°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
72.5°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
75°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
77.5°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
80°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
82.5°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
85°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
87.5°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
90°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
92.5°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
95°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
97.5°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
100°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
102.5°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
105°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
107.5°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
110°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0

Cooper Lighting Solutions Photometric Lab
1121 Highway 74 South
Peachtree City, GA 30269

Scaled Data Report

REPORT NUMBER: P1390194
CATALOG NUMBER: GSS-SA3D-935-U-RBC

CANDELA DISTRIBUTION (continued):

	55°	57.5°	60°	62.5°	65°	67.5°	70°	72.5°	75°	77.5°	80°
112.5°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
115°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
117.5°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
120°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
122.5°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
125°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
127.5°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
130°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
132.5°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
135°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
137.5°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
140°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
142.5°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
145°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
147.5°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
150°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
152.5°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
155°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
157.5°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
160°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
162.5°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
165°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
167.5°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
170°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
172.5°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
175°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
177.5°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
180°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0

Cooper Lighting Solutions Photometric Lab
1121 Highway 74 South
Peachtree City, GA 30269

Scaled Data Report

REPORT NUMBER: P1390194
CATALOG NUMBER: GSS-SA3D-935-U-RBC

CANDELA DISTRIBUTION (continued):

	82.5°	85°	87.5°	90°	92.5°	95°	97.5°	100°	102.5°	105°	107.5°
0°	37.3	37.3	37.3	37.3	37.3	37.3	37.3	37.3	37.3	37.3	37.3
2.5°	24.9	24.9	24.9	21.8	21.8	21.8	21.8	21.8	21.8	21.8	21.8
5°	18.7	18.7	18.7	18.7	18.7	18.7	18.7	18.7	18.7	18.7	18.7
7.5°	15.6	15.6	15.6	15.6	15.6	15.6	15.6	15.6	12.4	12.4	12.4
10°	12.4	12.4	12.4	12.4	12.4	12.4	12.4	12.4	9.3	9.3	9.3
12.5°	12.4	12.4	12.4	12.4	12.4	9.3	9.3	9.3	6.2	6.2	6.2
15°	9.3	9.3	9.3	9.3	9.3	6.2	6.2	6.2	3.1	3.1	3.1
17.5°	9.3	6.2	6.2	6.2	6.2	3.1	3.1	3.1	0.0	0.0	0.0
20°	3.1	3.1	3.1	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
22.5°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
25°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
27.5°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
30°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
32.5°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
35°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
37.5°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
40°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
42.5°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
45°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
47.5°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
50°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
52.5°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
55°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
57.5°	*0.0*	*0.0*	*0.0*	*0.0*	*0.0*	*0.0*	*0.0*	*0.0*	*0.0*	*0.0*	*0.0*
60°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
62.5°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
65°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
67.5°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
70°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
72.5°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
75°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
77.5°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
80°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
82.5°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
85°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
87.5°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
90°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
92.5°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
95°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
97.5°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
100°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
102.5°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
105°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
107.5°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
110°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0

Cooper Lighting Solutions Photometric Lab
1121 Highway 74 South
Peachtree City, GA 30269

Scaled Data Report

REPORT NUMBER: P1390194
CATALOG NUMBER: GSS-SA3D-935-U-RBC

CANDELA DISTRIBUTION (continued):

	82.5°	85°	87.5°	90°	92.5°	95°	97.5°	100°	102.5°	105°	107.5°
112.5°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
115°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
117.5°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
120°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
122.5°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
125°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
127.5°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
130°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
132.5°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
135°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
137.5°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
140°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
142.5°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
145°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
147.5°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
150°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
152.5°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
155°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
157.5°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
160°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
162.5°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
165°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
167.5°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
170°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
172.5°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
175°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
177.5°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
180°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0

Cooper Lighting Solutions Photometric Lab
1121 Highway 74 South
Peachtree City, GA 30269

Scaled Data Report

REPORT NUMBER: P1390194
CATALOG NUMBER: GSS-SA3D-935-U-RBC

CANDELA DISTRIBUTION (continued):

	110°	112.5°	115°	117.5°	120°	122.5°	125°	127.5°	130°	132.5°	135°
0°	37.3	37.3	37.3	37.3	37.3	37.3	37.3	37.3	37.3	37.3	37.3
2.5°	21.8	21.8	21.8	21.8	21.8	21.8	21.8	21.8	21.8	21.8	21.8
5°	18.7	15.6	15.6	15.6	15.6	15.6	15.6	15.6	15.6	15.6	15.6
7.5°	12.4	12.4	12.4	12.4	12.4	12.4	12.4	12.4	12.4	12.4	12.4
10°	9.3	9.3	9.3	9.3	9.3	9.3	9.3	9.3	9.3	9.3	9.3
12.5°	6.2	6.2	6.2	6.2	6.2	6.2	6.2	6.2	6.2	3.1	3.1
15°	3.1	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
17.5°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
20°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
22.5°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
25°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
27.5°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
30°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
32.5°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
35°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
37.5°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
40°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
42.5°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
45°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
47.5°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
50°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
52.5°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
55°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
57.5°	*0.0*	*0.0*	*0.0*	*0.0*	*0.0*	*0.0*	*0.0*	*0.0*	*0.0*	*0.0*	*0.0*
60°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
62.5°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
65°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
67.5°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
70°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
72.5°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
75°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
77.5°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
80°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
82.5°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
85°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
87.5°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
90°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
92.5°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
95°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
97.5°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
100°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
102.5°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
105°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
107.5°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
110°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0

Cooper Lighting Solutions Photometric Lab
1121 Highway 74 South
Peachtree City, GA 30269

Scaled Data Report

REPORT NUMBER: P1390194
CATALOG NUMBER: GSS-SA3D-935-U-RBC

CANDELA DISTRIBUTION (continued):

	110°	112.5°	115°	117.5°	120°	122.5°	125°	127.5°	130°	132.5°	135°
112.5°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
115°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
117.5°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
120°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
122.5°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
125°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
127.5°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
130°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
132.5°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
135°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
137.5°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
140°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
142.5°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
145°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
147.5°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
150°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
152.5°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
155°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
157.5°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
160°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
162.5°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
165°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
167.5°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
170°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
172.5°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
175°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
177.5°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
180°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0

Cooper Lighting Solutions Photometric Lab
1121 Highway 74 South
Peachtree City, GA 30269

Scaled Data Report

REPORT NUMBER: P1390194
CATALOG NUMBER: GSS-SA3D-935-U-RBC

CANDELA DISTRIBUTION (continued):

	137.5°	140°	142.5°	145°	147.5°	150°	152.5°	155°	157.5°	160°	162.5°
0°	37.3	37.3	37.3	37.3	37.3	37.3	37.3	37.3	37.3	37.3	37.3
2.5°	21.8	24.9	24.9	24.9	24.9	28.0	28.0	28.0	31.1	31.1	34.2
5°	15.6	18.7	18.7	18.7	18.7	21.8	21.8	21.8	24.9	24.9	28.0
7.5°	12.4	15.6	15.6	15.6	15.6	18.7	18.7	18.7	21.8	21.8	24.9
10°	9.3	9.3	9.3	9.3	12.4	12.4	15.6	15.6	18.7	18.7	21.8
12.5°	3.1	6.2	6.2	6.2	6.2	9.3	9.3	9.3	12.4	15.6	15.6
15°	0.0	3.1	3.1	3.1	3.1	6.2	6.2	6.2	9.3	12.4	12.4
17.5°	0.0	0.0	0.0	0.0	0.0	3.1	3.1	3.1	6.2	6.2	9.3
20°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	3.1	3.1	6.2
22.5°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	3.1	3.1
25°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
27.5°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
30°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
32.5°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
35°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
37.5°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
40°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
42.5°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
45°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
47.5°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
50°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
52.5°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
55°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
57.5°	*0.0*	*0.0*	*0.0*	*0.0*	*0.0*	*0.0*	*0.0*	*0.0*	*0.0*	*0.0*	*0.0*
60°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
62.5°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
65°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
67.5°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
70°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
72.5°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
75°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
77.5°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
80°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
82.5°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
85°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
87.5°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
90°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
92.5°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
95°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
97.5°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
100°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
102.5°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
105°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
107.5°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
110°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0

Cooper Lighting Solutions Photometric Lab
1121 Highway 74 South
Peachtree City, GA 30269

Scaled Data Report

REPORT NUMBER: P1390194
CATALOG NUMBER: GSS-SA3D-935-U-RBC

CANDELA DISTRIBUTION (continued):

	137.5°	140°	142.5°	145°	147.5°	150°	152.5°	155°	157.5°	160°	162.5°
112.5°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
115°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
117.5°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
120°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
122.5°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
125°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
127.5°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
130°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
132.5°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
135°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
137.5°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
140°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
142.5°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
145°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
147.5°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
150°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
152.5°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
155°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
157.5°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
160°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
162.5°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
165°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
167.5°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
170°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
172.5°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
175°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
177.5°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
180°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0

Cooper Lighting Solutions Photometric Lab
1121 Highway 74 South
Peachtree City, GA 30269

Scaled Data Report

REPORT NUMBER: P1390194
CATALOG NUMBER: GSS-SA3D-935-U-RBC

CANDELA DISTRIBUTION (continued):

	165°	167.5°	170°	172.5°	175°	177.5°	180°	182.5°	185°	187.5°	190°
0°	37.3	37.3	37.3	37.3	37.3	37.3	37.3	37.3	37.3	37.3	37.3
2.5°	34.2	37.3	37.3	40.5	40.5	43.6	43.6	46.7	46.7	46.7	49.8
5°	28.0	31.1	34.2	34.2	37.3	40.5	40.5	43.6	43.6	43.6	46.7
7.5°	24.9	28.0	31.1	31.1	34.2	37.3	37.3	40.5	40.5	40.5	43.6
10°	21.8	24.9	28.0	28.0	31.1	34.2	34.2	37.3	37.3	40.5	40.5
12.5°	18.7	21.8	24.9	24.9	28.0	31.1	31.1	34.2	37.3	37.3	40.5
15°	15.6	18.7	21.8	21.8	24.9	28.0	31.1	34.2	34.2	37.3	37.3
17.5°	9.3	12.4	15.6	18.7	21.8	24.9	28.0	31.1	31.1	34.2	37.3
20°	6.2	9.3	12.4	15.6	18.7	21.8	21.8	24.9	28.0	31.1	31.1
22.5°	3.1	6.2	9.3	9.3	12.4	15.6	18.7	21.8	21.8	24.9	28.0
25°	0.0	3.1	6.2	6.2	9.3	12.4	12.4	15.6	18.7	21.8	21.8
27.5°	0.0	3.1	3.1	6.2	6.2	9.3	12.4	15.6	15.6	18.7	18.7
30°	0.0	3.1	3.1	6.2	6.2	9.3	9.3	12.4	12.4	15.6	18.7
32.5°	0.0	0.0	3.1	3.1	3.1	6.2	9.3	12.4	12.4	15.6	15.6
35°	0.0	0.0	3.1	3.1	3.1	6.2	6.2	9.3	9.3	12.4	12.4
37.5°	0.0	0.0	3.1	3.1	3.1	6.2	6.2	9.3	9.3	12.4	12.4
40°	0.0	0.0	0.0	0.0	0.0	3.1	6.2	9.3	9.3	9.3	12.4
42.5°	0.0	0.0	0.0	0.0	0.0	3.1	3.1	6.2	6.2	9.3	9.3
45°	0.0	0.0	0.0	0.0	0.0	3.1	3.1	6.2	6.2	9.3	9.3
47.5°	0.0	0.0	0.0	0.0	0.0	3.1	3.1	6.2	6.2	9.3	9.3
50°	0.0	0.0	0.0	0.0	0.0	3.1	3.1	6.2	6.2	9.3	9.3
52.5°	0.0	0.0	0.0	0.0	0.0	3.1	3.1	6.2	6.2	6.2	9.3
55°	0.0	0.0	0.0	0.0	0.0	3.1	3.1	6.2	6.2	6.2	9.3
57.5°	*0.0*	*0.0*	*0.0*	*0.0*	*0.0*	*0.0*	*0.0*	*3.1*	*3.1*	*3.1*	*6.2*
60°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	3.1	3.1	3.1	6.2
62.5°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	3.1	3.1	3.1	6.2
65°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	3.1	3.1	3.1	6.2
67.5°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	3.1	3.1	3.1	6.2
70°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	3.1	3.1	3.1	6.2
72.5°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	3.1	3.1	3.1	6.2
75°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	3.1	3.1	6.2	6.2
77.5°	0.0	0.0	0.0	0.0	0.0	3.1	3.1	3.1	3.1	6.2	6.2
80°	0.0	0.0	0.0	0.0	0.0	3.1	3.1	6.2	6.2	6.2	9.3
82.5°	0.0	0.0	0.0	0.0	0.0	3.1	3.1	6.2	6.2	6.2	9.3
85°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	3.1	3.1	6.2	6.2
87.5°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	3.1	3.1	6.2	6.2
90°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
92.5°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
95°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
97.5°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
100°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
102.5°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
105°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
107.5°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
110°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0

Cooper Lighting Solutions Photometric Lab
1121 Highway 74 South
Peachtree City, GA 30269

Scaled Data Report

REPORT NUMBER: P1390194
CATALOG NUMBER: GSS-SA3D-935-U-RBC

CANDELA DISTRIBUTION (continued):

	165°	167.5°	170°	172.5°	175°	177.5°	180°	182.5°	185°	187.5°	190°
112.5°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
115°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
117.5°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
120°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
122.5°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
125°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
127.5°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
130°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
132.5°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
135°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
137.5°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
140°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
142.5°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
145°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
147.5°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
150°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
152.5°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
155°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
157.5°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
160°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
162.5°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
165°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
167.5°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
170°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
172.5°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
175°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
177.5°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
180°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0

Cooper Lighting Solutions Photometric Lab
1121 Highway 74 South
Peachtree City, GA 30269

Scaled Data Report

REPORT NUMBER: P1390194
CATALOG NUMBER: GSS-SA3D-935-U-RBC

CANDELA DISTRIBUTION (continued):

	192.5°	195°	197.5°	200°	202.5°	205°	207.5°	210°	212.5°	215°	217.5°
0°	37.3	37.3	37.3	37.3	37.3	37.3	37.3	37.3	37.3	37.3	37.3
2.5°	49.8	49.8	49.8	49.8	49.8	49.8	49.8	49.8	46.7	46.7	46.7
5°	46.7	46.7	46.7	46.7	46.7	46.7	46.7	46.7	43.6	43.6	43.6
7.5°	43.6	43.6	43.6	46.7	46.7	46.7	46.7	46.7	43.6	43.6	43.6
10°	43.6	43.6	43.6	46.7	46.7	46.7	46.7	46.7	43.6	43.6	43.6
12.5°	40.5	40.5	40.5	43.6	43.6	43.6	43.6	43.6	43.6	43.6	43.6
15°	40.5	40.5	40.5	43.6	43.6	43.6	43.6	43.6	43.6	43.6	43.6
17.5°	37.3	40.5	40.5	43.6	43.6	43.6	43.6	43.6	43.6	43.6	43.6
20°	34.2	34.2	37.3	37.3	40.5	40.5	40.5	43.6	43.6	43.6	43.6
22.5°	28.0	31.1	34.2	34.2	37.3	37.3	37.3	37.3	37.3	37.3	37.3
25°	24.9	24.9	28.0	31.1	31.1	34.2	34.2	34.2	34.2	34.2	34.2
27.5°	21.8	21.8	24.9	24.9	28.0	28.0	28.0	31.1	31.1	31.1	31.1
30°	18.7	21.8	21.8	24.9	24.9	24.9	28.0	28.0	31.1	31.1	31.1
32.5°	18.7	18.7	21.8	21.8	24.9	24.9	24.9	28.0	28.0	28.0	28.0
35°	15.6	15.6	18.7	18.7	21.8	21.8	24.9	24.9	28.0	28.0	28.0
37.5°	15.6	15.6	18.7	18.7	21.8	21.8	21.8	24.9	24.9	24.9	28.0
40°	12.4	12.4	15.6	15.6	18.7	18.7	21.8	21.8	24.9	24.9	28.0
42.5°	12.4	12.4	15.6	15.6	18.7	18.7	21.8	21.8	24.9	24.9	28.0
45°	12.4	12.4	15.6	15.6	18.7	18.7	21.8	21.8	24.9	24.9	28.0
47.5°	12.4	12.4	15.6	15.6	18.7	18.7	18.7	21.8	21.8	21.8	24.9
50°	12.4	12.4	12.4	15.6	15.6	15.6	18.7	18.7	21.8	21.8	24.9
52.5°	9.3	9.3	9.3	12.4	12.4	12.4	15.6	15.6	18.7	18.7	21.8
55°	9.3	9.3	9.3	12.4	12.4	12.4	12.4	15.6	15.6	15.6	18.7
57.5°	*6.2*	*6.2*	*6.2*	*9.3*	*9.3*	*9.3*	*9.3*	*12.4*	*12.4*	*12.4*	*15.6*
60°	6.2	6.2	6.2	9.3	9.3	9.3	9.3	9.3	9.3	9.3	12.4
62.5°	6.2	6.2	6.2	9.3	9.3	9.3	9.3	9.3	9.3	9.3	12.4
65°	6.2	6.2	6.2	9.3	9.3	9.3	9.3	9.3	9.3	9.3	12.4
67.5°	6.2	6.2	6.2	9.3	9.3	9.3	9.3	9.3	9.3	9.3	12.4
70°	6.2	6.2	6.2	9.3	9.3	9.3	9.3	9.3	9.3	9.3	12.4
72.5°	6.2	6.2	6.2	9.3	9.3	9.3	9.3	9.3	9.3	9.3	12.4
75°	9.3	9.3	9.3	9.3	9.3	9.3	9.3	9.3	9.3	9.3	9.3
77.5°	9.3	9.3	9.3	9.3	9.3	9.3	9.3	9.3	9.3	9.3	9.3
80°	9.3	9.3	9.3	9.3	9.3	9.3	9.3	9.3	9.3	9.3	9.3
82.5°	9.3	9.3	9.3	9.3	9.3	9.3	9.3	9.3	9.3	9.3	9.3
85°	9.3	9.3	9.3	9.3	9.3	9.3	9.3	9.3	9.3	9.3	9.3
87.5°	9.3	9.3	9.3	9.3	9.3	9.3	9.3	9.3	9.3	9.3	9.3
90°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
92.5°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
95°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
97.5°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
100°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
102.5°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
105°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
107.5°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
110°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0

Cooper Lighting Solutions Photometric Lab
1121 Highway 74 South
Peachtree City, GA 30269

Scaled Data Report

REPORT NUMBER: P1390194
CATALOG NUMBER: GSS-SA3D-935-U-RBC

CANDELA DISTRIBUTION (continued):

	192.5°	195°	197.5°	200°	202.5°	205°	207.5°	210°	212.5°	215°	217.5°
112.5°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
115°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
117.5°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
120°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
122.5°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
125°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
127.5°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
130°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
132.5°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
135°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
137.5°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
140°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
142.5°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
145°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
147.5°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
150°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
152.5°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
155°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
157.5°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
160°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
162.5°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
165°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
167.5°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
170°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
172.5°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
175°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
177.5°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
180°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0

Cooper Lighting Solutions Photometric Lab
1121 Highway 74 South
Peachtree City, GA 30269

Scaled Data Report

REPORT NUMBER: P1390194
CATALOG NUMBER: GSS-SA3D-935-U-RBC

CANDELA DISTRIBUTION (continued):

	220°	222.5°	225°	227.5°	230°	232.5°	235°	237.5°	240°	242.5°	245°
0°	37.3	37.3	37.3	37.3	37.3	37.3	37.3	37.3	37.3	37.3	37.3
2.5°	46.7	46.7	46.7	46.7	46.7	43.6	43.6	43.6	46.7	46.7	46.7
5°	43.6	43.6	43.6	43.6	43.6	43.6	43.6	43.6	43.6	43.6	43.6
7.5°	43.6	43.6	43.6	43.6	43.6	40.5	40.5	40.5	43.6	43.6	43.6
10°	43.6	40.5	40.5	40.5	40.5	40.5	40.5	40.5	43.6	43.6	43.6
12.5°	43.6	40.5	40.5	40.5	40.5	40.5	40.5	40.5	43.6	43.6	43.6
15°	43.6	40.5	40.5	40.5	40.5	40.5	40.5	43.6	43.6	46.7	46.7
17.5°	40.5	40.5	37.3	37.3	40.5	40.5	40.5	40.5	43.6	43.6	43.6
20°	40.5	40.5	37.3	37.3	37.3	37.3	37.3	40.5	40.5	43.6	43.6
22.5°	37.3	37.3	37.3	37.3	37.3	37.3	37.3	40.5	40.5	43.6	43.6
25°	34.2	34.2	34.2	34.2	37.3	37.3	37.3	40.5	43.6	43.6	46.7
27.5°	34.2	34.2	34.2	34.2	37.3	37.3	37.3	40.5	43.6	43.6	46.7
30°	34.2	34.2	34.2	34.2	37.3	37.3	37.3	40.5	43.6	43.6	46.7
32.5°	31.1	31.1	31.1	34.2	34.2	37.3	37.3	40.5	43.6	43.6	46.7
35°	31.1	31.1	31.1	34.2	34.2	37.3	37.3	40.5	43.6	43.6	46.7
37.5°	28.0	31.1	31.1	34.2	37.3	37.3	40.5	43.6	46.7	46.7	49.8
40°	28.0	31.1	31.1	34.2	37.3	37.3	40.5	43.6	46.7	46.7	49.8
42.5°	28.0	31.1	31.1	34.2	37.3	37.3	40.5	43.6	46.7	49.8	52.9
45°	31.1	31.1	34.2	37.3	37.3	40.5	40.5	43.6	46.7	49.8	52.9
47.5°	31.1	34.2	37.3	37.3	40.5	40.5	40.5	43.6	49.8	52.9	56.0
50°	28.0	31.1	34.2	37.3	37.3	40.5	40.5	43.6	49.8	52.9	56.0
52.5°	24.9	24.9	28.0	31.1	37.3	40.5	43.6	46.7	52.9	56.0	59.1
55°	21.8	21.8	24.9	31.1	37.3	43.6	49.8	52.9	56.0	56.0	59.1
57.5°	*18.7*	*18.7*	*21.8*	*31.1*	*40.5*	*49.8*	*59.1*	*59.1*	*62.2*	*62.2*	*62.2*
60°	15.6	15.6	18.7	28.0	40.5	49.8	59.1	62.2	65.4	65.4	68.5
62.5°	15.6	15.6	18.7	28.0	37.3	43.6	52.9	59.1	65.4	71.6	77.8
65°	12.4	15.6	15.6	24.9	31.1	40.5	46.7	56.0	65.4	74.7	84.0
67.5°	12.4	15.6	15.6	21.8	31.1	37.3	43.6	52.9	65.4	74.7	84.0
70°	15.6	15.6	18.7	24.9	28.0	34.2	37.3	49.8	59.1	71.6	80.9
72.5°	12.4	15.6	15.6	21.8	24.9	31.1	34.2	46.7	56.0	68.5	77.8
75°	12.4	12.4	12.4	18.7	21.8	28.0	31.1	40.5	52.9	62.2	71.6
77.5°	9.3	9.3	9.3	15.6	18.7	24.9	28.0	37.3	49.8	59.1	68.5
80°	9.3	9.3	9.3	12.4	15.6	15.6	18.7	28.0	40.5	49.8	59.1
82.5°	9.3	6.2	6.2	9.3	9.3	12.4	12.4	18.7	24.9	31.1	37.3
85°	9.3	6.2	6.2	6.2	6.2	6.2	6.2	6.2	6.2	6.2	6.2
87.5°	9.3	6.2	6.2	6.2	6.2	3.1	3.1	3.1	3.1	3.1	3.1
90°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
92.5°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
95°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
97.5°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
100°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
102.5°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
105°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
107.5°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
110°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0

Cooper Lighting Solutions Photometric Lab
1121 Highway 74 South
Peachtree City, GA 30269

Scaled Data Report

REPORT NUMBER: P1390194
CATALOG NUMBER: GSS-SA3D-935-U-RBC

CANDELA DISTRIBUTION (continued):

	220°	222.5°	225°	227.5°	230°	232.5°	235°	237.5°	240°	242.5°	245°
112.5°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
115°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
117.5°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
120°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
122.5°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
125°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
127.5°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
130°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
132.5°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
135°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
137.5°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
140°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
142.5°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
145°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
147.5°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
150°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
152.5°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
155°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
157.5°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
160°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
162.5°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
165°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
167.5°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
170°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
172.5°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
175°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
177.5°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
180°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0

Cooper Lighting Solutions Photometric Lab
1121 Highway 74 South
Peachtree City, GA 30269

Scaled Data Report

REPORT NUMBER: P1390194
CATALOG NUMBER: GSS-SA3D-935-U-RBC

CANDELA DISTRIBUTION (continued):

	247.5°	250°	252.5°	255°	257.5°	260°	262.5°	265°	267.5°	270°	272.5°
0°	37.3	37.3	37.3	37.3	37.3	37.3	37.3	37.3	37.3	37.3	37.3
2.5°	46.7	46.7	46.7	46.7	46.7	49.8	49.8	49.8	49.8	49.8	49.8
5°	46.7	46.7	49.8	49.8	49.8	52.9	52.9	52.9	52.9	52.9	52.9
7.5°	46.7	46.7	49.8	49.8	49.8	52.9	52.9	52.9	56.0	56.0	59.1
10°	46.7	46.7	49.8	49.8	52.9	52.9	56.0	56.0	59.1	59.1	62.2
12.5°	46.7	49.8	49.8	52.9	56.0	59.1	59.1	62.2	65.4	65.4	68.5
15°	49.8	49.8	52.9	52.9	56.0	59.1	62.2	65.4	68.5	71.6	74.7
17.5°	46.7	49.8	52.9	56.0	59.1	62.2	65.4	68.5	74.7	77.8	84.0
20°	46.7	49.8	52.9	56.0	59.1	65.4	68.5	71.6	77.8	84.0	93.4
22.5°	46.7	49.8	52.9	56.0	62.2	68.5	71.6	77.8	87.1	93.4	105.8
25°	49.8	52.9	56.0	59.1	65.4	71.6	77.8	84.0	96.5	105.8	133.8
27.5°	49.8	56.0	59.1	62.2	68.5	77.8	84.0	90.3	108.9	124.5	186.7
30°	49.8	56.0	59.1	62.2	71.6	80.9	90.3	99.6	130.7	158.7	264.5
32.5°	49.8	56.0	59.1	62.2	74.7	90.3	102.7	115.2	155.6	196.1	320.6
35°	52.9	56.0	62.2	65.4	80.9	96.5	108.9	124.5	161.8	199.2	348.6
37.5°	56.0	59.1	65.4	68.5	80.9	93.4	105.8	118.3	158.7	196.1	382.8
40°	56.0	62.2	65.4	71.6	80.9	93.4	102.7	112.0	155.6	199.2	441.9
42.5°	59.1	65.4	68.5	74.7	84.0	93.4	99.6	108.9	164.9	221.0	575.8
45°	59.1	62.2	68.5	71.6	80.9	90.3	99.6	108.9	208.5	305.0	915.0
47.5°	59.1	62.2	65.4	68.5	80.9	93.4	102.7	115.2	308.1	501.1	1512.6
50°	59.1	62.2	62.2	65.4	77.8	93.4	105.8	118.3	401.5	681.6	2181.7
52.5°	62.2	65.4	65.4	68.5	84.0	99.6	115.2	130.7	460.6	790.5	2368.4
55°	62.2	65.4	65.4	68.5	93.4	118.3	140.1	164.9	485.5	803.0	2175.5
57.5°	*65.4*	*68.5*	*71.6*	*74.7*	*99.6*	*127.6*	*152.5*	*177.4*	*463.7*	*750.1*	*1783.3*
60°	74.7	77.8	84.0	87.1	115.2	143.2	168.1	196.1	370.4	544.6	1403.6
62.5°	84.0	87.1	93.4	96.5	124.5	152.5	180.5	208.5	326.8	441.9	1045.7
65°	87.1	93.4	96.5	99.6	127.6	158.7	186.7	214.7	298.8	379.7	775.0
67.5°	90.3	96.5	99.6	105.8	133.8	161.8	189.8	217.9	283.2	345.5	575.8
70°	90.3	96.5	105.8	112.0	136.9	161.8	183.6	208.5	261.4	311.2	441.9
72.5°	90.3	102.7	115.2	127.6	146.3	164.9	180.5	199.2	239.6	277.0	342.3
75°	90.3	108.9	124.5	143.2	152.5	161.8	171.2	180.5	208.5	233.4	270.8
77.5°	87.1	102.7	121.4	136.9	140.1	143.2	146.3	149.4	149.4	149.4	149.4
80°	71.6	87.1	99.6	112.0	105.8	96.5	90.3	80.9	74.7	68.5	74.7
82.5°	37.3	40.5	40.5	40.5	37.3	37.3	34.2	31.1	31.1	28.0	28.0
85°	6.2	6.2	6.2	6.2	6.2	6.2	3.1	3.1	3.1	3.1	3.1
87.5°	3.1	3.1	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
90°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
92.5°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
95°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
97.5°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
100°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
102.5°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
105°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
107.5°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
110°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0

Cooper Lighting Solutions Photometric Lab
1121 Highway 74 South
Peachtree City, GA 30269

Scaled Data Report

REPORT NUMBER: P1390194
CATALOG NUMBER: GSS-SA3D-935-U-RBC

CANDELA DISTRIBUTION (continued):

	247.5°	250°	252.5°	255°	257.5°	260°	262.5°	265°	267.5°	270°	272.5°
112.5°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
115°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
117.5°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
120°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
122.5°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
125°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
127.5°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
130°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
132.5°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
135°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
137.5°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
140°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
142.5°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
145°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
147.5°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
150°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
152.5°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
155°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
157.5°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
160°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
162.5°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
165°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
167.5°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
170°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
172.5°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
175°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
177.5°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
180°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0

Cooper Lighting Solutions Photometric Lab
1121 Highway 74 South
Peachtree City, GA 30269

Scaled Data Report

REPORT NUMBER: P1390194
CATALOG NUMBER: GSS-SA3D-935-U-RBC

CANDELA DISTRIBUTION (continued):

	275°	277.5°	280°	282.5°	285°	287.5°	290°	292.5°	295°	297.5°	300°
0°	37.3	37.3	37.3	37.3	37.3	37.3	37.3	37.3	37.3	37.3	37.3
2.5°	49.8	49.8	49.8	49.8	49.8	49.8	49.8	46.7	46.7	46.7	46.7
5°	52.9	52.9	52.9	52.9	52.9	52.9	52.9	49.8	49.8	49.8	49.8
7.5°	59.1	59.1	59.1	59.1	59.1	59.1	59.1	59.1	59.1	59.1	59.1
10°	62.2	65.4	65.4	68.5	68.5	68.5	71.6	71.6	71.6	71.6	71.6
12.5°	71.6	74.7	74.7	77.8	77.8	80.9	80.9	84.0	84.0	84.0	87.1
15°	77.8	80.9	84.0	87.1	90.3	96.5	99.6	105.8	108.9	112.0	115.2
17.5°	90.3	96.5	105.8	112.0	118.3	130.7	143.2	152.5	164.9	180.5	199.2
20°	99.6	121.4	140.1	161.8	180.5	236.5	292.6	348.6	404.6	479.3	554.0
22.5°	118.3	186.7	258.3	326.8	395.3	578.9	759.4	939.9	1123.5	1297.8	1472.1
25°	161.8	308.1	457.5	603.8	750.1	1058.2	1363.2	1668.2	1976.3	2271.9	2570.7
27.5°	245.9	482.4	718.9	955.5	1192.0	1596.6	1998.1	2399.5	2804.1	3162.0	3516.8
30°	370.4	675.4	980.4	1285.4	1590.4	2113.2	2636.1	3158.9	3681.8	4030.4	4378.9
32.5°	441.9	840.3	1238.7	1633.9	2032.3	2601.8	3171.4	3744.0	4313.6	4712.0	5110.3
35°	494.8	989.7	1481.4	1976.3	2468.0	3102.9	3737.8	4375.8	5010.7	5486.9	5963.1
37.5°	566.4	1160.9	1752.2	2346.6	2938.0	3622.7	4307.4	4995.2	5679.9	6268.1	6859.4
40°	681.6	1388.1	2094.5	2797.9	3504.4	4363.4	5222.4	6081.3	6940.3	7721.5	8502.7
42.5°	930.6	1861.1	2794.8	3725.4	4655.9	5941.3	7223.5	8505.8	9791.1	10896.0	12000.8
45°	1525.0	2972.2	4419.4	5866.6	7313.8	8851.2	10385.6	11923.0	13460.5	15094.4	16728.4
47.5°	2524.0	4519.0	6513.9	8505.8	10500.7	12084.9	13665.9	15246.9	16831.1	18356.1	19881.1
50°	3681.8	5829.2	7976.7	10124.2	12271.6	13687.7	15100.7	16513.6	17929.7	19426.7	20920.6
52.5°	3946.3	6093.8	8241.2	10385.6	12533.0	13961.6	15390.1	16821.7	18250.3	19713.0	21178.9
55°	3544.9	5673.6	7799.3	9928.1	12053.8	13622.3	15190.9	16759.5	18328.1	19968.2	21608.4
57.5°	*2816.6*	*4967.2*	*7114.6*	*9265.2*	*11412.6*	*13273.8*	*15131.8*	*16992.9*	*18854.0*	*20584.4*	*22314.9*
60°	2262.6	4456.7	6650.9	8845.0	11039.2	13024.8	15007.3	16989.8	18975.4	20447.5	21919.6
62.5°	1649.5	3821.8	5994.2	8166.6	10338.9	12119.1	13899.3	15682.6	17462.9	18508.6	19554.3
65°	1170.2	3090.5	5010.7	6927.9	8848.1	10083.7	11319.3	12554.8	13790.4	14696.1	15601.7
67.5°	806.1	2159.9	3510.6	4864.5	6215.2	7267.1	8315.9	9367.9	10419.8	11182.3	11947.9
70°	572.7	1310.3	2047.9	2782.4	3520.0	4450.5	5381.1	6311.6	7242.2	8172.8	9106.5
72.5°	407.7	731.4	1051.9	1375.6	1696.2	2505.4	3314.5	4126.8	4936.0	5499.4	6065.8
75°	308.1	395.3	479.3	566.4	650.5	846.5	1042.6	1238.7	1434.7	1633.9	1833.1
77.5°	146.3	161.8	174.3	189.8	202.3	252.1	301.9	351.7	401.5	485.5	569.5
80°	77.8	84.0	90.3	96.5	102.7	105.8	108.9	112.0	115.2	124.5	136.9
82.5°	28.0	31.1	31.1	34.2	34.2	31.1	31.1	28.0	24.9	28.0	28.0
85°	3.1	3.1	3.1	3.1	3.1	3.1	3.1	3.1	3.1	3.1	3.1
87.5°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
90°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
92.5°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
95°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
97.5°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
100°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
102.5°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
105°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
107.5°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
110°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0

Cooper Lighting Solutions Photometric Lab
1121 Highway 74 South
Peachtree City, GA 30269

Scaled Data Report

REPORT NUMBER: P1390194
CATALOG NUMBER: GSS-SA3D-935-U-RBC

CANDELA DISTRIBUTION (continued):

	275°	277.5°	280°	282.5°	285°	287.5°	290°	292.5°	295°	297.5°	300°
112.5°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
115°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
117.5°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
120°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
122.5°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
125°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
127.5°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
130°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
132.5°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
135°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
137.5°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
140°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
142.5°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
145°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
147.5°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
150°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
152.5°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
155°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
157.5°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
160°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
162.5°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
165°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
167.5°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
170°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
172.5°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
175°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
177.5°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
180°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0

Cooper Lighting Solutions Photometric Lab
1121 Highway 74 South
Peachtree City, GA 30269

Scaled Data Report

REPORT NUMBER: P1390194
CATALOG NUMBER: GSS-SA3D-935-U-RBC

CANDELA DISTRIBUTION (continued):

	302.5°	305°	307.5°	310°	312.5°	315°	317.5°	320°	322.5°	325°	327.5°
0°	37.3	37.3	37.3	37.3	37.3	*37.3*	37.3	37.3	37.3	37.3	37.3
2.5°	43.6	43.6	43.6	43.6	40.5	*40.5*	40.5	40.5	37.3	37.3	37.3
5°	49.8	49.8	49.8	49.8	46.7	*46.7*	46.7	46.7	43.6	43.6	43.6
7.5°	59.1	59.1	59.1	59.1	56.0	*56.0*	56.0	56.0	52.9	52.9	52.9
10°	71.6	71.6	71.6	71.6	71.6	*71.6*	71.6	71.6	68.5	68.5	68.5
12.5°	87.1	87.1	87.1	87.1	87.1	*87.1*	87.1	87.1	84.0	84.0	84.0
15°	115.2	118.3	121.4	124.5	124.5	*127.6*	124.5	121.4	118.3	115.2	112.0
17.5°	214.7	230.3	236.5	239.6	245.9	*249.0*	245.9	239.6	236.5	230.3	214.7
20°	625.6	700.3	753.2	806.1	859.0	*911.9*	880.8	849.6	818.5	787.4	706.5
22.5°	1646.4	1820.7	1942.0	2063.4	2184.8	*2306.2*	2222.1	2138.1	2051.0	1966.9	1761.5
25°	2866.4	3162.0	3317.7	3476.4	3632.0	*3787.6*	3644.4	3501.3	3355.0	3211.8	2925.5
27.5°	3874.8	4229.6	4363.4	4494.1	4627.9	*4758.6*	4631.0	4506.5	4378.9	4251.3	3918.3
30°	4727.5	5076.1	5206.8	5337.5	5468.2	*5598.9*	5455.8	5309.5	5166.3	5020.1	4690.2
32.5°	5505.6	5903.9	6084.5	6265.0	6445.5	*6626.0*	6411.2	6196.5	5981.8	5767.0	5390.4
35°	6439.3	6915.4	7127.1	7341.8	7553.4	*7765.1*	7509.9	7251.5	6996.3	6738.0	6261.9
37.5°	7447.6	8035.8	8319.1	8602.3	8885.5	*9168.7*	8851.2	8533.8	8216.3	7898.9	7292.0
40°	9283.9	10065.0	10485.2	10902.2	11322.4	*11739.4*	11263.2	10784.0	10307.8	9828.5	8994.4
42.5°	13102.6	14207.4	14805.0	15402.5	16000.1	*16597.6*	15903.6	15206.5	14512.4	13815.3	12663.8
45°	18362.3	19996.2	20656.0	21312.7	21972.5	*22629.2*	21844.9	21060.6	20273.2	19488.9	17942.1
47.5°	21406.1	22931.1	23578.4	24225.8	24870.0	*25517.4*	24779.8	24042.2	23304.6	22566.9	21057.5
50°	22417.6	23911.4	24624.1	25340.0	26052.7	*26765.4*	25922.0	25075.4	24232.0	23385.5	21935.2
52.5°	22641.6	24104.4	24944.7	25785.0	26622.2	*27462.5*	26488.4	25514.2	24537.0	23562.9	22125.0
55°	23245.4	24885.6	25853.5	26818.3	27786.2	*28751.0*	27615.0	26475.9	25340.0	24200.9	22623.0
57.5°	*24045.3*	*25775.7*	*26659.6*	*27543.4*	*28424.2*	*29308.1*	*28209.5*	*27113.9*	*26015.3*	*24916.7*	*23270.3*
60°	23388.6	24860.7	25598.3	26332.8	27070.4	*27804.9*	26812.1	25822.4	24829.6	23836.7	22464.2
62.5°	20596.9	21642.6	22212.1	22781.7	23348.1	*23917.7*	23102.3	22286.8	21471.4	20656.0	19660.1
65°	16504.3	17409.9	17820.8	18228.5	18639.3	*19047.0*	18480.6	17914.1	17344.6	16778.2	15941.0
67.5°	12710.4	13472.9	14107.8	14739.6	15374.5	*16006.3*	15318.5	14630.7	13939.8	13252.0	12449.0
70°	10037.0	10967.6	11490.4	12013.3	12536.2	*13059.0*	12461.5	11863.9	11263.2	10665.7	9825.4
72.5°	6629.1	7192.4	7379.2	7569.0	7755.7	*7942.5*	7724.6	7509.9	7292.0	7074.2	6542.0
75°	2029.2	2228.4	2449.3	2673.4	2894.4	*3115.4*	2916.2	2717.0	2517.8	2318.6	2138.1
77.5°	650.5	734.5	799.8	865.2	927.5	*992.8*	995.9	999.0	999.0	1002.1	905.7
80°	146.3	155.6	155.6	155.6	152.5	*152.5*	168.1	180.5	196.1	208.5	196.1
82.5°	31.1	31.1	31.1	31.1	31.1	*31.1*	31.1	31.1	28.0	28.0	28.0
85°	3.1	3.1	3.1	3.1	0.0	*0.0*	0.0	0.0	0.0	0.0	0.0
87.5°	0.0	0.0	0.0	0.0	0.0	*0.0*	0.0	0.0	0.0	0.0	0.0
90°	0.0	0.0	0.0	0.0	0.0	*0.0*	0.0	0.0	0.0	0.0	0.0
92.5°	0.0	0.0	0.0	0.0	0.0	*0.0*	0.0	0.0	0.0	0.0	0.0
95°	0.0	0.0	0.0	0.0	0.0	*0.0*	0.0	0.0	0.0	0.0	0.0
97.5°	0.0	0.0	0.0	0.0	0.0	*0.0*	0.0	0.0	0.0	0.0	0.0
100°	0.0	0.0	0.0	0.0	0.0	*0.0*	0.0	0.0	0.0	0.0	0.0
102.5°	0.0	0.0	0.0	0.0	0.0	*0.0*	0.0	0.0	0.0	0.0	0.0
105°	0.0	0.0	0.0	0.0	0.0	*0.0*	0.0	0.0	0.0	0.0	0.0
107.5°	0.0	0.0	0.0	0.0	0.0	*0.0*	0.0	0.0	0.0	0.0	0.0
110°	0.0	0.0	0.0	0.0	0.0	*0.0*	0.0	0.0	0.0	0.0	0.0

Cooper Lighting Solutions Photometric Lab
1121 Highway 74 South
Peachtree City, GA 30269

Scaled Data Report

REPORT NUMBER: P1390194
CATALOG NUMBER: GSS-SA3D-935-U-RBC

CANDELA DISTRIBUTION (continued):

	302.5°	305°	307.5°	310°	312.5°	315°	317.5°	320°	322.5°	325°	327.5°
112.5°	0.0	0.0	0.0	0.0	0.0	*0.0*	0.0	0.0	0.0	0.0	0.0
115°	0.0	0.0	0.0	0.0	0.0	*0.0*	0.0	0.0	0.0	0.0	0.0
117.5°	0.0	0.0	0.0	0.0	0.0	*0.0*	0.0	0.0	0.0	0.0	0.0
120°	0.0	0.0	0.0	0.0	0.0	*0.0*	0.0	0.0	0.0	0.0	0.0
122.5°	0.0	0.0	0.0	0.0	0.0	*0.0*	0.0	0.0	0.0	0.0	0.0
125°	0.0	0.0	0.0	0.0	0.0	*0.0*	0.0	0.0	0.0	0.0	0.0
127.5°	0.0	0.0	0.0	0.0	0.0	*0.0*	0.0	0.0	0.0	0.0	0.0
130°	0.0	0.0	0.0	0.0	0.0	*0.0*	0.0	0.0	0.0	0.0	0.0
132.5°	0.0	0.0	0.0	0.0	0.0	*0.0*	0.0	0.0	0.0	0.0	0.0
135°	0.0	0.0	0.0	0.0	0.0	*0.0*	0.0	0.0	0.0	0.0	0.0
137.5°	0.0	0.0	0.0	0.0	0.0	*0.0*	0.0	0.0	0.0	0.0	0.0
140°	0.0	0.0	0.0	0.0	0.0	*0.0*	0.0	0.0	0.0	0.0	0.0
142.5°	0.0	0.0	0.0	0.0	0.0	*0.0*	0.0	0.0	0.0	0.0	0.0
145°	0.0	0.0	0.0	0.0	0.0	*0.0*	0.0	0.0	0.0	0.0	0.0
147.5°	0.0	0.0	0.0	0.0	0.0	*0.0*	0.0	0.0	0.0	0.0	0.0
150°	0.0	0.0	0.0	0.0	0.0	*0.0*	0.0	0.0	0.0	0.0	0.0
152.5°	0.0	0.0	0.0	0.0	0.0	*0.0*	0.0	0.0	0.0	0.0	0.0
155°	0.0	0.0	0.0	0.0	0.0	*0.0*	0.0	0.0	0.0	0.0	0.0
157.5°	0.0	0.0	0.0	0.0	0.0	*0.0*	0.0	0.0	0.0	0.0	0.0
160°	0.0	0.0	0.0	0.0	0.0	*0.0*	0.0	0.0	0.0	0.0	0.0
162.5°	0.0	0.0	0.0	0.0	0.0	*0.0*	0.0	0.0	0.0	0.0	0.0
165°	0.0	0.0	0.0	0.0	0.0	*0.0*	0.0	0.0	0.0	0.0	0.0
167.5°	0.0	0.0	0.0	0.0	0.0	*0.0*	0.0	0.0	0.0	0.0	0.0
170°	0.0	0.0	0.0	0.0	0.0	*0.0*	0.0	0.0	0.0	0.0	0.0
172.5°	0.0	0.0	0.0	0.0	0.0	*0.0*	0.0	0.0	0.0	0.0	0.0
175°	0.0	0.0	0.0	0.0	0.0	*0.0*	0.0	0.0	0.0	0.0	0.0
177.5°	0.0	0.0	0.0	0.0	0.0	*0.0*	0.0	0.0	0.0	0.0	0.0
180°	0.0	0.0	0.0	0.0	0.0	*0.0*	0.0	0.0	0.0	0.0	0.0

Cooper Lighting Solutions Photometric Lab
1121 Highway 74 South
Peachtree City, GA 30269

Scaled Data Report

REPORT NUMBER: P1390194
CATALOG NUMBER: GSS-SA3D-935-U-RBC

CANDELA DISTRIBUTION (continued):

	330°	332.5°	335°	337.5°	340°	342.5°	345°	347.5°	350°	352.5°	355°
0°	37.3	37.3	37.3	37.3	37.3	37.3	37.3	37.3	37.3	37.3	37.3
2.5°	37.3	37.3	37.3	37.3	37.3	37.3	37.3	37.3	37.3	34.2	34.2
5°	43.6	43.6	43.6	43.6	43.6	43.6	43.6	43.6	43.6	40.5	40.5
7.5°	52.9	52.9	52.9	52.9	52.9	49.8	49.8	49.8	49.8	46.7	46.7
10°	68.5	65.4	65.4	65.4	62.2	62.2	59.1	59.1	56.0	56.0	52.9
12.5°	84.0	80.9	80.9	77.8	77.8	74.7	71.6	68.5	65.4	62.2	59.1
15°	108.9	105.8	102.7	99.6	93.4	90.3	84.0	80.9	77.8	74.7	71.6
17.5°	199.2	183.6	168.1	152.5	140.1	124.5	108.9	102.7	93.4	87.1	77.8
20°	628.7	547.8	466.8	395.3	323.7	249.0	177.4	155.6	133.8	112.0	90.3
22.5°	1559.2	1353.8	1148.4	971.0	793.6	616.2	438.8	357.9	277.0	196.1	115.2
25°	2639.2	2349.8	2063.4	1752.2	1444.1	1132.9	821.6	659.8	494.8	329.9	168.1
27.5°	3585.3	3252.3	2919.3	2508.5	2097.7	1683.7	1272.9	1023.9	771.8	519.7	270.8
30°	4363.4	4033.5	3703.6	3199.4	2692.1	2187.9	1680.6	1356.9	1033.3	706.5	382.8
32.5°	5013.8	4637.3	4260.7	3706.7	3155.8	2601.8	2047.9	1646.4	1248.0	846.5	445.1
35°	5782.6	5306.4	4827.1	4235.8	3647.6	3056.2	2464.9	1976.3	1484.5	992.8	504.2
37.5°	6685.1	6078.2	5471.3	4830.2	4192.2	3551.1	2910.0	2331.1	1755.3	1176.4	597.6
40°	8163.4	7329.4	6495.3	5726.5	4954.7	4186.0	3414.1	2745.0	2075.9	1403.6	734.5
42.5°	11512.2	10360.7	9209.2	8057.6	6903.0	5751.4	4596.8	3684.9	2776.1	1864.2	952.3
45°	16395.3	14848.6	13301.8	11758.1	10214.4	8670.7	7127.1	5711.0	4294.9	2875.7	1459.6
47.5°	19548.1	18038.6	16529.2	15050.9	13575.6	12097.3	10619.0	8627.2	6635.3	4640.4	2648.5
50°	20488.0	19037.7	17587.3	16267.7	14951.3	13631.7	12312.1	10205.1	8101.2	5994.2	3887.2
52.5°	20687.1	19246.2	17808.3	16485.6	15166.0	13843.3	12520.6	10422.9	8325.3	6224.5	4126.8
55°	21045.1	19467.1	17889.2	16404.7	14920.1	13432.5	11947.9	9853.4	7758.8	5664.3	3569.8
57.5°	*21623.9*	*19974.4*	*18328.1*	*16560.3*	*14792.5*	*13024.8*	*11257.0*	*9143.8*	*7030.6*	*4917.4*	*2804.1*
60°	21091.7	19716.1	18343.6	16438.9	14531.1	12626.4	10718.6	8571.1	6420.6	4270.0	2122.6
62.5°	18661.1	17665.1	16666.1	14976.2	13286.2	11596.3	9906.3	7814.9	5723.4	3632.0	1540.6
65°	15100.7	14263.5	13423.1	12084.9	10746.6	9405.2	8067.0	6305.4	4547.0	2785.5	1023.9
67.5°	11646.1	10843.1	10040.1	8985.1	7930.0	6875.0	5819.9	4537.7	3255.4	1970.1	687.8
70°	8985.1	8144.8	7304.5	6355.2	5406.0	4456.7	3507.5	2760.6	2016.7	1269.8	522.9
72.5°	6009.8	5477.6	4945.4	4158.0	3370.6	2583.2	1795.8	1453.4	1111.1	765.6	423.3
75°	1954.5	1774.0	1590.4	1375.6	1160.9	943.0	728.3	631.8	532.2	432.6	336.1
77.5°	806.1	709.6	610.0	519.7	426.4	336.1	242.8	227.2	211.6	196.1	180.5
80°	180.5	168.1	152.5	143.2	133.8	124.5	115.2	108.9	99.6	93.4	84.0
82.5°	24.9	24.9	21.8	24.9	28.0	31.1	34.2	31.1	31.1	28.0	24.9
85°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
87.5°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
90°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
92.5°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
95°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
97.5°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
100°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
102.5°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
105°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
107.5°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
110°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0

Cooper Lighting Solutions Photometric Lab
1121 Highway 74 South
Peachtree City, GA 30269

Scaled Data Report

REPORT NUMBER: P1390194
CATALOG NUMBER: GSS-SA3D-935-U-RBC

CANDELA DISTRIBUTION (continued):

	330°	332.5°	335°	337.5°	340°	342.5°	345°	347.5°	350°	352.5°	355°
112.5°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
115°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
117.5°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
120°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
122.5°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
125°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
127.5°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
130°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
132.5°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
135°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
137.5°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
140°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
142.5°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
145°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
147.5°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
150°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
152.5°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
155°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
157.5°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
160°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
162.5°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
165°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
167.5°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
170°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
172.5°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
175°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
177.5°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
180°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0

Cooper Lighting Solutions Photometric Lab
1121 Highway 74 South
Peachtree City, GA 30269

Scaled Data Report

REPORT NUMBER: P1390194
CATALOG NUMBER: GSS-SA3D-935-U-RBC

CANDELA DISTRIBUTION (continued):

	357.5°	360°
0°	37.3	37.3
2.5°	34.2	34.2
5°	40.5	37.3
7.5°	46.7	43.6
10°	52.9	49.8
12.5°	59.1	56.0
15°	68.5	62.2
17.5°	74.7	68.5
20°	84.0	74.7
22.5°	99.6	84.0
25°	130.7	96.5
27.5°	193.0	118.3
30°	270.8	158.7
32.5°	320.6	196.1
35°	348.6	196.1
37.5°	395.3	193.0
40°	466.8	202.3
42.5°	585.1	221.0
45°	868.3	277.0
47.5°	1574.8	501.1
50°	2334.2	784.3
52.5°	2489.8	852.8
55°	2169.2	768.7
57.5°	*1727.3*	*650.5*
60°	1304.0	488.6
62.5°	967.9	398.4
65°	687.8	351.7
67.5°	507.3	326.8
70°	417.0	314.3
72.5°	357.9	292.6
75°	298.8	261.4
77.5°	186.7	189.8
80°	80.9	74.7
82.5°	24.9	21.8
85°	0.0	0.0
87.5°	0.0	0.0
90°	0.0	0.0
92.5°	0.0	0.0
95°	0.0	0.0
97.5°	0.0	0.0
100°	0.0	0.0
102.5°	0.0	0.0
105°	0.0	0.0
107.5°	0.0	0.0
110°	0.0	0.0

Cooper Lighting Solutions Photometric Lab
1121 Highway 74 South
Peachtree City, GA 30269

Scaled Data Report

REPORT NUMBER: P1390194
CATALOG NUMBER: GSS-SA3D-935-U-RBC

CANDELA DISTRIBUTION (continued):

	357.5°	360°
112.5°	0.0	0.0
115°	0.0	0.0
117.5°	0.0	0.0
120°	0.0	0.0
122.5°	0.0	0.0
125°	0.0	0.0
127.5°	0.0	0.0
130°	0.0	0.0
132.5°	0.0	0.0
135°	0.0	0.0
137.5°	0.0	0.0
140°	0.0	0.0
142.5°	0.0	0.0
145°	0.0	0.0
147.5°	0.0	0.0
150°	0.0	0.0
152.5°	0.0	0.0
155°	0.0	0.0
157.5°	0.0	0.0
160°	0.0	0.0
162.5°	0.0	0.0
165°	0.0	0.0
167.5°	0.0	0.0
170°	0.0	0.0
172.5°	0.0	0.0
175°	0.0	0.0
177.5°	0.0	0.0
180°	0.0	0.0

Cooper Lighting Solutions Photometric Lab
1121 Highway 74 South
Peachtree City, GA 30269

LM-79-2019: Approved Method: Electrical and Photometric Measurements of Solid-State Lighting Products

Report Prepared for

Cooper Lighting Solutions

McGraw-Edison

Report Number: SP1-2407-184-15

Test Date: 10/11/2024

Luminaire Tested: GSS-SB1A-935-U-5WQ

Data in this report applies to families of products including GSS-SB1A-935-U-5WQ

Report Generated By FNC07603 / LDUCLS01DT446
Version: v7.04


Test Information

Test Method:	LM-79-2019
Report Number:	SP1-2407-184-15
Test Lab:	COOPER LIGHTING SOLUTIONS
Photometer:	SP1 - 76IN SPHERE
Measurement Geometry:	4π
Issue Date:	10/15/2024
Manufacturer:	COOPER LIGHTING SOLUTIONS
Product Line:	McGraw-Edison
Catalog Number:	**GSS-SB1A-935-U-5WQ**
Description:	GALLEON II SITE SLIM 1SQ 350MA 5WQ HIGH DENSITY LIGHTSQUARE WITH 90 CRI 3500K CCT 26 LEDS

Spectral Parameters

CCT (K):	3455
CIE u':	0.2356
CIE v':	0.5159
Duv:	0.0028
CIE x:	0.4109
CIE y:	0.3999
CIE z:	0.1892
Peak Wavelength (nm):	616
Dominant Wavelength (nm):	579
Purity:	43.35383
Rf:	92.3
Rg:	98.5

CRI (Ra):	92.2				
R1:	92.0	R9:	59.8		
R2:	94.4	R10:	85.8		
R3:	95.6	R11:	93.2		
R4:	93.2	R12:	78.0		
R5:	91.4	R13:	92.5		
R6:	92.5	R14:	97.0		
R7:	94.5	R15:	88.4		
R8:	84.2				



Test Conditions


Stabilization Time:	20M
Operation Time:	1H 20M
Sphere Temperature (°C):	25.2

REPORT NUMBER: SP1-2407-184-15


Measurement and Test Equipment			
Instrument	Identification Number	Calibration Date	Calibration Due Date
Photometer	IN0058	6/18/2024	12/18/2024
Power Meter	INXT2011004	2/8/2024	2/8/2025
AC Power Source	IN0063	10/24/2023	10/24/2024
DC Power Source	IN0208	10/24/2023	10/24/2024
Sphere Thermometer	IN0085	10/24/2023	10/24/2024
Room Thermometer	IN0046	10/24/2023	10/24/2024

REPORT NUMBER: SP1-2407-184-15

CIE 1931 Chromaticity Diagram



CIE 1931 Chromaticity Diagram with 2017 ANSI 7-Step and 4-Step Quadrangles




CCT = 3455K
CIE x = 0.4109
CIE y = 0.3999
Duv = 0.0028

Point lies inside the ANSI 3500K 4-step quadrangle

REPORT NUMBER: SP1-2407-184-15

Photopic Flux vs. Wavelength




Photopic Lumens: NR

λ (nm)	Power W^/nm	Lumens (ϕ/nm)	λ (nm)	Power W^/nm	Lumens (ϕ/nm)	λ (nm)	Power W^/nm	Lumens (ϕ/nm)	λ (nm)	Power W^/nm	Lumens (ϕ/nm)	λ (nm)	Power W^/nm	Lumens (ϕ/nm)
360	0	NR	490	410	NR	620	997	NR	750	74	NR	880	1	NR
365	0	NR	495	454	NR	625	988	NR	755	64	NR	885	1	NR
370	0	NR	500	493	NR	630	973	NR	760	54	NR	890	1	NR
375	0	NR	505	530	NR	635	946	NR	765	47	NR	895	1	NR
380	0	NR	510	564	NR	640	913	NR	770	40	NR	900	1	NR
385	0	NR	515	599	NR	645	870	NR	775	34	NR	905	1	NR
390	0	NR	520	634	NR	650	826	NR	780	29	NR	910	1	NR
395	0	NR	525	664	NR	655	774	NR	785	25	NR	915	1	NR
400	2	NR	530	695	NR	660	720	NR	790	21	NR	920	1	NR
405	4	NR	535	722	NR	665	664	NR	795	18	NR	925	1	NR
410	9	NR	540	741	NR	670	605	NR	800	16	NR	930	0	NR
415	17	NR	545	762	NR	675	550	NR	805	13	NR	935	0	NR
420	32	NR	550	777	NR	680	497	NR	810	12	NR	940	0	NR
425	61	NR	555	789	NR	685	445	NR	815	10	NR	945	0	NR
430	114	NR	560	800	NR	690	398	NR	820	9	NR	950	0	NR
435	218	NR	565	813	NR	695	352	NR	825	7	NR	955	0	NR
440	427	NR	570	828	NR	700	309	NR	830	6	NR	960	0	NR
445	684	NR	575	846	NR	705	273	NR	835	5	NR	965	0	NR
450	611	NR	580	866	NR	710	237	NR	840	5	NR	970	0	NR
455	461	NR	585	888	NR	715	208	NR	845	4	NR	975	0	NR
460	427	NR	590	913	NR	720	181	NR	850	4	NR	980	0	NR
465	349	NR	595	936	NR	725	157	NR	855	3	NR	985	0	NR
470	298	NR	600	957	NR	730	136	NR	860	3	NR	990	1	NR
475	312	NR	605	976	NR	735	117	NR	865	2	NR	995	0	NR
480	335	NR	610	990	NR	740	100	NR	870	2	NR	1000	0	NR
485	367	NR	615	999	NR	745	86	NR	875	2	NR			

REPORT NUMBER: SP1-2407-184-15

Scotopic Flux vs. Wavelength




Scotopic Lumens: NR **S/P: 1.58**

λ (nm)	Power W^/nm	Lumens (ϕ/nm)	λ (nm)	Power W^/nm	Lumens (ϕ/nm)	λ (nm)	Power W^/nm	Lumens (ϕ/nm)	λ (nm)	Power W^/nm	Lumens (ϕ/nm)	λ (nm)	Power W^/nm	Lumens (ϕ/nm)
360	0	NR	490	410	NR	620	997	NR	750	74	NR	880	1	NR
365	0	NR	495	454	NR	625	988	NR	755	64	NR	885	1	NR
370	0	NR	500	493	NR	630	973	NR	760	54	NR	890	1	NR
375	0	NR	505	530	NR	635	946	NR	765	47	NR	895	1	NR
380	0	NR	510	564	NR	640	913	NR	770	40	NR	900	1	NR
385	0	NR	515	599	NR	645	870	NR	775	34	NR	905	1	NR
390	0	NR	520	634	NR	650	826	NR	780	29	NR	910	1	NR
395	0	NR	525	664	NR	655	774	NR	785	25	NR	915	1	NR
400	2	NR	530	695	NR	660	720	NR	790	21	NR	920	1	NR
405	4	NR	535	722	NR	665	664	NR	795	18	NR	925	1	NR
410	9	NR	540	741	NR	670	605	NR	800	16	NR	930	0	NR
415	17	NR	545	762	NR	675	550	NR	805	13	NR	935	0	NR
420	32	NR	550	777	NR	680	497	NR	810	12	NR	940	0	NR
425	61	NR	555	789	NR	685	445	NR	815	10	NR	945	0	NR
430	114	NR	560	800	NR	690	398	NR	820	9	NR	950	0	NR
435	218	NR	565	813	NR	695	352	NR	825	7	NR	955	0	NR
440	427	NR	570	828	NR	700	309	NR	830	6	NR	960	0	NR
445	684	NR	575	846	NR	705	273	NR	835	5	NR	965	0	NR
450	611	NR	580	866	NR	710	237	NR	840	5	NR	970	0	NR
455	461	NR	585	888	NR	715	208	NR	845	4	NR	975	0	NR
460	427	NR	590	913	NR	720	181	NR	850	4	NR	980	0	NR
465	349	NR	595	936	NR	725	157	NR	855	3	NR	985	0	NR
470	298	NR	600	957	NR	730	136	NR	860	3	NR	990	1	NR
475	312	NR	605	976	NR	735	117	NR	865	2	NR	995	0	NR
480	335	NR	610	990	NR	740	100	NR	870	2	NR	1000	0	NR
485	367	NR	615	999	NR	745	86	NR	875	2	NR			

REPORT NUMBER: SP1-2407-184-15

Melanopic Flux vs. Wavelength



Melanopic Lumens: NR **M/P: 3.14**

λ (nm)	Power W^/nm	Lumens (ϕ/nm)	λ (nm)	Power W^/nm	Lumens (ϕ/nm)	λ (nm)	Power W^/nm	Lumens (ϕ/nm)	λ (nm)	Power W^/nm	Lumens (ϕ/nm)	λ (nm)	Power W^/nm	Lumens (ϕ/nm)
360	0	NR	490	410	NR	620	997	NR	750	74	NR	880	1	NR
365	0	NR	495	454	NR	625	988	NR	755	64	NR	885	1	NR
370	0	NR	500	493	NR	630	973	NR	760	54	NR	890	1	NR
375	0	NR	505	530	NR	635	946	NR	765	47	NR	895	1	NR
380	0	NR	510	564	NR	640	913	NR	770	40	NR	900	1	NR
385	0	NR	515	599	NR	645	870	NR	775	34	NR	905	1	NR
390	0	NR	520	634	NR	650	826	NR	780	29	NR	910	1	NR
395	0	NR	525	664	NR	655	774	NR	785	25	NR	915	1	NR
400	2	NR	530	695	NR	660	720	NR	790	21	NR	920	1	NR
405	4	NR	535	722	NR	665	664	NR	795	18	NR	925	1	NR
410	9	NR	540	741	NR	670	605	NR	800	16	NR	930	0	NR
415	17	NR	545	762	NR	675	550	NR	805	13	NR	935	0	NR
420	32	NR	550	777	NR	680	497	NR	810	12	NR	940	0	NR
425	61	NR	555	789	NR	685	445	NR	815	10	NR	945	0	NR
430	114	NR	560	800	NR	690	398	NR	820	9	NR	950	0	NR
435	218	NR	565	813	NR	695	352	NR	825	7	NR	955	0	NR
440	427	NR	570	828	NR	700	309	NR	830	6	NR	960	0	NR
445	684	NR	575	846	NR	705	273	NR	835	5	NR	965	0	NR
450	611	NR	580	866	NR	710	237	NR	840	5	NR	970	0	NR
455	461	NR	585	888	NR	715	208	NR	845	4	NR	975	0	NR
460	427	NR	590	913	NR	720	181	NR	850	4	NR	980	0	NR
465	349	NR	595	936	NR	725	157	NR	855	3	NR	985	0	NR
470	298	NR	600	957	NR	730	136	NR	860	3	NR	990	1	NR
475	312	NR	605	976	NR	735	117	NR	865	2	NR	995	0	NR
480	335	NR	610	990	NR	740	100	NR	870	2	NR	1000	0	NR
485	367	NR	615	999	NR	745	86	NR	875	2	NR			


REPORT NUMBER: SP1-2407-184-15

TM-30-18


Summary


R_f = 92.3
R_g = 98.5
CIE R_a = 92.2
R_9 = 59.8


Spectral Power Distribution Comparison




Color Vector Graphics










REPORT NUMBER: SP1-2407-184-15

TM-30-18

Individual Sample Fidelity Index ($R_{f,i}$)


CES01 = 86	CES26 = 93	CES51 = 97	CES76 = 88
CES02 = 62	CES27 = 93	CES52 = 98	CES77 = 91
CES03 = 31	CES28 = 96	CES53 = 96	CES78 = 85
CES04 = 70	CES29 = 95	CES54 = 95	CES79 = 96
CES05 = 50	CES30 = 97	CES55 = 94	CES80 = 94
CES06 = 51	CES31 = 96	CES56 = 94	CES81 = 87
CES07 = 42	CES32 = 91	CES57 = 93	CES82 = 97
CES08 = 41	CES33 = 98	CES58 = 94	CES83 = 97
CES09 = 29	CES34 = 94	CES59 = 96	CES84 = 94
CES10 = 75	CES35 = 97	CES60 = 94	CES85 = 85
CES11 = 58	CES36 = 86	CES61 = 93	CES86 = 87
CES12 = 64	CES37 = 95	CES62 = 91	CES87 = 92
CES13 = 43	CES38 = 92	CES63 = 93	CES88 = 96
CES14 = 74	CES39 = 99	CES64 = 91	CES89 = 87
CES15 = 71	CES40 = 98	CES65 = 89	CES90 = 96
CES16 = 47	CES41 = 98	CES66 = 89	CES91 = 78
CES17 = 49	CES42 = 96	CES67 = 88	CES92 = 81
CES18 = 56	CES43 = 96	CES68 = 89	CES93 = 89
CES19 = 71	CES44 = 99	CES69 = 91	CES94 = 81
CES20 = 66	CES45 = 98	CES70 = 87	CES95 = 85
CES21 = 86	CES46 = 97	CES71 = 84	CES96 = 92
CES22 = 78	CES47 = 97	CES72 = 95	CES97 = 95
CES23 = 91	CES48 = 93	CES73 = 83	CES98 = 94
CES24 = 90	CES49 = 96	CES74 = 94	CES99 = 91
CES25 = 71	CES50 = 98	CES75 = 85	





REPORT NUMBER: SP1-2407-184-15

TM-30-18

Color Rendition by Hue-Angle Bin









REPORT NUMBER: SP1-2407-184-15

TM-30-18

Measure Comparisons





(END OF REPORT)