

Signify Classified - Internal
Cooper Lighting Solutions Photometric Lab
1121 Highway 74 South
Peachtree City, GA 30269



Scaled data based on original data using
LM-79-08 Approved Method: Electrical and Photometric Measurements of Solid-
State Lighting Products

Test Report Prepared for
Cooper Lighting Solutions
(formerly Eaton)

Brand: McGRAW-EDISON

Report Number: P436837

Luminaire Tested: **TT-D4-735-U-5WQ-PM-HSS**

Issue Date: 12/2/2020

Test Information

Test Method: LM-79-08
Report Number: P436837
TEST IS SCALED FROM IESNA LM-79-08 TEST DATA (G2-2010-017-2)
Test Lab: INNOVATION CENTER
Issue Date: 12/2/2020
Manufacturer: COOPER LIGHTING SOLUTIONS (FORMERLY EATON)
Product Line: MCGRAW-EDISON
Catalog Number: TT-D4-735-U-5WQ-PM-HSS
Description: TOPTIER LED SITE LUMINAIRE
3500K, 70 CRI LEDS AND WIDE DISTRIBUTION WITH HOUSE SIDE SHIELD
Light Source: -
Ballast/Driver: ELECTRONIC DRIVER

Summary

Lumens per Lamp: N/A
Luminaire Lumens: 5762.9 lumens
Efficiency: N/A
Efficacy: 100.1 lumens/watt
Luminous Opening: Circular (Dia: 1.12' x H: 0')
IES Classification: Type IV - Short
BUG Rating: B2 - U2 - G3


Input Watts (W): 57.6
Input Voltage (V): NR
Input Current (Ain): NR
Voltage Rise (V): NR
Power Factor: NR
Total Harmonic Distortion (THDi): NR
Frequency (hertz): 60
Stabilization Time: NR
Operation Time: NR
Ambient Temperature (°C): NR
Test Distance: 28.75 FT



REPORT NUMBER: P436837
 CATALOG NUMBER: TT-D4-735-U-5WQ-PM-HSS

Iso-Footcandle Lines of Horizontal Illumination


✕ Max cd
 - - - 1/2 Max cd



Based on 25 foot mounting height. Maximum calculated value = 0.8 fc
 Type IV - Short - N/A

REPORT NUMBER: P436837
CATALOG NUMBER: TT-D4-735-U-5WQ-PM-HSS

Luminous Intensity Polar Plot



REPORT NUMBER: P436837

CATALOG NUMBER: TT-D4-735-U-5WQ-PM-HSS


FLUX DISTRIBUTION:

		Downward	Upward	Total
House Side	Lumens	2029.8	1.3	2031.2
	% Fixture	35.2	0.0	35.2
Street Side	Lumens	3708.5	23.3	3731.8
	% Fixture	64.4	0.4	64.8
Total	Lumens	5738.3	24.6	5762.9
	% Fixture	99.6	0.4	100.0

ZONAL LUMENS:

Zone	Lumens	% Fixture
0°-10°	38.5	0.7
10°-20°	136.9	2.4
20°-30°	293.3	5.1
30°-40°	531.2	9.2
40°-50°	886.4	15.4
50°-60°	1227.8	21.3
60°-70°	1272.4	22.1
70°-80°	1024.1	17.8
80°-90°	327.6	5.7
90°-100°	16.6	0.3
100°-110°	5.3	0.1
110°-120°	1.0	0.0
120°-130°	0.6	0.0
130°-140°	0.4	0.0
140°-150°	0.3	0.0
150°-160°	0.2	0.0
160°-170°	0.1	0.0
170°-180°	0.0	0.0
0°-90°	5738.3	99.6
0°-180°	5762.9	100.0

Coefficient of Utilization



REPORT NUMBER: P436837


CATALOG NUMBER: TT-D4-735-U-5WQ-PM-HSS

LUMINAIRE CLASSIFICATION SYSTEM LUMEN TABLE AND BUG RATING:

Zone		Lumens	% Fixture	Zone Rating/Lumen Limit		
				B	U	G
FL	(0°-30°)	239.6	4.2			
FM	(30°-60°)	1532.1	26.6			
FH	(60°-80°)	1687.5	29.3			G1/1800
FVH	(80°-90°)	249.2	4.3			G3/500
BL	(0°-30°)	229.1	4.0	B1/500		
BM	(30°-60°)	1113.4	19.3	B2/2500		
BH	(60°-80°)	609.0	10.6	B2/1000		G2/1000
BVH	(80°-90°)	78.3	1.4			G1/100
UL	(90°-100°)	16.6	0.3		U2/50	
UH	(100°-180°)	8.0	0.1		U1/10	

BUG Rating: B2-U2-G3

Type IV Short



REPORT NUMBER: P436837

CATALOG NUMBER: TT-D4-735-U-5WQ-PM-HSS

CANDELA DISTRIBUTION (FULL):

	0°	5°	15°	25°	35°	44°	45°	55°	65°	75°	85°
0°	380.3	380.3	380.3	380.3	380.3	380.3	380.3	380.3	380.3	380.3	380.3
2.5°	391.5	390.4	390.4	389.3	389.3	389.3	389.3	389.3	388.2	387.0	385.9
5°	401.7	401.7	400.5	400.5	399.4	399.4	399.4	398.3	397.2	396.0	394.9
7.5°	415.2	414.0	414.0	411.8	411.8	410.7	410.7	410.7	409.5	407.3	406.2
10°	434.3	432.0	432.0	429.8	428.7	427.5	427.5	425.3	425.3	424.2	423.0
12.5°	455.7	453.4	455.7	454.5	452.3	450.0	450.0	447.8	446.7	445.5	441.0
15°	483.8	480.4	482.7	482.7	481.5	480.4	480.4	475.9	473.7	471.4	466.9
17.5°	517.5	515.3	516.4	517.5	520.9	520.9	522.0	516.4	511.9	504.0	500.7
20°	560.3	559.2	562.5	562.5	565.9	565.9	567.0	561.4	553.5	547.9	541.2
22.5°	601.9	601.9	606.4	606.4	609.8	607.5	607.5	605.3	596.3	589.5	582.8
25°	644.7	643.6	648.1	651.4	655.9	650.3	652.6	649.2	640.2	631.2	622.2
27.5°	691.9	689.7	691.9	696.4	704.3	699.8	702.1	696.4	687.4	675.1	667.2
30°	743.7	740.3	743.7	750.4	756.1	758.3	757.2	749.3	741.4	723.4	717.8
32.5°	794.3	794.3	802.2	814.6	821.3	820.2	821.3	814.6	803.3	780.8	767.3
35°	856.2	860.7	870.8	888.8	903.4	897.8	897.8	895.6	876.4	849.4	831.4
37.5°	938.3	942.8	963.1	984.5	1011.5	1009.2	1010.3	1003.6	966.5	938.3	912.4
40°	1034.0	1038.5	1068.8	1099.2	1125.1	1133.0	1134.1	1119.5	1079.0	1038.5	998.0
42.5°	1121.7	1127.3	1158.8	1201.6	1229.7	1242.1	1244.3	1220.7	1178.0	1131.8	1081.2
45°	1209.5	1216.2	1252.2	1297.2	1337.7	1343.4	1344.5	1324.2	1277.0	1224.1	1158.8
47.5°	1299.5	1305.1	1342.2	1396.2	1440.1	1451.4	1452.5	1433.4	1376.0	1311.9	1235.3
50°	1381.6	1392.9	1443.5	1500.9	1559.4	1568.4	1569.5	1548.1	1480.6	1408.6	1307.4
52.5°	1478.4	1484.0	1538.0	1633.6	1683.1	1718.0	1719.1	1677.5	1605.5	1508.7	1378.2
55°	1590.9	1601.0	1656.1	1751.8	1840.6	1864.3	1871.0	1821.5	1725.9	1621.3	1468.2
57.5°	1656.1	1675.3	1756.3	1847.4	1958.8	1974.5	1977.9	1926.2	1820.4	1705.6	1535.7
60°	1691.0	1702.3	1787.8	1929.5	2016.2	2030.8	2029.7	1990.3	1884.5	1745.0	1567.2
62.5°	1730.4	1749.5	1821.5	1965.5	2040.9	2076.9	2071.3	2030.8	1922.8	1769.8	1597.6
65°	1719.1	1734.9	1840.6	1957.7	2082.5	2121.9	2114.0	2060.0	1928.4	1774.3	1589.8
67.5°	1674.1	1686.5	1791.1	1936.3	2055.5	2083.7	2097.2	2044.3	1896.9	1725.9	1540.2
70°	1581.9	1601.0	1702.3	1850.8	1959.9	1980.2	1982.4	1949.8	1817.0	1637.0	1458.1
72.5°	1454.7	1470.5	1580.7	1731.5	1826.0	1849.6	1851.9	1802.4	1702.3	1515.5	1340.0
75°	1302.9	1317.5	1403.0	1560.5	1653.9	1677.5	1675.3	1629.1	1523.4	1346.7	1183.6
77.5°	1115.0	1142.0	1217.3	1346.7	1437.9	1450.2	1452.5	1401.9	1316.4	1163.3	1004.7
80°	879.8	905.7	991.2	1088.0	1164.5	1174.6	1178.0	1135.2	1057.6	922.6	787.6
82.5°	625.5	648.1	715.6	794.3	858.4	858.4	860.7	825.8	766.2	650.3	544.5
85°	356.7	373.5	418.5	474.8	520.9	515.3	516.4	484.9	445.5	355.5	288.0
87.5°	117.0	124.9	135.0	156.4	177.8	164.3	171.0	141.8	128.3	95.6	74.3
90°	61.9	61.9	59.6	57.4	52.9	46.1	46.1	37.1	28.1	18.0	6.8
92.5°	56.3	56.3	54.0	51.8	47.3	41.6	41.6	33.8	24.8	15.8	5.6
95°	46.1	46.1	45.0	42.8	39.4	34.9	33.8	28.1	21.4	12.4	4.5
97.5°	36.0	36.0	34.9	33.8	30.4	27.0	27.0	21.4	15.8	10.1	3.4
100°	27.0	27.0	27.0	24.8	23.6	20.3	20.3	16.9	12.4	7.9	2.3
102.5°	19.1	20.3	19.1	18.0	16.9	14.6	14.6	12.4	9.0	5.6	2.3
105°	13.5	13.5	12.4	12.4	11.3	10.1	10.1	7.9	5.6	3.4	1.1
107.5°	7.9	7.9	7.9	7.9	6.8	6.8	6.8	5.6	3.4	2.3	1.1
110°	4.5	4.5	4.5	4.5	3.4	3.4	3.4	2.3	2.3	1.1	1.1

REPORT NUMBER: P436837

CATALOG NUMBER: TT-D4-735-U-5WQ-PM-HSS

CANDELA DISTRIBUTION (continued):

	0°	5°	15°	25°	35°	44°	45°	55°	65°	75°	85°
112.5°	2.3	2.3	2.3	2.3	2.3	2.3	2.3	1.1	1.1	1.1	1.1
115°	1.1	1.1	1.1	2.3	1.1	1.1	1.1	1.1	1.1	1.1	1.1
117.5°	1.1	1.1	1.1	1.1	1.1	1.1	1.1	1.1	1.1	1.1	1.1
120°	0.0	0.0	1.1	1.1	1.1	1.1	1.1	1.1	1.1	1.1	1.1
122.5°	0.0	0.0	1.1	1.1	1.1	1.1	1.1	1.1	1.1	1.1	1.1
125°	0.0	0.0	1.1	1.1	1.1	1.1	1.1	1.1	1.1	1.1	1.1
127.5°	0.0	0.0	0.0	1.1	1.1	1.1	1.1	1.1	1.1	1.1	1.1
130°	0.0	0.0	0.0	1.1	1.1	1.1	1.1	1.1	1.1	1.1	1.1
132.5°	0.0	0.0	0.0	1.1	1.1	1.1	1.1	1.1	1.1	1.1	1.1
135°	0.0	0.0	0.0	0.0	1.1	1.1	1.1	1.1	1.1	1.1	1.1
137.5°	0.0	0.0	0.0	0.0	0.0	0.0	1.1	1.1	1.1	1.1	1.1
140°	1.1	1.1	0.0	0.0	0.0	0.0	1.1	1.1	1.1	1.1	1.1
142.5°	1.1	1.1	1.1	0.0	0.0	1.1	1.1	1.1	1.1	1.1	1.1
145°	1.1	1.1	0.0	0.0	0.0	0.0	0.0	1.1	1.1	1.1	1.1
147.5°	1.1	1.1	1.1	0.0	0.0	1.1	1.1	1.1	1.1	1.1	1.1
150°	1.1	1.1	0.0	0.0	0.0	0.0	1.1	1.1	1.1	1.1	1.1
152.5°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	1.1	1.1	1.1	1.1
155°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	1.1	1.1	1.1
157.5°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	1.1	1.1	1.1	1.1
160°	1.1	0.0	0.0	0.0	0.0	0.0	0.0	1.1	1.1	1.1	1.1
162.5°	1.1	1.1	0.0	0.0	0.0	0.0	0.0	1.1	1.1	1.1	1.1
165°	1.1	0.0	0.0	0.0	0.0	0.0	1.1	1.1	1.1	1.1	1.1
167.5°	1.1	1.1	0.0	0.0	0.0	0.0	1.1	1.1	1.1	1.1	1.1
170°	1.1	0.0	0.0	0.0	0.0	1.1	0.0	1.1	1.1	1.1	1.1
172.5°	1.1	1.1	0.0	0.0	0.0	0.0	1.1	1.1	1.1	1.1	1.1
175°	1.1	1.1	1.1	0.0	0.0	0.0	1.1	1.1	1.1	1.1	1.1
177.5°	0.0	1.1	0.0	0.0	0.0	0.0	0.0	1.1	1.1	1.1	1.1
180°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0

REPORT NUMBER: P436837

CATALOG NUMBER: TT-D4-735-U-5WQ-PM-HSS

CANDELA DISTRIBUTION (continued):

	90°	95°	105°	115°	125°	135°	145°	155°	165°	175°	180°
0°	380.3	380.3	380.3	380.3	380.3	380.3	380.3	380.3	380.3	380.3	380.3
2.5°	385.9	385.9	384.8	383.7	383.7	383.7	382.5	382.5	382.5	381.4	381.4
5°	394.9	393.8	393.8	392.7	392.7	391.5	391.5	390.4	389.3	389.3	388.2
7.5°	407.3	406.2	403.9	405.0	402.8	401.7	400.5	400.5	400.5	399.4	399.4
10°	421.9	421.9	419.7	419.7	417.4	416.3	415.2	415.2	416.3	416.3	415.2
12.5°	441.0	439.9	439.9	438.8	437.7	436.5	437.7	437.7	436.5	435.4	434.3
15°	464.7	464.7	464.7	465.8	464.7	464.7	464.7	463.5	461.3	459.0	459.0
17.5°	500.7	499.5	497.3	498.4	500.7	504.0	500.7	497.3	493.9	493.9	492.8
20°	537.8	538.9	538.9	540.0	543.4	546.8	542.3	540.0	537.8	535.5	533.3
22.5°	578.3	579.4	579.4	578.3	580.5	579.4	577.2	574.9	572.7	569.3	567.0
25°	617.7	618.8	617.7	616.5	617.7	614.3	610.9	607.5	601.9	596.3	596.3
27.5°	661.6	660.4	655.9	657.1	654.8	652.6	645.8	637.9	630.0	624.4	624.4
30°	707.7	707.7	698.7	703.2	698.7	697.6	682.9	672.8	661.6	653.7	652.6
32.5°	758.3	756.1	749.3	753.8	749.3	744.8	726.8	713.3	694.2	682.9	681.8
35°	819.1	813.4	807.8	812.3	812.3	799.9	781.9	757.2	730.2	716.7	715.6
37.5°	893.3	889.9	883.2	888.8	893.3	880.9	853.9	817.9	779.7	759.4	758.3
40°	975.5	971.0	967.6	975.5	978.8	966.5	930.4	879.8	828.1	798.8	794.3
42.5°	1053.1	1043.0	1037.3	1048.6	1045.2	1031.7	982.2	923.7	852.8	819.1	813.4
45°	1122.8	1111.6	1103.7	1113.8	1109.3	1082.3	1027.2	948.4	862.9	821.3	814.6
47.5°	1191.5	1174.6	1162.2	1175.7	1166.7	1125.1	1057.6	960.8	851.7	802.2	790.9
50°	1250.0	1229.7	1221.8	1237.6	1224.1	1165.6	1079.0	955.2	823.6	751.6	733.6
52.5°	1319.7	1289.4	1281.5	1311.9	1281.5	1203.8	1083.5	941.7	759.4	672.8	655.9
55°	1390.6	1356.9	1344.5	1372.6	1326.5	1211.7	1061.0	864.1	662.7	570.4	545.7
57.5°	1427.7	1396.2	1385.0	1405.2	1319.7	1135.2	960.8	720.1	517.5	414.0	387.0
60°	1461.5	1406.4	1391.7	1418.7	1250.0	957.5	743.7	516.4	312.8	235.1	214.9
62.5°	1485.1	1432.2	1401.9	1414.2	1121.7	696.4	427.5	248.6	118.1	82.1	81.0
65°	1472.7	1427.7	1407.5	1398.5	974.3	400.5	157.5	63.0	3.4	3.4	2.3
67.5°	1434.5	1385.0	1379.4	1387.2	964.2	384.8	146.3	57.4	0.0	0.0	0.0
70°	1350.1	1315.2	1315.2	1342.2	920.3	364.5	136.1	52.9	0.0	0.0	0.0
72.5°	1236.5	1209.5	1225.2	1265.7	855.1	336.4	122.6	47.3	0.0	0.0	0.0
75°	1100.3	1072.2	1092.5	1137.5	774.1	300.4	106.9	40.5	0.0	0.0	0.0
77.5°	927.1	907.9	939.4	981.1	666.1	253.1	87.8	32.6	0.0	0.0	0.0
80°	722.3	712.2	753.8	790.9	537.8	199.1	66.4	23.6	0.0	0.0	0.0
82.5°	498.4	493.9	534.4	572.7	384.8	139.5	45.0	15.8	0.0	0.0	0.0
85°	261.0	261.0	292.5	327.4	214.9	75.4	22.5	6.8	0.0	0.0	0.0
87.5°	57.4	55.1	59.6	76.5	42.8	14.6	3.4	1.1	0.0	0.0	0.0
90°	1.1	1.1	1.1	1.1	0.0	0.0	0.0	0.0	0.0	0.0	0.0
92.5°	1.1	1.1	1.1	1.1	0.0	0.0	0.0	0.0	0.0	0.0	0.0
95°	1.1	1.1	1.1	1.1	0.0	0.0	0.0	0.0	0.0	0.0	0.0
97.5°	1.1	1.1	1.1	1.1	1.1	0.0	0.0	0.0	0.0	0.0	0.0
100°	1.1	1.1	1.1	1.1	1.1	0.0	0.0	0.0	0.0	0.0	0.0
102.5°	1.1	1.1	1.1	1.1	1.1	1.1	0.0	0.0	0.0	0.0	0.0
105°	1.1	1.1	1.1	1.1	1.1	0.0	0.0	0.0	0.0	0.0	0.0
107.5°	1.1	1.1	1.1	1.1	1.1	0.0	0.0	0.0	0.0	0.0	0.0
110°	1.1	1.1	1.1	1.1	1.1	0.0	0.0	0.0	0.0	0.0	0.0

REPORT NUMBER: P436837

CATALOG NUMBER: TT-D4-735-U-5WQ-PM-HSS

CANDELA DISTRIBUTION (continued):

	90°	95°	105°	115°	125°	135°	145°	155°	165°	175°	180°
112.5°	1.1	1.1	1.1	1.1	1.1	0.0	0.0	0.0	0.0	0.0	0.0
115°	1.1	1.1	1.1	1.1	1.1	1.1	0.0	0.0	0.0	0.0	0.0
117.5°	1.1	1.1	1.1	1.1	1.1	0.0	0.0	0.0	0.0	0.0	0.0
120°	1.1	1.1	1.1	1.1	1.1	1.1	0.0	0.0	0.0	0.0	0.0
122.5°	1.1	1.1	1.1	1.1	1.1	1.1	0.0	0.0	0.0	0.0	0.0
125°	1.1	1.1	1.1	1.1	1.1	0.0	0.0	0.0	0.0	0.0	0.0
127.5°	1.1	1.1	1.1	1.1	0.0	0.0	0.0	0.0	0.0	0.0	0.0
130°	1.1	1.1	1.1	1.1	0.0	0.0	0.0	0.0	0.0	0.0	0.0
132.5°	1.1	1.1	1.1	1.1	0.0	0.0	0.0	0.0	0.0	0.0	0.0
135°	1.1	1.1	1.1	1.1	0.0	0.0	0.0	0.0	0.0	0.0	0.0
137.5°	1.1	1.1	1.1	1.1	0.0	0.0	0.0	0.0	0.0	0.0	0.0
140°	1.1	1.1	1.1	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
142.5°	1.1	1.1	1.1	1.1	0.0	0.0	0.0	0.0	0.0	0.0	0.0
145°	1.1	1.1	1.1	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
147.5°	1.1	1.1	1.1	1.1	0.0	0.0	0.0	0.0	0.0	0.0	0.0
150°	1.1	1.1	1.1	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
152.5°	1.1	1.1	1.1	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
155°	1.1	1.1	1.1	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
157.5°	1.1	1.1	1.1	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
160°	1.1	1.1	1.1	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
162.5°	1.1	1.1	1.1	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
165°	1.1	1.1	1.1	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
167.5°	1.1	1.1	1.1	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
170°	1.1	1.1	1.1	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
172.5°	1.1	1.1	1.1	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
175°	1.1	1.1	1.1	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
177.5°	1.1	1.1	1.1	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
180°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0

LM-79-2019: Approved Method: Electrical and Photometric Measurements of Solid-State Lighting Products

Report Prepared for

Cooper Lighting Solutions

MCGRAW EDISON

Report Number: SP1-2411-284-1

Test Date: 11/15/2024

Luminaire Tested: TTN-D0-735-U-WQ


Data in this report applies to families of products including TT-D* and TTN-D*

Test Information

Test Method: LM-79-2019
 Report Number: SP1-2411-284-1
 Test Lab: COOPER LIGHTING SOLUTIONS
 Photometer: SP1 - 76IN SPHERE
 Measurement Geometry: 4π
 Issue Date: 11/15/2024
 Manufacturer: COOPER LIGHTING SOLUTIONS
 Product Line: MCGRAW EDISON
 Catalog Number: **TTN-D0-735-U-WQ**
 Description: TOPTIER NANO LED PARKING GARAGE LUMINAIRE. 3500K, 70 CRI LEDS AND WIDE DISTRIBUTION

Spectral Parameters

CCT (K):	3405	CRI (Ra):	73.9		
CIE u':	0.2365	R1:	71.3	R9:	-18.0
CIE v':	0.5180	R2:	80.3	R10:	53.1
Duv:	0.0036	R3:	87.8	R11:	68.6
CIE x:	0.4148	R4:	73.2	R12:	42.6
CIE y:	0.4038	R5:	69.8	R13:	72.5
CIE z:	0.1814	R6:	71.8	R14:	92.7
Peak Wavelength (nm):	596	R7:	82.8	R15:	64.3
Dominant Wavelength (nm):	579	R8:	54.1		
Purity:	45.70672				
Rf:	76.6				
Rg:	95.4				



Test Conditions


Stabilization Time: 38M
 Operation Time: 1H 38M
 Sphere Temperature (°C): 24.9

REPORT NUMBER: SP1-2411-284-1


Measurement and Test Equipment			
Instrument	Identification Number	Calibration Date	Calibration Due Date
Photometer	IN0058	6/18/2024	12/18/2024
Power Meter	INXT2011004	2/8/2024	2/8/2025
AC Power Source	IN0063	10/22/2024	10/22/2025
DC Power Source	IN0208	10/22/2024	10/22/2025
Sphere Thermometer	IN0085	10/22/2024	10/22/2025
Room Thermometer	IN0046	10/22/2024	10/22/2025

REPORT NUMBER: SP1-2411-284-1

CIE 1931 Chromaticity Diagram




CIE 1931 Chromaticity Diagram with 2017 ANSI 7-Step and 4-Step Quadrangles



Point lies inside the ANSI 3500K 4-step quadrangle

REPORT NUMBER: SP1-2411-284-1

Photopic Flux vs. Wavelength




Photopic Lumens: NR

λ (nm)	Power W ^λ /nm	Lumens (φ/nm)	λ (nm)	Power W ^λ /nm	Lumens (φ/nm)	λ (nm)	Power W ^λ /nm	Lumens (φ/nm)	λ (nm)	Power W ^λ /nm	Lumens (φ/nm)	λ (nm)	Power W ^λ /nm	Lumens (φ/nm)
360	0	NR	490	119	NR	620	846	NR	750	28	NR	880	1	NR
365	0	NR	495	160	NR	625	793	NR	755	25	NR	885	0	NR
370	0	NR	500	225	NR	630	739	NR	760	22	NR	890	0	NR
375	0	NR	505	308	NR	635	681	NR	765	19	NR	895	0	NR
380	0	NR	510	392	NR	640	623	NR	770	16	NR	900	0	NR
385	0	NR	515	474	NR	645	563	NR	775	14	NR	905	0	NR
390	0	NR	520	545	NR	650	506	NR	780	12	NR	910	0	NR
395	1	NR	525	603	NR	655	451	NR	785	10	NR	915	0	NR
400	3	NR	530	649	NR	660	399	NR	790	9	NR	920	0	NR
405	5	NR	535	687	NR	665	352	NR	795	8	NR	925	0	NR
410	11	NR	540	721	NR	670	307	NR	800	6	NR	930	0	NR
415	21	NR	545	751	NR	675	268	NR	805	6	NR	935	0	NR
420	43	NR	550	779	NR	680	234	NR	810	5	NR	940	0	NR
425	88	NR	555	811	NR	685	203	NR	815	4	NR	945	0	NR
430	163	NR	560	843	NR	690	176	NR	820	4	NR	950	0	NR
435	288	NR	565	873	NR	695	152	NR	825	3	NR	955	0	NR
440	416	NR	570	907	NR	700	131	NR	830	3	NR	960	0	NR
445	566	NR	575	938	NR	705	112	NR	835	3	NR	965	0	NR
450	810	NR	580	965	NR	710	96	NR	840	2	NR	970	0	NR
455	669	NR	585	986	NR	715	81	NR	845	2	NR	975	0	NR
460	338	NR	590	997	NR	720	69	NR	850	2	NR	980	0	NR
465	246	NR	595	997	NR	725	58	NR	855	1	NR	985	0	NR
470	182	NR	600	991	NR	730	49	NR	860	1	NR	990	0	NR
475	115	NR	605	968	NR	735	42	NR	865	1	NR	995	0	NR
480	97	NR	610	939	NR	740	37	NR	870	1	NR	1000	0	NR
485	103	NR	615	896	NR	745	32	NR	875	1	NR			

REPORT NUMBER: SP1-2411-284-1

Scotopic Flux vs. Wavelength




Scotopic Lumens: NR

S/P: 1.33

λ (nm)	Power W [^] /nm	Lumens (Φ/nm)	λ (nm)	Power W [^] /nm	Lumens (Φ/nm)	λ (nm)	Power W [^] /nm	Lumens (Φ/nm)	λ (nm)	Power W [^] /nm	Lumens (Φ/nm)	λ (nm)	Power W [^] /nm	Lumens (Φ/nm)
360	0	NR	490	119	NR	620	846	NR	750	28	NR	880	1	NR
365	0	NR	495	160	NR	625	793	NR	755	25	NR	885	0	NR
370	0	NR	500	225	NR	630	739	NR	760	22	NR	890	0	NR
375	0	NR	505	308	NR	635	681	NR	765	19	NR	895	0	NR
380	0	NR	510	392	NR	640	623	NR	770	16	NR	900	0	NR
385	0	NR	515	474	NR	645	563	NR	775	14	NR	905	0	NR
390	0	NR	520	545	NR	650	506	NR	780	12	NR	910	0	NR
395	1	NR	525	603	NR	655	451	NR	785	10	NR	915	0	NR
400	3	NR	530	649	NR	660	399	NR	790	9	NR	920	0	NR
405	5	NR	535	687	NR	665	352	NR	795	8	NR	925	0	NR
410	11	NR	540	721	NR	670	307	NR	800	6	NR	930	0	NR
415	21	NR	545	751	NR	675	268	NR	805	6	NR	935	0	NR
420	43	NR	550	779	NR	680	234	NR	810	5	NR	940	0	NR
425	88	NR	555	811	NR	685	203	NR	815	4	NR	945	0	NR
430	163	NR	560	843	NR	690	176	NR	820	4	NR	950	0	NR
435	288	NR	565	873	NR	695	152	NR	825	3	NR	955	0	NR
440	416	NR	570	907	NR	700	131	NR	830	3	NR	960	0	NR
445	566	NR	575	938	NR	705	112	NR	835	3	NR	965	0	NR
450	810	NR	580	965	NR	710	96	NR	840	2	NR	970	0	NR
455	669	NR	585	986	NR	715	81	NR	845	2	NR	975	0	NR
460	338	NR	590	997	NR	720	69	NR	850	2	NR	980	0	NR
465	246	NR	595	997	NR	725	58	NR	855	1	NR	985	0	NR
470	182	NR	600	991	NR	730	49	NR	860	1	NR	990	0	NR
475	115	NR	605	968	NR	735	42	NR	865	1	NR	995	0	NR
480	97	NR	610	939	NR	740	37	NR	870	1	NR	1000	0	NR
485	103	NR	615	896	NR	745	32	NR	875	1	NR			

REPORT NUMBER: SP1-2411-284-1

Melanopic Flux vs. Wavelength



Melanopic Lumens: NR

M/P: 2.47


λ (nm)	Power $\text{W}^{\wedge}/\text{nm}$	Lumens (ϕ/nm)	λ (nm)	Power $\text{W}^{\wedge}/\text{nm}$	Lumens (ϕ/nm)	λ (nm)	Power $\text{W}^{\wedge}/\text{nm}$	Lumens (ϕ/nm)	λ (nm)	Power $\text{W}^{\wedge}/\text{nm}$	Lumens (ϕ/nm)	λ (nm)	Power $\text{W}^{\wedge}/\text{nm}$	Lumens (ϕ/nm)
360	0	NR	490	119	NR	620	846	NR	750	28	NR	880	1	NR
365	0	NR	495	160	NR	625	793	NR	755	25	NR	885	0	NR
370	0	NR	500	225	NR	630	739	NR	760	22	NR	890	0	NR
375	0	NR	505	308	NR	635	681	NR	765	19	NR	895	0	NR
380	0	NR	510	392	NR	640	623	NR	770	16	NR	900	0	NR
385	0	NR	515	474	NR	645	563	NR	775	14	NR	905	0	NR
390	0	NR	520	545	NR	650	506	NR	780	12	NR	910	0	NR
395	1	NR	525	603	NR	655	451	NR	785	10	NR	915	0	NR
400	3	NR	530	649	NR	660	399	NR	790	9	NR	920	0	NR
405	5	NR	535	687	NR	665	352	NR	795	8	NR	925	0	NR
410	11	NR	540	721	NR	670	307	NR	800	6	NR	930	0	NR
415	21	NR	545	751	NR	675	268	NR	805	6	NR	935	0	NR
420	43	NR	550	779	NR	680	234	NR	810	5	NR	940	0	NR
425	88	NR	555	811	NR	685	203	NR	815	4	NR	945	0	NR
430	163	NR	560	843	NR	690	176	NR	820	4	NR	950	0	NR
435	288	NR	565	873	NR	695	152	NR	825	3	NR	955	0	NR
440	416	NR	570	907	NR	700	131	NR	830	3	NR	960	0	NR
445	566	NR	575	938	NR	705	112	NR	835	3	NR	965	0	NR
450	810	NR	580	965	NR	710	96	NR	840	2	NR	970	0	NR
455	669	NR	585	986	NR	715	81	NR	845	2	NR	975	0	NR
460	338	NR	590	997	NR	720	69	NR	850	2	NR	980	0	NR
465	246	NR	595	997	NR	725	58	NR	855	1	NR	985	0	NR
470	182	NR	600	991	NR	730	49	NR	860	1	NR	990	0	NR
475	115	NR	605	968	NR	735	42	NR	865	1	NR	995	0	NR
480	97	NR	610	939	NR	740	37	NR	870	1	NR	1000	0	NR
485	103	NR	615	896	NR	745	32	NR	875	1	NR			

REPORT NUMBER: SP1-2411-284-1





TM-30-18

Summary

$R_f = 76.6$
 $R_g = 95.4$
 $CIE R_a = 73.9$
 $R_g = -18.0$







Color Vector Graphics




Individual Sample Fidelity Index ($R_{f,i}$)

CES01 = 86	CES26 = 67	CES51 = 88	CES76 = 56
CES02 = 62	CES27 = 89	CES52 = 88	CES77 = 75
CES03 = 31	CES28 = 83	CES53 = 78	CES78 = 60
CES04 = 70	CES29 = 69	CES54 = 86	CES79 = 85
CES05 = 48	CES30 = 83	CES55 = 85	CES80 = 82
CES06 = 51	CES31 = 72	CES56 = 75	CES81 = 78
CES07 = 41	CES32 = 65	CES57 = 75	CES82 = 92
CES08 = 40	CES33 = 78	CES58 = 76	CES83 = 90
CES09 = 29	CES34 = 74	CES59 = 87	CES84 = 88
CES10 = 75	CES35 = 86	CES60 = 91	CES85 = 79
CES11 = 58	CES36 = 93	CES61 = 84	CES86 = 72
CES12 = 64	CES37 = 81	CES62 = 88	CES87 = 79
CES13 = 43	CES38 = 92	CES63 = 74	CES88 = 82
CES14 = 74	CES39 = 96	CES64 = 69	CES89 = 72
CES15 = 71	CES40 = 92	CES65 = 66	CES90 = 82
CES16 = 47	CES41 = 93	CES66 = 62	CES91 = 79
CES17 = 50	CES42 = 83	CES67 = 60	CES92 = 63
CES18 = 56	CES43 = 79	CES68 = 68	CES93 = 77
CES19 = 72	CES44 = 99	CES69 = 76	CES94 = 56
CES20 = 65	CES45 = 86	CES70 = 61	CES95 = 70
CES21 = 86	CES46 = 83	CES71 = 55	CES96 = 79
CES22 = 79	CES47 = 85	CES72 = 85	CES97 = 85
CES23 = 92	CES48 = 78	CES73 = 53	CES98 = 78
CES24 = 91	CES49 = 81	CES74 = 95	CES99 = 68
CES25 = 72	CES50 = 88	CES75 = 57	



Color Rendition by Hue-Angle Bin


Measure Comparisons


(END OF REPORT)