

Cooper Lighting Solutions Photometric Lab
1121 Highway 74 South
Peachtree City, GA 30269



Scaled data based on original data using
LM-79-2019 Approved Method: Electrical and Photometric Measurements of Solid-
State Lighting Products

Test Report Prepared for
Cooper Lighting Solutions

Brand: NEO-RAY

Report Number: P929914

Luminaire Tested: DFN2DS-4P3F0-060DS830-RLL

Issue Date: 11/20/2024

Test Information

Test Method: LM-79-2019
Report Number: P929914
TEST IS SCALED FROM IESNA LM-79-08 TEST DATA (P333882)
Test Lab: INNOVATION CENTER
Issue Date: 11/20/2024
Manufacturer: COOPER LIGHTING SOLUTIONS
Product Line: NEO-RAY
Catalog Number: DFN2DS-4P3F0-060DS830-RLL
Description: 3 foot, 90deg - 4way Define Geo, with Direct 1in Regressed Frosted Lens
Light Source: -
Ballast/Driver: -

Summary


Lumens per Lamp: N/A
Luminaire Lumens: 4804.2 lumens
Efficiency: N/A
Efficacy: 73.9 lumens/watt
Spacing Criteria (0/90/45): 1.2 / 0.99 / 1.16
Luminous Opening: Rectangular (W 3.07' x L: 3.07' x H: 0')
CIE Type: Direct

Input Watts (W): 65
Input Voltage (V):
Input Current (Ain): NR
Voltage Rise (V): NR
Power Factor: 0.9963
Total Harmonic Distortion (THDi): 0.065
Frequency (hertz): 60
Stabilization Time: NR
Operation Time: NR
Ambient Temperature (°C): NR
Test Distance: 24 FT

TEST NUMBER: P929914

CATALOG NUMBER: DFN2DS-4P3F0-060DS830-RLL

Luminous Intensity Polar Plot



TEST NUMBER: P929914

CATALOG NUMBER: DFN2DS-4P3F0-060DS830-RLL

COEFFICIENT OF UTILIZATION - ZONAL CAVITY METHOD:

RF	20				20				20				20				20
RC	80				70				50				30				10
RW	70	50	30	10	70	50	30	10	50	30	10		50	30	10		50
RCR																	
0	119	119	119	119	116	116	116	116	111	111	111		106	106	106		102
1	110	106	102	98	107	103	100	97	99	96	94		95	93	91		92
2	101	94	87	82	98	92	86	81	88	83	79		85	81	78		82
3	93	83	76	70	90	82	75	69	79	73	68		76	71	67		74
4	86	75	66	60	83	73	66	60	71	64	59		69	63	58		66
5	79	67	59	53	77	66	58	52	64	57	52		62	56	51		60
6	74	61	53	47	72	60	52	46	58	51	46		57	50	46		55
7	68	56	47	42	67	55	47	42	53	46	41		52	46	41		51
8	64	51	43	38	62	51	43	37	49	42	37		48	42	37		47
9	60	47	39	34	59	47	39	34	46	39	34		44	38	34		44
10	56	44	36	31	55	43	36	31	42	36	31		41	35	31		41

AVERAGE LUMINANCE (cd/sqm):

	0°	45°	90°
0°	2662	2662	2662
5°	2672	2629	2643
10°	2652	2586	2564
15°	2621	2509	2437
20°	2579	2400	2279
25°	2536	2275	2127
30°	2476	2147	1931
35°	2418	2009	1759
40°	2359	1865	1560
45°	2289	1704	1380
50°	2219	1540	1203
55°	2146	1365	1033
60°	2062	1180	858
65°	1967	992	781
70°	1853	817	718
75°	1713	745	671
80°	1511	665	611
85°	1187	524	524

MAXIMUM LUMINANCE 45°-90°:

Horizontal Angle: 0°

Vertical Angle: 45°

Luminance: 2289 cd/sqm

TEST NUMBER: P929914

CATALOG NUMBER: DFN2DS-4P3F0-060DS830-RLL

ZONAL LUMENS:

Zone	Lumens	% Fixture
0°-10°	218.9	4.6
10°-20°	601.0	12.5
20°-30°	843.8	17.6
30°-40°	919.8	19.1
40°-50°	845.4	17.6
50°-60°	663.9	13.8
60°-70°	432.2	9.0
70°-80°	222.5	4.6
80°-90°	56.8	1.2
90°-100°	0.0	0.0
100°-110°	0.0	0.0
110°-120°	0.0	0.0
120°-130°	0.0	0.0
130°-140°	0.0	0.0
140°-150°	0.0	0.0
150°-160°	0.0	0.0
160°-170°	0.0	0.0
170°-180°	0.0	0.0
0°-30°	1663.7	34.6
0°-40°	2583.5	53.8
0°-60°	4092.8	85.2
0°-90°	4804.2	100.0
90°-120°	0.0	0.0
90°-150°	0.0	0.0
90°-180°	0.0	0.0
0°-180°	4804.2	100.0

CANDELA DISTRIBUTION:

	0°	22.5°	45°	67.5°	90°	Flux
0°	2336	2336	2336	2336	2336	
5°	2336	2325	2298	2317	2311	221
15°	2222	2198	2127	2086	2065	626
25°	2017	1949	1810	1723	1691	928
35°	1738	1630	1444	1311	1264	1088
45°	1421	1279	1057	907	856	1097
55°	1080	915	687	560	520	965
65°	729	558	368	296	290	723
75°	389	241	169	154	152	411
85°	91	46	40	40	40	109
90°	0	0	0	0	0	

TEST NUMBER: P929914

CATALOG NUMBER: DFN2DS-4P3F0-060DS830-RLL

CANDELA DISTRIBUTION (FULL):

	0°	22.5°	45°	67.5°	90°
0°	2336.0	2336.0	2336.0	2336.0	2336.0
2.5°	2346.5	2336.0	2312.6	2333.9	2329.7
5°	2336.0	2325.4	2297.8	2316.9	2310.6
7.5°	2316.9	2304.3	2274.7	2283.0	2272.5
10°	2291.5	2276.7	2234.6	2228.1	2215.5
12.5°	2260.0	2240.8	2183.7	2171.1	2147.8
15°	2221.8	2198.4	2126.7	2086.5	2065.4
17.5°	2177.4	2143.5	2054.7	2008.2	1974.4
20°	2126.7	2084.3	1978.7	1925.9	1879.3
22.5°	2071.7	2023.0	1900.4	1828.6	1797.0
25°	2016.8	1949.1	1809.6	1723.0	1691.2
27.5°	1951.4	1879.3	1725.0	1625.6	1577.0
30°	1881.6	1801.0	1631.9	1524.3	1467.1
32.5°	1813.8	1716.5	1543.4	1416.4	1363.5
35°	1737.8	1629.9	1444.0	1310.7	1264.1
37.5°	1663.8	1547.3	1350.9	1204.9	1152.2
40°	1585.5	1458.8	1253.5	1103.5	1048.5
42.5°	1505.2	1370.0	1156.4	999.8	947.2
45°	1420.6	1278.9	1057.1	906.8	856.1
47.5°	1340.4	1190.3	962.0	811.7	765.3
50°	1251.5	1101.5	868.9	722.9	678.7
52.5°	1164.7	1006.2	780.1	640.6	600.4
55°	1080.2	915.3	687.0	560.3	520.1
57.5°	993.6	824.4	604.7	486.3	452.3
60°	904.8	735.7	517.9	410.2	376.3
62.5°	818.2	649.1	443.9	342.5	325.6
65°	729.4	558.0	367.9	296.1	289.6
67.5°	644.8	473.4	296.1	260.0	253.7
70°	556.0	391.1	245.1	224.1	215.5
72.5°	471.5	314.9	205.0	188.2	183.9
75°	389.0	240.9	169.1	154.3	152.3
77.5°	306.6	171.2	133.2	124.7	120.5
80°	230.3	122.6	101.4	93.1	93.1
82.5°	160.6	82.5	69.7	65.5	65.5
85°	90.8	46.4	40.1	40.1	40.1
87.5°	33.9	16.9	16.9	14.8	14.8
90°	0.0	0.0	0.0	0.0	0.0

TEST NUMBER: P929914

CATALOG NUMBER: DFN2DS-4P3F0-060DS830-RLL

CIE UGR TABLE:

Reflectances:											
Ceiling		0.7	0.7	0.5	0.5	0.3	0.7	0.7	0.5	0.5	0.3
Wall		0.5	0.3	0.5	0.3	0.3	0.5	0.3	0.5	0.3	0.3
Reference plane		0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2
Room dimensions		Viewed crosswise					Viewed endwise				
X=2H	Y=2H	14.64	16.16	15.00	16.47	16.79	10.60	12.12	10.96	12.43	12.75
	3H	16.40	17.77	16.78	18.09	18.46	11.86	13.23	12.24	13.56	13.92
	4H	17.07	18.35	17.47	18.70	19.08	12.36	13.64	12.76	13.99	14.37
	6H	17.56	18.74	17.97	19.11	19.50	12.75	13.93	13.16	14.29	14.69
	8H	17.72	18.85	18.15	19.24	19.64	12.87	14.00	13.30	14.39	14.79
	12H	17.83	18.90	18.26	19.29	19.71	12.95	14.03	13.38	14.41	14.84
4H	2H	14.74	16.02	15.14	16.37	16.75	11.29	12.57	11.69	12.92	13.30
	3H	16.67	17.74	17.08	18.14	18.54	12.74	13.80	13.15	14.20	14.60
	4H	17.42	18.38	17.86	18.80	19.23	13.34	14.29	13.77	14.71	15.15
	6H	18.01	18.85	18.47	19.29	19.75	13.82	14.66	14.28	15.10	15.56
	8H	18.23	19.01	18.69	19.45	19.92	13.99	14.76	14.45	15.21	15.67
	12H	18.38	19.08	18.86	19.56	20.03	14.10	14.80	14.58	15.28	15.75
8H	4H	17.45	18.22	17.91	18.67	19.14	13.69	14.47	14.15	14.91	15.38
	6H	18.08	18.73	18.58	19.22	19.70	14.28	14.92	14.77	15.41	15.89
	8H	18.33	18.91	18.85	19.42	19.91	14.50	15.07	15.01	15.58	16.07
	12H	18.54	19.05	19.05	19.54	20.11	14.68	15.19	15.19	15.68	16.24
12H	4H	17.43	18.13	17.91	18.60	19.08	13.73	14.43	14.21	14.91	15.38
	6H	18.07	18.64	18.58	19.15	19.64	14.34	14.92	14.85	15.43	15.91
	8H	18.35	18.86	18.86	19.35	19.92	14.61	15.12	15.12	15.61	16.18