

Cooper Lighting Solutions Photometric Lab
1121 Highway 74 South
Peachtree City, GA 30269



Scaled data based on original data using
LM-79-2019 Approved Method: Electrical and Photometric Measurements of Solid-
State Lighting Products

Test Report Prepared for
Cooper Lighting Solutions

Brand: NEO-RAY

Report Number: P929950

Luminaire Tested: DFN2DS-4P4F0-040DS830-RLL

Issue Date: 11/20/2024

Test Information

Test Method: LM-79-2019
Report Number: P929950
TEST IS SCALED FROM IESNA LM-79-08 TEST DATA (P333882)
Test Lab: INNOVATION CENTER
Issue Date: 11/20/2024
Manufacturer: COOPER LIGHTING SOLUTIONS
Product Line: NEO-RAY
Catalog Number: DFN2DS-4P4F0-040DS830-RLL
Description: 4 foot, 90deg - 4way Define Geo, with Direct 1in Regressed Frosted Lens
Light Source: -
Ballast/Driver: -

Summary


Lumens per Lamp: N/A
Luminaire Lumens: 3202.8 lumens
Efficiency: N/A
Efficacy: 81.5 lumens/watt
Spacing Criteria (0/90/45): 1.2 / 0.99 / 1.16
Luminous Opening: Rectangular (W 4.07' x L: 4.07' x H: 0')
CIE Type: Direct

Input Watts (W): 39.3
Input Voltage (V):
Input Current (Ain): NR
Voltage Rise (V): NR
Power Factor: 0.9968
Total Harmonic Distortion (THDi): 0.064
Frequency (hertz): 60
Stabilization Time: NR
Operation Time: NR
Ambient Temperature (°C): NR
Test Distance: 24 FT

TEST NUMBER: P929950

CATALOG NUMBER: DFN2DS-4P4F0-040DS830-RLL

Luminous Intensity Polar Plot



TEST NUMBER: P929950

CATALOG NUMBER: DFN2DS-4P4F0-040DS830-RLL

COEFFICIENT OF UTILIZATION - ZONAL CAVITY METHOD:

RF	20				20				20				20				20
RC	80				70				50				30				10
RW	70	50	30	10	70	50	30	10	50	30	10		50	30	10		50
RCR																	
0	119	119	119	119	116	116	116	116	111	111	111		106	106	106		102
1	110	106	102	98	107	103	100	97	99	96	94		95	93	91		92
2	101	94	87	82	98	92	86	81	88	83	79		85	81	78		82
3	93	83	76	70	90	82	75	69	79	73	68		76	71	67		74
4	86	75	66	60	83	73	66	60	71	64	59		69	63	58		66
5	79	67	59	53	77	66	58	52	64	57	52		62	56	51		60
6	74	61	53	47	72	60	52	46	58	51	46		57	50	46		55
7	68	56	47	42	67	55	47	42	53	46	41		52	46	41		51
8	64	51	43	38	62	51	43	37	49	42	37		48	42	37		47
9	60	47	39	34	59	47	39	34	46	39	34		44	38	34		44
10	56	44	36	31	55	43	36	31	42	36	31		41	35	31		41

AVERAGE LUMINANCE (cd/sqm):

	0°	45°	90°
0°	1010	1010	1010
5°	1014	998	1003
10°	1006	981	973
15°	995	952	925
20°	979	911	865
25°	962	863	807
30°	940	815	733
35°	918	762	667
40°	895	708	592
45°	869	647	524
50°	842	585	457
55°	815	518	392
60°	783	448	326
65°	746	376	296
70°	703	310	273
75°	650	283	254
80°	573	252	232
85°	451	199	199

MAXIMUM LUMINANCE 45°-90°:

Horizontal Angle: 0°

Vertical Angle: 45°

Luminance: 869 cd/sqm

TEST NUMBER: P929950

CATALOG NUMBER: DFN2DS-4P4F0-040DS830-RLL

ZONAL LUMENS:

Zone	Lumens	% Fixture
0°-10°	146.0	4.6
10°-20°	400.7	12.5
20°-30°	562.5	17.6
30°-40°	613.2	19.1
40°-50°	563.6	17.6
50°-60°	442.6	13.8
60°-70°	288.1	9.0
70°-80°	148.3	4.6
80°-90°	37.9	1.2
90°-100°	0.0	0.0
100°-110°	0.0	0.0
110°-120°	0.0	0.0
120°-130°	0.0	0.0
130°-140°	0.0	0.0
140°-150°	0.0	0.0
150°-160°	0.0	0.0
160°-170°	0.0	0.0
170°-180°	0.0	0.0
0°-30°	1109.1	34.6
0°-40°	1722.3	53.8
0°-60°	2728.5	85.2
0°-90°	3202.8	100.0
90°-120°	0.0	0.0
90°-150°	0.0	0.0
90°-180°	0.0	0.0
0°-180°	3202.8	100.0

CANDELA DISTRIBUTION:

	0°	22.5°	45°	67.5°	90°	Flux
0°	1557	1557	1557	1557	1557	
5°	1557	1550	1532	1545	1540	148
15°	1481	1466	1418	1391	1377	417
25°	1344	1299	1206	1149	1127	618
35°	1159	1087	963	874	843	725
45°	947	853	705	605	571	731
55°	720	610	458	374	347	644
65°	486	372	245	197	193	482
75°	259	161	113	103	102	274
85°	61	31	27	27	27	73
90°	0	0	0	0	0	

TEST NUMBER: P929950

CATALOG NUMBER: DFN2DS-4P4F0-040DS830-RLL

CANDELA DISTRIBUTION (FULL):

	0°	22.5°	45°	67.5°	90°
0°	1557.3	1557.3	1557.3	1557.3	1557.3
2.5°	1564.4	1557.3	1541.8	1556.0	1553.1
5°	1557.3	1550.2	1531.9	1544.6	1540.5
7.5°	1544.6	1536.2	1516.5	1522.0	1515.0
10°	1527.7	1517.8	1489.7	1485.3	1477.1
12.5°	1506.6	1493.9	1455.8	1447.4	1431.8
15°	1481.2	1465.7	1417.8	1391.1	1377.0
17.5°	1451.6	1429.0	1369.8	1338.9	1316.3
20°	1417.8	1389.5	1319.1	1283.9	1252.9
22.5°	1381.2	1348.8	1266.9	1219.0	1198.0
25°	1344.5	1299.4	1206.3	1148.7	1127.4
27.5°	1300.9	1252.9	1150.0	1083.8	1051.3
30°	1254.4	1200.7	1087.9	1016.1	978.1
32.5°	1209.2	1144.3	1028.9	944.3	908.9
35°	1158.6	1086.6	962.6	873.8	842.7
37.5°	1109.2	1031.6	900.6	803.2	768.1
40°	1057.0	972.5	835.7	735.7	699.1
42.5°	1003.4	913.3	770.9	666.6	631.4
45°	947.1	852.6	704.7	604.6	570.8
47.5°	893.6	793.5	641.3	541.2	510.2
50°	834.3	734.3	579.2	481.9	452.4
52.5°	776.5	670.8	520.1	427.0	400.3
55°	720.2	610.2	458.0	373.5	346.8
57.5°	662.4	549.7	403.1	324.1	301.6
60°	603.2	490.4	345.2	273.5	250.9
62.5°	545.5	432.8	295.9	228.3	217.1
65°	486.3	372.0	245.2	197.3	193.0
67.5°	429.9	315.7	197.3	173.3	169.1
70°	370.7	260.7	163.4	149.4	143.7
72.5°	314.3	210.0	136.7	125.5	122.6
75°	259.2	160.6	112.8	102.9	101.5
77.5°	204.4	114.1	88.8	83.2	80.3
80°	153.5	81.8	67.5	62.1	62.1
82.5°	107.1	55.0	46.5	43.6	43.6
85°	60.6	31.0	26.8	26.8	26.8
87.5°	22.6	11.2	11.2	9.9	9.9
90°	0.0	0.0	0.0	0.0	0.0

TEST NUMBER: P929950

CATALOG NUMBER: DFN2DS-4P4F0-040DS830-RLL

CIE UGR TABLE:

Reflectances:											
Ceiling		0.7	0.7	0.5	0.5	0.3	0.7	0.7	0.5	0.5	0.3
Wall		0.5	0.3	0.5	0.3	0.3	0.5	0.3	0.5	0.3	0.3
Reference plane		0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2
Room dimensions		Viewed crosswise					Viewed endwise				
X=2H	Y=2H	11.27	12.79	11.64	13.11	13.42	7.23	8.75	7.59	9.06	9.38
	3H	13.04	14.40	13.41	14.73	15.09	8.50	9.86	8.87	10.19	10.55
	4H	13.70	14.98	14.10	15.33	15.71	9.00	10.28	9.40	10.63	11.00
	6H	14.19	15.37	14.60	15.74	16.13	9.38	10.56	9.79	10.93	11.32
	8H	14.36	15.48	14.78	15.87	16.27	9.50	10.63	9.93	11.02	11.42
	12H	14.46	15.54	14.89	15.92	16.35	9.58	10.66	10.01	11.04	11.47
4H	2H	11.37	12.66	11.77	13.00	13.38	7.93	9.21	8.33	9.55	9.93
	3H	13.31	14.37	13.72	14.77	15.17	9.37	10.43	9.78	10.83	11.23
	4H	14.06	15.01	14.49	15.43	15.87	9.97	10.93	10.40	11.34	11.78
	6H	14.65	15.48	15.11	15.92	16.38	10.46	11.29	10.91	11.73	12.19
	8H	14.86	15.64	15.33	16.08	16.55	10.62	11.40	11.08	11.84	12.31
	12H	15.02	15.71	15.50	16.19	16.66	10.74	11.43	11.22	11.91	12.38
8H	4H	14.08	14.86	14.54	15.30	15.77	10.32	11.10	10.79	11.54	12.01
	6H	14.72	15.36	15.22	15.85	16.33	10.91	11.55	11.41	12.04	12.52
	8H	14.97	15.55	15.48	16.06	16.54	11.13	11.71	11.64	12.22	12.70
	12H	15.17	15.68	15.68	16.18	16.74	11.31	11.82	11.82	12.31	12.88
12H	4H	14.07	14.76	14.55	15.24	15.71	10.37	11.06	10.85	11.54	12.01
	6H	14.70	15.28	15.21	15.79	16.27	10.97	11.55	11.49	12.06	12.55
	8H	14.98	15.49	15.49	15.99	16.55	11.25	11.76	11.76	12.25	12.81