

Cooper Lighting Solutions Photometric Lab
1121 Highway 74 South
Peachtree City, GA 30269



Scaled data based on original data using
LM-79-2019 Approved Method: Electrical and Photometric Measurements of Solid-
State Lighting Products

Test Report Prepared for
Cooper Lighting Solutions

Brand: NEO-RAY

Report Number: P929944

Luminaire Tested: DFN2DS-4P4F0-030DS935-RLL

Issue Date: 11/20/2024

Test Information

Test Method: LM-79-2019
Report Number: P929944
TEST IS SCALED FROM IESNA LM-79-08 TEST DATA (P333882)
Test Lab: INNOVATION CENTER
Issue Date: 11/20/2024
Manufacturer: COOPER LIGHTING SOLUTIONS
Product Line: NEO-RAY
Catalog Number: DFN2DS-4P4F0-030DS935-RLL
Description: 4 foot, 90deg - 4way Define Geo, with Direct 1in Regressed Frosted Lens
Light Source: -
Ballast/Driver: -

Summary


Lumens per Lamp: N/A
Luminaire Lumens: 2193.0 lumens
Efficiency: N/A
Efficacy: 77.8 lumens/watt
Spacing Criteria (0/90/45): 1.2 / 0.99 / 1.16
Luminous Opening: Rectangular (W 4.07' x L: 4.07' x H: 0')
CIE Type: Direct

Input Watts (W): 28.2
Input Voltage (V):
Input Current (Ain): NR
Voltage Rise (V): NR
Power Factor: 0.983
Total Harmonic Distortion (THDi): 0.073
Frequency (hertz): 60
Stabilization Time: NR
Operation Time: NR
Ambient Temperature (°C): NR
Test Distance: 24 FT

TEST NUMBER: P929944

CATALOG NUMBER: DFN2DS-4P4F0-030DS935-RLL

Luminous Intensity Polar Plot



TEST NUMBER: P929944

CATALOG NUMBER: DFN2DS-4P4F0-030DS935-RLL

COEFFICIENT OF UTILIZATION - ZONAL CAVITY METHOD:

RF	20				20				20				20				20
RC	80				70				50				30				10
RW	70	50	30	10	70	50	30	10	50	30	10		50	30	10		50
RCR																	
0	119	119	119	119	116	116	116	116	111	111	111		106	106	106		102
1	110	106	102	98	107	103	100	97	99	96	94		95	93	91		92
2	101	94	87	82	98	92	86	81	88	83	79		85	81	78		82
3	93	83	76	70	90	82	75	69	79	73	68		76	71	67		74
4	86	75	66	60	83	73	66	60	71	64	59		69	63	58		66
5	79	67	59	53	77	66	58	52	64	57	52		62	56	51		60
6	74	61	53	47	72	60	52	46	58	51	46		57	50	46		55
7	68	56	47	42	67	55	47	42	53	46	41		52	46	41		51
8	64	51	43	38	62	51	43	37	49	42	37		48	42	37		47
9	60	47	39	34	59	47	39	34	46	39	34		44	38	34		44
10	56	44	36	31	55	43	36	31	42	36	31		41	35	31		41

AVERAGE LUMINANCE (cd/sqm):

	0°	45°	90°
0°	692	692	692
5°	694	683	687
10°	689	672	666
15°	681	652	633
20°	670	624	592
25°	659	591	553
30°	643	558	502
35°	628	522	457
40°	613	485	405
45°	595	443	359
50°	577	400	313
55°	558	355	269
60°	536	307	223
65°	511	258	203
70°	481	212	187
75°	445	194	174
80°	393	173	159
85°	309	136	136

MAXIMUM LUMINANCE 45°-90°:

Horizontal Angle: 0°

Vertical Angle: 45°

Luminance: 595 cd/sqm

TEST NUMBER: P929944

CATALOG NUMBER: DFN2DS-4P4F0-030DS935-RLL

ZONAL LUMENS:

Zone	Lumens	% Fixture
0°-10°	99.9	4.6
10°-20°	274.3	12.5
20°-30°	385.2	17.6
30°-40°	419.9	19.1
40°-50°	385.9	17.6
50°-60°	303.1	13.8
60°-70°	197.3	9.0
70°-80°	101.5	4.6
80°-90°	25.9	1.2
90°-100°	0.0	0.0
100°-110°	0.0	0.0
110°-120°	0.0	0.0
120°-130°	0.0	0.0
130°-140°	0.0	0.0
140°-150°	0.0	0.0
150°-160°	0.0	0.0
160°-170°	0.0	0.0
170°-180°	0.0	0.0
0°-30°	759.4	34.6
0°-40°	1179.3	53.8
0°-60°	1868.3	85.2
0°-90°	2193.0	100.0
90°-120°	0.0	0.0
90°-150°	0.0	0.0
90°-180°	0.0	0.0
0°-180°	2193.0	100.0

CANDELA DISTRIBUTION:

	0°	22.5°	45°	67.5°	90°	Flux
0°	1066	1066	1066	1066	1066	
5°	1066	1062	1049	1058	1055	101
15°	1014	1004	971	952	943	286
25°	921	890	826	786	772	423
35°	793	744	659	598	577	497
45°	648	584	482	414	391	501
55°	493	418	314	256	237	441
65°	333	255	168	135	132	330
75°	178	110	77	70	70	188
85°	42	21	18	18	18	50
90°	0	0	0	0	0	

TEST NUMBER: P929944

CATALOG NUMBER: DFN2DS-4P4F0-030DS935-RLL

CANDELA DISTRIBUTION (FULL):

	0°	22.5°	45°	67.5°	90°
0°	1066.3	1066.3	1066.3	1066.3	1066.3
2.5°	1071.1	1066.3	1055.6	1065.4	1063.5
5°	1066.3	1061.5	1048.9	1057.6	1054.7
7.5°	1057.6	1051.9	1038.4	1042.1	1037.3
10°	1046.0	1039.3	1020.0	1017.0	1011.4
12.5°	1031.6	1022.9	996.8	991.1	980.4
15°	1014.2	1003.5	970.8	952.4	942.8
17.5°	993.9	978.5	937.9	916.8	901.3
20°	970.8	951.4	903.2	879.2	857.8
22.5°	945.7	923.5	867.5	834.7	820.3
25°	920.6	889.7	826.0	786.5	771.9
27.5°	890.7	857.8	787.4	742.1	719.8
30°	858.9	822.2	744.9	695.8	669.7
32.5°	827.9	783.5	704.5	646.5	622.4
35°	793.3	744.0	659.1	598.3	577.1
37.5°	759.5	706.3	616.6	550.0	526.0
40°	723.8	665.9	572.2	503.7	478.7
42.5°	687.1	625.4	527.9	456.4	432.3
45°	648.5	583.8	482.5	413.9	390.8
47.5°	611.8	543.3	439.1	370.5	349.3
50°	571.3	502.8	396.6	330.0	309.8
52.5°	531.7	459.3	356.1	292.4	274.1
55°	493.0	417.8	313.6	255.8	237.4
57.5°	453.6	376.3	276.1	222.0	206.5
60°	413.0	335.8	236.4	187.2	171.8
62.5°	373.5	296.3	202.6	156.3	148.7
65°	332.9	254.7	167.9	135.1	132.2
67.5°	294.4	216.1	135.1	118.7	115.8
70°	253.8	178.5	111.9	102.3	98.4
72.5°	215.2	143.7	93.6	85.9	83.9
75°	177.5	110.0	77.2	70.4	69.5
77.5°	139.9	78.1	60.8	56.9	55.0
80°	105.2	56.0	46.3	42.5	42.5
82.5°	73.3	37.7	31.8	29.9	29.9
85°	41.5	21.2	18.3	18.3	18.3
87.5°	15.5	7.7	7.7	6.8	6.8
90°	0.0	0.0	0.0	0.0	0.0

TEST NUMBER: P929944

CATALOG NUMBER: DFN2DS-4P4F0-030DS935-RLL

CIE UGR TABLE:

Reflectances:											
Ceiling		0.7	0.7	0.5	0.5	0.3	0.7	0.7	0.5	0.5	0.3
Wall		0.5	0.3	0.5	0.3	0.3	0.5	0.3	0.5	0.3	0.3
Reference plane		0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2
Room dimensions		Viewed crosswise					Viewed endwise				
X=2H	Y=2H	9.95	11.48	10.32	11.79	12.10	5.92	7.44	6.28	7.75	8.07
	3H	11.72	13.08	12.10	13.41	13.77	7.18	8.55	7.56	8.87	9.24
	4H	12.39	13.67	12.79	14.01	14.39	7.68	8.96	8.08	9.31	9.69
	6H	12.87	14.06	13.29	14.42	14.82	8.06	9.25	8.48	9.61	10.00
	8H	13.04	14.17	13.47	14.56	14.96	8.19	9.31	8.61	9.70	10.11
	12H	13.14	14.22	13.57	14.60	15.03	8.27	9.35	8.70	9.73	10.16
4H	2H	10.06	11.34	10.46	11.69	12.07	6.61	7.89	7.01	8.24	8.62
	3H	11.99	13.05	12.40	13.45	13.85	8.05	9.12	8.46	9.52	9.92
	4H	12.74	13.70	13.17	14.11	14.55	8.65	9.61	9.09	10.03	10.46
	6H	13.33	14.16	13.79	14.61	15.07	9.14	9.97	9.60	10.42	10.88
	8H	13.55	14.32	14.01	14.77	15.24	9.30	10.08	9.77	10.52	10.99
	12H	13.70	14.40	14.18	14.87	15.34	9.42	10.11	9.90	10.59	11.06
8H	4H	12.76	13.54	13.23	13.99	14.45	9.01	9.78	9.47	10.23	10.70
	6H	13.40	14.04	13.90	14.54	15.01	9.59	10.24	10.09	10.73	11.20
	8H	13.65	14.23	14.17	14.74	15.23	9.81	10.39	10.33	10.90	11.39
	12H	13.86	14.37	14.37	14.86	15.42	9.99	10.50	10.50	11.00	11.56
12H	4H	12.75	13.44	13.23	13.92	14.39	9.05	9.74	9.53	10.22	10.69
	6H	13.38	13.96	13.90	14.47	14.96	9.66	10.23	10.17	10.74	11.23
	8H	13.67	14.18	14.18	14.67	15.23	9.93	10.44	10.44	10.93	11.50

END OF REPORT