

Cooper Lighting Solutions Photometric Lab
1121 Highway 74 South
Peachtree City, GA 30269



Scaled data based on original data using
LM-79-2019 Approved Method: Electrical and Photometric Measurements of Solid-
State Lighting Products

Test Report Prepared for
Cooper Lighting Solutions

Brand: NEO-RAY

Report Number: P930240

Luminaire Tested: DFN2DS-HX3F0-090DS835-RLL

Issue Date: 11/20/2024

Test Information

Test Method: LM-79-2019
Report Number: P930240
TEST IS SCALED FROM IESNA LM-79-08 TEST DATA (P333882)
Test Lab: INNOVATION CENTER
Issue Date: 11/20/2024
Manufacturer: COOPER LIGHTING SOLUTIONS
Product Line: NEO-RAY
Catalog Number: DFN2DS-HX3F0-090DS835-RLL
Description: 3 foot, Hexagon Define Geo, with Direct 1in Regressed Frosted Lens
Light Source: -
Ballast/Driver: -

Summary


Lumens per Lamp: N/A
Luminaire Lumens: 7650.0 lumens
Efficiency: N/A
Efficacy: 78.8 lumens/watt
Spacing Criteria (0/90/45): 1.2 / 0.99 / 1.16
Luminous Opening: Rectangular (W 3.28' x L: 2.84' x H: 0')
CIE Type: Direct

Input Watts (W): 97.1
Input Voltage (V):
Input Current (Ain): NR
Voltage Rise (V): NR
Power Factor: 0.9968
Total Harmonic Distortion (THDi): 0.064
Frequency (hertz): 60
Stabilization Time: NR
Operation Time: NR
Ambient Temperature (°C): NR
Test Distance: 24 FT

TEST NUMBER: P930240

CATALOG NUMBER: DFN2DS-HX3F0-090DS835-RLL

Luminous Intensity Polar Plot



TEST NUMBER: P930240

CATALOG NUMBER: DFN2DS-HX3F0-090DS835-RLL

COEFFICIENT OF UTILIZATION - ZONAL CAVITY METHOD:

RF	20				20				20				20				20
RC	80				70				50				30				10
RW	70	50	30	10	70	50	30	10	50	30	10		50	30	10		50
RCR																	
0	119	119	119	119	116	116	116	116	111	111	111		106	106	106		102
1	110	106	102	98	107	103	100	97	99	96	94		95	93	91		92
2	101	94	87	82	98	92	86	81	88	83	79		85	81	78		82
3	93	83	76	70	90	82	75	69	79	73	68		76	71	67		74
4	86	75	66	60	83	73	66	60	71	64	59		69	63	58		66
5	79	67	59	53	77	66	58	52	64	57	52		62	56	51		60
6	74	61	53	47	72	60	52	46	58	51	46		57	50	46		55
7	68	56	47	42	67	55	47	42	53	46	41		52	46	41		51
8	64	51	43	38	62	51	43	37	49	42	37		48	42	37		47
9	60	47	39	34	59	47	39	34	46	39	34		44	38	34		44
10	56	44	36	31	55	43	36	31	42	36	31		41	35	31		41

AVERAGE LUMINANCE (cd/sqm):

	0°	45°	90°
0°	4309	4309	4309
5°	4325	4255	4278
10°	4292	4185	4150
15°	4243	4061	3944
20°	4175	3884	3689
25°	4105	3683	3442
30°	4007	3476	3125
35°	3913	3251	2846
40°	3818	3018	2525
45°	3706	2757	2233
50°	3591	2493	1948
55°	3474	2209	1673
60°	3338	1911	1388
65°	3183	1605	1264
70°	2999	1322	1162
75°	2772	1205	1085
80°	2447	1077	989
85°	1922	849	849

MAXIMUM LUMINANCE 45°-90°:

Horizontal Angle: 0°

Vertical Angle: 45°

Luminance: 3706 cd/sqm

TEST NUMBER: P930240

CATALOG NUMBER: DFN2DS-HX3F0-090DS835-RLL

ZONAL LUMENS:

Zone	Lumens	% Fixture
0°-10°	348.6	4.6
10°-20°	957.0	12.5
20°-30°	1343.6	17.6
30°-40°	1464.6	19.1
40°-50°	1346.2	17.6
50°-60°	1057.2	13.8
60°-70°	688.1	9.0
70°-80°	354.2	4.6
80°-90°	90.4	1.2
90°-100°	0.0	0.0
100°-110°	0.0	0.0
110°-120°	0.0	0.0
120°-130°	0.0	0.0
130°-140°	0.0	0.0
140°-150°	0.0	0.0
150°-160°	0.0	0.0
160°-170°	0.0	0.0
170°-180°	0.0	0.0
0°-30°	2649.2	34.6
0°-40°	4113.9	53.8
0°-60°	6517.2	85.2
0°-90°	7650.0	100.0
90°-120°	0.0	0.0
90°-150°	0.0	0.0
90°-180°	0.0	0.0
0°-180°	7650.0	100.0

CANDELA DISTRIBUTION:

	0°	22.5°	45°	67.5°	90°	Flux
0°	3720	3720	3720	3720	3720	
5°	3720	3703	3659	3689	3679	353
15°	3538	3501	3386	3322	3289	997
25°	3212	3104	2882	2744	2693	1477
35°	2767	2595	2299	2087	2013	1732
45°	2262	2036	1683	1444	1363	1747
55°	1720	1458	1094	892	828	1537
65°	1161	889	586	471	461	1151
75°	619	384	269	246	242	655
85°	145	74	64	64	64	173
90°	0	0	0	0	0	

TEST NUMBER: P930240

CATALOG NUMBER: DFN2DS-HX3F0-090DS835-RLL

CANDELA DISTRIBUTION (FULL):

	0°	22.5°	45°	67.5°	90°
0°	3719.7	3719.7	3719.7	3719.7	3719.7
2.5°	3736.5	3719.7	3682.5	3716.5	3709.7
5°	3719.7	3702.9	3659.0	3689.3	3679.3
7.5°	3689.3	3669.3	3622.2	3635.4	3618.6
10°	3649.0	3625.4	3558.3	3547.9	3527.9
12.5°	3598.6	3568.3	3477.2	3457.2	3420.0
15°	3537.9	3500.8	3386.5	3322.5	3289.0
17.5°	3467.2	3413.3	3271.8	3197.9	3144.0
20°	3386.5	3319.0	3150.7	3066.8	2992.5
22.5°	3299.0	3221.5	3026.1	2911.8	2861.5
25°	3211.5	3103.6	2881.5	2743.6	2692.9
27.5°	3107.2	2992.5	2746.8	2588.6	2511.1
30°	2996.1	2867.9	2598.6	2427.2	2336.1
32.5°	2888.2	2733.2	2457.5	2255.4	2171.1
35°	2767.2	2595.4	2299.3	2087.2	2012.9
37.5°	2649.3	2464.0	2151.1	1918.6	1834.7
40°	2524.7	2322.9	1996.1	1757.2	1669.7
42.5°	2396.8	2181.5	1841.4	1592.2	1508.2
45°	2262.2	2036.5	1683.2	1443.9	1363.2
47.5°	2134.3	1895.4	1531.8	1292.5	1218.6
50°	1992.9	1753.9	1383.6	1151.1	1080.7
52.5°	1854.7	1602.2	1242.2	1020.0	956.1
55°	1720.0	1457.5	1093.9	892.2	828.2
57.5°	1582.2	1312.9	962.9	774.3	720.4
60°	1440.7	1171.4	824.7	653.2	599.3
62.5°	1302.9	1033.6	706.8	545.4	518.6
65°	1161.4	888.6	585.7	471.4	461.1
67.5°	1026.8	753.9	471.4	413.9	403.9
70°	885.4	622.9	390.4	356.8	343.2
72.5°	750.7	501.4	326.4	299.6	292.9
75°	619.3	383.6	269.3	245.7	242.5
77.5°	488.2	272.5	212.1	198.6	191.8
80°	366.8	195.4	161.4	148.2	148.2
82.5°	255.7	131.4	111.1	104.3	104.3
85°	144.6	73.9	63.9	63.9	63.9
87.5°	53.9	26.8	26.8	23.6	23.6
90°	0.0	0.0	0.0	0.0	0.0

TEST NUMBER: P930240

CATALOG NUMBER: DFN2DS-HX3F0-090DS835-RLL

CIE UGR TABLE:

Reflectances:											
Ceiling		0.7	0.7	0.5	0.5	0.3	0.7	0.7	0.5	0.5	0.3
Wall		0.5	0.3	0.5	0.3	0.3	0.5	0.3	0.5	0.3	0.3
Reference plane		0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2
Room dimensions		Viewed crosswise					Viewed endwise				
X=2H	Y=2H	16.31	17.83	16.67	18.14	18.46	12.27	13.79	12.64	14.11	14.42
	3H	18.07	19.44	18.45	19.77	20.13	13.54	14.90	13.91	15.23	15.59
	4H	18.74	20.02	19.14	20.37	20.75	14.04	15.32	14.44	15.67	16.04
	6H	19.23	20.41	19.64	20.78	21.17	14.42	15.60	14.83	15.97	16.36
	8H	19.40	20.52	19.82	20.91	21.31	14.54	15.67	14.97	16.06	16.46
	12H	19.50	20.58	19.93	20.96	21.39	14.62	15.70	15.05	16.08	16.51
4H	2H	16.41	17.69	16.81	18.04	18.42	12.97	14.25	13.37	14.59	14.97
	3H	18.35	19.41	18.76	19.81	20.21	14.41	15.47	14.82	15.87	16.27
	4H	19.10	20.05	19.53	20.47	20.91	15.01	15.96	15.44	16.38	16.82
	6H	19.69	20.52	20.15	20.96	21.42	15.50	16.33	15.95	16.77	17.23
	8H	19.90	20.68	20.37	21.12	21.59	15.66	16.44	16.12	16.88	17.35
	12H	20.06	20.75	20.54	21.23	21.70	15.78	16.47	16.26	16.95	17.42
8H	4H	19.12	19.90	19.58	20.34	20.81	15.36	16.14	15.83	16.58	17.05
	6H	19.76	20.40	20.25	20.89	21.37	15.95	16.59	16.45	17.08	17.56
	8H	20.01	20.58	20.52	21.09	21.58	16.17	16.75	16.68	17.26	17.74
	12H	20.21	20.72	20.72	21.21	21.78	16.35	16.86	16.86	17.35	17.92
12H	4H	19.10	19.80	19.59	20.28	20.75	15.41	16.10	15.89	16.58	17.05
	6H	19.74	20.32	20.25	20.83	21.31	16.01	16.59	16.53	17.10	17.59
	8H	20.02	20.53	20.53	21.03	21.59	16.29	16.79	16.79	17.29	17.85