

Cooper Lighting Solutions Photometric Lab
1121 Highway 74 South
Peachtree City, GA 30269



Scaled data based on original data using
LM-79-2019 Approved Method: Electrical and Photometric Measurements of Solid-
State Lighting Products

Test Report Prepared for
Cooper Lighting Solutions

Brand: NEO-RAY

Report Number: P930595

Luminaire Tested: DFN2DS-PN3F0-070DS950-FLL

Issue Date: 11/20/2024

Test Information

Test Method: LM-79-2019
Report Number: P930595
TEST IS SCALED FROM IESNA LM-79-08 TEST DATA (P333812)
Test Lab: INNOVATION CENTER
Issue Date: 11/20/2024
Manufacturer: COOPER LIGHTING SOLUTIONS
Product Line: NEO-RAY
Catalog Number: DFN2DS-PN3F0-070DS950-FLL
Description: 3 foot, Pentagon Define Geo, with Direct Frosted Lens
Light Source: -
Ballast/Driver: -

Summary


Lumens per Lamp: N/A
Luminaire Lumens: 6548.9 lumens
Efficiency: N/A
Efficacy: 88.9 lumens/watt
Spacing Criteria (0/90/45): 1.2 / 1.16 / 1.29
Luminous Opening: Rectangular (W 3.11' x L: 2.96' x H: 0')
CIE Type: Direct

Input Watts (W): 73.7
Input Voltage (V):
Input Current (Ain): NR
Voltage Rise (V): NR
Power Factor: 0.946
Total Harmonic Distortion (THDi): 0.132
Frequency (hertz): 60
Stabilization Time: NR
Operation Time: NR
Ambient Temperature (°C): NR
Test Distance: 24 FT

TEST NUMBER: P930595

CATALOG NUMBER: DFN2DS-PN3F0-070DS950-FLL

Luminous Intensity Polar Plot



TEST NUMBER: P930595

CATALOG NUMBER: DFN2DS-PN3F0-070DS950-FLL

COEFFICIENT OF UTILIZATION - ZONAL CAVITY METHOD:

RF	20				20				20				20				20
RC	80				70				50				30				10
RW	70	50	30	10	70	50	30	10	50	30	10		50	30	10		50
RCR																	
0	119	119	119	119	116	116	116	116	111	111	111		106	106	106		102
1	109	104	100	96	106	102	98	95	98	95	92		94	91	89		90
2	99	91	85	79	97	89	83	78	86	81	76		83	78	74		80
3	91	80	72	66	88	79	71	65	76	69	64		73	68	63		71
4	83	71	63	56	81	70	62	56	68	61	55		65	59	54		63
5	77	64	55	49	75	63	55	48	61	53	48		59	52	47		57
6	71	58	49	43	69	57	48	42	55	48	42		53	47	42		52
7	66	52	44	38	64	52	43	38	50	43	37		49	42	37		47
8	61	48	40	34	60	47	39	34	46	39	33		45	38	33		44
9	57	44	36	30	56	43	36	30	42	35	30		41	35	30		40
10	54	41	33	28	53	40	33	28	39	32	27		38	32	27		37

AVERAGE LUMINANCE (cd/sqm):

	0°	45°	90°
0°	3009	3009	3009
5°	3020	2977	2995
10°	3003	2947	2961
15°	2965	2908	2906
20°	2912	2851	2848
25°	2860	2781	2781
30°	2793	2716	2693
35°	2730	2638	2600
40°	2652	2560	2512
45°	2574	2484	2422
50°	2489	2403	2318
55°	2401	2310	2225
60°	2303	2199	2118
65°	2198	2088	1992
70°	2064	1954	1861
75°	1878	1799	1756
80°	1667	1616	1533
85°	1360	1297	1163

MAXIMUM LUMINANCE 45°-90°:

Horizontal Angle: 0°

Vertical Angle: 45°

Luminance: 2574 cd/sqm

TEST NUMBER: P930595

CATALOG NUMBER: DFN2DS-PN3F0-070DS950-FLL

ZONAL LUMENS:

Zone	Lumens	% Fixture
0°-10°	242.3	3.7
10°-20°	681.6	10.4
20°-30°	1001.7	15.3
30°-40°	1163.4	17.8
40°-50°	1162.0	17.7
50°-60°	1013.2	15.5
60°-70°	749.0	11.4
70°-80°	423.8	6.5
80°-90°	111.9	1.7
90°-100°	0.0	0.0
100°-110°	0.0	0.0
110°-120°	0.0	0.0
120°-130°	0.0	0.0
130°-140°	0.0	0.0
140°-150°	0.0	0.0
150°-160°	0.0	0.0
160°-170°	0.0	0.0
170°-180°	0.0	0.0
0°-30°	1925.6	29.4
0°-40°	3089.0	47.2
0°-60°	5264.2	80.4
0°-90°	6548.9	100.0
90°-120°	0.0	0.0
90°-150°	0.0	0.0
90°-180°	0.0	0.0
0°-180°	6548.9	100.0

CANDELA DISTRIBUTION:

	0°	22.5°	45°	67.5°	90°	Flux
0°	2574	2574	2574	2574	2574	
5°	2574	2564	2537	2557	2552	244
15°	2450	2436	2403	2413	2401	690
25°	2218	2198	2156	2161	2156	1020
35°	1913	1889	1849	1834	1822	1195
45°	1557	1540	1502	1475	1465	1202
55°	1178	1163	1134	1104	1092	1053
65°	795	780	755	733	720	786
75°	416	411	398	384	389	444
85°	101	99	97	89	87	119
90°	0	0	0	0	0	

TEST NUMBER: P930595

CATALOG NUMBER: DFN2DS-PN3F0-070DS950-FLL

CANDELA DISTRIBUTION (FULL):

	0°	22.5°	45°	67.5°	90°
0°	2573.9	2573.9	2573.9	2573.9	2573.9
2.5°	2588.9	2576.5	2549.2	2573.9	2569.2
5°	2573.9	2564.3	2536.9	2556.6	2551.9
7.5°	2556.6	2541.9	2514.6	2534.6	2529.6
10°	2529.6	2512.2	2482.5	2502.3	2494.9
12.5°	2492.2	2477.6	2447.9	2460.2	2455.2
15°	2450.3	2435.5	2403.2	2413.2	2400.9
17.5°	2398.2	2383.6	2351.3	2363.6	2351.3
20°	2341.2	2326.6	2291.9	2299.3	2289.5
22.5°	2284.5	2262.2	2229.9	2229.9	2224.9
25°	2217.6	2197.9	2155.9	2160.6	2155.9
27.5°	2143.3	2126.0	2093.9	2086.6	2074.2
30°	2069.3	2049.2	2012.3	2004.9	1994.9
32.5°	1989.9	1975.2	1935.5	1920.6	1910.6
35°	1913.2	1888.6	1848.9	1834.0	1821.6
37.5°	1826.6	1804.3	1764.6	1747.3	1734.9
40°	1737.6	1717.6	1677.9	1655.9	1645.9
42.5°	1650.9	1631.0	1591.6	1566.6	1551.9
45°	1556.9	1539.6	1502.3	1475.2	1465.2
47.5°	1465.2	1447.9	1408.2	1380.9	1366.3
50°	1368.6	1356.3	1321.6	1287.0	1274.6
52.5°	1274.6	1257.3	1225.3	1198.0	1180.6
55°	1178.2	1163.3	1133.6	1103.9	1091.6
57.5°	1081.6	1069.3	1036.9	1007.3	997.4
60°	985.0	975.2	940.7	913.3	906.0
62.5°	890.9	873.7	849.0	824.3	814.3
65°	794.7	779.6	755.0	732.7	720.3
67.5°	695.6	683.0	660.9	643.6	633.6
70°	603.9	594.0	571.6	554.3	544.6
72.5°	509.9	500.0	487.6	470.3	463.0
75°	415.7	411.0	398.3	383.7	388.7
77.5°	331.7	321.7	316.7	309.3	302.0
80°	247.6	245.0	240.0	232.7	227.7
82.5°	168.3	168.3	165.9	156.0	156.0
85°	101.4	99.0	96.7	89.0	86.7
87.5°	44.6	39.7	34.7	27.3	24.7
90°	0.0	0.0	0.0	0.0	0.0

TEST NUMBER: P930595

CATALOG NUMBER: DFN2DS-PN3F0-070DS950-FLL

CIE UGR TABLE:

Reflectances:											
Ceiling		0.7	0.7	0.5	0.5	0.3	0.7	0.7	0.5	0.5	0.3
Wall		0.5	0.3	0.5	0.3	0.3	0.5	0.3	0.5	0.3	0.3
Reference plane		0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2
Room dimensions		Viewed crosswise					Viewed endwise				
X=2H	Y=2H	15.11	16.72	15.47	17.03	17.35	14.67	16.28	15.03	16.59	16.90
	3H	16.86	18.31	17.24	18.64	19.00	16.37	17.82	16.75	18.15	18.51
	4H	17.51	18.88	17.90	19.22	19.60	17.01	18.38	17.41	18.73	19.10
	6H	17.98	19.24	18.39	19.61	20.00	17.47	18.74	17.89	19.11	19.50
	8H	18.12	19.33	18.54	19.72	20.12	17.62	18.83	18.04	19.22	19.61
	12H	18.21	19.37	18.64	19.75	20.18	17.70	18.86	18.13	19.24	19.67
4H	2H	15.67	17.04	16.07	17.39	17.76	15.32	16.69	15.72	17.03	17.41
	3H	17.65	18.79	18.06	19.19	19.59	17.24	18.38	17.65	18.78	19.18
	4H	18.42	19.46	18.85	19.87	20.31	18.00	19.03	18.43	19.45	19.88
	6H	19.02	19.92	19.47	20.36	20.82	18.59	19.49	19.04	19.93	20.39
	8H	19.21	20.05	19.67	20.50	20.96	18.77	19.62	19.23	20.06	20.52
	12H	19.34	20.10	19.82	20.58	21.05	18.89	19.65	19.37	20.12	20.59
8H	4H	18.70	19.54	19.16	19.98	20.45	18.32	19.17	18.78	19.61	20.08
	6H	19.41	20.11	19.90	20.60	21.08	19.03	19.73	19.52	20.22	20.69
	8H	19.67	20.30	20.18	20.81	21.29	19.28	19.91	19.79	20.41	20.90
	12H	19.87	20.43	20.38	20.92	21.48	19.46	20.01	19.96	20.50	21.07
12H	4H	18.72	19.48	19.20	19.96	20.43	18.36	19.12	18.84	19.59	20.06
	6H	19.45	20.09	19.96	20.59	21.08	19.09	19.72	19.60	20.23	20.71
	8H	19.77	20.33	20.28	20.82	21.38	19.39	19.95	19.90	20.44	21.00