

Cooper Lighting Solutions Photometric Lab
1121 Highway 74 South
Peachtree City, GA 30269



Scaled data based on original data using
LM-79-2019 Approved Method: Electrical and Photometric Measurements of Solid-
State Lighting Products

Test Report Prepared for
Cooper Lighting Solutions

Brand: NEO-RAY

Report Number: P930708

Luminaire Tested: DFN2DS-PN4F0-080DS835-RLL

Issue Date: 11/20/2024

Test Information

Test Method: LM-79-2019
Report Number: P930708
TEST IS SCALED FROM IESNA LM-79-08 TEST DATA (P333882)
Test Lab: INNOVATION CENTER
Issue Date: 11/20/2024
Manufacturer: COOPER LIGHTING SOLUTIONS
Product Line: NEO-RAY
Catalog Number: DFN2DS-PN4F0-080DS835-RLL
Description: 4 foot, Pentagon Define Geo, with Direct 1in Regressed Frosted Lens
Light Source: -
Ballast/Driver: -

Summary


Lumens per Lamp: N/A
Luminaire Lumens: 6800.0 lumens
Efficiency: N/A
Efficacy: 83.0 lumens/watt
Spacing Criteria (0/90/45): 1.2 / 0.99 / 1.16
Luminous Opening: Rectangular (W 3.94' x L: 3.74' x H: 0')
CIE Type: Direct

Input Watts (W): 81.9
Input Voltage (V):
Input Current (Ain): NR
Voltage Rise (V): NR
Power Factor: 0.9971
Total Harmonic Distortion (THDi): 0.049
Frequency (hertz): 60
Stabilization Time: NR
Operation Time: NR
Ambient Temperature (°C): NR
Test Distance: 24 FT

TEST NUMBER: P930708

CATALOG NUMBER: DFN2DS-PN4F0-080DS835-RLL

Luminous Intensity Polar Plot



TEST NUMBER: P930708

CATALOG NUMBER: DFN2DS-PN4F0-080DS835-RLL

COEFFICIENT OF UTILIZATION - ZONAL CAVITY METHOD:

RF	20				20				20				20				20
RC	80				70				50				30				10
RW	70	50	30	10	70	50	30	10	50	30	10		50	30	10		50
RCR																	
0	119	119	119	119	116	116	116	116	111	111	111		106	106	106		102
1	110	106	102	98	107	103	100	97	99	96	94		95	93	91		92
2	101	94	87	82	98	92	86	81	88	83	79		85	81	78		82
3	93	83	76	70	90	82	75	69	79	73	68		76	71	67		74
4	86	75	66	60	83	73	66	60	71	64	59		69	63	58		66
5	79	67	59	53	77	66	58	52	64	57	52		62	56	51		60
6	74	61	53	47	72	60	52	46	58	51	46		57	50	46		55
7	68	56	47	42	67	55	47	42	53	46	41		52	46	41		51
8	64	51	43	38	62	51	43	37	49	42	37		48	42	37		47
9	60	47	39	34	59	47	39	34	46	39	34		44	38	34		44
10	56	44	36	31	55	43	36	31	42	36	31		41	35	31		41

AVERAGE LUMINANCE (cd/sqm):

	0°	45°	90°
0°	2414	2414	2414
5°	2423	2383	2396
10°	2404	2344	2324
15°	2377	2275	2209
20°	2338	2176	2066
25°	2299	2063	1928
30°	2245	1947	1750
35°	2192	1821	1594
40°	2138	1691	1414
45°	2076	1545	1251
50°	2012	1397	1091
55°	1946	1238	937
60°	1870	1070	778
65°	1783	899	708
70°	1680	741	651
75°	1553	675	608
80°	1370	603	554
85°	1077	476	476

MAXIMUM LUMINANCE 45°-90°:

Horizontal Angle: 0°

Vertical Angle: 45°

Luminance: 2076 cd/sqm

TEST NUMBER: P930708

CATALOG NUMBER: DFN2DS-PN4F0-080DS835-RLL

ZONAL LUMENS:

Zone	Lumens	% Fixture
0°-10°	309.9	4.6
10°-20°	850.7	12.5
20°-30°	1194.3	17.6
30°-40°	1301.9	19.1
40°-50°	1196.6	17.6
50°-60°	939.7	13.8
60°-70°	611.7	9.0
70°-80°	314.9	4.6
80°-90°	80.4	1.2
90°-100°	0.0	0.0
100°-110°	0.0	0.0
110°-120°	0.0	0.0
120°-130°	0.0	0.0
130°-140°	0.0	0.0
140°-150°	0.0	0.0
150°-160°	0.0	0.0
160°-170°	0.0	0.0
170°-180°	0.0	0.0
0°-30°	2354.9	34.6
0°-40°	3656.8	53.8
0°-60°	5793.1	85.2
0°-90°	6800.0	100.0
90°-120°	0.0	0.0
90°-150°	0.0	0.0
90°-180°	0.0	0.0
0°-180°	6800.0	100.0

CANDELA DISTRIBUTION:

	0°	22.5°	45°	67.5°	90°	Flux
0°	3306	3306	3306	3306	3306	
5°	3306	3292	3252	3279	3270	314
15°	3145	3112	3010	2953	2924	886
25°	2855	2759	2561	2439	2394	1313
35°	2460	2307	2044	1855	1789	1540
45°	2011	1810	1496	1284	1212	1553
55°	1529	1296	972	793	736	1366
65°	1032	790	521	419	410	1024
75°	550	341	239	218	216	582
85°	129	66	57	57	57	154
90°	0	0	0	0	0	

TEST NUMBER: P930708

CATALOG NUMBER: DFN2DS-PN4F0-080DS835-RLL

CANDELA DISTRIBUTION (FULL):

	0°	22.5°	45°	67.5°	90°
0°	3306.4	3306.4	3306.4	3306.4	3306.4
2.5°	3321.3	3306.4	3273.4	3303.5	3297.5
5°	3306.4	3291.5	3252.4	3279.4	3270.5
7.5°	3279.4	3261.6	3219.7	3231.5	3216.5
10°	3243.5	3222.6	3162.9	3153.7	3135.9
12.5°	3198.8	3171.8	3090.8	3073.0	3040.0
15°	3144.8	3111.8	3010.2	2953.4	2923.5
17.5°	3081.9	3034.0	2908.3	2842.6	2794.6
20°	3010.2	2950.2	2800.7	2726.1	2660.0
22.5°	2932.4	2863.5	2689.9	2588.3	2543.5
25°	2854.6	2758.8	2561.3	2438.8	2393.7
27.5°	2761.9	2660.0	2441.6	2301.0	2232.1
30°	2663.2	2549.2	2309.9	2157.5	2076.5
32.5°	2567.3	2429.6	2184.5	2004.8	1929.9
35°	2459.7	2307.0	2043.8	1855.3	1789.2
37.5°	2354.9	2190.2	1912.1	1705.4	1630.8
40°	2244.2	2064.8	1774.3	1561.9	1484.1
42.5°	2130.5	1939.1	1636.8	1415.3	1340.6
45°	2010.8	1810.2	1496.2	1283.5	1211.8
47.5°	1897.2	1684.8	1361.6	1148.9	1083.2
50°	1771.4	1559.1	1229.9	1023.2	960.6
52.5°	1648.6	1424.1	1104.1	906.7	849.9
55°	1528.9	1295.6	972.4	793.0	736.2
57.5°	1406.4	1167.0	855.9	688.3	640.3
60°	1280.6	1041.3	733.0	580.6	532.7
62.5°	1158.1	918.7	628.3	484.8	461.0
65°	1032.4	789.8	520.6	419.1	409.8
67.5°	912.7	670.2	419.1	367.9	359.1
70°	787.0	553.7	347.0	317.1	305.1
72.5°	667.3	445.7	290.2	266.4	260.3
75°	550.5	341.0	239.4	218.4	215.6
77.5°	434.0	242.2	188.6	176.5	170.5
80°	326.0	173.7	143.5	131.7	131.7
82.5°	227.3	116.8	98.7	92.7	92.7
85°	128.6	65.7	56.8	56.8	56.8
87.5°	47.9	23.8	23.8	21.0	21.0
90°	0.0	0.0	0.0	0.0	0.0

TEST NUMBER: P930708

CATALOG NUMBER: DFN2DS-PN4F0-080DS835-RLL

CIE UGR TABLE:

Reflectances:											
Ceiling		0.7	0.7	0.5	0.5	0.3	0.7	0.7	0.5	0.5	0.3
Wall		0.5	0.3	0.5	0.3	0.3	0.5	0.3	0.5	0.3	0.3
Reference plane		0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2
Room dimensions		Viewed crosswise					Viewed endwise				
X=2H	Y=2H	14.30	15.82	14.66	16.13	16.45	10.26	11.78	10.62	12.09	12.41
	3H	16.06	17.43	16.44	17.75	18.12	11.52	12.89	11.90	13.21	13.58
	4H	16.73	18.01	17.13	18.36	18.74	12.02	13.30	12.42	13.65	14.03
	6H	17.22	18.40	17.63	18.77	19.16	12.40	13.59	12.82	13.95	14.35
	8H	17.38	18.51	17.81	18.90	19.30	12.53	13.66	12.96	14.05	14.45
	12H	17.49	18.56	17.92	18.95	19.37	12.61	13.69	13.04	14.07	14.50
4H	2H	14.40	15.68	14.80	16.03	16.41	10.95	12.23	11.35	12.58	12.96
	3H	16.33	17.40	16.74	17.80	18.20	12.40	13.46	12.81	13.86	14.26
	4H	17.08	18.04	17.52	18.45	18.89	12.99	13.95	13.43	14.37	14.81
	6H	17.67	18.51	18.13	18.95	19.41	13.48	14.31	13.94	14.76	15.22
	8H	17.89	18.67	18.35	19.11	19.58	13.64	14.42	14.11	14.87	15.33
	12H	18.04	18.74	18.52	19.22	19.69	13.76	14.46	14.24	14.93	15.41
8H	4H	17.11	17.88	17.57	18.33	18.80	13.35	14.13	13.81	14.57	15.04
	6H	17.74	18.39	18.24	18.88	19.36	13.93	14.58	14.43	15.07	15.55
	8H	17.99	18.57	18.51	19.08	19.57	14.16	14.73	14.67	15.24	15.73
	12H	18.20	18.71	18.71	19.20	19.77	14.34	14.84	14.84	15.34	15.90
12H	4H	17.09	17.79	17.57	18.26	18.74	13.39	14.09	13.87	14.56	15.04
	6H	17.73	18.30	18.24	18.81	19.30	14.00	14.58	14.51	15.09	15.57
	8H	18.01	18.52	18.52	19.01	19.58	14.27	14.78	14.78	15.27	15.84