

Cooper Lighting Solutions Photometric Lab
1121 Highway 74 South
Peachtree City, GA 30269



Scaled data based on original data using
LM-79-2019 Approved Method: Electrical and Photometric Measurements of Solid-
State Lighting Products

Test Report Prepared for
Cooper Lighting Solutions

Brand: NEO-RAY

Report Number: P930768

Luminaire Tested: DFN2DS-PN4F0-110DS927-RLL

Issue Date: 11/20/2024

Test Information

Test Method: LM-79-2019
Report Number: P930768
TEST IS SCALED FROM IESNA LM-79-08 TEST DATA (P333882)
Test Lab: INNOVATION CENTER
Issue Date: 11/20/2024
Manufacturer: COOPER LIGHTING SOLUTIONS
Product Line: NEO-RAY
Catalog Number: DFN2DS-PN4F0-110DS927-RLL
Description: 4 foot, Pentagon Define Geo, with Direct 1in Regressed Frosted Lens
Light Source: -
Ballast/Driver: -

Summary


Lumens per Lamp: N/A
Luminaire Lumens: 7405.2 lumens
Efficiency: N/A
Efficacy: 62.2 lumens/watt
Spacing Criteria (0/90/45): 1.2 / 0.99 / 1.16
Luminous Opening: Rectangular (W 3.94' x L: 3.74' x H: 0')
CIE Type: Direct

Input Watts (W): 119
Input Voltage (V):
Input Current (Ain): NR
Voltage Rise (V): NR
Power Factor: 0.996
Total Harmonic Distortion (THDi): 0.064
Frequency (hertz): 60
Stabilization Time: NR
Operation Time: NR
Ambient Temperature (°C): NR
Test Distance: 24 FT

TEST NUMBER: P930768

CATALOG NUMBER: DFN2DS-PN4F0-110DS927-RLL

Luminous Intensity Polar Plot



TEST NUMBER: P930768

CATALOG NUMBER: DFN2DS-PN4F0-110DS927-RLL

COEFFICIENT OF UTILIZATION - ZONAL CAVITY METHOD:

RF	20				20				20				20				20
RC	80				70				50				30				10
RW	70	50	30	10	70	50	30	10	50	30	10		50	30	10		50
RCR																	
0	119	119	119	119	116	116	116	116	111	111	111		106	106	106		102
1	110	106	102	98	107	103	100	97	99	96	94		95	93	91		92
2	101	94	87	82	98	92	86	81	88	83	79		85	81	78		82
3	93	83	76	70	90	82	75	69	79	73	68		76	71	67		74
4	86	75	66	60	83	73	66	60	71	64	59		69	63	58		66
5	79	67	59	53	77	66	58	52	64	57	52		62	56	51		60
6	74	61	53	47	72	60	52	46	58	51	46		57	50	46		55
7	68	56	47	42	67	55	47	42	53	46	41		52	46	41		51
8	64	51	43	38	62	51	43	37	49	42	37		48	42	37		47
9	60	47	39	34	59	47	39	34	46	39	34		44	38	34		44
10	56	44	36	31	55	43	36	31	42	36	31		41	35	31		41

AVERAGE LUMINANCE (cd/sqm):

	0°	45°	90°
0°	2628	2628	2628
5°	2638	2595	2610
10°	2618	2553	2531
15°	2588	2477	2406
20°	2546	2369	2250
25°	2504	2247	2099
30°	2445	2120	1906
35°	2387	1983	1736
40°	2329	1841	1540
45°	2261	1682	1362
50°	2191	1521	1188
55°	2119	1348	1020
60°	2036	1165	847
65°	1942	979	771
70°	1829	807	709
75°	1691	735	662
80°	1493	657	603
85°	1173	518	518

MAXIMUM LUMINANCE 45°-90°:

Horizontal Angle: 0°
Vertical Angle: 45°
Luminance: 2261 cd/sqm

TEST NUMBER: P930768

CATALOG NUMBER: DFN2DS-PN4F0-110DS927-RLL

ZONAL LUMENS:

Zone	Lumens	% Fixture
0°-10°	337.5	4.6
10°-20°	926.4	12.5
20°-30°	1300.6	17.6
30°-40°	1417.8	19.1
40°-50°	1303.1	17.6
50°-60°	1023.4	13.8
60°-70°	666.1	9.0
70°-80°	342.9	4.6
80°-90°	87.6	1.2
90°-100°	0.0	0.0
100°-110°	0.0	0.0
110°-120°	0.0	0.0
120°-130°	0.0	0.0
130°-140°	0.0	0.0
140°-150°	0.0	0.0
150°-160°	0.0	0.0
160°-170°	0.0	0.0
170°-180°	0.0	0.0
0°-30°	2564.5	34.6
0°-40°	3982.2	53.8
0°-60°	6308.7	85.2
0°-90°	7405.2	100.0
90°-120°	0.0	0.0
90°-150°	0.0	0.0
90°-180°	0.0	0.0
0°-180°	7405.2	100.0

CANDELA DISTRIBUTION:

	0°	22.5°	45°	67.5°	90°	Flux
0°	3601	3601	3601	3601	3601	
5°	3601	3584	3542	3571	3562	341
15°	3425	3389	3278	3216	3184	965
25°	3109	3004	2789	2656	2607	1430
35°	2679	2512	2226	2020	1948	1677
45°	2190	1971	1629	1398	1320	1691
55°	1665	1411	1059	864	802	1488
65°	1124	860	567	456	446	1115
75°	600	371	261	238	235	634
85°	140	72	62	62	62	168
90°	0	0	0	0	0	

TEST NUMBER: P930768

CATALOG NUMBER: DFN2DS-PN4F0-110DS927-RLL

CANDELA DISTRIBUTION (FULL):

	0°	22.5°	45°	67.5°	90°
0°	3600.7	3600.7	3600.7	3600.7	3600.7
2.5°	3616.9	3600.7	3564.7	3597.6	3591.0
5°	3600.7	3584.4	3541.9	3571.3	3561.6
7.5°	3571.3	3551.9	3506.3	3519.1	3502.8
10°	3532.2	3509.4	3444.4	3434.3	3415.0
12.5°	3483.5	3454.1	3365.9	3346.5	3310.6
15°	3424.7	3388.7	3278.1	3216.2	3183.7
17.5°	3356.3	3304.1	3167.1	3095.5	3043.3
20°	3278.1	3212.7	3049.9	2968.7	2896.7
22.5°	3193.4	3118.3	2929.3	2818.6	2769.9
25°	3108.7	3004.3	2789.3	2655.8	2606.7
27.5°	3007.8	2896.7	2658.9	2505.7	2430.7
30°	2900.2	2776.1	2515.5	2349.5	2261.3
32.5°	2795.8	2645.8	2378.9	2183.2	2101.7
35°	2678.6	2512.3	2225.8	2020.4	1948.5
37.5°	2564.6	2385.1	2082.2	1857.2	1776.0
40°	2443.9	2248.6	1932.2	1700.9	1616.2
42.5°	2320.1	2111.6	1782.6	1541.2	1460.0
45°	2189.8	1971.3	1629.4	1397.7	1319.6
47.5°	2066.0	1834.7	1482.8	1251.1	1179.6
50°	1929.1	1697.8	1339.4	1114.3	1046.2
52.5°	1795.3	1550.9	1202.4	987.4	925.5
55°	1664.9	1410.9	1058.9	863.6	801.7
57.5°	1531.6	1270.8	932.0	749.5	697.3
60°	1394.6	1134.0	798.3	632.3	580.1
62.5°	1261.2	1000.5	684.2	527.9	502.0
65°	1124.2	860.1	567.0	456.4	446.3
67.5°	994.0	729.8	456.4	400.7	391.0
70°	857.0	602.9	377.9	345.4	332.2
72.5°	726.7	485.4	316.0	290.0	283.5
75°	599.5	371.3	260.6	237.8	234.7
77.5°	472.6	263.8	205.4	192.2	185.6
80°	355.1	189.1	156.3	143.5	143.5
82.5°	247.5	127.2	107.6	101.0	101.0
85°	140.0	71.6	61.9	61.9	61.9
87.5°	52.2	25.9	25.9	22.8	22.8
90°	0.0	0.0	0.0	0.0	0.0

TEST NUMBER: P930768

CATALOG NUMBER: DFN2DS-PN4F0-110DS927-RLL

CIE UGR TABLE:

Reflectances:											
Ceiling		0.7	0.7	0.5	0.5	0.3	0.7	0.7	0.5	0.5	0.3
Wall		0.5	0.3	0.5	0.3	0.3	0.5	0.3	0.5	0.3	0.3
Reference plane		0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2
Room dimensions		Viewed crosswise					Viewed endwise				
X=2H	Y=2H	14.59	16.11	14.96	16.43	16.74	10.55	12.07	10.92	12.39	12.70
	3H	16.36	17.72	16.74	18.05	18.41	11.82	13.18	12.20	13.51	13.87
	4H	17.02	18.30	17.42	18.65	19.03	12.32	13.60	12.72	13.95	14.33
	6H	17.51	18.70	17.92	19.06	19.45	12.70	13.88	13.11	14.25	14.64
	8H	17.68	18.80	18.10	19.19	19.60	12.83	13.95	13.25	14.34	14.74
	12H	17.78	18.86	18.21	19.24	19.67	12.91	13.98	13.34	14.37	14.80
4H	2H	14.70	15.98	15.10	16.33	16.70	11.25	12.53	11.65	12.88	13.26
	3H	16.63	17.69	17.04	18.09	18.49	12.69	13.75	13.10	14.15	14.56
	4H	17.38	18.34	17.81	18.75	19.19	13.29	14.25	13.72	14.66	15.10
	6H	17.97	18.80	18.43	19.25	19.70	13.78	14.61	14.24	15.05	15.51
	8H	18.18	18.96	18.65	19.41	19.87	13.94	14.72	14.40	15.16	15.63
	12H	18.34	19.03	18.82	19.51	19.98	14.06	14.75	14.54	15.23	15.70
8H	4H	17.40	18.18	17.87	18.62	19.09	13.64	14.42	14.11	14.87	15.33
	6H	18.04	18.68	18.54	19.17	19.65	14.23	14.87	14.73	15.36	15.84
	8H	18.29	18.87	18.80	19.38	19.87	14.45	15.03	14.97	15.54	16.03
	12H	18.49	19.00	19.00	19.50	20.06	14.63	15.14	15.14	15.63	16.20
12H	4H	17.39	18.08	17.87	18.56	19.03	13.69	14.38	14.17	14.86	15.33
	6H	18.02	18.60	18.54	19.11	19.60	14.29	14.87	14.81	15.38	15.87
	8H	18.31	18.82	18.82	19.31	19.87	14.57	15.08	15.08	15.57	16.13