

Cooper Lighting Solutions Photometric Lab
1121 Highway 74 South
Peachtree City, GA 30269



Scaled data based on original data using
LM-79-2019 Approved Method: Electrical and Photometric Measurements of Solid-
State Lighting Products

Test Report Prepared for
Cooper Lighting Solutions

Brand: NEO-RAY

Report Number: P930662

Luminaire Tested: DFN2DS-PN4F0-050DS930-RLL

Issue Date: 11/20/2024

Test Information

Test Method: LM-79-2019
Report Number: P930662
TEST IS SCALED FROM IESNA LM-79-08 TEST DATA (P333882)
Test Lab: INNOVATION CENTER
Issue Date: 11/20/2024
Manufacturer: COOPER LIGHTING SOLUTIONS
Product Line: NEO-RAY
Catalog Number: DFN2DS-PN4F0-050DS930-RLL
Description: 4 foot, Pentagon Define Geo, with Direct 1in Regressed Frosted Lens
Light Source: -
Ballast/Driver: -

Summary


Lumens per Lamp: N/A
Luminaire Lumens: 3463.8 lumens
Efficiency: N/A
Efficacy: 71.0 lumens/watt
Spacing Criteria (0/90/45): 1.2 / 0.99 / 1.16
Luminous Opening: Rectangular (W 3.94' x L: 3.74' x H: 0')
CIE Type: Direct

Input Watts (W): 48.8
Input Voltage (V):
Input Current (Ain): NR
Voltage Rise (V): NR
Power Factor: 0.9951
Total Harmonic Distortion (THDi): 0.07
Frequency (hertz): 60
Stabilization Time: NR
Operation Time: NR
Ambient Temperature (°C): NR
Test Distance: 24 FT

TEST NUMBER: P930662

CATALOG NUMBER: DFN2DS-PN4F0-050DS930-RLL

Luminous Intensity Polar Plot



TEST NUMBER: P930662

CATALOG NUMBER: DFN2DS-PN4F0-050DS930-RLL

COEFFICIENT OF UTILIZATION - ZONAL CAVITY METHOD:

RF	20				20				20				20				20
RC	80				70				50				30				10
RW	70	50	30	10	70	50	30	10	50	30	10		50	30	10		50
RCR																	
0	119	119	119	119	116	116	116	116	111	111	111		106	106	106		102
1	110	106	102	98	107	103	100	97	99	96	94		95	93	91		92
2	101	94	87	82	98	92	86	81	88	83	79		85	81	78		82
3	93	83	76	70	90	82	75	69	79	73	68		76	71	67		74
4	86	75	66	60	83	73	66	60	71	64	59		69	63	58		66
5	79	67	59	53	77	66	58	52	64	57	52		62	56	51		60
6	74	61	53	47	72	60	52	46	58	51	46		57	50	46		55
7	68	56	47	42	67	55	47	42	53	46	41		52	46	41		51
8	64	51	43	38	62	51	43	37	49	42	37		48	42	37		47
9	60	47	39	34	59	47	39	34	46	39	34		44	38	34		44
10	56	44	36	31	55	43	36	31	42	36	31		41	35	31		41

AVERAGE LUMINANCE (cd/sqm):

	0°	45°	90°
0°	1229	1229	1229
5°	1234	1214	1221
10°	1225	1194	1184
15°	1211	1159	1125
20°	1191	1108	1052
25°	1171	1051	982
30°	1143	992	892
35°	1116	928	812
40°	1089	861	720
45°	1057	787	637
50°	1025	711	556
55°	991	630	477
60°	952	545	396
65°	908	458	361
70°	856	377	332
75°	791	344	310
80°	698	307	282
85°	549	242	242

MAXIMUM LUMINANCE 45°-90°:

Horizontal Angle: 0°
Vertical Angle: 45°
Luminance: 1057 cd/sqm

TEST NUMBER: P930662

CATALOG NUMBER: DFN2DS-PN4F0-050DS930-RLL

ZONAL LUMENS:

Zone	Lumens	% Fixture
0°-10°	157.8	4.6
10°-20°	433.3	12.5
20°-30°	608.4	17.6
30°-40°	663.2	19.1
40°-50°	609.5	17.6
50°-60°	478.7	13.8
60°-70°	311.6	9.0
70°-80°	160.4	4.6
80°-90°	40.9	1.2
90°-100°	0.0	0.0
100°-110°	0.0	0.0
110°-120°	0.0	0.0
120°-130°	0.0	0.0
130°-140°	0.0	0.0
140°-150°	0.0	0.0
150°-160°	0.0	0.0
160°-170°	0.0	0.0
170°-180°	0.0	0.0
0°-30°	1199.5	34.6
0°-40°	1862.7	53.8
0°-60°	2950.9	85.2
0°-90°	3463.8	100.0
90°-120°	0.0	0.0
90°-150°	0.0	0.0
90°-180°	0.0	0.0
0°-180°	3463.8	100.0

CANDELA DISTRIBUTION:

	0°	22.5°	45°	67.5°	90°	Flux
0°	1684	1684	1684	1684	1684	
5°	1684	1677	1657	1670	1666	160
15°	1602	1585	1533	1504	1489	451
25°	1454	1405	1305	1242	1219	669
35°	1253	1175	1041	945	911	784
45°	1024	922	762	654	617	791
55°	779	660	495	404	375	696
65°	526	402	265	213	209	521
75°	280	174	122	111	110	297
85°	66	34	29	29	29	79
90°	0	0	0	0	0	

TEST NUMBER: P930662

CATALOG NUMBER: DFN2DS-PN4F0-050DS930-RLL

CANDELA DISTRIBUTION (FULL):

	0°	22.5°	45°	67.5°	90°
0°	1684.2	1684.2	1684.2	1684.2	1684.2
2.5°	1691.8	1684.2	1667.4	1682.7	1679.6
5°	1684.2	1676.6	1656.7	1670.4	1665.9
7.5°	1670.4	1661.4	1640.0	1646.1	1638.4
10°	1652.2	1641.5	1611.1	1606.4	1597.3
12.5°	1629.3	1615.7	1574.4	1565.4	1548.5
15°	1601.9	1585.1	1533.3	1504.4	1489.2
17.5°	1569.9	1545.5	1481.4	1447.9	1423.5
20°	1533.3	1502.8	1426.6	1388.6	1354.9
22.5°	1493.7	1458.6	1370.2	1318.4	1295.6
25°	1454.0	1405.2	1304.7	1242.2	1219.2
27.5°	1406.9	1354.9	1243.7	1172.1	1137.0
30°	1356.6	1298.5	1176.6	1098.9	1057.7
32.5°	1307.7	1237.6	1112.7	1021.2	983.1
35°	1252.9	1175.1	1041.1	945.0	911.4
37.5°	1199.5	1115.7	974.0	868.7	830.7
40°	1143.1	1051.8	903.8	795.6	756.0
42.5°	1085.3	987.7	833.7	720.9	682.9
45°	1024.3	922.1	762.1	653.8	617.2
47.5°	966.3	858.2	693.6	585.3	551.8
50°	902.4	794.1	626.5	521.2	489.3
52.5°	839.8	725.4	562.4	461.9	432.9
55°	778.8	659.9	495.3	403.9	375.0
57.5°	716.4	594.5	435.9	350.6	326.2
60°	652.3	530.4	373.4	295.8	271.3
62.5°	589.9	468.0	320.1	246.9	234.8
65°	525.8	402.4	265.2	213.4	208.8
67.5°	464.9	341.4	213.4	187.4	182.9
70°	400.9	282.0	176.8	161.5	155.4
72.5°	339.9	227.1	147.8	135.7	132.6
75°	280.4	173.7	121.9	111.2	109.8
77.5°	221.0	123.4	96.1	89.9	86.8
80°	166.1	88.4	73.1	67.1	67.1
82.5°	115.8	59.5	50.3	47.2	47.2
85°	65.5	33.5	28.9	28.9	28.9
87.5°	24.4	12.1	12.1	10.7	10.7
90°	0.0	0.0	0.0	0.0	0.0

TEST NUMBER: P930662

CATALOG NUMBER: DFN2DS-PN4F0-050DS930-RLL

CIE UGR TABLE:

Reflectances:											
Ceiling		0.7	0.7	0.5	0.5	0.3	0.7	0.7	0.5	0.5	0.3
Wall		0.5	0.3	0.5	0.3	0.3	0.5	0.3	0.5	0.3	0.3
Reference plane		0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2
Room dimensions		Viewed crosswise					Viewed endwise				
X=2H	Y=2H	11.95	13.47	12.32	13.79	14.10	7.91	9.43	8.28	9.75	10.06
	3H	13.72	15.08	14.10	15.41	15.77	9.18	10.54	9.56	10.87	11.23
	4H	14.38	15.66	14.78	16.01	16.39	9.68	10.96	10.08	11.31	11.69
	6H	14.87	16.06	15.29	16.42	16.81	10.06	11.24	10.47	11.61	12.00
	8H	15.04	16.16	15.46	16.55	16.96	10.18	11.31	10.61	11.70	12.10
	12H	15.14	16.22	15.57	16.60	17.03	10.27	11.34	10.70	11.73	12.16
4H	2H	12.06	13.34	12.46	13.69	14.06	8.61	9.89	9.01	10.24	10.62
	3H	13.99	15.05	14.40	15.45	15.85	10.05	11.11	10.46	11.51	11.92
	4H	14.74	15.70	15.17	16.11	16.55	10.65	11.61	11.08	12.02	12.46
	6H	15.33	16.16	15.79	16.61	17.07	11.14	11.97	11.60	12.41	12.87
	8H	15.55	16.32	16.01	16.77	17.23	11.30	12.08	11.76	12.52	12.99
	12H	15.70	16.39	16.18	16.87	17.34	11.42	12.11	11.90	12.59	13.06
8H	4H	14.76	15.54	15.23	15.98	16.45	11.00	11.78	11.47	12.23	12.69
	6H	15.40	16.04	15.90	16.53	17.01	11.59	12.23	12.09	12.72	13.20
	8H	15.65	16.23	16.17	16.74	17.23	11.81	12.39	12.33	12.90	13.39
	12H	15.86	16.37	16.36	16.86	17.42	11.99	12.50	12.50	12.99	13.56
12H	4H	14.75	15.44	15.23	15.92	16.39	11.05	11.74	11.53	12.22	12.69
	6H	15.38	15.96	15.90	16.47	16.96	11.65	12.23	12.17	12.74	13.23
	8H	15.67	16.18	16.18	16.67	17.23	11.93	12.44	12.44	12.93	13.49

END OF REPORT

FIELD PERFORMANCE MAY DIFFER FROM LABORATORY PERFORMANCE

7 of 7