

Cooper Lighting Solutions Photometric Lab
1121 Highway 74 South
Peachtree City, GA 30269



Scaled data based on original data using
LM-79-2019 Approved Method: Electrical and Photometric Measurements of Solid-
State Lighting Products

Test Report Prepared for
Cooper Lighting Solutions

Brand: NEO-RAY

Report Number: P931584

Luminaire Tested: DFN2DS-TR4F0-110DS940-RLL

Issue Date: 11/20/2024

Test Information

Test Method: LM-79-2019
Report Number: P931584
TEST IS SCALED FROM IESNA LM-79-08 TEST DATA (P333882)
Test Lab: INNOVATION CENTER
Issue Date: 11/20/2024
Manufacturer: COOPER LIGHTING SOLUTIONS
Product Line: NEO-RAY
Catalog Number: DFN2DS-TR4F0-110DS940-RLL
Description: 4 foot, Triangle Define Geo, with Direct 1in Regressed Frosted Lens
Light Source: -
Ballast/Driver: -

Summary


Lumens per Lamp: N/A
Luminaire Lumens: 8340.2 lumens
Efficiency: N/A
Efficacy: 70.1 lumens/watt
Spacing Criteria (0/90/45): 1.2 / 0.99 / 1.16
Luminous Opening: Rectangular (W 3.96' x L: 3.43' x H: 0')
CIE Type: Direct

Input Watts (W): 118.9
Input Voltage (V):
Input Current (Ain): NR
Voltage Rise (V): NR
Power Factor: 0.9613
Total Harmonic Distortion (THDi): 0.083
Frequency (hertz): 60
Stabilization Time: NR
Operation Time: NR
Ambient Temperature (°C): NR
Test Distance: 24 FT

TEST NUMBER: P931584

CATALOG NUMBER: DFN2DS-TR4F0-110DS940-RLL

Luminous Intensity Polar Plot



TEST NUMBER: P931584

CATALOG NUMBER: DFN2DS-TR4F0-110DS940-RLL

COEFFICIENT OF UTILIZATION - ZONAL CAVITY METHOD:

RF	20				20				20				20				20
RC	80				70				50				30				10
RW	70	50	30	10	70	50	30	10	50	30	10		50	30	10		50
RCR																	
0	119	119	119	119	116	116	116	116	111	111	111		106	106	106		102
1	110	106	102	98	107	103	100	97	99	96	94		95	93	91		92
2	101	94	87	82	98	92	86	81	88	83	79		85	81	78		82
3	93	83	76	70	90	82	75	69	79	73	68		76	71	67		74
4	86	75	66	60	83	73	66	60	71	64	59		69	63	58		66
5	79	67	59	53	77	66	58	52	64	57	52		62	56	51		60
6	74	61	53	47	72	60	52	46	58	51	46		57	50	46		55
7	68	56	47	42	67	55	47	42	53	46	41		52	46	41		51
8	64	51	43	38	62	51	43	37	49	42	37		48	42	37		47
9	60	47	39	34	59	47	39	34	46	39	34		44	38	34		44
10	56	44	36	31	55	43	36	31	42	36	31		41	35	31		41

AVERAGE LUMINANCE (cd/sqm):

	0°	45°	90°
0°	3222	3222	3222
5°	3234	3181	3199
10°	3209	3129	3103
15°	3172	3037	2949
20°	3121	2904	2758
25°	3069	2754	2573
30°	2996	2599	2336
35°	2926	2431	2128
40°	2854	2257	1888
45°	2771	2062	1670
50°	2685	1864	1456
55°	2597	1652	1251
60°	2496	1428	1038
65°	2380	1200	945
70°	2242	989	869
75°	2072	901	812
80°	1830	805	739
85°	1437	635	635

MAXIMUM LUMINANCE 45°-90°:

Horizontal Angle: 0°

Vertical Angle: 45°

Luminance: 2771 cd/sqm

TEST NUMBER: P931584

CATALOG NUMBER: DFN2DS-TR4F0-110DS940-RLL

ZONAL LUMENS:

Zone	Lumens	% Fixture
0°-10°	380.1	4.6
10°-20°	1043.4	12.5
20°-30°	1464.8	17.6
30°-40°	1596.8	19.1
40°-50°	1467.6	17.6
50°-60°	1152.6	13.8
60°-70°	750.2	9.0
70°-80°	386.2	4.6
80°-90°	98.6	1.2
90°-100°	0.0	0.0
100°-110°	0.0	0.0
110°-120°	0.0	0.0
120°-130°	0.0	0.0
130°-140°	0.0	0.0
140°-150°	0.0	0.0
150°-160°	0.0	0.0
160°-170°	0.0	0.0
170°-180°	0.0	0.0
0°-30°	2888.3	34.6
0°-40°	4485.0	53.8
0°-60°	7105.2	85.2
0°-90°	8340.2	100.0
90°-120°	0.0	0.0
90°-150°	0.0	0.0
90°-180°	0.0	0.0
0°-180°	8340.2	100.0

CANDELA DISTRIBUTION:

	0°	22.5°	45°	67.5°	90°	Flux
0°	4055	4055	4055	4055	4055	
5°	4055	4037	3989	4022	4011	385
15°	3857	3817	3692	3622	3586	1087
25°	3501	3384	3141	2991	2936	1610
35°	3017	2830	2507	2276	2194	1888
45°	2466	2220	1835	1574	1486	1905
55°	1875	1589	1193	973	903	1676
65°	1266	969	639	514	503	1255
75°	675	418	294	268	264	714
85°	158	81	70	70	70	189
90°	0	0	0	0	0	

TEST NUMBER: P931584

CATALOG NUMBER: DFN2DS-TR4F0-110DS940-RLL

CANDELA DISTRIBUTION (FULL):

	0°	22.5°	45°	67.5°	90°
0°	4055.3	4055.3	4055.3	4055.3	4055.3
2.5°	4073.6	4055.3	4014.8	4051.8	4044.4
5°	4055.3	4037.0	3989.1	4022.2	4011.3
7.5°	4022.2	4000.4	3949.0	3963.4	3945.0
10°	3978.2	3952.5	3879.3	3868.0	3846.2
12.5°	3923.3	3890.2	3790.9	3769.1	3728.6
15°	3857.1	3816.6	3692.0	3622.3	3585.7
17.5°	3780.0	3721.2	3567.0	3486.4	3427.6
20°	3692.0	3618.4	3435.0	3343.5	3262.5
22.5°	3596.6	3512.1	3299.2	3174.5	3119.6
25°	3501.2	3383.6	3141.4	2991.1	2935.8
27.5°	3387.5	3262.5	2994.6	2822.1	2737.6
30°	3266.4	3126.6	2833.1	2646.1	2546.8
32.5°	3148.8	2979.8	2679.2	2458.9	2367.0
35°	3016.8	2829.5	2506.8	2275.5	2194.5
37.5°	2888.4	2686.3	2345.2	2091.7	2000.2
40°	2752.4	2532.5	2176.2	1915.7	1820.3
42.5°	2613.0	2378.3	2007.6	1735.8	1644.3
45°	2466.3	2220.2	1835.1	1574.2	1486.3
47.5°	2326.9	2066.4	1670.0	1409.1	1328.5
50°	2172.6	1912.2	1508.5	1255.0	1178.2
52.5°	2022.0	1746.7	1354.2	1112.1	1042.3
55°	1875.2	1589.0	1192.6	972.6	903.0
57.5°	1724.9	1431.3	1049.7	844.2	785.3
60°	1570.7	1277.2	899.0	712.2	653.4
62.5°	1420.4	1126.9	770.6	594.6	565.3
65°	1266.2	968.7	638.6	514.0	502.6
67.5°	1119.5	822.0	514.0	451.3	440.4
70°	965.2	679.1	425.6	389.0	374.2
72.5°	818.4	546.7	355.9	326.7	319.2
75°	675.2	418.2	293.6	267.9	264.4
77.5°	532.3	297.1	231.3	216.5	209.1
80°	399.9	213.0	176.0	161.6	161.6
82.5°	278.8	143.3	121.1	113.7	113.7
85°	157.7	80.6	69.7	69.7	69.7
87.5°	58.8	29.2	29.2	25.7	25.7
90°	0.0	0.0	0.0	0.0	0.0

TEST NUMBER: P931584

CATALOG NUMBER: DFN2DS-TR4F0-110DS940-RLL

CIE UGR TABLE:

Reflectances:											
Ceiling		0.7	0.7	0.5	0.5	0.3	0.7	0.7	0.5	0.5	0.3
Wall		0.5	0.3	0.5	0.3	0.3	0.5	0.3	0.5	0.3	0.3
Reference plane		0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2
Room dimensions		Viewed crosswise					Viewed endwise				
X=2H	Y=2H	15.30	16.82	15.66	17.13	17.45	11.26	12.78	11.63	13.10	13.41
	3H	17.06	18.43	17.44	18.76	19.12	12.53	13.89	12.90	14.22	14.58
	4H	17.73	19.01	18.13	19.36	19.74	13.03	14.31	13.43	14.66	15.03
	6H	18.22	19.40	18.63	19.77	20.16	13.41	14.59	13.82	14.96	15.35
	8H	18.39	19.51	18.81	19.90	20.30	13.53	14.66	13.96	15.05	15.45
	12H	18.49	19.57	18.92	19.95	20.38	13.61	14.69	14.04	15.07	15.50
4H	2H	15.40	16.68	15.80	17.03	17.41	11.96	13.24	12.36	13.59	13.96
	3H	17.34	18.40	17.75	18.80	19.20	13.40	14.46	13.81	14.86	15.26
	4H	18.09	19.04	18.52	19.46	19.90	14.00	14.95	14.43	15.37	15.81
	6H	18.68	19.51	19.14	19.95	20.41	14.49	15.32	14.94	15.76	16.22
	8H	18.89	19.67	19.36	20.11	20.58	14.65	15.43	15.11	15.87	16.34
	12H	19.05	19.74	19.53	20.22	20.69	14.77	15.46	15.25	15.94	16.41
8H	4H	18.11	18.89	18.57	19.33	19.80	14.35	15.13	14.82	15.57	16.04
	6H	18.75	19.39	19.24	19.88	20.36	14.94	15.58	15.44	16.07	16.55
	8H	19.00	19.57	19.51	20.08	20.57	15.16	15.74	15.67	16.25	16.73
	12H	19.20	19.71	19.71	20.20	20.77	15.34	15.85	15.85	16.34	16.91
12H	4H	18.09	18.79	18.58	19.27	19.74	14.40	15.09	14.88	15.57	16.04
	6H	18.73	19.31	19.24	19.82	20.30	15.00	15.58	15.52	16.09	16.58
	8H	19.01	19.52	19.52	20.02	20.58	15.28	15.79	15.78	16.28	16.84