

Cooper Lighting Solutions Photometric Lab
1121 Highway 74 South
Peachtree City, GA 30269



Scaled data based on original data using
LM-79-2019 Approved Method: Electrical and Photometric Measurements of Solid-
State Lighting Products

Test Report Prepared for
Cooper Lighting Solutions

Brand: NEO-RAY

Report Number: P998296

Luminaire Tested: SA2XXDIP-B290D725UB35-4F0-XX-W2A-D4

Issue Date: 5/7/2025

Test Information

Test Method: LM-79-2019
Report Number: P998296
REPORT IS A COMBINATION OF REPORTS P984036 AND P1007351
Test Lab: INNOVATION CENTER
Issue Date: 5/7/2025
Manufacturer: COOPER LIGHTING SOLUTIONS
Product Line: NEO-RAY
Catalog Number: SA2XXDIP-B290D725UB35-4F0-XX-W2A-D4
Description: Define 2 Direct/Indirect Pendant with 3500K BioUP LEDs {m-DER=0.721} {m-EER=0.792}
Light Source: -
Ballast/Driver: -

Summary


Lumens per Lamp: N/A
Luminaire Lumens: 3951.2 lumens
Efficiency: N/A
Efficacy: 115.9 lumens/watt
Spacing Criteria (0/90/45): 1.21 / 1.31 / 1.42
Luminous Opening: Rectangular w/ Sides (W: 0.17' x L: 4' x H: 0.1')
CIE Type: Semi-Indirect

Input Watts (W): 34.1
Input Voltage (V):
Input Current (Ain): NR
Voltage Rise (V): NR
Power Factor: NR
Total Harmonic Distortion (THDi): NR
Frequency (hertz): 60
Stabilization Time: NR
Operation Time: NR
Ambient Temperature (°C): NR
Test Distance: 24 FT

TEST NUMBER: P998296

CATALOG NUMBER: SA2XXDIP-B290D725UB35-4F0-XX-W2A-D4

Luminous Intensity Polar Plot



TEST NUMBER: P998296

CATALOG NUMBER: SA2XXDIP-B290D725UB35-4F0-XX-W2A-D4

COEFFICIENT OF UTILIZATION - ZONAL CAVITY METHOD:

RF	20				20				20				20				20
RC	80				70				50				30				10
RW	70	50	30	10	70	50	30	10	50	30	10	50	30	10	50	30	10
RCR																	
0	102	102	102	102	91	91	91	91	70	70	70	52	52	52	34	34	34
1	92	87	83	79	82	78	74	71	60	58	56	44	43	41	29	28	27
2	83	76	69	64	74	67	62	58	52	49	45	38	36	34	25	24	22
3	76	66	59	53	67	59	53	48	46	41	38	33	31	28	22	20	19
4	69	58	50	44	61	52	45	40	40	36	32	30	26	24	19	18	16
5	63	52	44	38	56	46	39	34	36	31	27	26	23	20	17	15	14
6	58	46	38	32	51	41	34	29	32	27	23	24	20	18	16	14	12
7	53	41	34	28	47	37	30	26	29	24	20	21	18	15	14	12	10
8	49	37	30	25	44	34	27	22	26	21	18	19	16	14	13	11	9
9	46	34	27	22	41	30	24	20	24	19	16	18	14	12	12	10	8
10	43	31	24	19	38	28	22	18	22	17	14	16	13	11	11	9	7

AVERAGE LUMINANCE (cd/sqm):

	0°	45°	90°
0°	4850	4850	4850
5°	4872	4643	4617
10°	4839	4483	4417
15°	4770	4315	4212
20°	4684	4141	4017
25°	4599	3973	3840
30°	4479	3804	3665
35°	4360	3639	3537
40°	4232	3498	3409
45°	4112	3370	3298
50°	3982	3252	3188
55°	3845	3126	3076
60°	3678	2994	2959
65°	3505	2843	2824
70°	3309	2682	2678
75°	3054	2520	2542
80°	2659	2351	2399
85°	2260	2192	2276

MAXIMUM LUMINANCE 45°-90°:

Horizontal Angle: 0°
Vertical Angle: 45°
Luminance: 4112 cd/sqm

TEST NUMBER: P998296

CATALOG NUMBER: SA2XXDIP-B290D725UB35-4F0-XX-W2A-D4

ZONAL LUMENS:

Zone	Lumens	% Fixture
0°-10°	29.0	0.7
10°-20°	83.3	2.1
20°-30°	126.2	3.2
30°-40°	153.7	3.9
40°-50°	165.4	4.2
50°-60°	160.6	4.1
60°-70°	140.2	3.5
70°-80°	108.0	2.7
80°-90°	74.8	1.9
90°-100°	211.5	5.4
100°-110°	582.8	14.8
110°-120°	598.4	15.1
120°-130°	485.7	12.3
130°-140°	385.1	9.7
140°-150°	287.6	7.3
150°-160°	201.6	5.1
160°-170°	118.7	3.0
170°-180°	38.6	1.0
0°-30°	238.5	6.0
0°-40°	392.2	9.9
0°-60°	718.2	18.2
0°-90°	1041.2	26.4
90°-120°	1392.7	35.2
90°-150°	2551.1	64.6
90°-180°	2910.0	73.6
0°-180°	3951.2	100.0

CANDELA DISTRIBUTION:

	0°	22.5°	45°	67.5°	90°	Flux
0°	306	306	306	306	306	
5°	307	306	303	306	306	29
15°	293	294	294	298	298	83
25°	266	270	274	279	280	123
35°	230	237	246	255	258	143
45°	188	200	216	230	234	145
55°	144	160	183	199	205	129
65°	99	120	146	165	170	98
75°	55	80	108	127	133	58
85°	16	44	72	91	97	17
90°	5	41	85	101	107	5
95°	30	90	352	181	161	31
105°	96	156	606	1069	923	102
115°	167	215	502	1021	1182	165
125°	231	273	472	822	953	205
135°	270	322	456	682	782	209
145°	308	354	449	560	615	193
155°	350	378	436	493	513	161
165°	382	393	418	443	450	108
175°	398	398	402	407	406	38
180°	399	399	399	399	399	

TEST NUMBER: P998296

CATALOG NUMBER: SA2XXDIP-B290D725UB35-4F0-XX-W2A-D4

CANDELA DISTRIBUTION (FULL):

	0°	22.5°	45°	67.5°	90°
0°	306.4	306.4	306.4	306.4	306.4
2.5°	308.6	307.3	304.1	306.4	305.5
5°	307.3	305.9	303.3	305.9	305.5
7.5°	305.0	304.1	301.9	305.0	304.6
10°	302.4	301.5	300.2	303.7	303.3
12.5°	297.9	298.4	297.5	301.0	300.6
15°	293.0	293.9	293.9	297.9	297.5
17.5°	286.8	288.6	289.9	293.9	293.9
20°	280.6	282.8	284.6	289.5	289.5
22.5°	274.0	276.6	279.3	284.2	285.1
25°	266.4	269.5	273.5	278.8	280.2
27.5°	257.5	262.4	266.9	273.5	274.4
30°	248.6	254.4	260.2	267.3	268.6
32.5°	238.9	245.5	252.6	261.1	263.7
35°	229.6	237.1	245.5	255.3	258.4
37.5°	219.3	227.8	238.4	249.1	252.2
40°	209.1	218.9	230.9	242.4	246.4
42.5°	199.4	209.1	223.3	236.2	240.2
45°	188.3	200.3	215.8	229.6	234.0
47.5°	177.6	190.5	208.2	222.5	227.3
50°	166.5	180.3	200.3	215.3	220.2
52.5°	155.8	170.5	191.8	207.4	212.7
55°	144.3	160.3	183.4	199.4	205.1
57.5°	133.2	151.0	174.1	191.4	197.1
60°	121.2	140.3	165.6	182.5	188.7
62.5°	110.6	130.5	155.8	174.1	179.8
65°	98.6	120.3	146.5	164.7	170.5
67.5°	87.9	110.6	137.2	155.4	161.6
70°	76.4	99.5	127.0	146.1	151.4
72.5°	65.7	89.7	117.7	136.3	143.0
75°	54.6	79.5	107.9	127.0	132.8
77.5°	44.0	69.7	98.6	117.7	123.9
80°	33.3	60.4	89.2	107.9	114.1
82.5°	24.4	51.1	80.4	99.0	104.8
85°	16.0	43.5	71.9	90.6	96.8
87.5°	9.8	36.4	64.8	83.0	88.8
90°	5.2	40.6	84.7	101.3	107.0
92.5°	15.5	63.9	172.7	126.4	124.1
95°	30.4	90.3	351.6	181.4	160.7
97.5°	43.0	109.3	537.9	292.1	216.1
100°	62.1	126.0	650.1	514.3	340.2
102.5°	79.4	141.5	650.8	824.0	597.4
105°	95.7	156.2	606.3	1069.1	922.7
107.5°	114.1	170.8	564.9	1155.8	1140.7
110°	132.1	185.9	536.1	1137.6	1227.6

TEST NUMBER: P998296

CATALOG NUMBER: SA2XXDIP-B290D725UB35-4F0-XX-W2A-D4

CANDELA DISTRIBUTION (continued):

	0°	22.5°	45°	67.5°	90°
112.5°	149.0	200.6	516.2	1085.0	1223.0
115°	166.6	214.8	502.0	1021.0	1181.8
117.5°	184.5	229.6	492.7	960.0	1121.6
120°	201.4	243.8	484.8	904.6	1064.0
122.5°	217.5	259.0	479.0	861.3	1003.3
125°	230.9	273.0	472.1	821.8	953.4
127.5°	242.4	286.8	467.1	787.2	906.1
130°	252.4	299.4	462.9	752.6	866.6
132.5°	261.6	311.6	459.5	716.9	825.9
135°	270.3	322.4	456.5	682.0	782.2
137.5°	278.7	331.6	454.3	646.7	739.5
140°	288.7	339.6	451.7	615.2	695.4
142.5°	298.6	346.5	450.8	585.3	651.5
145°	308.2	354.2	449.3	560.5	615.2
147.5°	318.9	360.4	447.0	538.6	582.2
150°	329.7	366.5	444.7	521.4	554.3
152.5°	340.4	372.6	440.9	507.2	532.1
155°	350.4	378.4	436.3	493.4	512.9
157.5°	358.8	383.0	431.7	480.4	496.1
160°	367.2	387.6	427.1	467.3	480.0
162.5°	375.7	391.0	423.2	455.0	464.6
165°	381.8	393.3	417.9	443.2	450.1
167.5°	387.2	395.6	413.3	432.4	436.3
170°	392.5	396.8	409.4	422.4	424.0
172.5°	395.6	397.9	404.8	413.6	414.0
175°	397.9	398.3	401.7	406.7	405.6
177.5°	399.4	398.7	398.7	401.7	399.4
180°	398.7	398.7	398.7	398.7	398.7

TEST NUMBER: P998296

CATALOG NUMBER: SA2XXDIP-B290D725UB35-4F0-XX-W2A-D4

CIE UGR TABLE:

Reflectances:											
Ceiling		0.7	0.7	0.5	0.5	0.3	0.7	0.7	0.5	0.5	0.3
Wall		0.5	0.3	0.5	0.3	0.3	0.5	0.3	0.5	0.3	0.3
Reference plane		0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2
Room dimensions		Viewed crosswise					Viewed endwise				
X=2H	Y=2H	7.99	8.69	9.12	9.82	11.39	11.06	11.77	12.19	12.89	14.46
	3H	9.44	10.07	10.58	11.21	12.79	13.64	14.28	14.78	15.41	17.00
	4H	9.91	10.51	11.05	11.65	13.24	14.89	15.49	16.03	16.63	18.22
	6H	10.18	10.74	11.34	11.88	13.48	16.18	16.73	17.33	17.87	19.47
	8H	10.24	10.77	11.39	11.92	13.52	16.83	17.36	17.99	18.52	20.11
	12H	10.25	10.75	11.41	11.90	13.52	17.55	18.06	18.71	19.20	20.82
4H	2H	9.02	9.63	10.17	10.76	12.35	11.37	11.98	12.53	13.11	14.70
	3H	10.72	11.23	11.88	12.39	13.99	14.15	14.66	15.31	15.82	17.43
	4H	11.33	11.80	12.49	12.95	14.57	15.56	16.04	16.73	17.18	18.81
	6H	11.74	12.15	12.91	13.32	14.93	17.02	17.43	18.19	18.60	20.21
	8H	11.84	12.22	13.01	13.39	15.02	17.78	18.16	18.94	19.32	20.95
	12H	11.88	12.23	13.06	13.40	15.03	18.60	18.95	19.78	20.12	21.75
8H	4H	12.11	12.49	13.28	13.65	15.28	15.70	16.08	16.86	17.24	18.87
	6H	12.74	13.05	13.92	14.26	15.88	17.32	17.64	18.50	18.84	20.47
	8H	12.96	13.23	14.15	14.42	16.06	18.21	18.48	19.40	19.67	21.31
	12H	13.08	13.33	14.28	14.51	16.18	19.19	19.44	20.39	20.62	22.30
12H	4H	12.30	12.65	13.48	13.82	15.45	15.66	16.01	16.85	17.18	18.82
	6H	13.07	13.35	14.26	14.53	16.17	17.34	17.62	18.53	18.80	20.45
	8H	13.37	13.61	14.56	14.79	16.47	18.26	18.51	19.46	19.69	21.37