

Scaled data based on original data using
LM-79-2019 Approved Method: Electrical and Photometric Measurements of Solid-
State Lighting Products

Test Report Prepared for
Cooper Lighting Solutions

Brand: NEO-RAY

Report Number: P1025006

Luminaire Tested: S124DIP-B1020D810UB35-4F0-XX-W2A-D1

Issue Date: 5/7/2025

Test Information

Test Method: LM-79-2019
Report Number: P1025006
REPORT IS A COMBINATION OF REPORTS P995396 AND P1007351
Test Lab: INNOVATION CENTER
Issue Date: 5/7/2025
Manufacturer: COOPER LIGHTING SOLUTIONS
Product Line: NEO-RAY
Catalog Number: S124DIP-B1020D810UB35-4F0-XX-W2A-D1
Description: Define 4 Direct/Indirect Pendant with 3500K BioUP LEDs {m-DER=0.721} {m-EER=0.792}
Light Source: -
Ballast/Driver: -

Summary


Lumens per Lamp: N/A
Luminaire Lumens: 6955.0 lumens
Efficiency: N/A
Efficacy: 102.4 lumens/watt
Spacing Criteria (0/90/45): 1.23 / 1.28 / 1.39
Luminous Opening: Rectangular w/ Sides (W: 0.33' x L: 4' x H: 0.1')
CIE Type: General Diffuse

Input Watts (W): 67.9
Input Voltage (V):
Input Current (Ain): NR
Voltage Rise (V): NR
Power Factor: NR
Total Harmonic Distortion (THDi): NR
Frequency (hertz): 60
Stabilization Time: NR
Operation Time: NR
Ambient Temperature (°C): NR
Test Distance: 24 FT

TEST NUMBER: P1025006

CATALOG NUMBER: S124DIP-B1020D810UB35-4F0-XX-W2A-D1

Luminous Intensity Polar Plot



TEST NUMBER: P1025006

CATALOG NUMBER: S124DIP-B1020D810UB35-4F0-XX-W2A-D1

COEFFICIENT OF UTILIZATION - ZONAL CAVITY METHOD:

RF	20				20				20				20				20
RC	80				70				50				30				10
RW	70	50	30	10	70	50	30	10	50	30	10	50	30	10	50	30	10
RCR																	
0	109	109	109	109	101	101	101	101	87	87	87	74	74	74	62	62	62
1	98	93	89	85	91	87	83	79	74	71	69	63	61	59	53	51	50
2	89	81	74	68	82	75	69	64	64	60	56	55	51	48	46	43	41
3	81	71	63	56	74	66	59	53	56	51	47	48	44	40	40	37	34
4	74	62	54	47	68	58	50	45	50	44	39	42	38	34	36	32	29
5	67	55	47	40	62	52	44	38	45	38	34	38	33	29	32	28	25
6	62	49	41	35	57	46	39	33	40	34	29	34	29	26	29	25	22
7	57	45	36	30	53	42	34	29	36	30	26	31	26	23	26	22	20
8	53	40	32	27	49	38	31	25	33	27	23	28	24	20	24	20	17
9	50	37	29	24	46	35	28	23	30	24	20	26	21	18	22	18	16
10	46	34	26	21	43	32	25	20	28	22	18	24	19	16	21	17	14

AVERAGE LUMINANCE (cd/sqm):

	0°	45°	90°
0°	10050	10050	10050
5°	10078	9788	9806
10°	10012	9595	9568
15°	9919	9379	9300
20°	9779	9145	9040
25°	9623	8887	8759
30°	9454	8630	8472
35°	9263	8368	8217
40°	9108	8117	7953
45°	8881	7881	7720
50°	8689	7613	7474
55°	8487	7355	7190
60°	8177	7033	6923
65°	7834	6686	6602
70°	7420	6291	6231
75°	6841	5850	5877
80°	6186	5403	5507
85°	5319	4951	5207

MAXIMUM LUMINANCE 45°-90°:

Horizontal Angle: 0°

Vertical Angle: 45°

Luminance: 8881 cd/sqm

TEST NUMBER: P1025006

CATALOG NUMBER: S124DIP-B1020D810UB35-4F0-XX-W2A-D1

ZONAL LUMENS:

Zone	Lumens	% Fixture
0°-10°	116.8	1.7
10°-20°	334.6	4.8
20°-30°	505.9	7.3
30°-40°	612.0	8.8
40°-50°	647.0	9.3
50°-60°	608.9	8.8
60°-70°	505.3	7.3
70°-80°	354.6	5.1
80°-90°	202.0	2.9
90°-100°	183.6	2.6
100°-110°	281.7	4.1
110°-120°	388.0	5.6
120°-130°	467.0	6.7
130°-140°	501.5	7.2
140°-150°	481.6	6.9
150°-160°	402.7	5.8
160°-170°	267.9	3.9
170°-180°	93.8	1.3
0°-30°	957.3	13.8
0°-40°	1569.3	22.6
0°-60°	2825.3	40.6
0°-90°	3887.2	55.9
90°-120°	853.3	12.3
90°-150°	2303.4	33.1
90°-180°	3068.0	44.1
0°-180°	6955.0	100.0

CANDELA DISTRIBUTION:

	0°	22.5°	45°	67.5°	90°	Flux
0°	1232	1232	1232	1232	1232	
5°	1234	1230	1220	1231	1230	117
15°	1183	1184	1180	1192	1191	333
25°	1082	1090	1094	1110	1111	498
35°	947	963	977	996	1001	593
45°	789	816	842	865	872	610
55°	618	647	689	716	725	551
65°	428	472	519	553	564	424
75°	237	288	346	385	398	252
85°	73	131	193	235	248	76
90°	24	88	154	198	211	18
95°	64	116	178	218	230	64
105°	191	219	274	310	324	204
115°	343	355	398	427	436	338
125°	492	491	525	550	556	439
135°	631	635	645	666	672	488
145°	764	766	767	774	778	479
155°	874	874	873	876	873	402
165°	952	949	948	952	949	268
175°	990	986	985	991	985	94
180°	991	991	991	991	991	

TEST NUMBER: P1025006

CATALOG NUMBER: S124DIP-B1020D810UB35-4F0-XX-W2A-D1

CANDELA DISTRIBUTION (FULL):

	0°	22.5°	45°	67.5°	90°
0°	1232.5	1232.5	1232.5	1232.5	1232.5
2.5°	1238.0	1233.9	1222.8	1232.5	1231.1
5°	1233.9	1229.7	1220.0	1231.1	1229.7
7.5°	1225.6	1222.8	1214.5	1227.0	1225.6
10°	1214.5	1213.1	1206.2	1218.7	1217.3
12.5°	1199.3	1199.3	1195.2	1206.2	1206.2
15°	1182.8	1184.2	1180.0	1192.4	1191.1
17.5°	1160.7	1164.8	1163.5	1175.9	1174.5
20°	1137.2	1141.4	1142.8	1156.6	1156.6
22.5°	1111.0	1116.5	1119.3	1133.1	1135.9
25°	1082.0	1090.3	1094.5	1109.6	1111.0
27.5°	1050.3	1062.7	1068.2	1082.0	1083.4
30°	1018.5	1029.6	1039.3	1054.4	1057.2
32.5°	984.0	997.8	1008.9	1026.8	1029.6
35°	946.8	963.3	977.1	996.5	1000.6
37.5°	909.5	928.8	945.4	964.7	968.9
40°	873.6	891.6	910.9	931.6	937.1
42.5°	832.2	852.9	876.4	899.9	904.0
45°	789.4	815.7	841.9	865.4	872.3
47.5°	749.4	775.6	806.0	829.5	837.7
50°	705.3	735.6	766.0	793.6	801.9
52.5°	661.1	691.5	727.3	754.9	763.2
55°	618.3	647.3	688.7	716.3	724.6
57.5°	570.0	605.9	645.9	679.0	685.9
60°	523.1	559.0	604.5	636.2	647.3
62.5°	477.5	517.6	563.1	594.8	605.9
65°	427.8	472.0	518.9	553.4	564.5
67.5°	380.9	427.8	477.5	512.0	523.1
70°	332.6	379.5	432.0	469.2	478.9
72.5°	285.7	334.0	390.6	426.5	437.5
75°	237.4	288.5	346.4	385.1	397.5
77.5°	191.8	245.7	306.4	345.0	358.8
80°	150.4	205.6	266.4	307.8	318.8
82.5°	109.0	167.0	227.7	270.5	282.9
85°	73.1	131.1	193.2	234.6	248.4
87.5°	45.5	102.1	162.9	202.9	215.3
90°	24.4	88.0	153.5	198.2	210.7
92.5°	40.6	98.9	162.1	203.0	214.8
95°	63.9	116.4	178.4	217.9	230.4
97.5°	90.2	136.3	199.1	238.0	250.4
100°	122.5	161.5	222.2	261.1	270.7
102.5°	157.8	188.9	247.5	285.7	297.5
105°	191.1	219.4	273.6	310.4	323.7
107.5°	228.6	252.9	302.0	339.5	348.5
110°	265.6	286.5	334.0	364.2	377.6

TEST NUMBER: P1025006

CATALOG NUMBER: S124DIP-B1020D810UB35-4F0-XX-W2A-D1

CANDELA DISTRIBUTION (continued):

	0°	22.5°	45°	67.5°	90°
112.5°	304.1	320.6	364.7	395.0	406.1
115°	342.6	355.0	397.7	427.2	436.1
117.5°	380.2	388.5	429.1	455.7	464.5
120°	416.4	423.5	461.3	485.1	497.6
122.5°	455.5	456.2	492.8	518.1	523.8
125°	492.4	491.0	524.7	549.5	556.2
127.5°	526.9	527.8	553.9	577.2	586.1
130°	562.3	563.3	585.3	608.7	613.9
132.5°	599.9	600.1	615.9	637.8	645.4
135°	630.8	635.4	645.0	665.6	671.6
137.5°	666.8	667.7	674.8	693.2	700.8
140°	702.9	703.0	704.4	721.5	727.7
142.5°	734.4	736.0	733.8	749.0	754.5
145°	764.3	766.0	766.8	774.3	777.5
147.5°	795.0	797.4	796.7	797.3	802.0
150°	822.6	824.3	824.3	824.3	823.5
152.5°	847.3	848.8	849.6	851.9	849.6
155°	874.1	874.1	873.4	876.4	873.4
157.5°	897.1	895.6	895.6	897.9	895.6
160°	917.1	916.3	915.5	917.8	914.0
162.5°	935.5	933.2	932.4	937.0	933.2
165°	951.6	949.3	947.7	952.3	949.3
167.5°	964.6	961.5	961.5	966.1	961.5
170°	975.3	971.5	972.3	976.9	971.5
172.5°	983.0	979.9	979.9	985.3	979.9
175°	989.9	986.1	985.3	990.7	985.3
177.5°	993.0	989.1	989.1	994.5	988.4
180°	991.4	991.4	991.4	991.4	991.4

(END OF REPORT)