

Scaled data based on original data using
LM-79-2019 Approved Method: Electrical and Photometric Measurements of Solid-
State Lighting Products

Test Report Prepared for
Cooper Lighting Solutions

Brand: NEO-RAY

Report Number: P1025177

Luminaire Tested: S124DIP-B1195D590UB30-4F0-XX-W2A-D1

Issue Date: 5/7/2025

Test Information

Test Method: LM-79-2019
Report Number: P1025177
REPORT IS A COMBINATION OF REPORTS P995627 AND P1007351
Test Lab: INNOVATION CENTER
Issue Date: 5/7/2025
Manufacturer: COOPER LIGHTING SOLUTIONS
Product Line: NEO-RAY
Catalog Number: S124DIP-B1195D590UB30-4F0-XX-W2A-D1
Description: Define 4 Direct/Indirect Pendant with 3000K BioUP LEDs {m-DER=0.589} {m-EER=0.647}
Light Source: -
Ballast/Driver: -

Summary


Lumens per Lamp: N/A
Luminaire Lumens: 6923.9 lumens
Efficiency: N/A
Efficacy: 90.3 lumens/watt
Spacing Criteria (0/90/45): 1.23 / 1.28 / 1.39
Luminous Opening: Rectangular w/ Sides (W: 0.33' x L: 4' x H: 0.1')
CIE Type: Semi-Direct

Input Watts (W): 76.7
Input Voltage (V):
Input Current (Ain): NR
Voltage Rise (V): NR
Power Factor: NR
Total Harmonic Distortion (THDi): NR
Frequency (hertz): 60
Stabilization Time: NR
Operation Time: NR
Ambient Temperature (°C): NR
Test Distance: 24 FT

TEST NUMBER: P1025177

CATALOG NUMBER: S124DIP-B1195D590UB30-4F0-XX-W2A-D1

Luminous Intensity Polar Plot



TEST NUMBER: P1025177

CATALOG NUMBER: S124DIP-B1195D590UB30-4F0-XX-W2A-D1

COEFFICIENT OF UTILIZATION - ZONAL CAVITY METHOD:

RF	20				20				20				20				20
RC	80				70				50				30				10
RW	70	50	30	10	70	50	30	10	50	30	10	50	30	10	50	30	10
RCR																	
0	111	111	111	111	104	104	104	104	92	92	92	80	80	80	70	70	70
1	100	95	90	86	94	89	85	82	79	76	73	69	67	64	60	58	57
2	90	82	75	69	85	77	71	66	68	63	59	60	56	53	52	49	47
3	82	72	64	57	77	68	60	54	60	54	49	52	48	44	45	42	39
4	75	63	55	48	70	60	52	46	53	46	42	46	41	37	40	36	33
5	69	56	47	41	64	53	45	39	47	41	36	41	36	32	36	32	29
6	63	50	42	35	59	48	40	34	42	36	31	37	32	28	33	28	25
7	59	45	37	31	55	43	35	30	38	32	27	34	29	25	30	26	22
8	54	41	33	27	51	39	32	26	35	29	24	31	26	22	27	23	20
9	51	38	30	24	47	36	28	24	32	26	22	29	23	20	25	21	18
10	47	35	27	22	44	33	26	21	30	24	19	26	21	18	23	19	16

AVERAGE LUMINANCE (cd/sqm):

	0°	45°	90°
0°	11653	11653	11653
5°	11685	11349	11370
10°	11609	11126	11094
15°	11501	10875	10783
20°	11339	10603	10481
25°	11158	10303	10156
30°	10962	10006	9823
35°	10739	9702	9528
40°	10561	9411	9221
45°	10298	9137	8950
50°	10073	8827	8665
55°	9841	8527	8336
60°	9481	8155	8027
65°	9085	7753	7654
70°	8605	7294	7225
75°	7931	6784	6815
80°	7173	6263	6384
85°	6171	5740	6037

MAXIMUM LUMINANCE 45°-90°:

Horizontal Angle: 0°

Vertical Angle: 45°

Luminance: 10298 cd/sqm

TEST NUMBER: P1025177

CATALOG NUMBER: S124DIP-B1195D590UB30-4F0-XX-W2A-D1

ZONAL LUMENS:

Zone	Lumens	% Fixture
0°-10°	135.4	2.0
10°-20°	387.9	5.6
20°-30°	586.6	8.5
30°-40°	709.6	10.2
40°-50°	750.2	10.8
50°-60°	706.0	10.2
60°-70°	585.9	8.5
70°-80°	411.1	5.9
80°-90°	233.3	3.4
90°-100°	186.1	2.7
100°-110°	246.4	3.6
110°-120°	313.7	4.5
120°-130°	361.9	5.2
130°-140°	379.8	5.5
140°-150°	360.1	5.2
150°-160°	300.1	4.3
160°-170°	199.7	2.9
170°-180°	69.9	1.0
0°-30°	1109.9	16.0
0°-40°	1819.6	26.3
0°-60°	3275.8	47.3
0°-90°	4506.2	65.1
90°-120°	746.3	10.8
90°-150°	1848.0	26.7
90°-180°	2418.0	34.9
0°-180°	6923.9	100.0

CANDELA DISTRIBUTION:

	0°	22.5°	45°	67.5°	90°	Flux
0°	1429	1429	1429	1429	1429	
5°	1431	1426	1415	1427	1426	136
15°	1371	1373	1368	1383	1381	386
25°	1255	1264	1269	1287	1288	578
35°	1098	1117	1133	1155	1160	687
45°	915	946	976	1003	1011	707
55°	717	750	798	830	840	639
65°	496	547	602	642	654	492
75°	275	334	402	446	461	292
85°	85	152	224	272	288	88
90°	27	98	171	221	235	20
95°	55	113	183	228	242	54
105°	148	180	242	283	298	158
115°	259	273	323	358	368	256
125°	369	368	407	436	445	330
135°	471	475	486	510	518	365
145°	570	571	572	581	585	357
155°	652	652	651	653	651	300
165°	709	708	706	710	708	200
175°	738	735	734	738	734	70
180°	739	739	739	739	739	

TEST NUMBER: P1025177

CATALOG NUMBER: S124DIP-B1195D590UB30-4F0-XX-W2A-D1

CANDELA DISTRIBUTION (FULL):

	0°	22.5°	45°	67.5°	90°
0°	1429.0	1429.0	1429.0	1429.0	1429.0
2.5°	1435.4	1430.6	1417.8	1429.0	1427.4
5°	1430.6	1425.8	1414.6	1427.4	1425.8
7.5°	1421.0	1417.8	1408.2	1422.6	1421.0
10°	1408.2	1406.6	1398.6	1413.0	1411.4
12.5°	1390.6	1390.6	1385.8	1398.6	1398.6
15°	1371.4	1373.0	1368.2	1382.6	1381.0
17.5°	1345.8	1350.6	1349.0	1363.4	1361.8
20°	1318.6	1323.4	1325.0	1341.0	1341.0
22.5°	1288.2	1294.6	1297.8	1313.8	1317.0
25°	1254.6	1264.2	1269.0	1286.6	1288.2
27.5°	1217.8	1232.2	1238.6	1254.6	1256.2
30°	1181.0	1193.8	1205.0	1222.6	1225.8
32.5°	1140.9	1157.0	1169.8	1190.6	1193.8
35°	1097.7	1116.9	1132.9	1155.4	1160.2
37.5°	1054.5	1076.9	1096.1	1118.5	1123.3
40°	1012.9	1033.7	1056.1	1080.1	1086.5
42.5°	964.9	988.9	1016.1	1043.3	1048.1
45°	915.3	945.7	976.1	1003.3	1011.3
47.5°	868.9	899.3	934.5	961.7	971.3
50°	817.7	852.9	888.1	920.1	929.7
52.5°	766.5	801.7	843.3	875.3	884.9
55°	716.9	750.5	798.5	830.5	840.1
57.5°	660.9	702.5	748.9	787.3	795.3
60°	606.5	648.1	700.9	737.7	750.5
62.5°	553.7	600.1	652.9	689.7	702.5
65°	496.1	547.3	601.7	641.7	654.5
67.5°	441.7	496.1	553.7	593.7	606.5
70°	385.7	440.1	500.9	544.1	555.3
72.5°	331.2	387.3	452.9	494.5	507.3
75°	275.2	334.4	401.7	446.5	460.9
77.5°	222.4	284.8	355.2	400.1	416.1
80°	174.4	238.4	308.8	356.8	369.6
82.5°	126.4	193.6	264.0	313.6	328.0
85°	84.8	152.0	224.0	272.0	288.0
87.5°	52.8	118.4	188.8	235.2	249.6
90°	27.3	97.6	171.0	220.8	234.7
92.5°	38.9	102.3	173.9	220.5	233.8
95°	55.1	113.0	182.6	227.6	242.0
97.5°	74.1	125.0	195.2	239.1	253.5
100°	97.6	141.5	209.0	253.4	264.6
102.5°	123.9	159.7	225.0	268.4	281.7
105°	147.6	180.1	241.6	283.3	297.9
107.5°	175.6	203.3	259.9	302.2	312.8
110°	202.5	226.1	281.5	317.2	331.7



TEST NUMBER: P1025177

CATALOG NUMBER: S124DIP-B1195D590UB30-4F0-XX-W2A-D1

CANDELA DISTRIBUTION (continued):

	0°	22.5°	45°	67.5°	90°
112.5°	230.7	249.9	301.5	336.7	349.5
115°	258.8	273.2	323.2	357.9	368.5
117.5°	286.8	296.4	343.8	375.7	386.8
120°	313.2	320.3	365.0	394.1	408.1
122.5°	342.3	342.9	385.5	415.8	424.2
125°	369.3	367.7	407.1	436.4	444.9
127.5°	395.0	395.2	426.0	453.7	464.3
130°	420.9	421.0	446.6	474.2	481.6
132.5°	448.9	448.4	467.1	493.1	502.1
135°	471.3	474.7	485.9	510.4	518.3
137.5°	498.1	498.3	505.8	528.1	536.7
140°	525.0	524.5	526.1	546.4	553.8
142.5°	548.0	549.1	547.0	564.6	571.0
145°	570.3	571.0	571.5	580.6	585.2
147.5°	593.1	594.4	593.8	594.8	600.7
150°	613.7	614.4	614.4	614.4	613.8
152.5°	631.5	632.7	633.3	635.0	633.3
155°	651.5	651.5	651.0	653.3	651.0
157.5°	668.7	667.5	667.5	669.3	667.5
160°	683.5	683.0	682.4	684.1	681.3
162.5°	697.3	695.6	695.0	698.4	695.6
165°	709.3	707.6	706.4	709.8	707.6
167.5°	719.0	716.7	716.7	720.1	716.7
170°	727.0	724.1	724.7	728.1	724.1
172.5°	732.7	730.4	730.4	734.4	730.4
175°	737.8	735.0	734.4	738.4	734.4
177.5°	740.1	737.3	737.3	741.3	736.7
180°	739.0	739.0	739.0	739.0	739.0

(END OF REPORT)