

Scaled data based on original data using
LM-79-2019 Approved Method: Electrical and Photometric Measurements of Solid-
State Lighting Products

Test Report Prepared for
Cooper Lighting Solutions

Brand: NEO-RAY

Report Number: P1025241

Luminaire Tested: S124DIP-B1195D810UB40-4F0-XX-W2A-D4

Issue Date: 5/6/2025

Test Information

Test Method: LM-79-2019
Report Number: P1025241
REPORT IS A COMBINATION OF REPORTS P995706 AND P1007351
Test Lab: INNOVATION CENTER
Issue Date: 5/6/2025
Manufacturer: COOPER LIGHTING SOLUTIONS
Product Line: NEO-RAY
Catalog Number: S124DIP-B1195D810UB40-4F0-XX-W2A-D4
Description: Define 4 Direct/Indirect Pendant with 4000K BioUP LEDs {m-DER=0.865} {m-EER=0.951}
Light Source: -
Ballast/Driver: -

Summary


Lumens per Lamp: N/A
Luminaire Lumens: 7666.6 lumens
Efficiency: N/A
Efficacy: 93.0 lumens/watt
Spacing Criteria (0/90/45): 1.23 / 1.28 / 1.39
Luminous Opening: Rectangular w/ Sides (W: 0.33' x L: 4' x H: 0.1')
CIE Type: General Diffuse

Input Watts (W): 82.4
Input Voltage (V):
Input Current (Ain): NR
Voltage Rise (V): NR
Power Factor: NR
Total Harmonic Distortion (THDi): NR
Frequency (hertz): 60
Stabilization Time: NR
Operation Time: NR
Ambient Temperature (°C): NR
Test Distance: 24 FT

TEST NUMBER: P1025241

CATALOG NUMBER: S124DIP-B1195D810UB40-4F0-XX-W2A-D4

Luminous Intensity Polar Plot



TEST NUMBER: P1025241

CATALOG NUMBER: S124DIP-B1195D810UB40-4F0-XX-W2A-D4

COEFFICIENT OF UTILIZATION - ZONAL CAVITY METHOD:

RF	20				20				20				20				20
RC	80				70				50				30				10
RW	70	50	30	10	70	50	30	10	50	30	10	50	30	10	50	30	10
RCR																	
0	109	109	109	109	102	102	102	102	88	88	88	75	75	75	64	64	64
1	99	94	89	85	92	87	83	80	75	73	70	65	62	60	55	53	52
2	89	81	74	69	83	76	70	65	65	61	57	56	53	50	47	45	43
3	81	71	63	57	75	66	59	53	57	52	47	49	45	41	42	38	36
4	74	62	54	48	69	58	51	45	51	45	40	44	39	35	37	33	30
5	68	56	47	41	63	52	44	38	45	39	34	39	34	30	33	29	26
6	62	50	41	35	58	47	39	33	41	34	30	35	30	26	30	26	23
7	58	45	36	31	54	42	34	29	37	31	26	32	27	23	27	23	20
8	54	41	33	27	50	38	31	26	34	27	23	29	24	21	25	21	18
9	50	37	29	24	46	35	28	23	31	25	21	27	22	18	23	19	16
10	47	34	27	22	43	32	25	21	28	23	19	25	20	17	21	18	15

AVERAGE LUMINANCE (cd/sqm):

	0°	45°	90°
0°	11588	11588	11588
5°	11620	11286	11307
10°	11545	11064	11033
15°	11437	10814	10723
20°	11277	10544	10422
25°	11096	10246	10099
30°	10901	9951	9769
35°	10681	9649	9474
40°	10502	9359	9170
45°	10241	9087	8901
50°	10018	8778	8617
55°	9786	8480	8290
60°	9428	8109	7982
65°	9034	7709	7612
70°	8556	7253	7184
75°	7887	6745	6776
80°	7136	6228	6350
85°	6134	5709	6003

MAXIMUM LUMINANCE 45°-90°:

Horizontal Angle: 0°

Vertical Angle: 45°

Luminance: 10241 cd/sqm

TEST NUMBER: P1025241

CATALOG NUMBER: S124DIP-B1195D810UB40-4F0-XX-W2A-D4

ZONAL LUMENS:

Zone	Lumens	% Fixture
0°-10°	134.6	1.8
10°-20°	385.8	5.0
20°-30°	583.3	7.6
30°-40°	705.7	9.2
40°-50°	746.0	9.7
50°-60°	702.1	9.2
60°-70°	582.6	7.6
70°-80°	408.9	5.3
80°-90°	232.0	3.0
90°-100°	424.3	5.5
100°-110°	685.4	8.9
110°-120°	588.6	7.7
120°-130°	475.5	6.2
130°-140°	381.4	5.0
140°-150°	281.9	3.7
150°-160°	195.8	2.6
160°-170°	115.2	1.5
170°-180°	37.4	0.5
0°-30°	1103.7	14.4
0°-40°	1809.5	23.6
0°-60°	3257.6	42.5
0°-90°	4481.1	58.4
90°-120°	1698.3	22.2
90°-150°	2837.0	37.0
90°-180°	3185.0	41.5
0°-180°	7666.6	100.0

CANDELA DISTRIBUTION:

	0°	22.5°	45°	67.5°	90°	Flux
0°	1421	1421	1421	1421	1421	
5°	1423	1418	1407	1420	1418	135
15°	1364	1365	1361	1375	1373	384
25°	1248	1257	1262	1279	1281	575
35°	1092	1111	1127	1149	1154	684
45°	910	940	971	998	1006	704
55°	713	746	794	826	836	635
65°	493	544	598	638	651	489
75°	274	333	399	444	458	291
85°	84	151	223	270	286	88
90°	26	95	171	219	232	19
95°	46	152	757	488	381	44
105°	103	175	603	1217	1226	111
115°	166	220	519	963	1147	165
125°	224	264	486	801	903	200
135°	262	311	452	684	781	203
145°	300	342	436	553	613	188
155°	339	366	424	480	500	157
165°	370	381	406	430	436	104
175°	386	386	390	395	393	37
180°	386	386	386	386	386	

TEST NUMBER: P1025241

CATALOG NUMBER: S124DIP-B1195D810UB40-4F0-XX-W2A-D4

CANDELA DISTRIBUTION (FULL):

	0°	22.5°	45°	67.5°	90°
0°	1421.1	1421.1	1421.1	1421.1	1421.1
2.5°	1427.4	1422.7	1409.9	1421.1	1419.5
5°	1422.7	1417.9	1406.7	1419.5	1417.9
7.5°	1413.1	1409.9	1400.4	1414.7	1413.1
10°	1400.4	1398.8	1390.8	1405.2	1403.6
12.5°	1382.9	1382.9	1378.1	1390.8	1390.8
15°	1363.8	1365.4	1360.6	1374.9	1373.3
17.5°	1338.3	1343.1	1341.5	1355.8	1354.2
20°	1311.3	1316.0	1317.6	1333.5	1333.5
22.5°	1281.0	1287.4	1290.6	1306.5	1309.7
25°	1247.6	1257.2	1261.9	1279.4	1281.0
27.5°	1211.0	1225.3	1231.7	1247.6	1249.2
30°	1174.4	1187.1	1198.3	1215.8	1219.0
32.5°	1134.6	1150.5	1163.3	1184.0	1187.1
35°	1091.7	1110.8	1126.7	1148.9	1153.7
37.5°	1048.7	1071.0	1090.1	1112.3	1117.1
40°	1007.3	1028.0	1050.3	1074.2	1080.5
42.5°	959.6	983.4	1010.5	1037.6	1042.3
45°	910.2	940.5	970.7	997.8	1005.7
47.5°	864.1	894.3	929.3	956.4	965.9
50°	813.2	848.2	883.2	915.0	924.6
52.5°	762.3	797.3	838.6	870.5	880.0
55°	712.9	746.3	794.1	825.9	835.5
57.5°	657.2	698.6	744.7	782.9	790.9
60°	603.1	644.5	697.0	733.6	746.3
62.5°	550.6	596.8	649.3	685.9	698.6
65°	493.3	544.2	598.3	638.1	650.9
67.5°	439.2	493.3	550.6	590.4	603.1
70°	383.5	437.6	498.1	541.1	552.2
72.5°	329.4	385.1	450.3	491.7	504.5
75°	273.7	332.6	399.4	444.0	458.3
77.5°	221.2	283.3	353.3	397.8	413.7
80°	173.5	237.1	307.1	354.9	367.6
82.5°	125.7	192.6	262.6	311.9	326.2
85°	84.3	151.2	222.8	270.5	286.4
87.5°	52.5	117.8	187.8	233.9	248.2
90°	26.3	95.2	171.2	218.9	232.3
92.5°	34.5	138.0	445.6	290.9	274.4
95°	45.8	152.2	757.1	487.8	380.9
97.5°	60.9	152.5	792.5	797.5	631.1
100°	75.2	157.6	731.3	1029.4	871.2
102.5°	90.4	164.8	658.9	1170.2	1081.9
105°	103.1	174.8	603.0	1217.1	1225.7
107.5°	120.6	186.8	564.0	1192.2	1289.1
110°	136.4	197.0	543.2	1121.8	1282.6

TEST NUMBER: P1025241

CATALOG NUMBER: S124DIP-B1195D810UB40-4F0-XX-W2A-D4

CANDELA DISTRIBUTION (continued):

	0°	22.5°	45°	67.5°	90°
112.5°	151.6	209.0	528.3	1038.0	1228.3
115°	165.9	220.2	518.9	963.1	1146.6
117.5°	182.6	231.6	510.2	901.2	1068.1
120°	197.8	241.2	502.3	856.4	1000.8
122.5°	213.0	252.0	493.5	825.2	945.7
125°	224.3	263.7	486.5	801.0	902.7
127.5°	236.4	277.3	476.9	775.8	873.6
130°	244.7	289.0	468.2	749.3	845.7
132.5°	254.6	300.4	461.1	719.3	817.3
135°	262.1	311.4	452.4	684.3	781.2
137.5°	271.2	319.3	446.1	649.0	740.5
140°	281.1	328.1	440.5	614.6	698.4
142.5°	290.1	336.0	437.3	583.5	654.0
145°	300.0	341.6	435.8	553.1	613.4
147.5°	311.4	348.5	433.5	526.6	575.1
150°	322.0	354.9	431.2	507.9	542.1
152.5°	330.3	361.0	427.4	493.5	519.3
155°	339.4	366.3	423.6	479.8	500.3
157.5°	348.5	371.2	419.8	466.9	482.8
160°	356.8	375.4	415.3	454.0	466.9
162.5°	364.4	378.8	410.7	441.4	451.7
165°	369.7	381.1	406.2	430.1	436.5
167.5°	375.8	383.0	401.6	420.2	424.4
170°	379.6	384.5	397.1	410.4	413.0
172.5°	383.4	385.6	392.5	401.6	401.6
175°	385.7	386.4	389.5	394.8	393.3
177.5°	387.2	386.4	387.2	389.8	387.2
180°	386.4	386.4	386.4	386.4	386.4

(END OF REPORT)