

Scaled data based on original data using
LM-79-2019 Approved Method: Electrical and Photometric Measurements of Solid-
State Lighting Products

Test Report Prepared for
Cooper Lighting Solutions

Brand: NEO-RAY

Report Number: P1025243

Luminaire Tested: S124DIP-B1195D810UB40-4F0-XX-W2A-F1

Issue Date: 5/6/2025

Test Information

Test Method: LM-79-2019
Report Number: P1025243
REPORT IS A COMBINATION OF REPORTS P995708 AND P1007351
Test Lab: INNOVATION CENTER
Issue Date: 5/6/2025
Manufacturer: COOPER LIGHTING SOLUTIONS
Product Line: NEO-RAY
Catalog Number: S124DIP-B1195D810UB40-4F0-XX-W2A-F1
Description: Define 4 Direct/Indirect Pendant with 4000K BioUP LEDs {m-DER=0.865} {m-EER=0.951}
Light Source: -
Ballast/Driver: -

Summary


Lumens per Lamp: N/A
Luminaire Lumens: 7823.0 lumens
Efficiency: N/A
Efficacy: 94.9 lumens/watt
Spacing Criteria (0/90/45): 1.2 / 1.17 / 1.29
Luminous Opening: Rectangular w/ Sides (W: 0.33' x L: 4' x H: 0.1')
CIE Type: Semi-Direct

Input Watts (W): 82.4
Input Voltage (V):
Input Current (Ain): NR
Voltage Rise (V): NR
Power Factor: NR
Total Harmonic Distortion (THDi): NR
Frequency (hertz): 60
Stabilization Time: NR
Operation Time: NR
Ambient Temperature (°C): NR
Test Distance: 24 FT

TEST NUMBER: P1025243

CATALOG NUMBER: S124DIP-B1195D810UB40-4F0-XX-W2A-F1

Luminous Intensity Polar Plot



TEST NUMBER: P1025243

CATALOG NUMBER: S124DIP-B1195D810UB40-4F0-XX-W2A-F1

COEFFICIENT OF UTILIZATION - ZONAL CAVITY METHOD:

RF	20				20				20				20				20
RC	80				70				50				30				10
RW	70	50	30	10	70	50	30	10	50	30	10		50	30	10		50
RCR																	
0	111	111	111	111	104	104	104	104	92	92	92		80	80	80		70
1	101	97	93	89	95	91	88	84	81	78	75		71	69	67		62
2	92	84	78	73	86	80	74	69	71	66	62		62	59	56		54
3	84	74	67	61	79	70	63	58	62	57	53		55	51	47		48
4	77	66	58	51	72	62	55	49	55	50	45		49	44	41		43
5	71	59	50	44	66	56	48	42	50	43	39		44	39	35		39
6	65	53	44	38	61	50	42	37	45	39	34		40	35	31		35
7	60	48	40	34	57	45	38	33	41	34	30		36	31	27		32
8	56	43	35	30	53	41	34	29	37	31	27		33	28	25		30
9	52	40	32	27	49	38	31	26	34	28	24		31	26	22		27
10	49	37	29	24	46	35	28	23	32	26	22		28	24	20		25

AVERAGE LUMINANCE (cd/sqm):

	0°	45°	90°
0°	16193	16193	16193
5°	16206	15728	15747
10°	16069	15291	15184
15°	15839	14772	14549
20°	15545	14210	13892
25°	15213	13617	13184
30°	14814	12976	12407
35°	14400	12318	11656
40°	13969	11612	10857
45°	13517	10904	10111
50°	13016	10216	9284
55°	12472	9414	8463
60°	11915	8534	7608
65°	11277	7627	6644
70°	10544	6534	5610
75°	9446	5267	4493
80°	8049	3809	3161
85°	6251	2119	1702

MAXIMUM LUMINANCE 45°-90°:

Horizontal Angle: 0°

Vertical Angle: 45°

Luminance: 13517 cd/sqm

TEST NUMBER: P1025243

CATALOG NUMBER: S124DIP-B1195D810UB40-4F0-XX-W2A-F1

ZONAL LUMENS:

Zone	Lumens	% Fixture
0°-10°	187.2	2.4
10°-20°	527.3	6.7
20°-30°	776.1	9.9
30°-40°	902.1	11.5
40°-50°	902.1	11.5
50°-60°	789.0	10.1
60°-70°	585.7	7.5
70°-80°	332.3	4.2
80°-90°	97.3	1.2
90°-100°	64.0	0.8
100°-110°	191.7	2.5
110°-120°	325.6	4.2
120°-130°	429.4	5.5
130°-140°	482.3	6.2
140°-150°	474.0	6.1
150°-160°	398.7	5.1
160°-170°	265.3	3.4
170°-180°	92.9	1.2
0°-30°	1490.6	19.1
0°-40°	2392.7	30.6
0°-60°	4083.7	52.2
0°-90°	5099.1	65.2
90°-120°	581.3	7.4
90°-150°	1967.0	25.1
90°-180°	2724.0	34.8
0°-180°	7823.0	100.0

CANDELA DISTRIBUTION:

	0°	22.5°	45°	67.5°	90°	Flux
0°	1986	1986	1986	1986	1986	
5°	1984	1978	1960	1978	1975	188
15°	1889	1882	1858	1868	1863	532
25°	1710	1699	1677	1679	1672	787
35°	1472	1461	1438	1427	1419	920
45°	1201	1190	1165	1147	1142	926
55°	909	904	882	862	853	814
65°	616	608	592	576	568	609
75°	328	320	312	306	304	348
85°	86	86	83	83	81	92
90°	2	11	17	21	23	9
95°	46	52	58	60	60	49
105°	177	178	181	183	185	188
115°	331	331	330	329	328	326
125°	482	482	481	480	478	430
135°	622	626	626	625	623	481
145°	756	758	759	758	756	473
155°	866	866	865	868	865	398
165°	942	940	938	943	940	266
175°	980	976	976	981	976	93
180°	982	982	982	982	982	

TEST NUMBER: P1025243

CATALOG NUMBER: S124DIP-B1195D810UB40-4F0-XX-W2A-F1

CANDELA DISTRIBUTION (FULL):

	0°	22.5°	45°	67.5°	90°
0°	1985.8	1985.8	1985.8	1985.8	1985.8
2.5°	1992.2	1987.4	1969.9	1985.8	1984.2
5°	1984.2	1977.9	1960.4	1977.9	1974.7
7.5°	1969.9	1963.5	1944.5	1958.8	1957.2
10°	1949.2	1942.9	1922.2	1934.9	1931.7
12.5°	1922.2	1915.8	1893.5	1907.9	1903.1
15°	1888.8	1882.4	1858.5	1868.1	1863.3
17.5°	1850.6	1842.6	1820.3	1826.7	1823.5
20°	1807.6	1799.7	1775.8	1780.6	1777.4
22.5°	1761.5	1750.3	1726.5	1736.0	1729.6
25°	1710.5	1699.4	1677.1	1678.7	1672.4
27.5°	1653.3	1642.1	1621.4	1618.3	1610.3
30°	1596.0	1583.2	1562.6	1556.2	1548.2
32.5°	1535.5	1524.4	1502.1	1494.1	1486.2
35°	1471.9	1460.7	1438.4	1427.3	1419.4
37.5°	1405.0	1395.5	1371.6	1360.5	1349.3
40°	1339.8	1327.1	1303.2	1287.3	1279.3
42.5°	1269.8	1263.4	1236.4	1217.3	1212.5
45°	1201.4	1190.2	1164.8	1147.3	1142.5
47.5°	1129.8	1121.8	1097.9	1078.8	1066.1
50°	1056.6	1050.2	1027.9	1005.6	996.1
52.5°	985.0	977.0	953.1	934.0	921.3
55°	908.6	903.8	881.5	862.4	852.9
57.5°	837.0	832.2	809.9	790.8	781.3
60°	762.2	754.2	733.5	719.2	711.3
62.5°	689.0	682.6	660.3	647.6	639.7
65°	615.8	607.8	591.9	576.0	568.1
67.5°	541.0	534.6	518.7	502.8	501.2
70°	472.6	461.4	448.7	436.0	431.2
72.5°	399.4	388.3	378.7	369.2	364.4
75°	327.8	319.8	311.9	305.5	303.9
77.5°	257.8	254.6	246.6	245.0	240.3
80°	195.7	190.9	187.8	184.6	183.0
82.5°	135.3	133.7	133.7	132.1	130.5
85°	85.9	85.9	82.7	82.7	81.2
87.5°	41.4	39.8	38.2	38.2	38.2
90°	2.3	10.6	16.7	21.3	22.8
92.5°	19.7	29.6	33.4	35.7	36.4
95°	45.6	52.4	57.7	60.0	60.0
97.5°	72.9	79.0	85.0	88.1	88.1
100°	106.3	109.3	116.2	117.7	117.7
102.5°	141.2	142.0	148.1	150.3	151.1
105°	176.9	177.7	180.7	183.0	185.3
107.5°	214.1	214.9	215.6	218.7	217.9
110°	252.1	253.6	252.8	251.3	253.6

TEST NUMBER: P1025243

CATALOG NUMBER: S124DIP-B1195D810UB40-4F0-XX-W2A-F1

CANDELA DISTRIBUTION (continued):

	0°	22.5°	45°	67.5°	90°
112.5°	291.6	291.6	290.0	290.0	290.0
115°	331.0	331.0	329.5	328.8	328.0
117.5°	368.2	368.2	367.5	365.2	362.9
120°	405.4	408.5	406.2	402.4	403.9
122.5°	444.2	444.9	444.2	441.9	438.1
125°	482.1	482.1	481.4	479.8	478.3
127.5°	516.3	518.6	517.1	515.5	514.8
130°	552.7	555.0	555.0	553.5	550.5
132.5°	589.9	591.5	590.7	589.2	588.4
135°	621.8	626.4	626.4	624.9	622.6
137.5°	657.5	659.8	661.3	659.0	659.8
140°	693.2	694.7	694.7	694.0	693.2
142.5°	725.8	727.4	726.6	726.6	726.6
145°	755.5	758.5	759.3	758.5	756.2
147.5°	785.8	789.6	788.9	788.1	787.3
150°	813.2	816.2	816.2	816.2	815.4
152.5°	839.0	840.5	841.3	843.5	841.3
155°	865.6	865.6	864.8	867.8	864.8
157.5°	888.3	886.8	886.8	889.1	886.8
160°	908.1	907.3	906.5	908.8	905.0
162.5°	926.3	924.0	923.3	927.8	924.0
165°	942.2	940.0	938.4	943.0	940.0
167.5°	955.1	952.1	952.1	956.7	952.1
170°	965.8	962.0	962.7	967.3	962.0
172.5°	973.4	970.3	970.3	975.6	970.3
175°	980.2	976.4	975.6	981.0	975.6
177.5°	983.2	979.4	979.4	984.8	978.7
180°	981.7	981.7	981.7	981.7	981.7

(END OF REPORT)