

Scaled data based on original data using
LM-79-2019 Approved Method: Electrical and Photometric Measurements of Solid-
State Lighting Products

Test Report Prepared for
Cooper Lighting Solutions

Brand: NEO-RAY

Report Number: P1025751

Luminaire Tested: S124DIP-B795D1205UB27-4F0-XX-W2A-A4

Issue Date: 5/7/2025

Test Information

Test Method: LM-79-2019
Report Number: P1025751
REPORT IS A COMBINATION OF REPORTS P996381 AND P1007351
Test Lab: INNOVATION CENTER
Issue Date: 5/7/2025
Manufacturer: COOPER LIGHTING SOLUTIONS
Product Line: NEO-RAY
Catalog Number: S124DIP-B795D1205UB27-4F0-XX-W2A-A4
Description: Define 4 Direct/Indirect Pendant with 2700K BioUP LEDs {m-DER=0.473} {m-EER=0.52}
Light Source: -
Ballast/Driver: -

Summary


Lumens per Lamp: N/A
Luminaire Lumens: 7801.0 lumens
Efficiency: N/A
Efficacy: 110.0 lumens/watt
Spacing Criteria (0/90/45): 1.22 / 1.3 / 1.41
Luminous Opening: Rectangular w/ Sides (W: 0.33' x L: 4' x H: 0.1')
CIE Type: General Diffuse

Input Watts (W): 70.9
Input Voltage (V):
Input Current (A_{in}): NR
Voltage Rise (V): NR
Power Factor: NR
Total Harmonic Distortion (THDi): NR
Frequency (hertz): 60
Stabilization Time: NR
Operation Time: NR
Ambient Temperature (°C): NR
Test Distance: 24 FT

TEST NUMBER: P1025751

CATALOG NUMBER: S124DIP-B795D1205UB27-4F0-XX-W2A-A4

Luminous Intensity Polar Plot



TEST NUMBER: P1025751

CATALOG NUMBER: S124DIP-B795D1205UB27-4F0-XX-W2A-A4

COEFFICIENT OF UTILIZATION - ZONAL CAVITY METHOD:

RF	20				20				20				20				20
RC	80				70				50				30				10
RW	70	50	30	10	70	50	30	10	50	30	10	50	30	10	50	30	10
RCR																	
0	106	106	106	106	97	97	97	97	81	81	81	66	66	66	52	52	52
1	97	93	89	85	89	85	82	79	71	69	67	58	56	55	46	45	44
2	88	81	75	70	81	75	70	65	62	59	55	51	49	46	41	39	37
3	81	72	64	59	74	66	60	55	55	51	47	45	42	39	36	34	32
4	74	63	56	50	68	58	52	46	49	44	40	41	37	34	33	30	28
5	68	57	49	43	62	52	45	40	44	39	35	37	33	29	29	27	24
6	63	51	43	37	57	47	40	35	40	34	30	33	29	26	27	24	22
7	58	46	38	33	53	42	36	31	36	31	27	30	26	23	24	21	19
8	54	42	34	29	49	39	32	27	33	28	24	28	23	20	22	19	17
9	50	38	31	26	46	35	29	24	30	25	21	25	21	18	21	18	16
10	47	35	28	23	43	32	26	22	28	23	19	23	19	17	19	16	14

AVERAGE LUMINANCE (cd/sqm):

	0°	90°	180°	270°
0°	10434	10434	10434	10434
5°	10408	11971	10469	8995
10°	10330	13966	10410	7892
15°	10207	16100	10277	7061
20°	10074	17459	10147	6331
25°	9881	17259	9975	5792
30°	9693	14265	9811	5514
35°	9428	10631	9532	5345
40°	9119	8007	9207	5264
45°	8647	6427	8755	5151
50°	8084	5415	8202	5098
55°	7422	4713	7539	5039
60°	6778	4150	6977	4955
65°	6173	3571	6232	4748
70°	5464	2938	5582	4373
75°	4766	2258	4735	3716
80°	3751	1484	3706	2821
85°	2467	667	2314	1645

MAXIMUM LUMINANCE 45°-90°:

Horizontal Angle: 145°

Vertical Angle: 45°

Luminance: 13492 cd/sqm

TEST NUMBER: P1025751

CATALOG NUMBER: S124DIP-B795D1205UB27-4F0-XX-W2A-A4

ZONAL LUMENS:

Zone	Lumens	% Fixture
0°-10°	124.5	1.6
10°-20°	384.4	4.9
20°-30°	610.7	7.8
30°-40°	678.5	8.7
40°-50°	617.1	7.9
50°-60°	504.3	6.5
60°-70°	359.9	4.6
70°-80°	198.1	2.5
80°-90°	55.8	0.7
90°-100°	424.7	5.4
100°-110°	886.6	11.4
110°-120°	788.1	10.1
120°-130°	663.4	8.5
130°-140°	553.5	7.1
140°-150°	422.6	5.4
150°-160°	297.1	3.8
160°-170°	174.7	2.2
170°-180°	56.8	0.7
0°-30°	1119.6	14.4
0°-40°	1798.1	23.1
0°-60°	2919.5	37.4
0°-90°	3533.3	45.3
90°-120°	2099.4	26.9
90°-150°	3739.0	47.9
90°-180°	4268.0	54.7
0°-180°	7801.0	100.0

CANDELA DISTRIBUTION:

	0°	90°	180°	270°	360°	Flux
0°	1280	1280	1280	1280	1280	
5°	1274	1501	1282	1128	1274	121
15°	1217	2062	1226	904	1217	343
25°	1111	2189	1122	735	1111	512
35°	964	1294	974	651	964	602
45°	769	726	778	582	769	593
55°	541	475	549	508	541	486
65°	337	305	340	406	337	333
75°	165	153	164	251	165	174
85°	34	32	32	78	34	39
90°	1	24	1	24	1	5
95°	38	281	38	281	38	42
105°	135	1620	135	1620	135	143
115°	237	1555	237	1555	237	235
125°	330	1241	330	1241	330	294
135°	393	1110	393	1110	393	303
145°	452	906	452	906	452	284
155°	515	759	515	759	515	237
165°	561	662	561	662	561	158
175°	585	596	585	596	585	56
180°	586	586	586	586	586	

TEST NUMBER: P1025751

CATALOG NUMBER: S124DIP-B795D1205UB27-4F0-XX-W2A-A4

CANDELA DISTRIBUTION (FULL):

	0°	5°	10°	15°	20°	22.5°	25°	30°	35°	40°	45°
0°	1279.6	1279.6	1279.6	1279.6	1279.6	1279.6	1279.6	1279.6	1279.6	1279.6	1279.6
2.5°	1279.6	1292.3	1297.6	1301.9	1315.7	1319.9	1321.0	1327.3	1332.6	1333.7	1333.7
5°	1274.3	1294.5	1310.4	1325.2	1347.5	1357.0	1368.7	1381.4	1398.4	1409.0	1414.3
7.5°	1265.8	1295.5	1319.9	1345.3	1376.1	1395.2	1405.8	1439.7	1463.0	1482.1	1505.4
10°	1253.1	1291.3	1326.3	1363.4	1406.8	1430.2	1453.5	1494.8	1527.7	1564.8	1594.5
12.5°	1234.0	1283.9	1326.3	1378.2	1432.3	1459.8	1487.4	1559.5	1597.7	1630.5	1683.5
15°	1217.1	1266.9	1327.3	1380.3	1447.1	1488.5	1528.8	1575.4	1635.8	1706.9	1757.7
17.5°	1198.0	1260.5	1316.7	1390.9	1465.1	1504.4	1537.2	1609.3	1694.1	1764.1	1810.8
20°	1171.5	1235.1	1309.3	1387.7	1475.7	1506.5	1550.0	1646.4	1722.8	1791.7	1868.0
22.5°	1140.7	1214.9	1293.4	1368.7	1459.8	1524.5	1572.2	1657.0	1749.3	1828.8	1914.6
25°	1111.0	1191.6	1260.5	1363.4	1459.8	1503.3	1557.4	1658.1	1758.8	1855.3	1943.3
27.5°	1079.2	1154.5	1247.8	1329.4	1438.6	1486.3	1544.7	1654.9	1762.0	1858.5	1952.8
30°	1044.3	1124.8	1202.2	1298.7	1404.7	1466.2	1520.3	1640.1	1749.3	1850.0	1938.0
32.5°	1005.0	1081.4	1164.1	1255.2	1366.5	1429.1	1496.9	1619.9	1736.5	1823.5	1891.3
35°	963.7	1041.1	1113.2	1206.5	1321.0	1383.5	1449.2	1584.9	1700.5	1771.5	1810.8
37.5°	918.1	991.2	1062.3	1154.5	1269.0	1335.8	1402.6	1534.1	1643.2	1702.6	1692.0
40°	874.6	940.4	1006.1	1093.0	1212.8	1283.9	1342.2	1474.7	1570.1	1595.5	1560.6
42.5°	824.8	881.0	944.6	1033.7	1150.3	1217.1	1290.2	1411.1	1482.1	1471.5	1412.1
45°	768.6	818.4	882.1	965.8	1084.5	1153.5	1214.9	1329.4	1381.4	1354.9	1246.7
47.5°	714.5	763.3	815.3	899.0	1014.6	1072.9	1135.4	1238.3	1268.0	1211.8	1103.6
50°	656.2	696.5	750.6	830.1	938.2	999.7	1051.7	1134.4	1145.0	1076.1	963.7
52.5°	600.1	634.0	685.9	764.4	865.1	913.9	964.7	1037.9	1029.4	958.4	850.2
55°	540.7	572.5	620.2	692.3	781.3	828.0	871.5	936.1	918.1	844.9	750.6
57.5°	490.9	513.1	559.8	626.6	699.7	750.6	787.7	838.6	811.0	737.9	649.9
60°	433.6	461.2	500.4	554.5	626.6	660.5	693.3	727.3	708.2	638.2	559.8
62.5°	381.7	402.9	436.8	488.7	544.9	575.7	610.7	631.9	612.8	548.1	482.4
65°	337.1	354.1	380.6	423.0	477.1	502.5	522.7	542.8	526.9	466.5	418.8
67.5°	288.4	303.2	325.5	359.4	405.0	423.0	442.1	455.9	437.8	397.6	350.9
70°	244.9	255.5	276.7	302.1	334.0	350.9	366.8	380.6	364.7	330.8	295.8
72.5°	200.4	208.9	227.9	246.0	274.6	286.2	297.9	308.5	303.2	271.4	242.8
75°	165.4	168.6	181.3	196.1	214.2	226.9	235.4	241.7	237.5	212.0	194.0
77.5°	125.1	129.3	138.9	150.5	166.4	173.9	179.2	185.5	180.2	160.1	147.4
80°	91.2	92.2	97.5	108.1	118.7	119.8	125.1	133.6	130.4	116.6	107.1
82.5°	58.3	61.5	63.6	70.0	77.4	79.5	82.7	84.8	83.8	75.3	72.1
85°	33.9	33.9	36.0	40.3	42.4	45.6	46.6	47.7	49.8	44.5	41.3
87.5°	14.8	15.9	15.9	17.0	19.1	19.1	20.1	21.2	22.3	21.2	18.0
90°	1.2	3.5	6.9	8.1	9.2	9.2	9.2	16.1	16.1	18.4	20.7
92.5°	16.1	23.0	35.7	53.0	73.7	88.6	103.6	175.0	286.6	394.9	451.3
95°	38.0	41.4	53.0	67.9	95.5	119.7	143.9	244.1	432.9	708.0	938.2
97.5°	63.3	63.3	73.7	87.5	111.7	132.4	153.1	232.5	394.9	678.1	1003.8
100°	87.5	87.5	95.5	109.4	131.2	149.6	168.1	236.0	366.1	600.9	925.6
102.5°	110.5	112.8	119.7	132.4	153.1	170.4	187.6	247.5	358.0	549.1	827.7
105°	134.7	138.1	143.9	157.7	178.4	195.1	211.8	267.1	362.6	523.8	755.2
107.5°	161.2	163.5	169.2	184.2	203.8	220.4	237.1	287.8	376.4	516.9	708.0
110°	187.6	189.9	195.7	209.5	230.2	245.8	261.3	312.0	392.6	519.2	686.1

TEST NUMBER: P1025751

CATALOG NUMBER: S124DIP-B795D1205UB27-4F0-XX-W2A-A4

CANDELA DISTRIBUTION (continued):

	0°	5°	10°	15°	20°	22.5°	25°	30°	35°	40°	45°
112.5°	213.0	215.3	222.2	234.8	255.6	271.1	286.6	335.0	409.8	526.1	675.8
115°	237.1	240.6	248.7	260.2	282.0	297.6	313.1	359.2	428.2	535.3	673.5
117.5°	262.5	265.9	272.8	285.5	306.2	322.4	338.5	382.2	446.7	544.5	672.3
120°	287.8	290.1	298.2	310.8	330.4	346.5	362.6	406.4	466.2	554.9	672.3
122.5°	310.8	313.1	321.2	332.7	354.6	370.2	385.7	429.4	484.7	565.2	671.1
125°	330.4	335.0	341.9	354.6	376.4	392.5	408.7	450.1	503.1	575.6	670.0
127.5°	348.8	352.3	360.3	374.1	397.2	413.3	429.4	469.7	519.2	583.7	667.7
130°	363.8	368.4	377.6	394.9	416.7	433.4	450.1	489.3	534.2	592.9	666.5
132.5°	378.7	382.2	394.9	411.0	435.2	450.7	466.2	505.4	549.1	600.9	665.4
135°	392.6	397.2	408.7	428.2	452.4	467.4	482.4	520.3	561.8	609.0	664.2
137.5°	406.4	411.0	423.6	442.1	467.4	481.8	496.2	531.9	571.0	613.6	664.2
140°	421.3	424.8	437.5	457.0	481.2	495.0	508.8	543.4	580.2	619.3	663.1
142.5°	437.5	440.9	452.4	470.8	493.9	507.1	520.3	553.7	587.1	623.9	663.1
145°	452.4	455.9	467.4	483.5	505.4	518.0	530.7	560.6	591.7	625.1	660.8
147.5°	469.7	470.8	481.2	498.5	516.9	528.4	539.9	568.7	596.3	626.3	657.3
150°	485.8	487.0	496.2	510.0	527.2	538.2	549.1	574.4	599.8	626.3	653.9
152.5°	500.8	500.8	510.0	522.6	537.6	547.4	557.2	579.1	602.1	623.9	648.1
155°	514.6	515.7	522.6	534.2	546.8	555.4	564.1	583.7	603.2	621.6	642.4
157.5°	528.4	528.4	535.3	544.5	556.0	562.9	569.8	587.1	603.2	619.3	636.6
160°	541.1	541.1	545.7	553.7	562.9	569.2	575.6	589.4	603.2	615.9	629.7
162.5°	552.6	551.4	554.9	561.8	569.8	574.4	579.1	591.7	603.2	612.4	622.8
165°	560.6	560.6	562.9	568.7	574.4	577.9	581.4	591.7	600.9	607.8	615.9
167.5°	569.8	568.7	569.8	574.4	577.9	580.8	583.7	591.7	598.6	603.2	609.0
170°	575.6	574.4	575.6	579.1	581.4	583.1	584.8	590.6	596.3	598.6	602.1
172.5°	581.4	580.2	580.2	582.5	583.7	584.8	586.0	589.4	594.0	594.0	595.2
175°	584.8	583.7	583.7	584.8	586.0	586.0	586.0	588.3	591.7	590.6	590.6
177.5°	587.1	586.0	584.8	586.0	586.0	586.0	586.0	587.1	589.4	587.1	587.1
180°	586.0	586.0	586.0	586.0	586.0	586.0	586.0	586.0	586.0	586.0	586.0

TEST NUMBER: P1025751

CATALOG NUMBER: S124DIP-B795D1205UB27-4F0-XX-W2A-A4

CANDELA DISTRIBUTION (continued):

	50°	55°	60°	65°	67.5°	70°	75°	80°	85°	90°	95°
0°	1279.6	1279.6	1279.6	1279.6	1279.6	1279.6	1279.6	1279.6	1279.6	1279.6	1279.6
2.5°	1336.9	1355.9	1364.4	1366.5	1378.2	1370.8	1374.0	1372.9	1381.4	1382.4	1382.4
5°	1434.4	1456.7	1464.1	1474.7	1490.6	1494.8	1491.6	1498.0	1509.7	1501.2	1513.9
7.5°	1537.2	1561.6	1578.6	1601.9	1607.2	1621.0	1629.5	1636.9	1639.0	1640.1	1642.2
10°	1632.6	1663.4	1686.7	1725.9	1734.4	1741.8	1778.9	1764.1	1783.2	1776.8	1778.9
12.5°	1710.0	1770.5	1789.6	1855.3	1861.6	1887.1	1885.0	1908.3	1912.5	1921.0	1912.5
15°	1811.8	1881.8	1912.5	1949.6	1970.8	2000.5	2005.8	2037.6	2050.3	2062.0	2050.3
17.5°	1905.1	1942.2	2020.7	2050.3	2064.1	2080.0	2120.3	2132.0	2151.1	2143.6	2164.8
20°	1951.8	2004.8	2087.5	2138.3	2159.5	2174.4	2208.3	2226.3	2233.8	2233.8	2235.9
22.5°	1993.1	2069.4	2130.9	2189.2	2208.3	2218.9	2239.1	2252.8	2256.0	2258.1	2260.3
25°	2030.2	2099.1	2148.9	2181.8	2189.2	2189.2	2200.9	2192.4	2178.6	2189.2	2195.6
27.5°	2030.2	2079.0	2101.2	2112.9	2112.9	2084.3	2067.3	2032.3	2002.6	1994.2	2013.2
30°	1996.3	2018.5	1987.8	1959.2	1936.9	1917.8	1851.0	1798.0	1787.4	1780.0	1808.6
32.5°	1917.8	1889.2	1828.8	1746.1	1713.2	1669.8	1617.8	1577.5	1553.1	1544.7	1538.3
35°	1778.9	1704.7	1626.3	1515.0	1491.6	1436.5	1365.5	1335.8	1295.5	1294.5	1308.2
37.5°	1627.3	1512.8	1428.0	1322.0	1289.2	1230.8	1164.1	1133.3	1105.7	1084.5	1110.0
40°	1450.3	1350.6	1221.3	1134.4	1087.7	1057.0	1000.8	966.9	954.1	943.5	959.4
42.5°	1284.9	1175.7	1075.0	985.9	947.8	912.8	875.7	842.8	833.3	832.2	843.9
45°	1120.6	1013.5	920.2	843.9	819.5	798.3	762.3	752.7	736.8	726.2	731.5
47.5°	989.1	878.9	801.5	743.2	722.0	703.9	680.6	664.7	650.9	646.7	653.1
50°	859.8	785.6	706.1	657.3	641.4	624.4	606.4	591.6	585.2	581.0	585.2
52.5°	755.9	676.4	622.3	583.1	567.2	554.5	541.7	535.4	526.9	529.0	533.3
55°	662.6	592.6	547.0	518.4	508.9	503.6	487.7	480.3	477.1	475.0	477.1
57.5°	574.6	523.7	489.8	465.4	452.7	449.5	436.8	436.8	433.6	430.4	431.5
60°	504.6	461.2	428.3	409.2	407.1	401.8	393.3	392.3	384.8	388.0	389.1
62.5°	433.6	398.6	376.4	364.7	357.3	355.2	349.9	348.8	345.6	346.7	344.6
65°	377.4	348.8	326.5	317.0	313.8	312.7	308.5	305.3	303.2	305.3	303.2
67.5°	321.2	302.1	285.2	275.6	271.4	270.3	267.2	265.0	266.1	262.9	265.0
70°	268.2	249.1	238.5	233.2	231.1	227.9	227.9	227.9	227.9	225.8	224.8
72.5°	225.8	206.7	199.3	196.1	194.0	192.9	189.8	190.8	189.8	188.7	192.9
75°	179.2	167.5	160.1	156.9	159.0	155.8	152.7	154.8	151.6	152.7	156.9
77.5°	135.7	130.4	126.2	124.0	121.9	119.8	119.8	117.7	117.7	117.7	117.7
80°	98.6	97.5	90.1	89.1	89.1	86.9	86.9	86.9	86.9	85.9	86.9
82.5°	65.7	64.7	62.5	61.5	59.4	60.4	60.4	58.3	58.3	57.2	58.3
85°	38.2	38.2	36.0	35.0	33.9	35.0	32.9	31.8	32.9	31.8	32.9
87.5°	18.0	15.9	17.0	15.9	13.8	14.8	12.7	13.8	12.7	11.7	13.8
90°	19.6	20.7	21.9	23.0	23.0	23.0	24.2	25.3	24.2	24.2	24.2
92.5°	375.3	277.4	207.2	163.5	149.1	134.7	117.4	109.4	104.8	104.8	104.8
95°	964.7	853.0	674.6	520.3	464.5	408.7	352.3	316.6	295.9	280.9	295.9
97.5°	1209.9	1228.3	1139.7	1013.1	948.6	884.1	805.8	736.8	702.2	674.6	702.2
100°	1220.3	1388.3	1411.4	1355.0	1312.4	1269.8	1169.6	1099.4	1064.9	1055.6	1064.9
102.5°	1133.9	1380.3	1517.3	1551.8	1540.3	1528.8	1477.0	1430.9	1394.1	1387.2	1394.1
105°	1025.7	1289.3	1488.5	1602.5	1626.1	1649.7	1652.0	1642.8	1626.6	1619.7	1626.6
107.5°	937.1	1177.7	1392.9	1551.8	1600.2	1648.5	1699.2	1719.9	1729.1	1730.3	1729.1
110°	873.8	1078.7	1277.8	1444.8	1508.1	1571.4	1653.1	1701.5	1722.2	1732.6	1722.2

TEST NUMBER: P1025751

CATALOG NUMBER: S124DIP-B795D1205UB27-4F0-XX-W2A-A4

CANDELA DISTRIBUTION (continued):

	50°	55°	60°	65°	67.5°	70°	75°	80°	85°	90°	95°
112.5°	838.1	1006.1	1176.5	1331.9	1395.2	1458.6	1554.1	1615.1	1646.2	1664.6	1646.2
115°	818.5	962.4	1104.0	1238.7	1294.0	1349.2	1440.1	1509.2	1546.1	1555.3	1546.1
117.5°	808.1	937.1	1056.8	1166.2	1214.6	1262.9	1343.4	1403.3	1442.5	1448.2	1442.5
120°	800.1	921.0	1028.0	1120.1	1161.0	1201.9	1267.5	1318.1	1348.1	1360.7	1348.1
122.5°	790.9	907.1	1009.6	1091.3	1125.8	1160.4	1213.4	1254.8	1279.0	1291.6	1279.0
125°	780.5	891.0	990.0	1069.5	1101.2	1132.8	1178.8	1212.2	1234.1	1241.0	1234.1
127.5°	766.7	872.6	968.2	1047.6	1077.6	1107.5	1153.5	1183.4	1201.9	1208.8	1201.9
130°	754.0	849.6	940.5	1018.8	1049.3	1079.8	1127.0	1155.8	1174.2	1181.1	1174.2
132.5°	742.5	825.4	909.4	985.4	1015.9	1046.4	1092.5	1125.9	1143.1	1150.0	1143.1
135°	731.0	803.5	878.4	948.6	977.4	1006.1	1052.2	1084.4	1102.8	1109.8	1102.8
137.5°	720.7	782.8	848.4	909.4	935.9	962.4	1006.1	1039.5	1054.5	1062.6	1054.5
140°	712.6	765.5	819.7	871.5	895.6	919.8	960.1	985.4	1001.5	1010.8	1001.5
142.5°	705.7	749.4	795.5	838.1	858.2	878.4	912.9	935.9	949.7	955.5	949.7
145°	697.6	734.5	773.6	808.1	824.2	840.4	869.2	888.7	900.2	906.0	900.2
147.5°	690.7	721.8	754.0	782.8	796.0	809.3	831.2	848.4	857.6	859.9	857.6
150°	682.7	710.3	736.8	759.8	770.2	780.5	798.9	813.9	820.8	822.0	820.8
152.5°	673.5	697.6	719.5	740.2	748.2	756.3	771.3	782.8	786.3	787.4	786.3
155°	664.2	685.0	703.4	720.7	727.6	734.5	746.0	755.2	758.6	758.6	758.6
157.5°	655.0	671.1	687.3	702.2	708.0	713.7	723.0	729.9	732.2	732.2	732.2
160°	644.7	658.5	671.1	683.8	688.4	693.0	699.9	706.8	708.0	708.0	708.0
162.5°	635.5	645.8	656.2	665.4	669.4	673.5	678.1	685.0	686.1	685.0	686.1
165°	625.1	634.3	641.2	649.3	652.2	655.0	659.6	664.2	663.1	661.9	663.1
167.5°	615.9	622.8	628.6	635.5	637.2	638.9	641.2	644.7	644.7	643.5	644.7
170°	606.7	612.4	615.9	620.5	622.2	623.9	626.3	627.4	626.3	626.3	626.3
172.5°	598.6	603.2	605.5	607.8	609.0	610.1	611.3	612.4	611.3	609.0	611.3
175°	592.9	595.2	596.3	598.6	598.6	598.6	598.6	600.9	598.6	596.3	598.6
177.5°	588.3	589.4	590.6	590.6	591.2	591.7	590.6	591.7	589.4	587.1	589.4
180°	586.0	586.0	586.0	586.0	586.0	586.0	586.0	586.0	586.0	586.0	586.0

TEST NUMBER: P1025751

CATALOG NUMBER: S124DIP-B795D1205UB27-4F0-XX-W2A-A4

CANDELA DISTRIBUTION (continued):

	100°	105°	110°	112.5°	115°	120°	125°	130°	135°	140°	145°
0°	1279.6	1279.6	1279.6	1279.6	1279.6	1279.6	1279.6	1279.6	1279.6	1279.6	1279.6
2.5°	1380.3	1377.1	1372.9	1372.9	1367.6	1367.6	1359.1	1344.3	1331.6	1327.3	1329.4
5°	1498.0	1499.1	1492.7	1487.4	1477.9	1470.4	1456.7	1430.2	1421.7	1404.7	1393.1
7.5°	1632.6	1628.4	1616.7	1608.3	1606.1	1589.2	1559.5	1527.7	1502.2	1485.3	1460.9
10°	1784.2	1767.3	1750.3	1745.0	1732.3	1703.7	1669.8	1634.8	1599.8	1562.7	1521.3
12.5°	1911.5	1878.6	1877.5	1864.8	1840.4	1824.5	1784.2	1734.4	1674.0	1632.6	1586.0
15°	2048.2	2017.5	1992.0	1968.7	1957.1	1910.4	1876.5	1813.9	1741.8	1697.3	1665.5
17.5°	2145.8	2132.0	2088.5	2077.9	2062.0	2007.9	1953.9	1892.4	1829.8	1767.3	1681.4
20°	2224.2	2215.7	2187.1	2172.3	2146.8	2104.4	2038.7	1967.7	1895.6	1806.5	1725.9
22.5°	2258.1	2247.5	2224.2	2211.5	2195.6	2159.5	2103.4	2022.8	1928.4	1848.9	1763.0
25°	2191.4	2210.4	2204.1	2198.8	2192.4	2171.2	2128.8	2057.8	1965.5	1875.4	1768.3
27.5°	2040.8	2073.7	2105.5	2109.7	2120.3	2128.8	2111.8	2061.0	1983.6	1888.1	1770.5
30°	1838.3	1853.2	1917.8	1936.9	1951.8	2005.8	2037.6	2024.9	1965.5	1879.7	1771.5
32.5°	1578.6	1617.8	1683.5	1729.1	1769.4	1829.8	1912.5	1945.4	1924.2	1854.2	1747.1
35°	1332.6	1379.3	1455.6	1513.9	1554.2	1640.1	1737.6	1808.6	1835.1	1800.2	1704.7
37.5°	1131.2	1187.4	1255.2	1277.5	1324.1	1430.2	1564.8	1663.4	1728.1	1731.2	1657.0
40°	979.6	1008.2	1062.3	1096.2	1141.8	1230.8	1362.3	1492.7	1590.2	1623.1	1583.9
42.5°	851.3	873.6	913.9	955.2	996.6	1064.4	1185.3	1307.2	1438.6	1504.4	1503.3
45°	749.5	772.9	800.4	834.3	863.0	936.1	1031.5	1156.6	1270.1	1371.8	1397.3
47.5°	660.5	680.6	714.5	729.4	748.5	817.4	900.1	1016.7	1134.4	1251.0	1280.7
50°	594.7	611.7	635.0	644.6	665.8	716.7	784.5	878.9	1009.3	1116.3	1171.5
52.5°	535.4	548.1	566.1	573.5	588.4	626.6	688.0	762.3	870.4	980.6	1058.0
55°	484.5	493.0	505.7	514.2	524.8	558.7	604.3	671.1	764.4	859.8	935.1
57.5°	436.8	443.1	455.9	460.1	468.6	495.1	526.9	583.1	669.0	753.8	826.9
60°	392.3	396.5	403.9	413.5	419.8	437.8	467.5	514.2	583.1	660.5	719.8
62.5°	349.9	356.2	358.3	362.6	367.9	384.8	408.2	442.1	502.5	566.1	628.7
65°	306.4	311.7	315.9	317.0	322.3	335.0	356.2	385.9	425.1	480.3	538.6
67.5°	266.1	269.3	271.4	275.6	280.9	287.3	304.3	326.5	362.6	407.1	453.7
70°	229.0	229.0	232.2	233.2	239.6	247.0	254.4	275.6	307.4	343.5	375.3
72.5°	188.7	194.0	192.9	198.2	197.2	202.5	212.0	225.8	249.1	277.8	308.5
75°	153.7	156.9	156.9	156.9	159.0	163.3	168.6	181.3	199.3	222.6	240.7
77.5°	119.8	121.9	121.9	121.9	123.0	127.2	132.5	141.0	153.7	167.5	178.1
80°	85.9	88.0	88.0	90.1	90.1	91.2	96.5	100.7	107.1	117.7	128.3
82.5°	58.3	59.4	61.5	61.5	60.4	62.5	63.6	67.9	74.2	76.3	83.8
85°	31.8	32.9	33.9	33.9	35.0	37.1	36.0	40.3	40.3	44.5	46.6
87.5°	12.7	14.8	14.8	13.8	14.8	14.8	14.8	17.0	18.0	19.1	18.0
90°	25.3	24.2	23.0	23.0	23.0	21.9	20.7	19.6	20.7	18.4	16.1
92.5°	109.4	117.4	134.7	149.1	163.5	207.2	277.4	375.3	451.3	394.9	286.6
95°	316.6	352.3	408.7	464.5	520.3	674.6	853.0	964.7	938.2	708.0	432.9
97.5°	736.8	805.8	884.1	948.6	1013.1	1139.7	1228.3	1209.9	1003.8	678.1	394.9
100°	1099.4	1169.6	1269.8	1312.4	1355.0	1411.4	1388.3	1220.3	925.6	600.9	366.1
102.5°	1430.9	1477.0	1528.8	1540.3	1551.8	1517.3	1380.3	1133.9	827.7	549.1	358.0
105°	1642.8	1652.0	1649.7	1626.1	1602.5	1488.5	1289.3	1025.7	755.2	523.8	362.6
107.5°	1719.9	1699.2	1648.5	1600.2	1551.8	1392.9	1177.7	937.1	708.0	516.9	376.4
110°	1701.5	1653.1	1571.4	1508.1	1444.8	1277.8	1078.7	873.8	686.1	519.2	392.6

TEST NUMBER: P1025751

CATALOG NUMBER: S124DIP-B795D1205UB27-4F0-XX-W2A-A4

CANDELA DISTRIBUTION (continued):

	100°	105°	110°	112.5°	115°	120°	125°	130°	135°	140°	145°
112.5°	1615.1	1554.1	1458.6	1395.2	1331.9	1176.5	1006.1	838.1	675.8	526.1	409.8
115°	1509.2	1440.1	1349.2	1294.0	1238.7	1104.0	962.4	818.5	673.5	535.3	428.2
117.5°	1403.3	1343.4	1262.9	1214.6	1166.2	1056.8	937.1	808.1	672.3	544.5	446.7
120°	1318.1	1267.5	1201.9	1161.0	1120.1	1028.0	921.0	800.1	672.3	554.9	466.2
122.5°	1254.8	1213.4	1160.4	1125.8	1091.3	1009.6	907.1	790.9	671.1	565.2	484.7
125°	1212.2	1178.8	1132.8	1101.2	1069.5	990.0	891.0	780.5	670.0	575.6	503.1
127.5°	1183.4	1153.5	1107.5	1077.6	1047.6	968.2	872.6	766.7	667.7	583.7	519.2
130°	1155.8	1127.0	1079.8	1049.3	1018.8	940.5	849.6	754.0	666.5	592.9	534.2
132.5°	1125.9	1092.5	1046.4	1015.9	985.4	909.4	825.4	742.5	665.4	600.9	549.1
135°	1084.4	1052.2	1006.1	977.4	948.6	878.4	803.5	731.0	664.2	609.0	561.8
137.5°	1039.5	1006.1	962.4	935.9	909.4	848.4	782.8	720.7	664.2	613.6	571.0
140°	985.4	960.1	919.8	895.6	871.5	819.7	765.5	712.6	663.1	619.3	580.2
142.5°	935.9	912.9	878.4	858.2	838.1	795.5	749.4	705.7	663.1	623.9	587.1
145°	888.7	869.2	840.4	824.2	808.1	773.6	734.5	697.6	660.8	625.1	591.7
147.5°	848.4	831.2	809.3	796.0	782.8	754.0	721.8	690.7	657.3	626.3	596.3
150°	813.9	798.9	780.5	770.2	759.8	736.8	710.3	682.7	653.9	626.3	599.8
152.5°	782.8	771.3	756.3	748.2	740.2	719.5	697.6	673.5	648.1	623.9	602.1
155°	755.2	746.0	734.5	727.6	720.7	703.4	685.0	664.2	642.4	621.6	603.2
157.5°	729.9	723.0	713.7	708.0	702.2	687.3	671.1	655.0	636.6	619.3	603.2
160°	706.8	699.9	693.0	688.4	683.8	671.1	658.5	644.7	629.7	615.9	603.2
162.5°	685.0	678.1	673.5	669.4	665.4	656.2	645.8	635.5	622.8	612.4	603.2
165°	664.2	659.6	655.0	652.2	649.3	641.2	634.3	625.1	615.9	607.8	600.9
167.5°	644.7	641.2	638.9	637.2	635.5	628.6	622.8	615.9	609.0	603.2	598.6
170°	627.4	626.3	623.9	622.2	620.5	615.9	612.4	606.7	602.1	598.6	596.3
172.5°	612.4	611.3	610.1	609.0	607.8	605.5	603.2	598.6	595.2	594.0	594.0
175°	600.9	598.6	598.6	598.6	598.6	596.3	595.2	592.9	590.6	590.6	591.7
177.5°	591.7	590.6	591.7	591.2	590.6	590.6	589.4	588.3	587.1	587.1	589.4
180°	586.0	586.0	586.0	586.0	586.0	586.0	586.0	586.0	586.0	586.0	586.0

TEST NUMBER: P1025751

CATALOG NUMBER: S124DIP-B795D1205UB27-4F0-XX-W2A-A4

CANDELA DISTRIBUTION (continued):

	150°	155°	157.5°	160°	165°	170°	175°	180°	185°	190°	195°
0°	1279.6	1279.6	1279.6	1279.6	1279.6	1279.6	1279.6	1279.6	1279.6	1279.6	1279.6
2.5°	1319.9	1315.7	1312.5	1312.5	1302.9	1293.4	1288.1	1286.0	1283.9	1275.4	1263.7
5°	1374.0	1360.2	1350.6	1341.1	1325.2	1308.2	1291.3	1281.7	1268.0	1248.9	1235.1
7.5°	1434.4	1401.5	1390.9	1379.3	1347.5	1318.8	1295.5	1275.4	1253.1	1228.7	1204.3
10°	1485.3	1450.3	1427.0	1406.8	1365.5	1327.3	1292.3	1262.7	1234.0	1202.2	1172.5
12.5°	1534.1	1484.2	1459.8	1430.2	1386.7	1331.6	1286.0	1248.9	1206.5	1173.6	1137.6
15°	1601.9	1518.1	1477.9	1458.8	1400.5	1335.8	1280.7	1225.5	1190.6	1140.7	1108.9
17.5°	1612.5	1544.7	1518.1	1469.4	1399.4	1326.3	1262.7	1207.5	1154.5	1110.0	1068.6
20°	1649.6	1560.6	1518.1	1487.4	1395.2	1321.0	1251.0	1180.0	1129.1	1081.4	1034.7
22.5°	1672.9	1572.2	1527.7	1478.9	1390.9	1301.9	1219.2	1157.7	1095.1	1046.4	1009.3
25°	1666.6	1565.9	1516.0	1470.4	1363.4	1274.3	1200.1	1121.6	1063.3	1010.3	961.6
27.5°	1663.4	1550.0	1496.9	1446.1	1345.3	1252.0	1158.8	1095.1	1030.5	969.0	932.9
30°	1654.9	1529.8	1468.3	1413.2	1308.2	1210.7	1131.2	1057.0	992.3	936.1	888.4
32.5°	1626.3	1495.9	1436.5	1377.1	1268.0	1170.4	1089.8	1020.9	956.3	898.0	852.4
35°	1588.1	1455.6	1390.9	1328.4	1219.2	1120.6	1046.4	974.3	913.9	857.7	814.2
37.5°	1550.0	1409.0	1348.5	1276.4	1175.7	1072.9	996.6	931.9	875.7	817.4	769.7
40°	1494.8	1353.8	1287.0	1225.5	1107.9	1011.4	941.4	883.1	828.0	772.9	732.6
42.5°	1419.6	1293.4	1224.5	1156.6	1046.4	951.0	883.1	831.2	779.2	733.6	689.1
45°	1343.2	1220.2	1158.8	1098.3	978.5	888.4	825.9	778.2	734.7	684.9	648.8
47.5°	1251.0	1147.1	1085.6	1026.2	912.8	822.7	765.4	720.9	680.6	639.3	605.4
50°	1156.6	1066.5	1010.3	948.8	840.7	759.1	702.9	665.8	632.9	593.7	566.1
52.5°	1054.9	976.4	928.7	869.3	773.9	698.6	641.4	604.3	576.7	548.1	523.7
55°	946.7	889.5	838.6	790.9	700.8	632.9	582.0	549.2	530.1	503.6	482.4
57.5°	849.2	794.1	763.3	709.2	630.8	564.0	523.7	496.2	473.9	458.0	441.0
60°	747.4	702.9	669.0	629.7	560.8	504.6	462.2	446.3	423.0	411.3	403.9
62.5°	649.9	618.1	586.3	556.6	495.1	442.1	410.3	390.1	376.4	364.7	358.3
65°	557.6	528.0	505.7	479.2	428.3	385.9	356.2	340.3	326.5	323.3	315.9
67.5°	467.5	454.8	430.4	409.2	365.8	332.9	310.6	290.5	283.1	279.9	273.5
70°	391.2	376.4	357.3	339.3	306.4	277.8	257.6	250.2	239.6	238.5	231.1
72.5°	322.3	304.3	290.5	276.7	252.3	226.9	216.3	205.7	200.4	196.1	192.9
75°	255.5	242.8	233.2	221.6	200.4	183.4	168.6	164.3	161.1	160.1	158.0
77.5°	190.8	182.3	178.1	166.4	151.6	136.8	130.4	124.0	124.0	121.9	123.0
80°	135.7	130.4	125.1	118.7	106.0	99.7	94.4	90.1	88.0	86.9	88.0
82.5°	85.9	82.7	81.6	77.4	68.9	65.7	61.5	58.3	58.3	58.3	58.3
85°	47.7	47.7	47.7	41.3	38.2	35.0	32.9	31.8	31.8	31.8	32.9
87.5°	20.1	20.1	17.0	17.0	15.9	13.8	12.7	12.7	13.8	13.8	14.8
90°	16.1	9.2	9.2	9.2	8.1	6.9	3.5	1.2	3.5	6.9	8.1
92.5°	175.0	103.6	88.6	73.7	53.0	35.7	23.0	16.1	23.0	35.7	53.0
95°	244.1	143.9	119.7	95.5	67.9	53.0	41.4	38.0	41.4	53.0	67.9
97.5°	232.5	153.1	132.4	111.7	87.5	73.7	63.3	63.3	63.3	73.7	87.5
100°	236.0	168.1	149.6	131.2	109.4	95.5	87.5	87.5	87.5	95.5	109.4
102.5°	247.5	187.6	170.4	153.1	132.4	119.7	112.8	110.5	112.8	119.7	132.4
105°	267.1	211.8	195.1	178.4	157.7	143.9	138.1	134.7	138.1	143.9	157.7
107.5°	287.8	237.1	220.4	203.8	184.2	169.2	163.5	161.2	163.5	169.2	184.2
110°	312.0	261.3	245.8	230.2	209.5	195.7	189.9	187.6	189.9	195.7	209.5

TEST NUMBER: P1025751

CATALOG NUMBER: S124DIP-B795D1205UB27-4F0-XX-W2A-A4

CANDELA DISTRIBUTION (continued):

	150°	155°	157.5°	160°	165°	170°	175°	180°	185°	190°	195°
112.5°	335.0	286.6	271.1	255.6	234.8	222.2	215.3	213.0	215.3	222.2	234.8
115°	359.2	313.1	297.6	282.0	260.2	248.7	240.6	237.1	240.6	248.7	260.2
117.5°	382.2	338.5	322.4	306.2	285.5	272.8	265.9	262.5	265.9	272.8	285.5
120°	406.4	362.6	346.5	330.4	310.8	298.2	290.1	287.8	290.1	298.2	310.8
122.5°	429.4	385.7	370.2	354.6	332.7	321.2	313.1	310.8	313.1	321.2	332.7
125°	450.1	408.7	392.5	376.4	354.6	341.9	335.0	330.4	335.0	341.9	354.6
127.5°	469.7	429.4	413.3	397.2	374.1	360.3	352.3	348.8	352.3	360.3	374.1
130°	489.3	450.1	433.4	416.7	394.9	377.6	368.4	363.8	368.4	377.6	394.9
132.5°	505.4	466.2	450.7	435.2	411.0	394.9	382.2	378.7	382.2	394.9	411.0
135°	520.3	482.4	467.4	452.4	428.2	408.7	397.2	392.6	397.2	408.7	428.2
137.5°	531.9	496.2	481.8	467.4	442.1	423.6	411.0	406.4	411.0	423.6	442.1
140°	543.4	508.8	495.0	481.2	457.0	437.5	424.8	421.3	424.8	437.5	457.0
142.5°	553.7	520.3	507.1	493.9	470.8	452.4	440.9	437.5	440.9	452.4	470.8
145°	560.6	530.7	518.0	505.4	483.5	467.4	455.9	452.4	455.9	467.4	483.5
147.5°	568.7	539.9	528.4	516.9	498.5	481.2	470.8	469.7	470.8	481.2	498.5
150°	574.4	549.1	538.2	527.2	510.0	496.2	487.0	485.8	487.0	496.2	510.0
152.5°	579.1	557.2	547.4	537.6	522.6	510.0	500.8	500.8	500.8	510.0	522.6
155°	583.7	564.1	555.4	546.8	534.2	522.6	515.7	514.6	515.7	522.6	534.2
157.5°	587.1	569.8	562.9	556.0	544.5	535.3	528.4	528.4	528.4	535.3	544.5
160°	589.4	575.6	569.2	562.9	553.7	545.7	541.1	541.1	541.1	545.7	553.7
162.5°	591.7	579.1	574.4	569.8	561.8	554.9	551.4	552.6	551.4	554.9	561.8
165°	591.7	581.4	577.9	574.4	568.7	562.9	560.6	560.6	560.6	562.9	568.7
167.5°	591.7	583.7	580.8	577.9	574.4	569.8	568.7	569.8	568.7	569.8	574.4
170°	590.6	584.8	583.1	581.4	579.1	575.6	574.4	575.6	574.4	575.6	579.1
172.5°	589.4	586.0	584.8	583.7	582.5	580.2	580.2	581.4	580.2	580.2	582.5
175°	588.3	586.0	586.0	586.0	584.8	583.7	583.7	584.8	583.7	583.7	584.8
177.5°	587.1	586.0	586.0	586.0	586.0	584.8	586.0	587.1	586.0	584.8	586.0
180°	586.0	586.0	586.0	586.0	586.0	586.0	586.0	586.0	586.0	586.0	586.0

TEST NUMBER: P1025751

CATALOG NUMBER: S124DIP-B795D1205UB27-4F0-XX-W2A-A4

CANDELA DISTRIBUTION (continued):

	200°	202.5°	205°	210°	215°	220°	225°	230°	235°	240°	245°
0°	1279.6	1279.6	1279.6	1279.6	1279.6	1279.6	1279.6	1279.6	1279.6	1279.6	1279.6
2.5°	1260.5	1256.3	1258.4	1247.8	1238.3	1224.5	1212.8	1210.7	1208.6	1214.9	1210.7
5°	1224.5	1219.2	1213.9	1201.2	1182.1	1170.4	1153.5	1152.4	1146.0	1136.5	1138.6
7.5°	1185.3	1182.1	1174.7	1154.5	1137.6	1117.4	1103.6	1092.0	1086.7	1078.2	1075.0
10°	1153.5	1141.8	1135.4	1113.2	1093.0	1071.8	1053.8	1045.3	1035.8	1028.4	1023.1
12.5°	1110.0	1106.8	1088.8	1070.8	1053.8	1029.4	1015.6	991.2	978.5	984.9	982.8
15°	1081.4	1066.5	1062.3	1036.8	1008.2	992.3	966.9	951.0	945.7	936.1	924.5
17.5°	1043.2	1033.7	1018.8	995.5	962.6	940.4	922.3	907.5	901.1	888.4	878.9
20°	1007.2	991.2	979.6	958.4	926.6	898.0	875.7	866.2	850.2	839.6	834.3
22.5°	974.3	962.6	945.7	913.9	886.3	858.7	832.2	818.4	803.6	797.2	788.8
25°	934.0	914.9	903.3	868.3	838.6	816.3	791.9	773.9	765.4	754.8	752.7
27.5°	894.8	876.8	863.0	832.2	796.2	767.6	752.7	740.0	725.1	725.1	719.8
30°	855.5	842.8	821.6	791.9	758.0	730.5	713.5	701.8	696.5	692.3	691.2
32.5°	816.3	799.4	786.6	746.4	720.9	695.5	682.7	673.2	666.8	665.8	666.8
35°	776.0	757.0	744.2	708.2	682.7	659.4	654.1	645.6	642.5	641.4	646.7
37.5°	733.6	718.8	702.9	673.2	644.6	630.8	620.2	617.0	616.0	622.3	624.4
40°	694.4	681.7	666.8	635.0	613.8	599.0	593.7	590.5	594.7	601.1	604.3
42.5°	657.3	639.3	627.6	599.0	579.9	571.4	565.1	565.1	569.3	576.7	582.0
45°	618.1	604.3	592.6	567.2	550.2	540.7	539.6	540.7	546.0	551.3	557.6
47.5°	579.9	566.1	553.4	532.2	517.4	512.1	511.0	512.1	520.5	528.0	535.4
50°	544.9	530.1	518.4	498.3	486.6	480.3	481.3	486.6	493.0	503.6	513.1
52.5°	503.6	493.0	482.4	464.4	453.7	449.5	452.7	456.9	468.6	476.0	487.7
55°	463.3	453.7	445.3	431.5	423.0	419.8	421.9	428.3	437.8	450.6	464.4
57.5°	426.2	415.6	407.1	397.6	388.0	389.1	390.1	398.6	410.3	421.9	437.8
60°	384.8	378.5	371.1	359.4	355.2	355.2	358.3	367.9	378.5	397.6	411.3
62.5°	347.7	339.3	334.0	326.5	320.2	321.2	328.6	337.1	349.9	365.8	383.8
65°	309.6	300.0	295.8	289.4	287.3	288.4	293.7	306.4	320.2	334.0	350.9
67.5°	267.2	264.0	259.7	253.4	255.5	256.6	261.9	272.5	287.3	301.1	320.2
70°	231.1	224.8	223.7	218.4	218.4	221.6	232.2	239.6	253.4	268.2	288.4
72.5°	192.9	187.6	187.6	183.4	186.6	189.8	195.1	205.7	218.4	233.2	250.2
75°	153.7	151.6	153.7	151.6	151.6	156.9	163.3	171.7	185.5	201.4	215.2
77.5°	118.7	118.7	117.7	120.9	120.9	124.0	132.5	141.0	151.6	164.3	179.2
80°	86.9	86.9	86.9	90.1	93.3	93.3	98.6	109.2	118.7	127.2	141.0
82.5°	59.4	59.4	59.4	61.5	65.7	65.7	72.1	78.5	89.1	96.5	102.8
85°	36.0	36.0	35.0	37.1	38.2	41.3	46.6	50.9	56.2	62.5	68.9
87.5°	15.9	15.9	17.0	18.0	19.1	21.2	23.3	25.4	30.7	32.9	36.0
90°	9.2	9.2	9.2	16.1	16.1	18.4	20.7	19.6	20.7	21.9	23.0
92.5°	73.7	88.6	103.6	175.0	286.6	394.9	451.3	375.3	277.4	207.2	163.5
95°	95.5	119.7	143.9	244.1	432.9	708.0	938.2	964.7	853.0	674.6	520.3
97.5°	111.7	132.4	153.1	232.5	394.9	678.1	1003.8	1209.9	1228.3	1139.7	1013.1
100°	131.2	149.6	168.1	236.0	366.1	600.9	925.6	1220.3	1388.3	1411.4	1355.0
102.5°	153.1	170.4	187.6	247.5	358.0	549.1	827.7	1133.9	1380.3	1517.3	1551.8
105°	178.4	195.1	211.8	267.1	362.6	523.8	755.2	1025.7	1289.3	1488.5	1602.5
107.5°	203.8	220.4	237.1	287.8	376.4	516.9	708.0	937.1	1177.7	1392.9	1551.8
110°	230.2	245.8	261.3	312.0	392.6	519.2	686.1	873.8	1078.7	1277.8	1444.8

TEST NUMBER: P1025751

CATALOG NUMBER: S124DIP-B795D1205UB27-4F0-XX-W2A-A4

CANDELA DISTRIBUTION (continued):

	200°	202.5°	205°	210°	215°	220°	225°	230°	235°	240°	245°
112.5°	255.6	271.1	286.6	335.0	409.8	526.1	675.8	838.1	1006.1	1176.5	1331.9
115°	282.0	297.6	313.1	359.2	428.2	535.3	673.5	818.5	962.4	1104.0	1238.7
117.5°	306.2	322.4	338.5	382.2	446.7	544.5	672.3	808.1	937.1	1056.8	1166.2
120°	330.4	346.5	362.6	406.4	466.2	554.9	672.3	800.1	921.0	1028.0	1120.1
122.5°	354.6	370.2	385.7	429.4	484.7	565.2	671.1	790.9	907.1	1009.6	1091.3
125°	376.4	392.5	408.7	450.1	503.1	575.6	670.0	780.5	891.0	990.0	1069.5
127.5°	397.2	413.3	429.4	469.7	519.2	583.7	667.7	766.7	872.6	968.2	1047.6
130°	416.7	433.4	450.1	489.3	534.2	592.9	666.5	754.0	849.6	940.5	1018.8
132.5°	435.2	450.7	466.2	505.4	549.1	600.9	665.4	742.5	825.4	909.4	985.4
135°	452.4	467.4	482.4	520.3	561.8	609.0	664.2	731.0	803.5	878.4	948.6
137.5°	467.4	481.8	496.2	531.9	571.0	613.6	664.2	720.7	782.8	848.4	909.4
140°	481.2	495.0	508.8	543.4	580.2	619.3	663.1	712.6	765.5	819.7	871.5
142.5°	493.9	507.1	520.3	553.7	587.1	623.9	663.1	705.7	749.4	795.5	838.1
145°	505.4	518.0	530.7	560.6	591.7	625.1	660.8	697.6	734.5	773.6	808.1
147.5°	516.9	528.4	539.9	568.7	596.3	626.3	657.3	690.7	721.8	754.0	782.8
150°	527.2	538.2	549.1	574.4	599.8	626.3	653.9	682.7	710.3	736.8	759.8
152.5°	537.6	547.4	557.2	579.1	602.1	623.9	648.1	673.5	697.6	719.5	740.2
155°	546.8	555.4	564.1	583.7	603.2	621.6	642.4	664.2	685.0	703.4	720.7
157.5°	556.0	562.9	569.8	587.1	603.2	619.3	636.6	655.0	671.1	687.3	702.2
160°	562.9	569.2	575.6	589.4	603.2	615.9	629.7	644.7	658.5	671.1	683.8
162.5°	569.8	574.4	579.1	591.7	603.2	612.4	622.8	635.5	645.8	656.2	665.4
165°	574.4	577.9	581.4	591.7	600.9	607.8	615.9	625.1	634.3	641.2	649.3
167.5°	577.9	580.8	583.7	591.7	598.6	603.2	609.0	615.9	622.8	628.6	635.5
170°	581.4	583.1	584.8	590.6	596.3	598.6	602.1	606.7	612.4	615.9	620.5
172.5°	583.7	584.8	586.0	589.4	594.0	594.0	595.2	598.6	603.2	605.5	607.8
175°	586.0	586.0	586.0	588.3	591.7	590.6	590.6	592.9	595.2	596.3	598.6
177.5°	586.0	586.0	586.0	587.1	589.4	587.1	587.1	588.3	589.4	590.6	590.6
180°	586.0	586.0	586.0	586.0	586.0	586.0	586.0	586.0	586.0	586.0	586.0

TEST NUMBER: P1025751

CATALOG NUMBER: S124DIP-B795D1205UB27-4F0-XX-W2A-A4

CANDELA DISTRIBUTION (continued):

	247.5°	250°	255°	260°	265°	270°	275°	280°	285°	290°	292.5°
0°	1279.6	1279.6	1279.6	1279.6	1279.6	1279.6	1279.6	1279.6	1279.6	1279.6	1279.6
2.5°	1207.5	1206.5	1201.2	1203.3	1196.9	1199.0	1202.2	1203.3	1207.5	1204.3	1203.3
5°	1133.3	1131.2	1128.0	1124.8	1123.8	1128.0	1120.6	1122.7	1124.8	1128.0	1132.3
7.5°	1072.9	1071.8	1068.6	1063.3	1061.2	1059.1	1060.2	1067.6	1066.5	1065.5	1072.9
10°	1017.8	1018.8	1012.5	1011.4	1005.0	1004.0	1005.0	1007.2	1010.3	1014.6	1015.6
12.5°	960.5	974.3	962.6	958.4	948.8	954.1	956.3	946.7	952.0	955.2	971.1
15°	924.5	918.1	910.7	910.7	906.4	904.3	899.0	906.4	910.7	917.0	914.9
17.5°	874.6	864.0	859.8	855.5	856.6	860.8	849.2	866.2	866.2	869.3	864.0
20°	831.2	822.7	817.4	815.3	812.1	810.0	808.9	813.1	819.5	821.6	826.9
22.5°	785.6	785.6	777.1	773.9	771.8	768.6	773.9	770.7	775.0	779.2	787.7
25°	747.4	747.4	744.2	740.0	736.8	734.7	737.9	736.8	740.0	745.3	747.4
27.5°	716.7	713.5	712.4	711.4	710.3	711.4	710.3	713.5	716.7	717.7	715.6
30°	690.2	687.0	688.0	688.0	689.1	688.0	687.0	690.2	691.2	689.1	690.2
32.5°	665.8	665.8	667.9	669.0	669.0	670.0	671.1	669.0	670.0	666.8	667.9
35°	645.6	647.8	649.9	650.9	652.0	650.9	653.1	652.0	649.9	647.8	646.7
37.5°	625.5	627.6	631.9	632.9	636.1	637.2	635.0	635.0	634.0	629.7	627.6
40°	604.3	606.4	611.7	614.9	617.0	620.2	618.1	618.1	613.8	609.6	606.4
42.5°	584.1	588.4	593.7	596.9	601.1	601.1	601.1	599.0	593.7	589.4	586.3
45°	564.0	565.1	572.5	577.8	582.0	582.0	582.0	578.8	575.7	567.2	562.9
47.5°	541.7	544.9	553.4	558.7	562.9	564.0	564.0	560.8	554.5	547.0	541.7
50°	517.4	522.7	532.2	539.6	544.9	547.0	543.9	541.7	534.3	525.8	519.5
52.5°	494.0	500.4	512.1	518.4	525.8	526.9	525.8	522.7	514.2	502.5	497.2
55°	470.7	476.0	488.7	499.3	505.7	507.8	505.7	500.4	489.8	478.1	472.8
57.5°	445.3	452.7	466.5	477.1	484.5	485.6	483.4	478.1	469.7	454.8	447.4
60°	418.8	428.3	442.1	452.7	462.2	463.3	461.2	453.7	443.1	428.3	421.9
62.5°	392.3	399.7	415.6	427.2	434.7	440.0	435.7	428.3	417.7	402.9	393.3
65°	361.5	372.1	385.9	396.5	405.0	406.0	403.9	397.6	385.9	370.0	362.6
67.5°	331.8	339.3	353.0	366.8	370.0	373.2	370.0	363.6	354.1	340.3	329.7
70°	295.8	302.1	319.1	328.6	332.9	336.1	334.0	327.6	319.1	306.4	297.9
72.5°	259.7	265.0	280.9	288.4	296.8	295.8	294.7	290.5	278.8	270.3	265.0
75°	221.6	227.9	238.5	248.1	251.3	251.3	251.3	248.1	240.7	226.9	221.6
77.5°	186.6	189.8	198.2	203.6	206.7	207.8	206.7	201.4	197.2	187.6	184.5
80°	143.1	151.6	158.0	159.0	163.3	163.3	163.3	161.1	156.9	147.4	146.3
82.5°	108.1	110.3	116.6	119.8	121.9	120.9	120.9	116.6	115.6	110.3	108.1
85°	73.2	76.3	75.3	79.5	80.6	78.5	78.5	80.6	75.3	76.3	73.2
87.5°	40.3	40.3	42.4	41.3	45.6	45.6	43.5	44.5	42.4	41.3	40.3
90°	23.0	23.0	24.2	25.3	24.2	24.2	24.2	25.3	24.2	23.0	23.0
92.5°	149.1	134.7	117.4	109.4	104.8	104.8	104.8	109.4	117.4	134.7	149.1
95°	464.5	408.7	352.3	316.6	295.9	280.9	295.9	316.6	352.3	408.7	464.5
97.5°	948.6	884.1	805.8	736.8	702.2	674.6	702.2	736.8	805.8	884.1	948.6
100°	1312.4	1269.8	1169.6	1099.4	1064.9	1055.6	1064.9	1099.4	1169.6	1269.8	1312.4
102.5°	1540.3	1528.8	1477.0	1430.9	1394.1	1387.2	1394.1	1430.9	1477.0	1528.8	1540.3
105°	1626.1	1649.7	1652.0	1642.8	1626.6	1619.7	1626.6	1642.8	1652.0	1649.7	1626.1
107.5°	1600.2	1648.5	1699.2	1719.9	1729.1	1730.3	1729.1	1719.9	1699.2	1648.5	1600.2
110°	1508.1	1571.4	1653.1	1701.5	1722.2	1732.6	1722.2	1701.5	1653.1	1571.4	1508.1

TEST NUMBER: P1025751

CATALOG NUMBER: S124DIP-B795D1205UB27-4F0-XX-W2A-A4

CANDELA DISTRIBUTION (continued):

	247.5°	250°	255°	260°	265°	270°	275°	280°	285°	290°	292.5°
112.5°	1395.2	1458.6	1554.1	1615.1	1646.2	1664.6	1646.2	1615.1	1554.1	1458.6	1395.2
115°	1294.0	1349.2	1440.1	1509.2	1546.1	1555.3	1546.1	1509.2	1440.1	1349.2	1294.0
117.5°	1214.6	1262.9	1343.4	1403.3	1442.5	1448.2	1442.5	1403.3	1343.4	1262.9	1214.6
120°	1161.0	1201.9	1267.5	1318.1	1348.1	1360.7	1348.1	1318.1	1267.5	1201.9	1161.0
122.5°	1125.8	1160.4	1213.4	1254.8	1279.0	1291.6	1279.0	1254.8	1213.4	1160.4	1125.8
125°	1101.2	1132.8	1178.8	1212.2	1234.1	1241.0	1234.1	1212.2	1178.8	1132.8	1101.2
127.5°	1077.6	1107.5	1153.5	1183.4	1201.9	1208.8	1201.9	1183.4	1153.5	1107.5	1077.6
130°	1049.3	1079.8	1127.0	1155.8	1174.2	1181.1	1174.2	1155.8	1127.0	1079.8	1049.3
132.5°	1015.9	1046.4	1092.5	1125.9	1143.1	1150.0	1143.1	1125.9	1092.5	1046.4	1015.9
135°	977.4	1006.1	1052.2	1084.4	1102.8	1109.8	1102.8	1084.4	1052.2	1006.1	977.4
137.5°	935.9	962.4	1006.1	1039.5	1054.5	1062.6	1054.5	1039.5	1006.1	962.4	935.9
140°	895.6	919.8	960.1	985.4	1001.5	1010.8	1001.5	985.4	960.1	919.8	895.6
142.5°	858.2	878.4	912.9	935.9	949.7	955.5	949.7	935.9	912.9	878.4	858.2
145°	824.2	840.4	869.2	888.7	900.2	906.0	900.2	888.7	869.2	840.4	824.2
147.5°	796.0	809.3	831.2	848.4	857.6	859.9	857.6	848.4	831.2	809.3	796.0
150°	770.2	780.5	798.9	813.9	820.8	822.0	820.8	813.9	798.9	780.5	770.2
152.5°	748.2	756.3	771.3	782.8	786.3	787.4	786.3	782.8	771.3	756.3	748.2
155°	727.6	734.5	746.0	755.2	758.6	758.6	758.6	755.2	746.0	734.5	727.6
157.5°	708.0	713.7	723.0	729.9	732.2	732.2	732.2	729.9	723.0	713.7	708.0
160°	688.4	693.0	699.9	706.8	708.0	708.0	708.0	706.8	699.9	693.0	688.4
162.5°	669.4	673.5	678.1	685.0	686.1	685.0	686.1	685.0	678.1	673.5	669.4
165°	652.2	655.0	659.6	664.2	663.1	661.9	663.1	664.2	659.6	655.0	652.2
167.5°	637.2	638.9	641.2	644.7	644.7	643.5	644.7	644.7	641.2	638.9	637.2
170°	622.2	623.9	626.3	627.4	626.3	626.3	626.3	627.4	626.3	623.9	622.2
172.5°	609.0	610.1	611.3	612.4	611.3	609.0	611.3	612.4	611.3	610.1	609.0
175°	598.6	598.6	598.6	600.9	598.6	596.3	598.6	600.9	598.6	598.6	598.6
177.5°	591.2	591.7	590.6	591.7	589.4	587.1	589.4	591.7	590.6	591.7	591.2
180°	586.0	586.0	586.0	586.0	586.0	586.0	586.0	586.0	586.0	586.0	586.0

TEST NUMBER: P1025751

CATALOG NUMBER: S124DIP-B795D1205UB27-4F0-XX-W2A-A4

CANDELA DISTRIBUTION (continued):

	295°	300°	305°	310°	315°	320°	325°	330°	335°	337.5°	340°
0°	1279.6	1279.6	1279.6	1279.6	1279.6	1279.6	1279.6	1279.6	1279.6	1279.6	1279.6
2.5°	1203.3	1209.6	1203.3	1207.5	1209.6	1214.9	1217.1	1226.6	1229.8	1237.2	1237.2
5°	1131.2	1134.4	1135.4	1139.7	1143.9	1154.5	1161.9	1175.7	1191.6	1193.7	1203.3
7.5°	1072.9	1078.2	1086.7	1083.5	1090.9	1106.8	1116.3	1133.3	1149.2	1157.7	1169.4
10°	1020.9	1027.3	1030.5	1033.7	1047.4	1061.2	1076.1	1087.7	1108.9	1121.6	1131.2
12.5°	978.5	973.2	979.6	991.2	1007.2	1015.6	1035.8	1053.8	1069.7	1083.5	1092.0
15°	923.4	927.6	934.0	954.1	958.4	979.6	987.0	1007.2	1036.8	1049.6	1060.2
17.5°	870.4	884.2	896.9	904.3	917.0	934.0	955.2	977.5	996.6	1011.4	1024.1
20°	828.0	841.8	849.2	854.5	867.2	890.5	910.7	938.2	962.6	974.3	991.2
22.5°	794.1	794.1	804.7	820.6	828.0	850.2	867.2	896.9	923.4	938.2	954.1
25°	751.7	758.0	766.5	780.3	790.9	808.9	833.3	858.7	887.4	900.1	920.2
27.5°	716.7	724.1	735.8	738.9	749.5	765.4	790.9	818.4	848.1	861.9	878.9
30°	690.2	694.4	698.6	705.0	714.5	728.3	749.5	773.9	810.0	820.6	841.8
32.5°	666.8	669.0	671.1	676.4	681.7	695.5	712.4	738.9	768.6	784.5	803.6
35°	645.6	643.5	644.6	647.8	653.1	658.4	676.4	698.6	726.2	745.3	760.1
37.5°	625.5	621.3	620.2	620.2	622.3	628.7	642.5	661.5	691.2	707.1	722.0
40°	603.2	599.0	596.9	595.8	594.7	599.0	609.6	628.7	652.0	666.8	683.8
42.5°	582.0	577.8	572.5	571.4	569.3	571.4	578.8	596.9	617.0	631.9	645.6
45°	560.8	553.4	547.0	542.8	543.9	540.7	546.0	559.8	583.1	592.6	606.4
47.5°	537.5	529.0	520.5	516.3	512.1	514.2	516.3	528.0	548.1	557.6	571.4
50°	515.2	503.6	494.0	488.7	485.6	483.4	485.6	497.2	512.1	520.5	532.2
52.5°	489.8	478.1	468.6	460.1	455.9	452.7	453.7	464.4	478.1	486.6	498.3
55°	466.5	451.6	438.9	428.3	425.1	424.1	423.0	430.4	442.1	450.6	460.1
57.5°	440.0	425.1	411.3	398.6	392.3	391.2	391.2	393.3	408.2	414.5	419.8
60°	413.5	397.6	382.7	371.1	361.5	358.3	357.3	361.5	368.9	375.3	382.7
62.5°	383.8	367.9	349.9	339.3	329.7	321.2	324.4	325.5	336.1	339.3	345.6
65°	355.2	337.1	322.3	305.3	294.7	289.4	287.3	289.4	297.9	299.0	303.2
67.5°	322.3	305.3	287.3	275.6	266.1	256.6	254.4	254.4	258.7	261.9	267.2
70°	290.5	273.5	253.4	240.7	231.1	222.6	219.5	218.4	221.6	223.7	229.0
72.5°	253.4	236.4	221.6	207.8	196.1	189.8	186.6	184.5	187.6	189.8	190.8
75°	214.2	200.4	185.5	171.7	164.3	158.0	153.7	150.5	152.7	152.7	152.7
77.5°	177.0	163.3	151.6	142.1	132.5	125.1	121.9	118.7	119.8	119.8	121.9
80°	137.8	128.3	118.7	110.3	101.8	95.4	93.3	90.1	88.0	86.9	86.9
82.5°	101.8	94.4	85.9	78.5	74.2	67.9	65.7	61.5	61.5	60.4	60.4
85°	67.9	63.6	55.1	49.8	46.6	43.5	41.3	39.2	36.0	36.0	35.0
87.5°	36.0	33.9	31.8	25.4	25.4	22.3	21.2	20.1	17.0	18.0	18.0
90°	23.0	21.9	20.7	19.6	20.7	18.4	16.1	16.1	9.2	9.2	9.2
92.5°	163.5	207.2	277.4	375.3	451.3	394.9	286.6	175.0	103.6	88.6	73.7
95°	520.3	674.6	853.0	964.7	938.2	708.0	432.9	244.1	143.9	119.7	95.5
97.5°	1013.1	1139.7	1228.3	1209.9	1003.8	678.1	394.9	232.5	153.1	132.4	111.7
100°	1355.0	1411.4	1388.3	1220.3	925.6	600.9	366.1	236.0	168.1	149.6	131.2
102.5°	1551.8	1517.3	1380.3	1133.9	827.7	549.1	358.0	247.5	187.6	170.4	153.1
105°	1602.5	1488.5	1289.3	1025.7	755.2	523.8	362.6	267.1	211.8	195.1	178.4
107.5°	1551.8	1392.9	1177.7	937.1	708.0	516.9	376.4	287.8	237.1	220.4	203.8
110°	1444.8	1277.8	1078.7	873.8	686.1	519.2	392.6	312.0	261.3	245.8	230.2

TEST NUMBER: P1025751

CATALOG NUMBER: S124DIP-B795D1205UB27-4F0-XX-W2A-A4

CANDELA DISTRIBUTION (continued):

	295°	300°	305°	310°	315°	320°	325°	330°	335°	337.5°	340°
112.5°	1331.9	1176.5	1006.1	838.1	675.8	526.1	409.8	335.0	286.6	271.1	255.6
115°	1238.7	1104.0	962.4	818.5	673.5	535.3	428.2	359.2	313.1	297.6	282.0
117.5°	1166.2	1056.8	937.1	808.1	672.3	544.5	446.7	382.2	338.5	322.4	306.2
120°	1120.1	1028.0	921.0	800.1	672.3	554.9	466.2	406.4	362.6	346.5	330.4
122.5°	1091.3	1009.6	907.1	790.9	671.1	565.2	484.7	429.4	385.7	370.2	354.6
125°	1069.5	990.0	891.0	780.5	670.0	575.6	503.1	450.1	408.7	392.5	376.4
127.5°	1047.6	968.2	872.6	766.7	667.7	583.7	519.2	469.7	429.4	413.3	397.2
130°	1018.8	940.5	849.6	754.0	666.5	592.9	534.2	489.3	450.1	433.4	416.7
132.5°	985.4	909.4	825.4	742.5	665.4	600.9	549.1	505.4	466.2	450.7	435.2
135°	948.6	878.4	803.5	731.0	664.2	609.0	561.8	520.3	482.4	467.4	452.4
137.5°	909.4	848.4	782.8	720.7	664.2	613.6	571.0	531.9	496.2	481.8	467.4
140°	871.5	819.7	765.5	712.6	663.1	619.3	580.2	543.4	508.8	495.0	481.2
142.5°	838.1	795.5	749.4	705.7	663.1	623.9	587.1	553.7	520.3	507.1	493.9
145°	808.1	773.6	734.5	697.6	660.8	625.1	591.7	560.6	530.7	518.0	505.4
147.5°	782.8	754.0	721.8	690.7	657.3	626.3	596.3	568.7	539.9	528.4	516.9
150°	759.8	736.8	710.3	682.7	653.9	626.3	599.8	574.4	549.1	538.2	527.2
152.5°	740.2	719.5	697.6	673.5	648.1	623.9	602.1	579.1	557.2	547.4	537.6
155°	720.7	703.4	685.0	664.2	642.4	621.6	603.2	583.7	564.1	555.4	546.8
157.5°	702.2	687.3	671.1	655.0	636.6	619.3	603.2	587.1	569.8	562.9	556.0
160°	683.8	671.1	658.5	644.7	629.7	615.9	603.2	589.4	575.6	569.2	562.9
162.5°	665.4	656.2	645.8	635.5	622.8	612.4	603.2	591.7	579.1	574.4	569.8
165°	649.3	641.2	634.3	625.1	615.9	607.8	600.9	591.7	581.4	577.9	574.4
167.5°	635.5	628.6	622.8	615.9	609.0	603.2	598.6	591.7	583.7	580.8	577.9
170°	620.5	615.9	612.4	606.7	602.1	598.6	596.3	590.6	584.8	583.1	581.4
172.5°	607.8	605.5	603.2	598.6	595.2	594.0	594.0	589.4	586.0	584.8	583.7
175°	598.6	596.3	595.2	592.9	590.6	590.6	591.7	588.3	586.0	586.0	586.0
177.5°	590.6	590.6	589.4	588.3	587.1	587.1	589.4	587.1	586.0	586.0	586.0
180°	586.0	586.0	586.0	586.0	586.0	586.0	586.0	586.0	586.0	586.0	586.0

TEST NUMBER: P1025751

CATALOG NUMBER: S124DIP-B795D1205UB27-4F0-XX-W2A-A4

CANDELA DISTRIBUTION (continued):

	345°	350°	355°	360°
0°	1279.6	1279.6	1279.6	1279.6
2.5°	1244.6	1255.2	1264.8	1279.6
5°	1217.1	1231.9	1252.0	1274.3
7.5°	1185.3	1208.6	1235.1	1265.8
10°	1155.6	1182.1	1216.0	1253.1
12.5°	1124.8	1156.6	1193.7	1234.0
15°	1089.8	1121.6	1163.0	1217.1
17.5°	1058.0	1096.2	1140.7	1198.0
20°	1020.9	1057.0	1105.7	1171.5
22.5°	988.1	1029.4	1083.5	1140.7
25°	952.0	988.1	1042.1	1111.0
27.5°	916.0	960.5	1012.5	1079.2
30°	881.0	918.1	974.3	1044.3
32.5°	842.8	887.4	939.3	1005.0
35°	801.5	843.9	892.7	963.7
37.5°	764.4	805.7	855.5	918.1
40°	723.0	766.5	812.1	874.6
42.5°	682.7	722.0	767.6	824.8
45°	643.5	677.4	718.8	768.6
47.5°	603.2	631.9	670.0	714.5
50°	559.8	590.5	619.1	656.2
52.5°	519.5	546.0	569.3	600.1
55°	480.3	498.3	517.4	540.7
57.5°	438.9	452.7	466.5	490.9
60°	397.6	410.3	417.7	433.6
62.5°	357.3	362.6	372.1	381.7
65°	312.7	320.2	325.5	337.1
67.5°	272.5	275.6	280.9	288.4
70°	230.1	237.5	239.6	244.9
72.5°	194.0	197.2	199.3	200.4
75°	153.7	156.9	159.0	165.4
77.5°	120.9	119.8	124.0	125.1
80°	89.1	85.9	86.9	91.2
82.5°	58.3	59.4	58.3	58.3
85°	36.0	35.0	32.9	33.9
87.5°	15.9	15.9	14.8	14.8
90°	8.1	6.9	3.5	1.2
92.5°	53.0	35.7	23.0	16.1
95°	67.9	53.0	41.4	38.0
97.5°	87.5	73.7	63.3	63.3
100°	109.4	95.5	87.5	87.5
102.5°	132.4	119.7	112.8	110.5
105°	157.7	143.9	138.1	134.7
107.5°	184.2	169.2	163.5	161.2
110°	209.5	195.7	189.9	187.6

TEST NUMBER: P1025751

CATALOG NUMBER: S124DIP-B795D1205UB27-4F0-XX-W2A-A4

CANDELA DISTRIBUTION (continued):

	345°	350°	355°	360°
112.5°	234.8	222.2	215.3	213.0
115°	260.2	248.7	240.6	237.1
117.5°	285.5	272.8	265.9	262.5
120°	310.8	298.2	290.1	287.8
122.5°	332.7	321.2	313.1	310.8
125°	354.6	341.9	335.0	330.4
127.5°	374.1	360.3	352.3	348.8
130°	394.9	377.6	368.4	363.8
132.5°	411.0	394.9	382.2	378.7
135°	428.2	408.7	397.2	392.6
137.5°	442.1	423.6	411.0	406.4
140°	457.0	437.5	424.8	421.3
142.5°	470.8	452.4	440.9	437.5
145°	483.5	467.4	455.9	452.4
147.5°	498.5	481.2	470.8	469.7
150°	510.0	496.2	487.0	485.8
152.5°	522.6	510.0	500.8	500.8
155°	534.2	522.6	515.7	514.6
157.5°	544.5	535.3	528.4	528.4
160°	553.7	545.7	541.1	541.1
162.5°	561.8	554.9	551.4	552.6
165°	568.7	562.9	560.6	560.6
167.5°	574.4	569.8	568.7	569.8
170°	579.1	575.6	574.4	575.6
172.5°	582.5	580.2	580.2	581.4
175°	584.8	583.7	583.7	584.8
177.5°	586.0	584.8	586.0	587.1
180°	586.0	586.0	586.0	586.0

(END OF REPORT)