

Scaled data based on original data using
LM-79-2019 Approved Method: Electrical and Photometric Measurements of Solid-
State Lighting Products

Test Report Prepared for
Cooper Lighting Solutions

Brand: NEO-RAY

Report Number: P1025874

Luminaire Tested: S124DIP-B795D590UB40-4F0-XX-W2A-F4

Issue Date: 5/6/2025

Test Information

Test Method: LM-79-2019
Report Number: P1025874
REPORT IS A COMBINATION OF REPORTS P996549 AND P1007351
Test Lab: INNOVATION CENTER
Issue Date: 5/6/2025
Manufacturer: COOPER LIGHTING SOLUTIONS
Product Line: NEO-RAY
Catalog Number: S124DIP-B795D590UB40-4F0-XX-W2A-F4
Description: Define 4 Direct/Indirect Pendant with 4000K BioUP LEDs {m-DER=0.865} {m-EER=0.951}
Light Source: -
Ballast/Driver: -

Summary


Lumens per Lamp: N/A
Luminaire Lumens: 5518.2 lumens
Efficiency: N/A
Efficacy: 107.6 lumens/watt
Spacing Criteria (0/90/45): 1.2 / 1.17 / 1.29
Luminous Opening: Rectangular w/ Sides (W: 0.33' x L: 4' x H: 0.1')
CIE Type: Semi-Direct

Input Watts (W): 51.3
Input Voltage (V):
Input Current (Ain): NR
Voltage Rise (V): NR
Power Factor: NR
Total Harmonic Distortion (THDi): NR
Frequency (hertz): 60
Stabilization Time: NR
Operation Time: NR
Ambient Temperature (°C): NR
Test Distance: 24 FT

TEST NUMBER: P1025874

CATALOG NUMBER: S124DIP-B795D590UB40-4F0-XX-W2A-F4

Luminous Intensity Polar Plot



TEST NUMBER: P1025874

CATALOG NUMBER: S124DIP-B795D590UB40-4F0-XX-W2A-F4

COEFFICIENT OF UTILIZATION - ZONAL CAVITY METHOD:

RF	20				20				20				20				20
RC	80				70				50				30				10
RW	70	50	30	10	70	50	30	10	50	30	10	50	30	10	50	30	10
RCR																	
0	110	110	110	110	103	103	103	103	90	90	90	78	78	78	67	67	67
1	100	96	92	88	94	90	87	83	79	76	74	69	67	65	59	58	56
2	91	84	78	72	85	79	73	68	69	65	61	60	57	54	52	50	48
3	83	74	66	60	78	69	63	57	61	56	51	53	49	46	46	43	40
4	76	65	57	51	71	61	54	49	54	48	44	47	43	39	41	38	35
5	70	58	50	44	65	55	47	42	49	43	38	43	38	34	37	33	30
6	65	52	44	38	60	49	42	36	44	38	33	39	34	30	34	30	27
7	60	47	39	33	56	45	37	32	40	34	29	35	30	27	31	27	24
8	56	43	35	30	52	41	33	28	36	30	26	32	27	24	28	24	21
9	52	39	32	27	49	37	30	25	33	28	23	30	25	21	26	22	19
10	48	36	29	24	45	34	28	23	31	25	21	27	23	19	24	20	18

AVERAGE LUMINANCE (cd/sqm):

	0°	45°	90°
0°	10821	10821	10821
5°	10830	10510	10523
10°	10738	10218	10146
15°	10584	9871	9722
20°	10387	9495	9283
25°	10166	9099	8810
30°	9899	8671	8291
35°	9623	8232	7789
40°	9335	7759	7255
45°	9032	7286	6756
50°	8697	6827	6204
55°	8334	6291	5655
60°	7961	5703	5084
65°	7536	5096	4439
70°	7045	4367	3750
75°	6311	3519	3003
80°	5380	2545	2113
85°	4177	1417	1136

MAXIMUM LUMINANCE 45°-90°:

Horizontal Angle: 0°

Vertical Angle: 45°

Luminance: 9032 cd/sqm

TEST NUMBER: P1025874

CATALOG NUMBER: S124DIP-B795D590UB40-4F0-XX-W2A-F4

ZONAL LUMENS:

Zone	Lumens	% Fixture
0°-10°	125.1	2.3
10°-20°	352.4	6.4
20°-30°	518.6	9.4
30°-40°	602.8	10.9
40°-50°	602.8	10.9
50°-60°	527.2	9.6
60°-70°	391.4	7.1
70°-80°	222.1	4.0
80°-90°	64.7	1.2
90°-100°	214.9	3.9
100°-110°	437.0	7.9
110°-120°	389.5	7.1
120°-130°	327.2	5.9
130°-140°	273.1	4.9
140°-150°	208.5	3.8
150°-160°	146.6	2.7
160°-170°	86.2	1.6
170°-180°	28.0	0.5
0°-30°	996.1	18.1
0°-40°	1598.9	29.0
0°-60°	2728.9	49.5
0°-90°	3407.1	61.7
90°-120°	1041.5	18.9
90°-150°	1850.3	33.5
90°-180°	2111.0	38.3
0°-180°	5518.2	100.0

CANDELA DISTRIBUTION:

	0°	22.5°	45°	67.5°	90°	Flux
0°	1327	1327	1327	1327	1327	
5°	1326	1322	1310	1322	1320	126
15°	1262	1258	1242	1248	1245	356
25°	1143	1136	1121	1122	1118	526
35°	984	976	961	954	948	615
45°	803	795	778	767	763	619
55°	607	604	589	576	570	544
65°	412	406	396	385	380	407
75°	219	214	208	204	203	232
85°	57	57	55	55	54	62
90°	1	4	10	11	12	5
95°	19	59	463	229	139	21
105°	66	96	373	803	800	71
115°	117	147	332	639	768	116
125°	163	194	331	544	613	145
135°	194	231	328	482	548	150
145°	223	256	326	407	447	140
155°	254	274	317	359	374	117
165°	277	285	304	322	327	78
175°	289	289	292	296	294	27
180°	289	289	289	289	289	

TEST NUMBER: P1025874

CATALOG NUMBER: S124DIP-B795D590UB40-4F0-XX-W2A-F4

CANDELA DISTRIBUTION (FULL):

	0°	22.5°	45°	67.5°	90°
0°	1327.0	1327.0	1327.0	1327.0	1327.0
2.5°	1331.3	1328.1	1316.4	1327.0	1325.9
5°	1325.9	1321.7	1310.0	1321.7	1319.6
7.5°	1316.4	1312.1	1299.4	1308.9	1307.9
10°	1302.5	1298.3	1284.5	1293.0	1290.8
12.5°	1284.5	1280.2	1265.3	1274.9	1271.7
15°	1262.1	1257.9	1241.9	1248.3	1245.1
17.5°	1236.6	1231.3	1216.4	1220.7	1218.5
20°	1207.9	1202.6	1186.6	1189.8	1187.7
22.5°	1177.1	1169.6	1153.7	1160.1	1155.8
25°	1143.0	1135.6	1120.7	1121.8	1117.5
27.5°	1104.8	1097.3	1083.5	1081.4	1076.1
30°	1066.5	1058.0	1044.2	1039.9	1034.6
32.5°	1026.1	1018.6	1003.8	998.4	993.1
35°	983.6	976.1	961.2	953.8	948.5
37.5°	938.9	932.5	916.6	909.1	901.7
40°	895.3	886.8	870.8	860.2	854.9
42.5°	848.5	844.3	826.2	813.4	810.2
45°	802.8	795.3	778.3	766.6	763.4
47.5°	754.9	749.6	733.7	720.9	712.4
50°	706.0	701.8	686.9	672.0	665.6
52.5°	658.2	652.9	636.9	624.2	615.7
55°	607.1	604.0	589.1	576.3	569.9
57.5°	559.3	556.1	541.2	528.5	522.1
60°	509.3	504.0	490.2	480.6	475.3
62.5°	460.4	456.2	441.3	432.8	427.4
65°	411.5	406.2	395.5	384.9	379.6
67.5°	361.5	357.3	346.6	336.0	334.9
70°	315.8	308.4	299.9	291.3	288.2
72.5°	266.9	259.4	253.1	246.7	243.5
75°	219.0	213.7	208.4	204.2	203.1
77.5°	172.3	170.1	164.8	163.7	160.6
80°	130.8	127.6	125.5	123.3	122.3
82.5°	90.4	89.3	89.3	88.3	87.2
85°	57.4	57.4	55.3	55.3	54.2
87.5°	27.6	26.6	25.5	25.5	25.5
90°	0.6	4.5	10.2	11.4	11.9
92.5°	8.0	43.8	222.8	73.6	51.7
95°	18.8	59.1	463.2	229.4	138.7
97.5°	31.3	65.4	495.6	468.3	333.0
100°	43.2	73.9	456.9	647.9	521.1
102.5°	54.6	84.1	408.6	760.4	684.8
105°	66.5	96.4	372.8	802.8	799.6
107.5°	79.6	108.8	349.5	790.0	854.2
110°	92.6	121.4	338.7	744.5	855.3

TEST NUMBER: P1025874

CATALOG NUMBER: S124DIP-B795D590UB40-4F0-XX-W2A-F4

CANDELA DISTRIBUTION (continued):

	0°	22.5°	45°	67.5°	90°
112.5°	105.1	133.8	333.6	688.8	821.8
115°	117.1	146.9	332.5	638.8	767.8
117.5°	129.6	159.1	331.9	599.6	714.9
120°	142.1	171.0	331.9	573.2	671.8
122.5°	153.4	182.7	331.3	555.8	637.7
125°	163.1	193.8	330.8	543.6	612.6
127.5°	172.2	204.0	329.6	532.0	596.7
130°	179.6	214.0	329.1	518.0	583.1
132.5°	187.0	222.5	328.5	501.6	567.8
135°	193.8	230.7	327.9	482.5	547.9
137.5°	200.6	237.8	327.9	462.0	524.6
140°	208.0	244.4	327.4	442.2	499.0
142.5°	216.0	250.4	327.4	423.6	471.7
145°	223.3	255.8	326.2	407.0	447.3
147.5°	231.9	260.8	324.5	393.0	424.5
150°	239.8	265.7	322.8	380.2	405.8
152.5°	247.2	270.2	320.0	369.4	388.7
155°	254.0	274.2	317.1	359.2	374.5
157.5°	260.9	277.9	314.3	349.5	361.5
160°	267.1	281.0	310.9	339.8	349.5
162.5°	272.8	283.6	307.5	330.5	338.2
165°	276.8	285.3	304.1	322.0	326.8
167.5°	281.3	286.7	300.6	314.5	317.7
170°	284.2	287.8	297.2	307.2	309.2
172.5°	287.0	288.7	293.8	300.6	300.6
175°	288.7	289.3	291.5	295.5	294.4
177.5°	289.8	289.3	289.8	291.8	289.8
180°	289.3	289.3	289.3	289.3	289.3

(END OF REPORT)