

Scaled data based on original data using
LM-79-2019 Approved Method: Electrical and Photometric Measurements of Solid-
State Lighting Products

Test Report Prepared for
Cooper Lighting Solutions

Brand: NEO-RAY

Report Number: P1028393

Luminaire Tested: S125DIP-B850D850UB35-4F0-XX-W2A-D

Issue Date: 5/7/2025

Test Information

Test Method: LM-79-2019
Report Number: P1028393
REPORT IS A COMBINATION OF REPORTS P1002695 AND P1007351
Test Lab: INNOVATION CENTER
Issue Date: 5/7/2025
Manufacturer: COOPER LIGHTING SOLUTIONS
Product Line: NEO-RAY
Catalog Number: S125DIP-B850D850UB35-4F0-XX-W2A-D
Description: Define 5 Direct/Indirect Pendant with 3500K BioUP LEDs {m-DER=0.721} {m-EER=0.792}
Light Source: -
Ballast/Driver: -

Summary


Lumens per Lamp: N/A
Luminaire Lumens: 6493.0 lumens
Efficiency: N/A
Efficacy: 113.9 lumens/watt
Spacing Criteria (0/90/45): 1.21 / 1.21 / 1.34
Luminous Opening: Rectangular w/ Sides (W: 0.42' x L: 4' x H: 0.1')
CIE Type: General Diffuse

Input Watts (W): 57
Input Voltage (V):
Input Current (Ain): NR
Voltage Rise (V): NR
Power Factor: NR
Total Harmonic Distortion (THDi): NR
Frequency (hertz): 60
Stabilization Time: NR
Operation Time: NR
Ambient Temperature (°C): NR
Test Distance: 24 FT

TEST NUMBER: P1028393

CATALOG NUMBER: S125DIP-B850D850UB35-4F0-XX-W2A-D

Luminous Intensity Polar Plot



TEST NUMBER: P1028393

CATALOG NUMBER: S125DIP-B850D850UB35-4F0-XX-W2A-D

COEFFICIENT OF UTILIZATION - ZONAL CAVITY METHOD:

RF	20				20				20				20				20
RC	80				70				50				30				10
RW	70	50	30	10	70	50	30	10	50	30	10	50	30	10	50	30	10
RCR																	
0	107	107	107	107	98	98	98	98	82	82	82	68	68	68	54	54	54
1	97	92	88	84	89	85	81	78	71	68	66	58	57	55	47	46	44
2	88	80	74	68	80	74	68	63	62	58	54	51	48	45	41	39	37
3	80	70	62	56	73	65	58	53	54	49	45	45	41	38	36	33	31
4	73	62	54	47	67	57	50	44	48	43	38	40	36	32	32	29	27
5	67	55	47	41	61	51	43	38	43	37	33	36	31	28	29	26	23
6	61	49	41	35	56	46	38	33	39	33	29	32	28	24	26	23	20
7	57	44	36	31	52	41	34	29	35	29	25	29	25	21	24	20	18
8	53	40	32	27	48	37	30	25	32	26	22	27	22	19	22	18	16
9	49	37	29	24	45	34	27	23	29	24	20	24	20	17	20	17	14
10	46	34	26	21	42	31	25	20	27	21	18	23	18	15	19	15	13

AVERAGE LUMINANCE (cd/sqm):

	0°	45°	90°
0°	6852	6852	6852
5°	6864	6708	6725
10°	6812	6571	6553
15°	6729	6412	6341
20°	6617	6220	6131
25°	6484	6016	5877
30°	6324	5793	5646
35°	6173	5587	5434
40°	6021	5370	5219
45°	5849	5183	5026
50°	5684	4978	4852
55°	5484	4784	4650
60°	5267	4563	4442
65°	5039	4329	4209
70°	4778	4017	3966
75°	4368	3707	3669
80°	3829	3332	3341
85°	3299	3033	3169

MAXIMUM LUMINANCE 45°-90°:

Horizontal Angle: 0°
Vertical Angle: 45°
Luminance: 5849 cd/sqm

TEST NUMBER: P1028393

CATALOG NUMBER: S125DIP-B850D850UB35-4F0-XX-W2A-D

ZONAL LUMENS:

Zone	Lumens	% Fixture
0°-10°	101.2	1.6
10°-20°	287.3	4.4
20°-30°	427.2	6.6
30°-40°	505.9	7.8
40°-50°	523.1	8.1
50°-60°	481.9	7.4
60°-70°	389.5	6.0
70°-80°	260.6	4.0
80°-90°	136.2	2.1
90°-100°	111.0	1.7
100°-110°	289.5	4.5
110°-120°	458.0	7.1
120°-130°	561.0	8.6
130°-140°	589.8	9.1
140°-150°	546.7	8.4
150°-160°	440.7	6.8
160°-170°	285.0	4.4
170°-180°	98.3	1.5
0°-30°	815.7	12.6
0°-40°	1321.6	20.4
0°-60°	2326.6	35.8
0°-90°	3112.9	47.9
90°-120°	858.4	13.2
90°-150°	2555.9	39.4
90°-180°	3380.0	52.1
0°-180°	6493.0	100.0

CANDELA DISTRIBUTION:

	0°	22.5°	45°	67.5°	90°	Flux
0°	1070	1070	1070	1070	1070	
5°	1070	1067	1060	1068	1067	101
15°	1021	1022	1015	1021	1017	288
25°	928	931	925	929	924	427
35°	803	810	807	810	810	503
45°	662	673	678	686	687	511
55°	508	525	542	554	558	455
65°	350	374	400	415	419	348
75°	193	220	254	275	280	204
85°	58	92	129	152	160	60
90°	18	57	98	126	136	14
95°	57	82	89	116	123	64
105°	235	255	286	307	314	249
115°	430	441	469	485	486	426
125°	606	611	632	645	648	541
135°	753	756	762	774	775	581
145°	872	872	872	878	878	545
155°	959	954	956	958	952	442
165°	1012	1007	1008	1012	1006	286
175°	1035	1030	1031	1037	1030	99
180°	1035	1035	1035	1035	1035	

TEST NUMBER: P1028393

CATALOG NUMBER: S125DIP-B850D850UB35-4F0-XX-W2A-D

CANDELA DISTRIBUTION (FULL):

	0°	22.5°	45°	67.5°	90°
0°	1069.5	1069.5	1069.5	1069.5	1069.5
2.5°	1072.6	1070.5	1063.2	1070.5	1069.5
5°	1069.5	1067.4	1060.0	1068.4	1067.4
7.5°	1062.1	1061.1	1053.7	1061.1	1060.0
10°	1051.6	1051.6	1043.2	1050.6	1049.5
12.5°	1037.0	1038.0	1031.7	1037.0	1033.8
15°	1021.2	1022.3	1014.9	1021.2	1017.0
17.5°	1001.3	1003.4	996.1	1001.3	998.2
20°	979.3	981.4	974.0	977.2	977.2
22.5°	954.1	958.3	949.9	954.1	951.0
25°	927.9	931.1	924.8	929.0	923.7
27.5°	899.6	903.8	896.5	899.6	897.5
30°	867.1	873.4	867.1	869.2	868.1
32.5°	837.7	843.0	838.8	840.9	839.8
35°	803.1	810.5	807.3	810.5	810.5
37.5°	769.6	775.9	774.8	779.0	778.0
40°	735.0	743.4	742.3	746.5	748.6
42.5°	697.2	708.8	711.9	717.2	717.2
45°	661.6	673.1	678.4	685.7	686.8
47.5°	624.9	635.4	643.8	654.3	656.4
50°	587.2	598.7	610.2	621.8	624.9
52.5°	547.3	562.0	576.7	589.3	591.3
55°	508.5	525.3	542.1	553.6	557.8
57.5°	468.7	488.6	507.5	520.1	523.2
60°	428.8	449.8	470.8	486.5	489.6
62.5°	390.0	411.0	434.1	451.9	456.1
65°	350.2	374.3	399.5	415.2	419.4
67.5°	313.5	336.6	361.7	380.6	385.8
70°	272.6	296.7	324.0	343.9	350.2
72.5°	232.8	257.9	288.3	310.4	314.5
75°	192.9	220.2	253.7	274.7	279.9
77.5°	154.1	185.6	217.0	240.1	244.3
80°	118.5	149.9	185.6	208.6	212.8
82.5°	86.0	119.5	156.2	178.2	186.6
85°	57.7	92.3	129.0	152.0	160.4
87.5°	36.7	70.2	105.9	130.0	137.4
90°	17.6	57.2	98.3	126.2	135.8
92.5°	29.3	52.8	94.1	120.9	129.1
95°	57.3	82.3	88.8	115.7	123.0
97.5°	94.7	124.4	86.1	109.7	117.8
100°	139.6	164.0	200.6	108.3	111.5
102.5°	185.4	208.4	242.4	264.9	206.8
105°	234.9	254.8	286.3	307.2	313.8
107.5°	286.1	300.8	332.7	354.4	357.6
110°	335.6	348.2	379.1	396.7	404.8

TEST NUMBER: P1028393

CATALOG NUMBER: S125DIP-B850D850UB35-4F0-XX-W2A-D

CANDELA DISTRIBUTION (continued):

	0°	22.5°	45°	67.5°	90°
112.5°	383.1	394.9	424.0	439.8	445.6
115°	429.7	440.8	468.9	484.7	486.4
117.5°	478.5	483.8	513.0	526.2	532.1
120°	524.5	526.9	553.3	569.6	572.0
122.5°	564.1	569.0	592.8	608.1	609.8
125°	606.3	610.6	631.6	645.3	648.2
127.5°	645.9	648.7	665.7	679.9	680.1
130°	682.7	685.5	701.0	713.4	714.8
132.5°	718.5	723.1	731.3	746.0	746.4
135°	753.0	756.5	762.4	774.5	775.2
137.5°	785.2	788.7	791.4	804.0	804.4
140°	815.6	817.1	817.5	830.5	830.1
142.5°	844.0	843.7	845.3	854.7	854.3
145°	871.6	872.1	872.1	878.1	877.7
147.5°	895.1	895.1	895.9	898.8	895.5
150°	918.1	916.6	918.1	919.7	914.5
152.5°	940.4	936.5	938.1	939.6	934.2
155°	958.8	954.2	955.7	958.0	951.9
157.5°	973.4	971.1	971.1	973.4	967.2
160°	988.7	984.1	984.9	987.9	981.8
162.5°	1001.0	996.4	997.1	1001.7	994.8
165°	1011.7	1007.1	1007.9	1012.5	1006.3
167.5°	1020.2	1015.6	1016.3	1021.7	1014.8
170°	1027.1	1021.7	1022.5	1028.6	1021.7
172.5°	1031.7	1026.3	1027.8	1033.2	1026.3
175°	1034.7	1030.1	1030.9	1037.0	1030.1
177.5°	1037.0	1032.4	1033.2	1038.6	1032.4
180°	1034.7	1034.7	1034.7	1034.7	1034.7

(END OF REPORT)