

Cooper Lighting Solutions Photometric Lab
1121 Highway 74 South
Peachtree City, GA 30269



Scaled data based on original data using
LM-79-2019 Approved Method: Electrical and Photometric Measurements of Solid-
State Lighting Products

Test Report Prepared for
Cooper Lighting Solutions

Brand: NEO-RAY

Report Number: P918545

Luminaire Tested: DFN2DIP-4P3F0-020D020US935-RLONL

Issue Date: 11/21/2024

Test Information

Test Method: LM-79-2019
Report Number: P918545
REPORT IS A COMBINATION OF REPORTS P900550 AND P897473
Test Lab: INNOVATION CENTER
Issue Date: 11/21/2024
Manufacturer: COOPER LIGHTING SOLUTIONS
Product Line: NEO-RAY
Catalog Number: DFN2DIP-4P3F0-020D020US935-RLLONL
Description: 3 foot, 90deg - 4way Define Geo, with Direct 1in Regressed Frosted Lens, Indirect Open
No Lens
Light Source: -
Ballast/Driver: -

Summary


Lumens per Lamp: N/A
Luminaire Lumens: 3168.5 lumens
Efficiency: N/A
Efficacy: 102.2 lumens/watt
Spacing Criteria (0/90/45): 1.2 / 0.99 / 1.16
Luminous Opening: Rectangular w/ Sides (W: 3.07' x L: 3.07' x H: 0.1')
CIE Type: General Diffuse

Input Watts (W): 31
Input Voltage (V):
Input Current (Ain): NR
Voltage Rise (V): NR
Power Factor: 0.9951
Total Harmonic Distortion (THDi): 0.07
Frequency (hertz): 60
Stabilization Time: NR
Operation Time: NR
Ambient Temperature (°C): NR
Test Distance: 24 FT

TEST NUMBER: P918545

CATALOG NUMBER: DFN2DIP-4P3F0-020D020US935-RLLONL

Luminous Intensity Polar Plot



TEST NUMBER: P918545

CATALOG NUMBER: DFN2DIP-4P3F0-020D020US935-RLONL

COEFFICIENT OF UTILIZATION - ZONAL CAVITY METHOD:

RF	20				20					20					20					20
RC	80				70					50					30					10
RW	70	50	30	10	70	50	30	10	50	30	10	50	30	10	50	30	10	50	30	10
RCR																				
0	106	106	106	106	98	98	98	98	81	81	81	66	66	66	53	53	53			46
1	97	93	90	86	89	86	83	80	72	70	68	59	58	56	47	46	45			40
2	89	82	76	71	82	76	70	66	63	60	57	52	50	48	42	40	39			34
3	81	72	65	60	75	67	61	56	56	52	48	47	43	41	38	35	34			29
4	75	64	57	51	68	60	53	48	50	45	41	42	38	35	34	31	29			26
5	69	58	50	44	63	53	46	41	45	40	36	38	34	31	31	28	26			23
6	63	52	44	38	58	48	41	36	41	36	32	34	30	27	28	25	23			20
7	59	47	39	34	54	44	37	32	37	32	28	31	27	24	26	23	21			18
8	55	43	35	30	50	40	33	28	34	29	25	29	25	22	24	21	19			16
9	51	39	32	27	47	36	30	25	31	26	22	27	23	20	22	19	17			15
10	48	36	29	24	44	33	27	23	29	24	20	25	21	18	20	18	15			13

AVERAGE LUMINANCE (cd/sqm):

	0°	45°	90°
0°	811	811	811
5°	812	798	803
10°	803	781	777
15°	792	755	736
20°	777	719	686
25°	761	679	638
30°	740	637	577
35°	720	593	524
40°	699	547	463
45°	676	496	407
50°	651	445	353
55°	625	390	301
60°	595	333	247
65°	560	275	223
70°	518	221	201
75°	465	194	182
80°	389	161	157
85°	263	105	116

MAXIMUM LUMINANCE 45°-90°:

Horizontal Angle: 0°

Vertical Angle: 45°

Luminance: 676 cd/sqm

TEST NUMBER: P918545

CATALOG NUMBER: DFN2DIP-4P3F0-020D020US935-RLONL

ZONAL LUMENS:

Zone	Lumens	% Fixture
0°-10°	66.7	2.1
10°-20°	183.1	5.8
20°-30°	257.1	8.1
30°-40°	280.2	8.8
40°-50°	257.6	8.1
50°-60°	202.3	6.4
60°-70°	131.7	4.2
70°-80°	67.8	2.1
80°-90°	18.3	0.6
90°-100°	19.2	0.6
100°-110°	71.4	2.3
110°-120°	189.5	6.0
120°-130°	314.2	9.9
130°-140°	333.8	10.5
140°-150°	310.2	9.8
150°-160°	249.4	7.9
160°-170°	160.7	5.1
170°-180°	55.3	1.7
0°-30°	506.9	16.0
0°-40°	787.1	24.8
0°-60°	1247.0	39.4
0°-90°	1464.7	46.2
90°-120°	280.0	8.8
90°-150°	1238.3	39.1
90°-180°	1704.0	53.8
0°-180°	3168.5	100.0

CANDELA DISTRIBUTION:

	0°	22.5°	45°	67.5°	90°	Flux
0°	712	712	712	712	712	
5°	712	708	700	706	704	67
15°	677	670	648	636	629	191
25°	614	594	551	525	515	283
35°	529	497	440	399	385	331
45°	433	390	322	276	261	334
55°	329	279	209	171	158	294
65°	222	170	112	90	88	220
75°	118	73	52	47	46	125
85°	28	14	12	12	12	32
90°	0	5	8	10	11	3
95°	27	13	16	18	18	32
105°	128	140	26	30	32	137
115°	242	249	260	65	34	238
125°	342	347	355	358	360	305
135°	423	430	434	438	437	327
145°	491	490	498	500	498	307
155°	540	537	542	544	541	249
165°	569	567	568	571	568	161
175°	582	580	580	583	579	55
180°	581	581	581	581	581	

TEST NUMBER: P918545

CATALOG NUMBER: DFN2DIP-4P3F0-020D020US935-RLLONL

CANDELA DISTRIBUTION (FULL):

	0°	22.5°	45°	67.5°	90°
0°	711.7	711.7	711.7	711.7	711.7
2.5°	714.9	711.7	704.6	711.1	709.8
5°	711.7	708.5	700.1	705.9	704.0
7.5°	705.9	702.1	693.0	695.6	692.3
10°	698.2	693.6	680.8	678.8	675.0
12.5°	688.5	682.7	665.3	661.5	654.4
15°	676.9	669.8	647.9	635.7	629.3
17.5°	663.4	653.1	626.0	611.8	601.6
20°	647.9	635.0	602.9	586.8	572.6
22.5°	631.2	616.4	579.0	557.2	547.5
25°	614.5	593.8	551.3	525.0	515.2
27.5°	594.5	572.6	525.6	495.2	480.4
30°	573.3	548.7	497.2	464.4	446.9
32.5°	552.6	523.0	470.2	431.5	415.4
35°	529.4	496.6	440.0	399.3	385.1
37.5°	506.9	471.4	411.6	367.1	351.0
40°	483.0	444.4	381.9	336.2	319.4
42.5°	458.6	417.4	352.3	304.6	288.6
45°	432.8	389.6	322.1	276.3	260.8
47.5°	408.4	362.7	293.1	247.3	233.2
50°	381.3	335.6	264.8	220.2	206.8
52.5°	354.8	306.5	237.6	195.2	183.0
55°	329.1	278.9	209.3	170.7	158.4
57.5°	302.7	251.2	184.3	148.2	137.8
60°	275.7	224.1	157.8	125.0	114.7
62.5°	249.3	197.8	135.3	104.4	99.2
65°	222.2	170.0	112.1	90.2	88.3
67.5°	196.5	144.2	90.2	79.2	77.3
70°	169.4	119.2	74.6	68.3	65.7
72.5°	143.6	95.9	62.4	57.3	56.1
75°	118.5	73.4	51.5	47.0	46.4
77.5°	93.4	52.2	40.6	38.0	36.7
80°	70.2	37.4	30.9	28.3	28.3
82.5°	48.9	25.1	21.3	20.0	20.0
85°	27.6	14.1	12.2	12.2	12.2
87.5°	10.3	5.2	5.2	4.5	4.5
90°	0.4	5.1	8.4	10.5	11.4
92.5°	10.5	8.9	10.1	10.9	11.4
95°	27.3	13.4	16.4	18.5	18.1
97.5°	49.2	14.7	21.4	22.7	23.2
100°	74.5	16.8	23.9	27.3	28.2
102.5°	102.2	101.3	24.8	29.4	30.7
105°	127.9	140.4	25.7	30.2	31.9
107.5°	157.7	168.2	26.5	31.1	32.8
110°	186.3	195.1	73.6	31.6	33.2



TEST NUMBER: P918545

CATALOG NUMBER: DFN2DIP-4P3F0-020D020US935-RLLONL

CANDELA DISTRIBUTION (continued):

	0°	22.5°	45°	67.5°	90°
112.5°	213.2	220.8	213.6	32.4	33.7
115°	241.8	248.9	259.5	64.7	34.5
117.5°	266.6	275.0	282.1	222.1	111.8
120°	294.4	300.7	308.2	313.3	256.5
122.5°	317.9	324.6	333.0	335.5	336.0
125°	341.9	347.3	355.3	358.3	359.6
127.5°	363.8	369.6	376.0	380.1	380.6
130°	384.3	391.1	395.7	400.4	399.9
132.5°	405.4	410.9	415.4	419.2	418.9
135°	423.1	429.8	433.5	437.8	437.0
137.5°	441.5	446.6	450.8	455.0	453.7
140°	459.6	463.0	467.6	471.4	469.3
142.5°	474.8	477.8	483.2	486.5	484.4
145°	490.8	490.3	497.5	500.4	498.3
147.5°	504.6	503.3	510.5	512.6	510.9
150°	518.1	515.1	521.9	524.3	522.3
152.5°	529.4	526.1	532.4	534.9	531.9
155°	540.4	536.6	541.7	544.2	540.8
157.5°	549.2	545.9	549.7	552.6	549.2
160°	556.8	554.2	556.8	559.3	556.4
162.5°	563.4	560.9	563.1	566.0	562.2
165°	569.4	566.9	568.1	571.1	568.1
167.5°	574.0	571.4	572.7	575.7	571.9
170°	577.8	575.2	576.1	579.0	575.2
172.5°	580.3	577.8	578.7	581.6	577.8
175°	582.4	579.5	580.3	583.2	579.0
177.5°	583.2	580.3	580.7	583.7	579.9
180°	581.2	581.2	581.2	581.2	581.2

TEST NUMBER: P918545

CATALOG NUMBER: DFN2DIP-4P3F0-020D020US935-RLONL

CIE UGR TABLE:

Reflectances:											
Ceiling		0.7	0.7	0.5	0.5	0.3	0.7	0.7	0.5	0.5	0.3
Wall		0.5	0.3	0.5	0.3	0.3	0.5	0.3	0.5	0.3	0.3
Reference plane		0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2
Room dimensions		Viewed crosswise					Viewed endwise				
X=2H	Y=2H	6.02	6.82	7.02	7.83	9.15	1.99	2.79	2.98	3.79	5.11
	3H	7.69	8.41	8.70	9.42	10.77	3.17	3.88	4.17	4.89	6.24
	4H	8.30	8.97	9.32	9.99	11.35	3.61	4.29	4.63	5.30	6.66
	6H	8.71	9.34	9.74	10.36	11.72	3.92	4.55	4.95	5.56	6.93
	8H	8.84	9.43	9.87	10.47	11.83	4.01	4.60	5.04	5.64	7.00
	12H	8.90	9.46	9.94	10.49	11.88	4.05	4.61	5.09	5.64	7.03
4H	2H	6.04	6.71	7.06	7.73	9.08	2.57	3.25	3.60	4.27	5.62
	3H	7.86	8.42	8.89	9.46	10.83	3.91	4.48	4.95	5.52	6.89
	4H	8.54	9.06	9.58	10.09	11.49	4.46	4.97	5.50	6.01	7.40
	6H	9.05	9.50	10.10	10.55	11.94	4.87	5.31	5.92	6.37	7.75
	8H	9.23	9.64	10.28	10.69	12.09	4.99	5.40	6.04	6.45	7.86
	12H	9.32	9.69	10.38	10.75	12.16	5.05	5.42	6.12	6.49	7.90
8H	4H	8.51	8.92	9.56	9.97	11.37	4.73	5.14	5.78	6.19	7.60
	6H	9.07	9.41	10.14	10.50	11.90	5.24	5.58	6.31	6.67	8.07
	8H	9.28	9.58	10.36	10.66	12.08	5.43	5.72	6.51	6.80	8.22
	12H	9.41	9.68	10.50	10.75	12.21	5.54	5.80	6.62	6.87	8.33
12H	4H	8.46	8.83	9.53	9.90	11.30	4.73	5.11	5.80	6.17	7.58
	6H	9.04	9.34	10.12	10.42	11.84	5.29	5.59	6.37	6.66	8.08
	8H	9.26	9.52	10.34	10.59	12.05	5.49	5.75	6.58	6.83	8.29

END OF REPORT