

Cooper Lighting Solutions Photometric Lab
1121 Highway 74 South
Peachtree City, GA 30269



Scaled data based on original data using
LM-79-2019 Approved Method: Electrical and Photometric Measurements of Solid-
State Lighting Products

Test Report Prepared for
Cooper Lighting Solutions

Brand: NEO-RAY

Report Number: P924265

Luminaire Tested: DFN2DIP-HX2F0-030D020US950-RLLONL

Issue Date: 11/21/2024

Test Information

Test Method: LM-79-2019
Report Number: P924265
REPORT IS A COMBINATION OF REPORTS P900674 AND P897595
Test Lab: INNOVATION CENTER
Issue Date: 11/21/2024
Manufacturer: COOPER LIGHTING SOLUTIONS
Product Line: NEO-RAY
Catalog Number: DFN2DIP-HX2F0-030D020US950-RLLONL
Description: 2 foot, Hexagon Define Geo, with Direct 1in Regressed Frosted Lens, Indirect Open No Lens
Light Source: -
Ballast/Driver: -

Summary


Lumens per Lamp: N/A
Luminaire Lumens: 4321.6 lumens
Efficiency: N/A
Efficacy: 106.7 lumens/watt
Spacing Criteria (0/90/45): 1.2 / 0.99 / 1.16
Luminous Opening: Rectangular w/ Sides (W: 1.99' x L: 2.3' x H: 0.1')
CIE Type: General Diffuse

Input Watts (W): 40.5
Input Voltage (V):
Input Current (Ain): NR
Voltage Rise (V): NR
Power Factor: 0.9951
Total Harmonic Distortion (THDi): 0.07
Frequency (hertz): 60
Stabilization Time: NR
Operation Time: NR
Ambient Temperature (°C): NR
Test Distance: 24 FT

TEST NUMBER: P924265

CATALOG NUMBER: DFN2DIP-HX2F0-030D020US950-RLLONL

Luminous Intensity Polar Plot



TEST NUMBER: P924265

CATALOG NUMBER: DFN2DIP-HX2F0-030D020US950-RLLONL

COEFFICIENT OF UTILIZATION - ZONAL CAVITY METHOD:

RF	20					20					20					20					20
RC	80					70					50					30					10
RW	70	50	30	10		70	50	30	10		50	30	10		50	30	10		50	30	10
RCR																					
0	109	109	109	109		101	101	101	101		87	87	87		74	74	74		62	62	62
1	100	96	92	88		93	89	86	83		77	75	72		66	64	63		56	54	53
2	91	84	78	73		85	79	73	69		68	64	61		58	56	53		50	48	46
3	84	74	67	62		78	70	63	58		61	56	52		52	49	46		44	42	40
4	77	66	59	53		71	62	55	50		54	49	45		47	43	40		40	37	35
5	71	59	51	46		66	56	49	43		49	43	39		42	38	35		36	33	31
6	65	54	46	40		61	50	43	38		44	39	34		39	34	31		33	30	27
7	61	49	41	35		56	46	39	34		40	35	30		35	31	27		30	27	24
8	56	44	37	31		52	42	35	30		37	31	27		32	28	25		28	25	22
9	53	41	33	28		49	38	32	27		34	28	25		30	25	22		26	23	20
10	49	37	30	25		46	35	29	24		31	26	22		28	23	20		24	21	18

AVERAGE LUMINANCE (cd/sqm):

	0°	45°	90°
0°	2787	2787	2787
5°	2787	2736	2755
10°	2755	2676	2661
15°	2713	2581	2517
20°	2658	2453	2343
25°	2602	2311	2175
30°	2529	2165	1964
35°	2456	2010	1779
40°	2382	1850	1567
45°	2297	1673	1375
50°	2208	1495	1188
55°	2115	1305	1010
60°	2007	1109	826
65°	1883	909	738
70°	1732	723	660
75°	1542	625	591
80°	1270	506	497
85°	830	312	349

MAXIMUM LUMINANCE 45°-90°:

Horizontal Angle: 0°

Vertical Angle: 45°

Luminance: 2297 cd/sqm

TEST NUMBER: P924265

CATALOG NUMBER: DFN2DIP-HX2F0-030D020US950-RLLONL

ZONAL LUMENS:

Zone	Lumens	% Fixture
0°-10°	110.9	2.6
10°-20°	304.3	7.0
20°-30°	427.3	9.9
30°-40°	465.7	10.8
40°-50°	428.1	9.9
50°-60°	336.2	7.8
60°-70°	218.8	5.1
70°-80°	112.6	2.6
80°-90°	29.9	0.7
90°-100°	21.2	0.5
100°-110°	79.1	1.8
110°-120°	209.9	4.9
120°-130°	348.2	8.1
130°-140°	369.8	8.6
140°-150°	343.7	8.0
150°-160°	276.4	6.4
160°-170°	178.1	4.1
170°-180°	61.3	1.4
0°-30°	842.5	19.5
0°-40°	1308.2	30.3
0°-60°	2072.5	48.0
0°-90°	2433.8	56.3
90°-120°	310.3	7.2
90°-150°	1372.0	31.7
90°-180°	1888.0	43.7
0°-180°	4321.6	100.0

CANDELA DISTRIBUTION:

	0°	22.5°	45°	67.5°	90°	Flux
0°	1183	1183	1183	1183	1183	
5°	1183	1178	1164	1173	1170	112
15°	1125	1113	1077	1057	1046	317
25°	1021	987	916	872	856	470
35°	880	825	731	664	640	551
45°	719	648	535	459	434	556
55°	547	464	348	284	263	489
65°	369	283	186	150	147	366
75°	197	122	86	78	77	208
85°	46	24	20	20	20	53
90°	0	6	9	12	13	4
95°	30	15	18	20	20	36
105°	142	156	28	34	35	151
115°	268	276	288	72	38	264
125°	379	385	394	397	398	338
135°	469	476	480	485	484	362
145°	544	543	551	554	552	340
155°	599	594	600	603	599	276
165°	631	628	629	633	629	178
175°	645	642	643	646	642	61
180°	644	644	644	644	644	

TEST NUMBER: P924265

CATALOG NUMBER: DFN2DIP-HX2F0-030D020US950-RLLONL

CANDELA DISTRIBUTION (FULL):

	0°	22.5°	45°	67.5°	90°
0°	1182.9	1182.9	1182.9	1182.9	1182.9
2.5°	1188.2	1182.9	1171.0	1181.8	1179.7
5°	1182.9	1177.5	1163.6	1173.2	1170.0
7.5°	1173.2	1166.8	1151.9	1156.1	1150.7
10°	1160.4	1152.9	1131.5	1128.2	1121.9
12.5°	1144.3	1134.7	1105.8	1099.4	1087.6
15°	1125.1	1113.2	1076.9	1056.6	1045.9
17.5°	1102.5	1085.5	1040.4	1017.0	999.8
20°	1076.9	1055.4	1001.9	975.3	951.6
22.5°	1049.1	1024.4	962.3	926.0	909.9
25°	1021.3	986.9	916.3	872.4	856.3
27.5°	988.1	951.6	873.5	823.2	798.5
30°	952.8	912.0	826.4	771.9	742.9
32.5°	918.4	869.2	781.5	717.2	690.4
35°	880.0	825.3	731.1	663.7	640.1
37.5°	842.5	783.5	684.0	610.1	583.5
40°	802.9	738.7	634.8	558.8	531.0
42.5°	762.2	693.7	585.6	506.3	479.6
45°	719.4	647.6	535.3	459.2	433.5
47.5°	678.7	602.7	487.1	411.0	387.5
50°	633.7	557.7	440.0	366.0	343.6
52.5°	589.8	509.5	395.1	324.4	304.0
55°	546.9	463.5	347.8	283.7	263.4
57.5°	503.1	417.5	306.2	246.2	229.1
60°	458.1	372.5	262.3	207.7	190.6
62.5°	414.3	328.7	224.8	173.4	164.9
65°	369.3	282.6	186.2	149.9	146.6
67.5°	326.6	239.7	149.9	131.7	128.4
70°	281.5	198.1	124.1	113.4	109.1
72.5°	238.7	159.4	103.8	95.3	93.1
75°	196.9	122.0	85.7	78.1	77.1
77.5°	155.2	86.6	67.4	63.2	61.0
80°	116.7	62.1	51.3	47.1	47.1
82.5°	81.3	41.8	35.3	33.2	33.2
85°	46.0	23.5	20.3	20.3	20.3
87.5°	17.2	8.5	8.5	7.5	7.5
90°	0.5	5.6	9.3	11.6	12.6
92.5°	11.6	9.8	11.2	12.1	12.6
95°	30.2	14.9	18.1	20.5	20.0
97.5°	54.5	16.3	23.8	25.2	25.7
100°	82.5	18.6	26.5	30.2	31.2
102.5°	113.2	112.3	27.5	32.6	34.1
105°	141.7	155.6	28.4	33.5	35.4
107.5°	174.8	186.3	29.4	34.4	36.3
110°	206.4	216.2	81.6	35.0	36.8

TEST NUMBER: P924265

CATALOG NUMBER: DFN2DIP-HX2F0-030D020US950-RLLONL

CANDELA DISTRIBUTION (continued):

	0°	22.5°	45°	67.5°	90°
112.5°	236.2	244.6	236.7	35.9	37.3
115°	267.9	275.8	287.5	71.7	38.3
117.5°	295.4	304.7	312.6	246.0	123.9
120°	326.2	333.1	341.5	347.2	284.2
122.5°	352.2	359.7	369.0	371.8	372.3
125°	378.8	384.8	393.7	397.0	398.4
127.5°	403.1	409.6	416.6	421.2	421.7
130°	425.9	433.3	438.5	443.6	443.1
132.5°	449.1	455.2	460.3	464.5	464.1
135°	468.8	476.2	480.3	485.1	484.2
137.5°	489.2	494.8	499.5	504.2	502.8
140°	509.2	513.1	518.1	522.3	520.0
142.5°	526.0	529.4	535.4	539.1	536.7
145°	543.8	543.3	551.2	554.5	552.2
147.5°	559.1	557.7	565.6	567.9	566.1
150°	574.0	570.8	578.2	581.0	578.7
152.5°	586.6	582.9	589.9	592.7	589.4
155°	598.7	594.5	600.2	602.9	599.2
157.5°	608.6	604.8	609.0	612.3	608.6
160°	617.0	614.1	617.0	619.7	616.5
162.5°	624.3	621.5	623.9	627.2	623.0
165°	630.9	628.1	629.4	632.8	629.4
167.5°	636.0	633.2	634.6	637.9	633.6
170°	640.2	637.4	638.3	641.6	637.4
172.5°	643.0	640.2	641.2	644.4	640.2
175°	645.3	642.0	643.0	646.2	641.6
177.5°	646.2	643.0	643.5	646.7	642.5
180°	643.9	643.9	643.9	643.9	643.9

TEST NUMBER: P924265

CATALOG NUMBER: DFN2DIP-HX2F0-030D020US950-RLONL

CIE UGR TABLE:

Reflectances:											
Ceiling		0.7	0.7	0.5	0.5	0.3	0.7	0.7	0.5	0.5	0.3
Wall		0.5	0.3	0.5	0.3	0.3	0.5	0.3	0.5	0.3	0.3
Reference plane		0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2
Room dimensions		Viewed crosswise					Viewed endwise				
X=2H	Y=2H	11.14	12.03	12.05	12.95	14.13	7.12	8.01	8.03	8.93	10.11
	3H	12.80	13.59	13.72	14.52	15.73	8.30	9.09	9.22	10.02	11.23
	4H	13.39	14.14	14.33	15.08	16.29	8.74	9.49	9.68	10.42	11.64
	6H	13.80	14.48	14.74	15.43	16.65	9.05	9.74	10.00	10.68	11.91
	8H	13.91	14.57	14.87	15.53	16.75	9.13	9.79	10.09	10.75	11.97
	12H	13.97	14.59	14.92	15.54	16.79	9.17	9.79	10.13	10.75	12.00
4H	2H	11.16	11.91	12.10	12.85	14.06	7.71	8.46	8.65	9.40	10.61
	3H	12.97	13.59	13.92	14.56	15.79	9.05	9.67	10.00	10.63	11.86
	4H	13.64	14.21	14.60	15.17	16.42	9.58	10.15	10.54	11.11	12.36
	6H	14.14	14.62	15.11	15.61	16.86	9.99	10.47	10.96	11.46	12.71
	8H	14.30	14.75	15.27	15.73	17.00	10.11	10.56	11.08	11.54	12.81
	12H	14.38	14.79	15.38	15.79	17.06	10.16	10.57	11.16	11.57	12.84
8H	4H	13.61	14.07	14.59	15.04	16.31	9.85	10.31	10.83	11.28	12.55
	6H	14.15	14.53	15.15	15.55	16.81	10.35	10.72	11.35	11.74	13.01
	8H	14.35	14.68	15.36	15.69	16.98	10.53	10.86	11.54	11.87	13.15
	12H	14.48	14.77	15.49	15.77	17.10	10.63	10.93	11.65	11.93	13.26
12H	4H	13.56	13.97	14.56	14.97	16.24	9.85	10.26	10.85	11.26	12.53
	6H	14.13	14.46	15.13	15.47	16.75	10.39	10.72	11.40	11.73	13.02
	8H	14.33	14.62	15.34	15.62	16.95	10.59	10.88	11.60	11.88	13.21