

Scaled data based on original data using
LM-79-2019 Approved Method: Electrical and Photometric Measurements of Solid-
State Lighting Products

Test Report Prepared for
Cooper Lighting Solutions

Brand: NEO-RAY

Report Number: P1031479

Luminaire Tested: S123DIW-B1165D1535UB35-4F0-XX-W2A-D

Issue Date: 5/7/2025

Test Information

Test Method: LM-79-2019
Report Number: P1031479
REPORT IS A COMBINATION OF REPORTS P991023 AND P1007351
Test Lab: INNOVATION CENTER
Issue Date: 5/7/2025
Manufacturer: COOPER LIGHTING SOLUTIONS
Product Line: NEO-RAY
Catalog Number: S123DIW-B1165D1535UB35-4F0-XX-W2A-D
Description: Define 3 Direct/Indirect Wall Mount with 3500K BioUP LEDs {m-DER=0.721} {m-EER=0.792}
Light Source: -
Ballast/Driver: -

Summary


Lumens per Lamp: N/A
Luminaire Lumens: 11136.0 lumens
Efficiency: N/A
Efficacy: 98.1 lumens/watt
Spacing Criteria (0/90/45): 1.2 / 1.25 / 1.37
Luminous Opening: Rectangular w/ Sides (W: 0.25' x L: 4' x H: 0.1')
CIE Type: General Diffuse

Input Watts (W): 113.5
Input Voltage (V):
Input Current (Ain): NR
Voltage Rise (V): NR
Power Factor: NR
Total Harmonic Distortion (THDi): NR
Frequency (hertz): 60
Stabilization Time: NR
Operation Time: NR
Ambient Temperature (°C): NR
Test Distance: 24 FT

TEST NUMBER: P1031479

CATALOG NUMBER: S123DIW-B1165D1535UB35-4F0-XX-W2A-D

Luminous Intensity Polar Plot



TEST NUMBER: P1031479

CATALOG NUMBER: S123DIW-B1165D1535UB35-4F0-XX-W2A-D

COEFFICIENT OF UTILIZATION - ZONAL CAVITY METHOD:

RF	20				20				20				20				20
RC	80				70				50				30				10
RW	70	50	30	10	70	50	30	10	50	30	10	50	30	10	50	30	10
RCR																	
0	105	105	105	105	95	95	95	95	78	78	78	62	62	62	47	47	47
1	95	90	86	82	86	82	78	75	67	64	62	53	51	50	40	39	38
2	86	78	72	66	78	71	66	61	58	54	51	46	43	41	35	33	31
3	78	68	61	55	71	62	56	51	51	46	42	40	37	34	31	28	26
4	71	60	52	46	64	55	48	43	45	40	36	36	32	29	27	25	22
5	65	54	45	39	59	49	42	36	40	35	31	32	28	25	24	22	19
6	60	48	40	34	54	44	37	31	36	31	26	29	25	22	22	19	17
7	55	43	35	30	50	39	32	27	33	27	23	26	22	19	20	17	15
8	51	39	31	26	47	36	29	24	30	24	20	24	20	17	18	16	13
9	48	36	28	23	43	33	26	21	27	22	18	22	18	15	17	14	12
10	45	33	25	20	40	30	23	19	25	20	16	20	16	14	16	13	11

AVERAGE LUMINANCE (cd/sqm):

	0°	45°	90°
0°	15632	15632	15632
5°	15675	15174	15162
10°	15529	14763	14650
15°	15323	14310	14108
20°	15032	13803	13526
25°	14672	13234	12922
30°	14306	12718	12317
35°	13893	12177	11822
40°	13500	11682	11301
45°	13063	11204	10872
50°	12632	10728	10406
55°	12154	10242	9976
60°	11687	9744	9537
65°	11204	9214	9022
70°	10484	8617	8492
75°	9567	7939	7945
80°	8502	7252	7320
85°	7444	6697	6873

MAXIMUM LUMINANCE 45°-90°:

Horizontal Angle: 0°

Vertical Angle: 45°

Luminance: 13063 cd/sqm

TEST NUMBER: P1031479

CATALOG NUMBER: S123DIW-B1165D1535UB35-4F0-XX-W2A-D

ZONAL LUMENS:

Zone	Lumens	% Fixture
0°-10°	137.8	1.2
10°-20°	392.8	3.5
20°-30°	587.3	5.3
30°-40°	701.2	6.3
40°-50°	733.7	6.6
50°-60°	688.5	6.2
60°-70°	575.1	5.2
70°-80°	411.2	3.7
80°-90°	248.8	2.2
90°-100°	226.1	2.0
100°-110°	462.6	4.2
110°-120°	932.1	8.4
120°-130°	1130.6	10.2
130°-140°	1181.1	10.6
140°-150°	1090.4	9.8
150°-160°	876.3	7.9
160°-170°	565.5	5.1
170°-180°	194.9	1.7
0°-30°	1117.9	10.0
0°-40°	1819.1	16.3
0°-60°	3241.3	29.1
0°-90°	4476.4	40.2
90°-120°	1620.8	14.6
90°-150°	5022.9	45.1
90°-180°	6660.0	59.8
0°-180°	11136.0	100.0

CANDELA DISTRIBUTION:

	0°	22.5°	45°	67.5°	90°	Flux
0°	1452	1452	1452	1452	1452	
5°	1454	1451	1441	1454	1452	138
15°	1384	1389	1388	1403	1402	390
25°	1250	1266	1270	1291	1291	576
35°	1076	1101	1122	1145	1152	673
45°	880	918	957	987	1000	678
55°	671	723	780	823	835	601
65°	464	525	595	642	658	458
75°	252	326	405	457	476	269
85°	78	157	240	294	310	80
90°	22	115	215	275	294	20
95°	110	110	204	264	279	125
105°	467	521	452	227	244	494
115°	860	888	958	1011	1030	849
125°	1205	1217	1269	1306	1320	1077
135°	1498	1505	1529	1562	1565	1153
145°	1726	1735	1738	1754	1760	1080
155°	1900	1897	1898	1906	1897	875
165°	2003	1999	1997	2009	1999	566
175°	2050	2043	2044	2055	2043	195
180°	2050	2050	2050	2050	2050	

TEST NUMBER: P1031479

CATALOG NUMBER: S123DIW-B1165D1535UB35-4F0-XX-W2A-D

CANDELA DISTRIBUTION (FULL):

	0°	22.5°	45°	67.5°	90°
0°	1452.3	1452.3	1452.3	1452.3	1452.3
2.5°	1460.3	1455.5	1442.8	1455.5	1453.9
5°	1453.9	1450.8	1441.3	1453.9	1452.3
7.5°	1442.8	1442.8	1433.4	1449.2	1447.6
10°	1427.0	1430.2	1422.3	1438.1	1434.9
12.5°	1408.0	1412.8	1408.0	1422.3	1419.1
15°	1384.3	1389.1	1387.5	1403.3	1401.7
17.5°	1355.8	1365.3	1363.7	1378.0	1374.8
20°	1324.2	1333.7	1336.8	1351.1	1352.7
22.5°	1291.0	1300.5	1305.2	1324.2	1322.6
25°	1249.8	1265.7	1270.4	1291.0	1291.0
27.5°	1210.3	1227.7	1237.2	1254.6	1256.2
30°	1167.6	1188.1	1200.8	1219.8	1219.8
32.5°	1120.1	1143.8	1161.2	1181.8	1186.6
35°	1075.8	1101.1	1121.7	1145.4	1151.7
37.5°	1028.3	1056.8	1080.6	1107.4	1112.2
40°	980.9	1009.4	1041.0	1067.9	1074.2
42.5°	928.7	965.1	998.3	1028.3	1037.8
45°	879.6	917.6	957.2	987.2	999.9
47.5°	827.4	870.1	914.4	947.7	957.2
50°	776.8	821.1	870.1	906.5	917.6
52.5°	723.0	770.5	825.8	863.8	878.0
55°	670.8	723.0	780.0	822.7	835.3
57.5°	620.2	674.0	735.7	778.4	792.6
60°	566.4	623.3	688.2	732.5	749.9
62.5°	515.8	574.3	643.9	688.2	704.0
65°	463.5	525.2	594.9	642.3	658.1
67.5°	411.3	476.2	545.8	598.0	610.7
70°	356.0	424.0	499.9	550.6	566.4
72.5°	305.3	373.4	452.5	504.7	520.5
75°	251.5	325.9	405.0	457.2	476.2
77.5°	205.7	280.0	359.1	414.5	428.7
80°	156.6	234.1	316.4	370.2	386.0
82.5°	113.9	193.0	276.9	330.7	346.5
85°	77.5	156.6	240.5	294.3	310.1
87.5°	47.5	126.6	207.3	261.0	276.9
90°	22.1	114.9	215.4	275.3	294.1
92.5°	54.0	112.9	205.7	268.6	284.4
95°	110.3	109.6	203.8	263.6	279.4
97.5°	184.9	199.2	195.8	255.5	272.9
100°	271.6	352.8	187.9	246.0	263.3
102.5°	370.7	434.8	240.8	234.9	253.8
105°	466.7	521.3	452.3	227.0	244.2
107.5°	567.1	614.0	701.8	509.9	324.5
110°	667.6	708.3	788.3	779.2	573.9

TEST NUMBER: P1031479

CATALOG NUMBER: S123DIW-B1165D1535UB35-4F0-XX-W2A-D

CANDELA DISTRIBUTION (continued):

	0°	22.5°	45°	67.5°	90°
112.5°	765.1	797.8	874.8	928.0	939.3
115°	859.5	887.6	958.2	1011.4	1030.2
117.5°	953.9	977.3	1038.7	1088.8	1103.0
120°	1039.1	1060.7	1117.5	1166.1	1177.2
122.5°	1127.5	1141.3	1196.4	1238.9	1251.5
125°	1205.1	1217.3	1269.3	1305.5	1319.7
127.5°	1284.3	1295.0	1342.1	1378.4	1386.3
130°	1357.4	1368.1	1405.8	1442.0	1448.5
132.5°	1426.0	1438.2	1466.5	1501.1	1507.5
135°	1497.6	1505.1	1528.6	1561.7	1565.0
137.5°	1558.5	1569.1	1583.3	1616.2	1621.0
140°	1617.9	1627.0	1636.3	1666.2	1671.0
142.5°	1674.2	1681.8	1686.3	1711.5	1714.8
145°	1726.0	1735.1	1738.1	1753.9	1760.2
147.5°	1774.7	1782.3	1785.4	1793.1	1791.9
150°	1820.4	1825.0	1828.0	1831.1	1829.7
152.5°	1861.5	1863.1	1864.6	1870.7	1863.1
155°	1899.6	1896.6	1898.1	1905.7	1896.6
157.5°	1930.1	1930.1	1928.6	1937.7	1925.5
160°	1957.5	1956.0	1954.5	1963.6	1952.9
162.5°	1983.4	1978.8	1977.3	1988.0	1978.8
165°	2003.2	1998.6	1997.1	2009.3	1998.6
167.5°	2020.0	2013.9	2013.9	2026.1	2013.9
170°	2033.7	2027.6	2027.6	2039.8	2027.6
172.5°	2042.8	2035.2	2036.7	2048.9	2035.2
175°	2050.4	2042.8	2044.3	2055.0	2042.8
177.5°	2053.5	2045.9	2047.4	2059.6	2044.3
180°	2050.4	2050.4	2050.4	2050.4	2050.4

(END OF REPORT)