

Scaled data based on original data using
LM-79-2019 Approved Method: Electrical and Photometric Measurements of Solid-
State Lighting Products

Test Report Prepared for
Cooper Lighting Solutions

Brand: NEO-RAY

Report Number: P1032008

Luminaire Tested: S123RDIW-B1000D1320UB30-4F0-XX-W2A-F

Issue Date: 5/7/2025

Test Information

Test Method: LM-79-2019
Report Number: P1032008
REPORT IS A COMBINATION OF REPORTS P993786 AND P1007351
Test Lab: INNOVATION CENTER
Issue Date: 5/7/2025
Manufacturer: COOPER LIGHTING SOLUTIONS
Product Line: NEO-RAY
Catalog Number: S123RDIW-B1000D1320UB30-4F0-XX-W2A-F
Description: Define 3 Regressed Direct/Indirect Wall Mount with 3000K BioUP LEDs {m-DER=0.589}
{m-EER=0.647}
Light Source: -
Ballast/Driver: -

Summary


Lumens per Lamp: N/A
Luminaire Lumens: 9051.0 lumens
Efficiency: N/A
Efficacy: 101.8 lumens/watt
Spacing Criteria (0/90/45): 1.21 / 1.07 / 1.22
Luminous Opening: Rectangular w/ Sides (W: 0.25' x L: 4' x H: 0.1')
CIE Type: General Diffuse

Input Watts (W): 88.9
Input Voltage (V):
Input Current (Ain): NR
Voltage Rise (V): NR
Power Factor: NR
Total Harmonic Distortion (THDi): NR
Frequency (hertz): 60
Stabilization Time: NR
Operation Time: NR
Ambient Temperature (°C): NR
Test Distance: 24 FT

TEST NUMBER: P1032008

CATALOG NUMBER: S123RDIW-B1000D1320UB30-4F0-XX-W2A-F

Luminous Intensity Polar Plot



TEST NUMBER: P1032008

CATALOG NUMBER: S123RDIW-B1000D1320UB30-4F0-XX-W2A-F

COEFFICIENT OF UTILIZATION - ZONAL CAVITY METHOD:

RF	20				20				20				20				20
RC	80				70				50				30				10
RW	70	50	30	10	70	50	30	10	50	30	10	50	30	10	50	30	10
RCR																	
0	105	105	105	105	96	96	96	96	79	79	79	63	63	63	48	48	48
1	96	92	88	85	88	84	81	78	69	67	65	56	54	53	43	42	41
2	88	81	75	70	80	74	69	64	61	57	54	49	47	45	38	37	35
3	80	71	64	58	73	65	59	54	54	50	46	44	41	38	34	32	30
4	73	63	55	50	67	58	51	46	48	43	39	39	36	33	31	28	26
5	67	56	48	43	61	52	45	40	43	38	34	35	31	28	28	25	23
6	62	50	43	37	57	46	40	35	39	34	30	32	28	25	25	23	20
7	58	46	38	32	52	42	35	30	35	30	26	29	25	22	23	20	18
8	53	41	34	29	49	38	32	27	32	27	23	27	23	20	21	18	16
9	50	38	30	26	45	35	28	24	30	24	21	24	21	18	20	17	15
10	46	35	28	23	42	32	26	22	27	22	19	23	19	16	18	16	14

AVERAGE LUMINANCE (cd/sqm):

	0°	45°	90°
0°	17957	17957	17957
5°	17987	17322	17276
10°	17845	16671	16343
15°	17614	15866	15321
20°	17310	14990	14179
25°	16997	14081	13097
30°	16594	13112	11818
35°	16180	12162	10653
40°	15791	11130	9366
45°	15292	10120	8209
50°	14741	9043	7011
55°	14171	7889	5914
60°	13625	6705	4801
65°	12921	5491	3747
70°	12033	4151	2678
75°	10758	2811	2122
80°	9180	1953	1489
85°	6887	1055	780

MAXIMUM LUMINANCE 45°-90°:

Horizontal Angle: 0°

Vertical Angle: 45°

Luminance: 15292 cd/sqm

TEST NUMBER: P1032008

CATALOG NUMBER: S123RDIW-B1000D1320UB30-4F0-XX-W2A-F

ZONAL LUMENS:

Zone	Lumens	% Fixture
0°-10°	156.8	1.7
10°-20°	436.3	4.8
20°-30°	628.2	6.9
30°-40°	707.4	7.8
40°-50°	676.7	7.5
50°-60°	553.9	6.1
60°-70°	373.5	4.1
70°-80°	187.3	2.1
80°-90°	52.4	0.6
90°-100°	61.1	0.7
100°-110°	295.2	3.3
110°-120°	723.4	8.0
120°-130°	918.4	10.1
130°-140°	981.1	10.8
140°-150°	917.4	10.1
150°-160°	740.0	8.2
160°-170°	477.5	5.3
170°-180°	164.6	1.8
0°-30°	1221.3	13.5
0°-40°	1928.7	21.3
0°-60°	3159.3	34.9
0°-90°	3772.5	41.7
90°-120°	1079.7	11.9
90°-150°	3896.5	43.1
90°-180°	5279.0	58.3
0°-180°	9051.0	100.0

CANDELA DISTRIBUTION:

	0°	22.5°	45°	67.5°	90°	Flux
0°	1668	1668	1668	1668	1668	
5°	1668	1662	1645	1658	1655	158
15°	1591	1576	1538	1532	1522	448
25°	1448	1414	1352	1323	1308	666
35°	1253	1204	1120	1062	1038	784
45°	1030	969	865	788	755	795
55°	782	716	601	522	495	701
65°	534	460	354	288	273	529
75°	283	218	143	130	127	301
85°	72	42	38	35	35	79
90°	1	14	31	36	39	9
95°	78	26	40	49	49	94
105°	383	398	282	54	57	406
115°	719	727	738	751	756	710
125°	1014	1024	1029	1032	1034	906
135°	1262	1270	1275	1279	1275	972
145°	1456	1465	1468	1470	1470	912
155°	1604	1602	1603	1609	1602	739
165°	1692	1688	1686	1697	1688	478
175°	1732	1725	1726	1735	1725	165
180°	1732	1732	1732	1732	1732	

TEST NUMBER: P1032008

CATALOG NUMBER: S123RDIW-B1000D1320UB30-4F0-XX-W2A-F

CANDELA DISTRIBUTION (FULL):

	0°	22.5°	45°	67.5°	90°
0°	1668.3	1668.3	1668.3	1668.3	1668.3
2.5°	1675.1	1669.7	1653.4	1668.3	1665.6
5°	1668.3	1661.5	1645.3	1657.5	1654.8
7.5°	1656.1	1649.4	1629.1	1637.2	1633.1
10°	1639.9	1630.4	1606.1	1607.4	1600.7
12.5°	1616.9	1606.1	1574.9	1573.6	1565.5
15°	1591.2	1576.3	1538.4	1531.6	1522.2
17.5°	1560.1	1543.8	1496.5	1482.9	1469.4
20°	1524.9	1503.2	1451.8	1434.2	1418.0
22.5°	1485.6	1459.9	1404.5	1381.5	1366.6
25°	1447.8	1413.9	1351.7	1323.3	1308.4
27.5°	1401.8	1365.2	1297.6	1259.7	1236.7
30°	1354.4	1313.8	1238.0	1192.0	1170.4
32.5°	1307.0	1259.7	1178.5	1127.1	1104.1
35°	1252.9	1204.2	1120.3	1062.1	1037.8
37.5°	1198.8	1146.0	1058.1	993.1	963.4
40°	1147.4	1087.8	991.8	921.4	890.3
42.5°	1089.2	1029.7	929.5	851.1	824.0
45°	1029.7	968.8	864.6	787.5	755.0
47.5°	971.5	903.8	801.0	717.1	688.7
50°	906.5	842.9	733.4	649.5	618.3
52.5°	848.4	778.0	669.8	581.8	554.7
55°	782.1	715.8	600.8	522.3	495.2
57.5°	722.5	650.8	534.5	460.0	437.0
60°	660.3	585.9	473.6	400.5	377.5
62.5°	598.0	523.6	411.3	343.7	319.3
65°	534.5	460.0	354.5	288.2	273.3
67.5°	470.9	395.1	292.3	242.2	226.0
70°	408.6	335.6	240.8	193.5	178.6
72.5°	346.4	274.7	190.8	154.2	150.2
75°	282.8	217.8	143.4	129.9	127.2
77.5°	224.6	165.1	112.3	104.2	101.5
80°	169.1	113.7	85.2	81.2	78.5
82.5°	116.4	70.4	60.9	56.8	56.8
85°	71.7	41.9	37.9	35.2	35.2
87.5°	32.5	17.6	17.6	16.2	14.9
90°	1.3	14.2	30.9	36.0	38.6
92.5°	29.6	21.9	33.4	42.5	43.7
95°	78.5	25.7	39.9	48.9	48.9
97.5°	142.8	106.8	41.2	51.5	52.7
100°	217.4	243.1	42.5	52.7	54.0
102.5°	302.3	319.0	95.2	52.7	55.3
105°	383.3	397.5	281.7	54.0	56.6
107.5°	469.5	481.1	500.4	302.3	133.8
110°	555.7	566.0	580.2	537.7	353.8

TEST NUMBER: P1032008

CATALOG NUMBER: S123RDIW-B1000D1320UB30-4F0-XX-W2A-F

CANDELA DISTRIBUTION (continued):

	0°	22.5°	45°	67.5°	90°
112.5°	638.0	647.1	661.2	672.8	670.2
115°	719.1	726.8	738.4	751.2	756.4
117.5°	798.8	807.8	814.3	824.6	825.9
120°	872.2	883.7	887.6	897.9	897.9
122.5°	946.8	955.8	960.9	967.4	968.6
125°	1013.7	1024.0	1029.1	1031.7	1034.3
127.5°	1080.6	1090.9	1097.3	1101.1	1098.6
130°	1142.3	1152.6	1157.7	1162.9	1160.3
132.5°	1201.5	1211.8	1215.6	1220.8	1216.9
135°	1261.9	1269.7	1274.8	1278.7	1274.8
137.5°	1313.4	1323.7	1326.3	1332.7	1330.1
140°	1364.9	1372.6	1376.4	1381.6	1379.0
142.5°	1412.4	1420.2	1424.0	1427.9	1424.0
145°	1456.2	1465.2	1467.8	1470.3	1470.3
147.5°	1498.6	1505.1	1507.6	1510.2	1503.8
150°	1537.2	1541.1	1543.7	1546.2	1542.4
152.5°	1572.0	1573.2	1574.5	1579.7	1573.2
155°	1604.1	1601.5	1602.8	1609.3	1601.5
157.5°	1629.8	1629.8	1628.6	1636.3	1626.0
160°	1653.0	1651.7	1650.4	1658.1	1649.1
162.5°	1674.9	1671.0	1669.7	1678.7	1671.0
165°	1691.6	1687.7	1686.4	1696.7	1687.7
167.5°	1705.7	1700.6	1700.6	1710.9	1700.6
170°	1717.3	1712.2	1712.2	1722.5	1712.2
172.5°	1725.0	1718.6	1719.9	1730.2	1718.6
175°	1731.5	1725.0	1726.3	1735.3	1725.0
177.5°	1734.0	1727.6	1728.9	1739.2	1726.3
180°	1731.5	1731.5	1731.5	1731.5	1731.5

(END OF REPORT)