

Scaled data based on original data using
LM-79-2019 Approved Method: Electrical and Photometric Measurements of Solid-
State Lighting Products

Test Report Prepared for
Cooper Lighting Solutions

Brand: NEO-RAY

Report Number: P1033162

Luminaire Tested: S124DIW-B1020D1560UB35-4F0-XX-W2A-A1

Issue Date: 5/6/2025

Test Information

Test Method: LM-79-2019
Report Number: P1033162
REPORT IS A COMBINATION OF REPORTS P996791 AND P1007351
Test Lab: INNOVATION CENTER
Issue Date: 5/6/2025
Manufacturer: COOPER LIGHTING SOLUTIONS
Product Line: NEO-RAY
Catalog Number: S124DIW-B1020D1560UB35-4F0-XX-W2A-A1
Description: Define 4 Direct/Indirect Wall Mount with 3500K BioUP LEDs {m-DER=0.721} {m-EER=0.792}
Light Source: -
Ballast/Driver: -

Summary


Lumens per Lamp: N/A
Luminaire Lumens: 10114.0 lumens
Efficiency: N/A
Efficacy: 102.2 lumens/watt
Spacing Criteria (0/90/45): 1.22 / 1.3 / 1.41
Luminous Opening: Rectangular w/ Sides (W: 0.33' x L: 4' x H: 0.1')
CIE Type: General Diffuse

Input Watts (W): 99
Input Voltage (V):
Input Current (Ain): NR
Voltage Rise (V): NR
Power Factor: NR
Total Harmonic Distortion (THDi): NR
Frequency (hertz): 60
Stabilization Time: NR
Operation Time: NR
Ambient Temperature (°C): NR
Test Distance: 24 FT

TEST NUMBER: P1033162

CATALOG NUMBER: S124DIW-B1020D1560UB35-4F0-XX-W2A-A1

Luminous Intensity Polar Plot



TEST NUMBER: P1033162

CATALOG NUMBER: S124DIW-B1020D1560UB35-4F0-XX-W2A-A1

COEFFICIENT OF UTILIZATION - ZONAL CAVITY METHOD:

RF	20				20				20				20				20
RC	80				70				50				30				10
RW	70	50	30	10	70	50	30	10	50	30	10	50	30	10	50	30	10
RCR																	
0	106	106	106	106	97	97	97	97	81	81	81	66	66	66	52	52	52
1	97	93	89	86	89	85	82	79	71	69	67	58	57	55	46	45	44
2	88	81	75	70	81	75	70	65	63	59	56	51	49	46	41	39	38
3	81	72	64	59	74	66	60	55	55	51	47	46	42	39	36	34	32
4	74	63	56	50	68	59	52	47	49	44	40	41	37	34	33	30	28
5	68	57	49	43	62	52	45	40	44	39	35	37	33	30	30	27	24
6	63	51	43	37	57	47	40	35	40	34	30	33	29	26	27	24	22
7	58	46	38	33	53	43	36	31	36	31	27	30	26	23	25	22	19
8	54	42	34	29	49	39	32	27	33	28	24	28	24	21	23	20	17
9	50	38	31	26	46	35	29	24	30	25	21	25	21	18	21	18	16
10	47	35	28	23	43	32	26	22	28	23	19	23	19	17	19	16	14

AVERAGE LUMINANCE (cd/sqm):

	0°	90°	180°	270°
0°	13585	13585	13585	13585
5°	13550	15585	13630	11711
10°	13449	18182	13551	10274
15°	13288	20961	13380	9193
20°	13115	22729	13211	8242
25°	12865	22470	12988	7541
30°	12619	18571	12773	7179
35°	12274	13839	12409	6960
40°	11872	10425	11987	6852
45°	11259	8368	11398	6706
50°	10525	7050	10678	6638
55°	9662	6135	9815	6560
60°	8824	5403	9084	6451
65°	8038	4649	8115	6182
70°	7112	3825	7266	5692
75°	6204	2939	6164	4836
80°	4882	1931	4824	3672
85°	3216	868	3013	2140

MAXIMUM LUMINANCE 45°-90°:

Horizontal Angle: 145°

Vertical Angle: 45°

Luminance: 17565 cd/sqm

TEST NUMBER: P1033162

CATALOG NUMBER: S124DIW-B1020D1560UB35-4F0-XX-W2A-A1

ZONAL LUMENS:

Zone	Lumens	% Fixture
0°-10°	162.1	1.6
10°-20°	500.4	4.9
20°-30°	795.0	7.9
30°-40°	883.4	8.7
40°-50°	803.4	7.9
50°-60°	656.5	6.5
60°-70°	468.6	4.6
70°-80°	257.9	2.5
80°-90°	73.9	0.7
90°-100°	129.5	1.3
100°-110°	387.9	3.8
110°-120°	659.0	6.5
120°-130°	869.1	8.6
130°-140°	976.1	9.7
140°-150°	959.4	9.5
150°-160°	806.9	8.0
160°-170°	536.9	5.3
170°-180°	188.0	1.9
0°-30°	1457.6	14.4
0°-40°	2341.0	23.1
0°-60°	3800.8	37.6
0°-90°	4601.2	45.5
90°-120°	1176.4	11.6
90°-150°	3981.0	39.4
90°-180°	5513.0	54.5
0°-180°	10114.0	100.0

CANDELA DISTRIBUTION:

	0°	90°	180°	270°	360°	Flux
0°	1666	1666	1666	1666	1666	
5°	1659	1954	1669	1469	1659	157
15°	1584	2684	1596	1177	1584	447
25°	1446	2850	1460	956	1446	667
35°	1255	1685	1268	848	1255	784
45°	1001	946	1013	758	1001	772
55°	704	618	715	661	704	633
65°	439	398	443	529	439	433
75°	215	199	214	327	215	226
85°	44	41	41	102	44	51
90°	5	46	5	46	5	9
95°	92	121	92	121	92	100
105°	358	375	358	375	358	380
115°	670	664	670	664	670	661
125°	976	968	976	968	976	870
135°	1258	1260	1258	1260	1258	974
145°	1529	1530	1529	1530	1529	957
155°	1752	1750	1752	1750	1752	806
165°	1907	1902	1907	1902	1907	538
175°	1984	1974	1984	1974	1984	188
180°	1987	1987	1987	1987	1987	

TEST NUMBER: P1033162

CATALOG NUMBER: S124DIW-B1020D1560UB35-4F0-XX-W2A-A1

CANDELA DISTRIBUTION (FULL):

	0°	5°	10°	15°	20°	22.5°	25°	30°	35°	40°	45°
0°	1665.9	1665.9	1665.9	1665.9	1665.9	1665.9	1665.9	1665.9	1665.9	1665.9	1665.9
2.5°	1665.9	1682.5	1689.4	1694.9	1712.9	1718.4	1719.8	1728.0	1734.9	1736.3	1736.3
5°	1659.0	1685.2	1706.0	1725.3	1754.3	1766.7	1781.9	1798.4	1820.5	1834.3	1841.2
7.5°	1648.0	1686.6	1718.4	1751.5	1791.5	1816.4	1830.2	1874.3	1904.7	1929.5	1959.9
10°	1631.4	1681.1	1726.7	1775.0	1831.6	1861.9	1892.3	1946.1	1988.9	2037.2	2075.9
12.5°	1606.6	1671.4	1726.7	1794.3	1864.7	1900.6	1936.4	2030.3	2080.0	2122.8	2191.8
15°	1584.5	1649.4	1728.0	1797.0	1884.0	1937.8	1990.3	2051.0	2129.7	2222.2	2288.4
17.5°	1559.6	1641.1	1714.2	1810.8	1907.5	1958.5	2001.3	2095.2	2205.6	2296.7	2357.4
20°	1525.1	1608.0	1704.6	1806.7	1921.3	1961.3	2017.9	2143.5	2242.9	2332.6	2431.9
22.5°	1485.1	1581.7	1683.9	1781.9	1900.6	1984.8	2046.9	2157.3	2277.4	2380.9	2492.7
25°	1446.5	1551.4	1641.1	1775.0	1900.6	1957.2	2027.5	2158.7	2289.8	2415.4	2529.9
27.5°	1405.1	1503.1	1624.5	1730.8	1873.0	1935.1	2011.0	2154.5	2293.9	2419.5	2542.4
30°	1359.5	1464.4	1565.2	1690.8	1828.8	1908.8	1979.2	2135.2	2277.4	2408.5	2523.0
32.5°	1308.4	1407.8	1515.5	1634.2	1779.1	1860.5	1948.9	2109.0	2260.8	2374.0	2462.3
35°	1254.6	1355.4	1449.2	1570.7	1719.8	1801.2	1886.8	2063.4	2213.9	2306.3	2357.4
37.5°	1195.3	1290.5	1383.0	1503.1	1652.1	1739.1	1826.0	1997.2	2139.3	2216.6	2202.8
40°	1138.7	1224.3	1309.8	1423.0	1579.0	1671.4	1747.4	1919.9	2044.1	2077.2	2031.7
42.5°	1073.8	1147.0	1229.8	1345.7	1497.5	1584.5	1679.7	1837.1	1929.5	1915.7	1838.5
45°	1000.7	1065.5	1148.3	1257.4	1412.0	1501.7	1581.7	1730.8	1798.4	1763.9	1623.1
47.5°	930.3	993.8	1061.4	1170.4	1320.9	1396.8	1478.2	1612.1	1650.7	1577.6	1436.8
50°	854.4	906.8	977.2	1080.7	1221.5	1301.5	1369.2	1476.8	1490.6	1400.9	1254.6
52.5°	781.2	825.4	893.0	995.1	1126.3	1189.7	1256.0	1351.2	1340.2	1247.7	1106.9
55°	703.9	745.3	807.4	901.3	1017.2	1078.0	1134.5	1218.7	1195.3	1100.0	977.2
57.5°	639.0	668.0	728.8	815.7	910.9	977.2	1025.5	1091.8	1055.9	960.6	846.1
60°	564.5	600.4	651.5	721.9	815.7	859.9	902.7	946.8	922.0	830.9	728.8
62.5°	496.9	524.5	568.7	636.3	709.4	749.5	795.0	822.6	797.8	713.6	628.0
65°	438.9	461.0	495.5	550.7	621.1	654.2	680.4	706.7	686.0	607.3	545.2
67.5°	375.4	394.7	423.7	467.9	527.2	550.7	575.6	593.5	570.0	517.6	456.9
70°	318.8	332.6	360.2	393.4	434.8	456.9	477.6	495.5	474.8	430.6	385.1
72.5°	260.9	271.9	296.7	320.2	357.5	372.7	387.8	401.6	394.7	353.3	316.1
75°	215.3	219.5	236.0	255.3	278.8	295.4	306.4	314.7	309.2	276.0	252.6
77.5°	162.9	168.4	180.8	196.0	216.7	226.4	233.3	241.5	234.6	208.4	191.9
80°	118.7	120.1	127.0	140.8	154.6	156.0	162.9	173.9	169.8	151.8	139.4
82.5°	75.9	80.1	82.8	91.1	100.8	103.5	107.7	110.4	109.0	98.0	93.9
85°	44.2	44.2	46.9	52.4	55.2	59.3	60.7	62.1	64.9	58.0	53.8
87.5°	19.3	20.7	20.7	22.1	24.8	24.8	26.2	27.6	29.0	27.6	23.5
90°	4.6	8.4	12.1	15.9	19.6	21.5	22.9	25.6	28.3	31.1	33.8
92.5°	40.0	44.4	48.8	53.3	57.7	59.9	60.8	62.5	64.2	65.9	67.6
95°	92.2	95.3	98.3	101.4	104.5	106.0	107.2	109.6	112.0	114.4	116.8
97.5°	147.5	150.2	153.0	155.7	158.4	159.8	161.2	163.9	166.6	169.4	172.1
100°	215.1	216.5	217.9	219.2	220.6	221.3	222.8	225.9	229.0	232.0	235.1
102.5°	285.8	286.1	286.5	286.8	287.1	287.3	288.7	291.4	294.1	296.9	299.6
105°	358.0	358.4	358.7	359.1	359.4	359.6	360.3	361.6	363.0	364.3	365.7
107.5°	433.3	433.7	434.0	434.4	434.7	434.9	435.1	435.4	435.7	436.1	436.4
110°	510.2	510.9	511.5	512.2	512.9	513.2	513.0	512.7	512.4	512.0	511.7

TEST NUMBER: P1033162

CATALOG NUMBER: S124DIW-B1020D1560UB35-4F0-XX-W2A-A1

CANDELA DISTRIBUTION (continued):

	0°	5°	10°	15°	20°	22.5°	25°	30°	35°	40°	45°
112.5°	590.1	590.1	590.1	590.1	590.1	590.1	589.8	589.1	588.4	587.7	587.0
115°	670.0	670.0	670.0	670.0	670.0	670.0	669.7	669.0	668.3	667.6	666.9
117.5°	745.3	745.3	745.3	745.3	745.3	745.3	745.1	744.8	744.4	744.1	743.7
120°	820.6	822.0	823.3	824.7	826.0	826.7	826.2	825.2	824.1	823.1	822.1
122.5°	898.9	899.3	899.6	900.0	900.3	900.5	900.3	900.0	899.6	899.3	898.9
125°	975.7	975.7	975.7	975.7	975.7	975.7	975.5	975.2	974.9	974.5	974.2
127.5°	1044.9	1045.9	1046.9	1048.0	1049.0	1049.5	1049.2	1048.5	1047.8	1047.1	1046.4
130°	1118.7	1119.7	1120.7	1121.8	1122.8	1123.3	1123.3	1123.3	1123.3	1123.3	1123.3
132.5°	1193.9	1194.6	1195.3	1196.0	1196.7	1197.0	1196.8	1196.5	1196.2	1195.8	1195.5
135°	1258.5	1260.5	1262.6	1264.6	1266.7	1267.7	1267.7	1267.7	1267.7	1267.7	1267.7
137.5°	1330.7	1331.7	1332.7	1333.8	1334.8	1335.3	1335.6	1336.3	1337.0	1337.7	1338.4
140°	1402.9	1403.6	1404.3	1405.0	1405.7	1406.0	1406.0	1406.0	1406.0	1406.0	1406.0
142.5°	1469.0	1469.7	1470.4	1471.1	1471.8	1472.1	1471.9	1471.6	1471.2	1470.9	1470.5
145°	1528.9	1530.3	1531.7	1533.0	1534.4	1535.1	1535.3	1535.6	1535.9	1536.3	1536.6
147.5°	1590.4	1592.1	1593.8	1595.5	1597.2	1598.1	1597.9	1597.6	1597.2	1596.9	1596.5
150°	1645.7	1647.1	1648.5	1649.8	1651.2	1651.9	1651.9	1651.9	1651.9	1651.9	1651.9
152.5°	1698.0	1698.7	1699.3	1700.0	1700.7	1701.0	1701.2	1701.5	1701.9	1702.2	1702.6
155°	1751.7	1751.7	1751.7	1751.7	1751.7	1751.7	1751.5	1751.2	1750.9	1750.5	1750.2
157.5°	1797.8	1797.1	1796.5	1795.8	1795.1	1794.8	1794.8	1794.8	1794.8	1794.8	1794.8
160°	1837.8	1837.5	1837.1	1836.8	1836.5	1836.3	1836.1	1835.8	1835.4	1835.1	1834.7
162.5°	1874.7	1873.7	1872.7	1871.6	1870.6	1870.1	1869.9	1869.6	1869.2	1868.9	1868.5
165°	1906.9	1905.9	1904.9	1903.8	1902.8	1902.3	1902.0	1901.3	1900.6	1900.0	1899.3
167.5°	1933.1	1931.7	1930.3	1929.0	1927.6	1926.9	1926.9	1926.9	1926.9	1926.9	1926.9
170°	1954.6	1952.9	1951.2	1949.5	1947.8	1946.9	1947.1	1947.4	1947.7	1948.1	1948.4
172.5°	1969.9	1968.5	1967.2	1965.8	1964.5	1963.8	1963.8	1963.8	1963.8	1963.8	1963.8
175°	1983.8	1982.1	1980.4	1978.7	1977.0	1976.1	1975.9	1975.6	1975.2	1974.9	1974.5
177.5°	1989.9	1988.2	1986.5	1984.8	1983.1	1982.2	1982.2	1982.2	1982.2	1982.2	1982.2
180°	1986.8	1986.8	1986.8	1986.8	1986.8	1986.8	1986.8	1986.8	1986.8	1986.8	1986.8

TEST NUMBER: P1033162

CATALOG NUMBER: S124DIW-B1020D1560UB35-4F0-XX-W2A-A1

CANDELA DISTRIBUTION (continued):

	50°	55°	60°	65°	67.5°	70°	75°	80°	85°	90°	95°
0°	1665.9	1665.9	1665.9	1665.9	1665.9	1665.9	1665.9	1665.9	1665.9	1665.9	1665.9
2.5°	1740.5	1765.3	1776.3	1779.1	1794.3	1784.6	1788.8	1787.4	1798.4	1799.8	1799.8
5°	1867.4	1896.4	1906.1	1919.9	1940.6	1946.1	1942.0	1950.3	1965.4	1954.4	1971.0
7.5°	2001.3	2033.1	2055.1	2085.5	2092.4	2110.4	2121.4	2131.1	2133.8	2135.2	2138.0
10°	2125.5	2165.6	2195.9	2247.0	2258.0	2267.7	2316.0	2296.7	2321.5	2313.2	2316.0
12.5°	2226.3	2305.0	2329.8	2415.4	2423.7	2456.8	2454.0	2484.4	2489.9	2501.0	2489.9
15°	2358.8	2449.9	2489.9	2538.2	2565.8	2604.5	2611.4	2652.8	2669.3	2684.5	2669.3
17.5°	2480.3	2528.6	2630.7	2669.3	2687.3	2708.0	2760.4	2775.6	2800.5	2790.8	2818.4
20°	2541.0	2610.0	2717.7	2783.9	2811.5	2830.8	2875.0	2898.5	2908.1	2908.1	2910.9
22.5°	2594.8	2694.2	2774.2	2850.2	2875.0	2888.8	2915.0	2933.0	2937.1	2939.9	2942.6
25°	2643.1	2732.8	2797.7	2840.5	2850.2	2850.2	2865.3	2854.3	2836.4	2850.2	2858.4
27.5°	2643.1	2706.6	2735.6	2750.8	2750.8	2713.5	2691.4	2645.9	2607.2	2596.2	2621.0
30°	2599.0	2627.9	2587.9	2550.6	2521.7	2496.8	2409.9	2340.9	2327.1	2317.4	2354.7
32.5°	2496.8	2459.6	2380.9	2273.2	2230.4	2173.8	2106.2	2053.8	2022.0	2011.0	2002.7
35°	2316.0	2219.4	2117.3	1972.3	1942.0	1870.2	1777.7	1739.1	1686.6	1685.2	1703.2
37.5°	2118.6	1969.6	1859.2	1721.1	1678.3	1602.4	1515.5	1475.5	1439.6	1412.0	1445.1
40°	1888.1	1758.4	1590.0	1476.8	1416.1	1376.1	1302.9	1258.8	1242.2	1228.4	1249.1
42.5°	1672.8	1530.7	1399.5	1283.6	1233.9	1188.4	1140.1	1097.3	1084.9	1083.5	1098.7
45°	1458.9	1319.5	1198.0	1098.7	1066.9	1039.3	992.4	980.0	959.3	945.5	952.4
47.5°	1287.7	1144.2	1043.4	967.5	939.9	916.5	886.1	865.4	847.5	841.9	850.2
50°	1119.4	1022.7	919.2	855.7	835.0	812.9	789.5	770.2	761.9	756.4	761.9
52.5°	984.1	880.6	810.2	759.1	738.4	721.9	705.3	697.0	686.0	688.7	694.3
55°	862.6	771.5	712.2	674.9	662.5	655.6	634.9	625.2	621.1	618.3	621.1
57.5°	748.1	681.8	637.7	605.9	589.4	585.2	568.7	568.7	564.5	560.4	561.7
60°	657.0	600.4	557.6	532.8	530.0	523.1	512.1	510.7	501.0	505.2	506.5
62.5°	564.5	519.0	490.0	474.8	465.1	462.4	455.5	454.1	450.0	451.3	448.6
65°	491.4	454.1	425.1	412.7	408.5	407.2	401.6	397.5	394.7	397.5	394.7
67.5°	418.2	393.4	371.3	358.9	353.3	352.0	347.8	345.1	346.4	342.3	345.1
70°	349.2	324.4	310.5	303.6	300.9	296.7	296.7	296.7	296.7	294.0	292.6
72.5°	294.0	269.1	259.5	255.3	252.6	251.2	247.1	248.4	247.1	245.7	251.2
75°	233.3	218.1	208.4	204.3	207.0	202.9	198.8	201.5	197.4	198.8	204.3
77.5°	176.7	169.8	164.2	161.5	158.7	156.0	156.0	153.2	153.2	153.2	153.2
80°	128.4	127.0	117.3	115.9	115.9	113.2	113.2	113.2	113.2	111.8	113.2
82.5°	85.6	84.2	81.4	80.1	77.3	78.7	78.7	75.9	75.9	74.5	75.9
85°	49.7	49.7	46.9	45.5	44.2	45.5	42.8	41.4	42.8	41.4	42.8
87.5°	23.5	20.7	22.1	20.7	17.9	19.3	16.6	17.9	16.6	15.2	17.9
90°	35.8	37.9	39.9	42.0	43.0	43.3	44.0	44.7	45.4	46.1	45.4
92.5°	68.6	69.6	70.7	71.7	72.2	72.4	72.7	73.1	73.4	73.8	73.4
95°	117.8	118.8	119.9	120.9	121.4	121.4	121.4	121.4	121.4	121.4	121.4
97.5°	173.5	174.8	176.2	177.5	178.2	178.2	178.2	178.2	178.2	178.2	178.2
100°	235.8	236.5	237.2	237.9	238.2	238.2	238.2	238.2	238.2	238.2	238.2
102.5°	300.6	301.6	302.7	303.7	304.2	304.4	304.7	305.1	305.4	305.8	305.4
105°	366.7	367.7	368.8	369.8	370.3	370.8	371.8	372.9	373.9	374.9	373.9
107.5°	437.8	439.1	440.5	441.8	442.5	442.3	442.0	441.7	441.3	441.0	441.3
110°	511.0	510.3	509.6	508.9	508.6	509.1	510.1	511.2	512.2	513.2	512.2

TEST NUMBER: P1033162

CATALOG NUMBER: S124DIW-B1020D1560UB35-4F0-XX-W2A-A1

CANDELA DISTRIBUTION (continued):

	50°	55°	60°	65°	67.5°	70°	75°	80°	85°	90°	95°
112.5°	587.0	587.0	587.0	587.0	587.0	587.0	587.0	587.0	587.0	587.0	587.0
115°	666.6	666.2	665.9	665.6	665.4	665.2	664.9	664.5	664.2	663.8	664.2
117.5°	742.7	741.7	740.6	739.6	739.1	738.6	737.6	736.5	735.5	734.5	735.5
120°	820.4	818.7	817.0	815.3	814.4	814.7	815.4	816.1	816.8	817.5	816.8
122.5°	897.9	896.9	895.8	894.8	894.3	893.4	891.7	890.0	888.3	886.6	888.3
125°	973.5	972.8	972.1	971.4	971.1	970.8	970.1	969.4	968.8	968.1	968.8
127.5°	1045.7	1045.1	1044.4	1043.7	1043.4	1043.2	1042.9	1042.5	1042.2	1041.8	1042.2
130°	1122.6	1121.9	1121.2	1120.5	1120.2	1119.5	1118.1	1116.8	1115.4	1114.0	1115.4
132.5°	1194.8	1194.1	1193.4	1192.7	1192.4	1192.2	1191.9	1191.6	1191.2	1190.9	1191.2
135°	1267.0	1266.3	1265.6	1264.9	1264.6	1264.1	1263.1	1262.0	1261.0	1260.0	1261.0
137.5°	1337.4	1336.4	1335.3	1334.3	1333.8	1334.0	1334.3	1334.6	1335.0	1335.3	1335.0
140°	1405.7	1405.3	1405.0	1404.7	1404.5	1404.3	1404.0	1403.6	1403.3	1402.9	1403.3
142.5°	1470.5	1470.5	1470.5	1470.5	1470.5	1470.5	1470.5	1470.5	1470.5	1470.5	1470.5
145°	1536.3	1535.9	1535.6	1535.3	1535.1	1534.6	1533.6	1532.5	1531.5	1530.5	1531.5
147.5°	1596.2	1595.8	1595.5	1595.2	1595.0	1594.8	1594.5	1594.2	1593.8	1593.5	1593.8
150°	1651.9	1651.9	1651.9	1651.9	1651.9	1651.7	1651.4	1651.0	1650.7	1650.3	1650.7
152.5°	1703.6	1704.6	1705.7	1706.7	1707.2	1706.7	1705.7	1704.6	1703.6	1702.6	1703.6
155°	1751.6	1752.9	1754.3	1755.6	1756.3	1755.6	1754.3	1752.9	1751.6	1750.2	1751.6
157.5°	1795.8	1796.8	1797.9	1798.9	1799.4	1798.9	1797.9	1796.8	1795.8	1794.8	1795.8
160°	1835.7	1836.7	1837.8	1838.8	1839.3	1838.4	1836.7	1835.0	1833.3	1831.6	1833.3
162.5°	1870.5	1872.6	1874.6	1876.7	1877.7	1876.9	1875.2	1873.5	1871.8	1870.1	1871.8
165°	1901.3	1903.4	1905.4	1907.5	1908.5	1907.8	1906.4	1905.1	1903.7	1902.3	1903.7
167.5°	1928.9	1931.0	1933.0	1935.1	1936.1	1935.1	1933.0	1931.0	1928.9	1926.9	1928.9
170°	1950.4	1952.5	1954.5	1956.6	1957.6	1956.4	1954.0	1951.7	1949.3	1946.9	1949.3
172.5°	1966.2	1968.6	1970.9	1973.3	1974.5	1973.3	1970.9	1968.6	1966.2	1963.8	1966.2
175°	1976.9	1979.3	1981.7	1984.1	1985.3	1984.1	1981.7	1979.3	1976.9	1974.5	1976.9
177.5°	1984.6	1987.0	1989.4	1991.8	1993.0	1991.6	1988.9	1986.2	1983.4	1980.7	1983.4
180°	1986.8	1986.8	1986.8	1986.8	1986.8	1986.8	1986.8	1986.8	1986.8	1986.8	1986.8

TEST NUMBER: P1033162

CATALOG NUMBER: S124DIW-B1020D1560UB35-4F0-XX-W2A-A1

CANDELA DISTRIBUTION (continued):

	100°	105°	110°	112.5°	115°	120°	125°	130°	135°	140°	145°
0°	1665.9	1665.9	1665.9	1665.9	1665.9	1665.9	1665.9	1665.9	1665.9	1665.9	1665.9
2.5°	1797.0	1792.9	1787.4	1787.4	1780.5	1780.5	1769.4	1750.1	1733.6	1728.0	1730.8
5°	1950.3	1951.6	1943.3	1936.4	1924.0	1914.4	1896.4	1861.9	1850.9	1828.8	1813.6
7.5°	2125.5	2120.0	2104.8	2093.8	2091.0	2068.9	2030.3	1988.9	1955.8	1933.7	1901.9
10°	2322.9	2300.8	2278.7	2271.8	2255.3	2218.0	2173.8	2128.3	2082.8	2034.4	1980.6
12.5°	2488.5	2445.7	2444.4	2427.8	2396.1	2375.4	2322.9	2258.0	2179.4	2125.5	2064.8
15°	2666.6	2626.6	2593.4	2563.1	2547.9	2487.2	2443.0	2361.6	2267.7	2209.7	2168.3
17.5°	2793.6	2775.6	2719.0	2705.2	2684.5	2614.1	2543.7	2463.7	2382.3	2300.8	2189.0
20°	2895.7	2884.7	2847.4	2828.1	2794.9	2739.7	2654.2	2561.7	2467.8	2351.9	2247.0
22.5°	2939.9	2926.1	2895.7	2879.1	2858.4	2811.5	2738.4	2633.5	2510.6	2407.1	2295.3
25°	2852.9	2877.8	2869.5	2862.6	2854.3	2826.7	2771.5	2679.0	2558.9	2441.6	2302.2
27.5°	2656.9	2699.7	2741.1	2746.6	2760.4	2771.5	2749.4	2683.1	2582.4	2458.2	2305.0
30°	2393.3	2412.6	2496.8	2521.7	2541.0	2611.4	2652.8	2636.2	2558.9	2447.1	2306.3
32.5°	2055.1	2106.2	2191.8	2251.1	2303.6	2382.3	2489.9	2532.7	2505.1	2414.0	2274.6
35°	1734.9	1795.7	1895.0	1971.0	2023.4	2135.2	2262.2	2354.7	2389.2	2343.6	2219.4
37.5°	1472.7	1545.8	1634.2	1663.2	1723.9	1861.9	2037.2	2165.6	2249.8	2253.9	2157.3
40°	1275.3	1312.6	1383.0	1427.1	1486.5	1602.4	1773.6	1943.3	2070.3	2113.1	2062.0
42.5°	1108.3	1137.3	1189.7	1243.6	1297.4	1385.7	1543.1	1701.8	1873.0	1958.5	1957.2
45°	975.8	1006.2	1042.1	1086.2	1123.5	1218.7	1343.0	1505.8	1653.5	1786.0	1819.1
47.5°	859.9	886.1	930.3	949.6	974.4	1064.1	1171.8	1323.6	1476.8	1628.7	1667.3
50°	774.3	796.4	826.8	839.2	866.8	933.0	1021.4	1144.2	1314.0	1453.4	1525.1
52.5°	697.0	713.6	737.0	746.7	766.0	815.7	895.8	992.4	1133.2	1276.7	1377.5
55°	630.8	641.8	658.4	669.4	683.2	727.4	786.7	873.7	995.1	1119.4	1217.4
57.5°	568.7	576.9	593.5	599.0	610.1	644.6	686.0	759.1	870.9	981.3	1076.6
60°	510.7	516.2	525.9	538.3	546.6	570.0	608.7	669.4	759.1	859.9	937.2
62.5°	455.5	463.8	466.5	472.0	478.9	501.0	531.4	575.6	654.2	737.0	818.5
65°	398.9	405.8	411.3	412.7	419.6	436.1	463.8	502.4	553.5	625.2	701.2
67.5°	346.4	350.6	353.3	358.9	365.8	374.0	396.1	425.1	472.0	530.0	590.7
70°	298.1	298.1	302.3	303.6	311.9	321.6	331.3	358.9	400.3	447.2	488.6
72.5°	245.7	252.6	251.2	258.1	256.7	263.6	276.0	294.0	324.4	361.6	401.6
75°	200.1	204.3	204.3	204.3	207.0	212.6	219.5	236.0	259.5	289.8	313.3
77.5°	156.0	158.7	158.7	158.7	160.1	165.6	172.5	183.6	200.1	218.1	231.9
80°	111.8	114.6	114.6	117.3	117.3	118.7	125.6	131.1	139.4	153.2	167.0
82.5°	75.9	77.3	80.1	80.1	78.7	81.4	82.8	88.3	96.6	99.4	109.0
85°	41.4	42.8	44.2	44.2	45.5	48.3	46.9	52.4	52.4	58.0	60.7
87.5°	16.6	19.3	19.3	17.9	19.3	19.3	19.3	22.1	23.5	24.8	23.5
90°	44.7	44.0	43.3	43.0	42.0	39.9	37.9	35.8	33.8	31.1	28.3
92.5°	73.1	72.7	72.4	72.2	71.7	70.7	69.6	68.6	67.6	65.9	64.2
95°	121.4	121.4	121.4	121.4	120.9	119.9	118.8	117.8	116.8	114.4	112.0
97.5°	178.2	178.2	178.2	178.2	177.5	176.2	174.8	173.5	172.1	169.4	166.6
100°	238.2	238.2	238.2	238.2	237.9	237.2	236.5	235.8	235.1	232.0	229.0
102.5°	305.1	304.7	304.4	304.2	303.7	302.7	301.6	300.6	299.6	296.9	294.1
105°	372.9	371.8	370.8	370.3	369.8	368.8	367.7	366.7	365.7	364.3	363.0
107.5°	441.7	442.0	442.3	442.5	441.8	440.5	439.1	437.8	436.4	436.1	435.7
110°	511.2	510.1	509.1	508.6	508.9	509.6	510.3	511.0	511.7	512.0	512.4

TEST NUMBER: P1033162

CATALOG NUMBER: S124DIW-B1020D1560UB35-4F0-XX-W2A-A1

CANDELA DISTRIBUTION (continued):

	100°	105°	110°	112.5°	115°	120°	125°	130°	135°	140°	145°
112.5°	587.0	587.0	587.0	587.0	587.0	587.0	587.0	587.0	587.0	587.7	588.4
115°	664.5	664.9	665.2	665.4	665.6	665.9	666.2	666.6	666.9	667.6	668.3
117.5°	736.5	737.6	738.6	739.1	739.6	740.6	741.7	742.7	743.7	744.1	744.4
120°	816.1	815.4	814.7	814.4	815.3	817.0	818.7	820.4	822.1	823.1	824.1
122.5°	890.0	891.7	893.4	894.3	894.8	895.8	896.9	897.9	898.9	899.3	899.6
125°	969.4	970.1	970.8	971.1	971.4	972.1	972.8	973.5	974.2	974.5	974.9
127.5°	1042.5	1042.9	1043.2	1043.4	1043.7	1044.4	1045.1	1045.7	1046.4	1047.1	1047.8
130°	1116.8	1118.1	1119.5	1120.2	1120.5	1121.2	1121.9	1122.6	1123.3	1123.3	1123.3
132.5°	1191.6	1191.9	1192.2	1192.4	1192.7	1193.4	1194.1	1194.8	1195.5	1195.8	1196.2
135°	1262.0	1263.1	1264.1	1264.6	1264.9	1265.6	1266.3	1267.0	1267.7	1267.7	1267.7
137.5°	1334.6	1334.3	1334.0	1333.8	1334.3	1335.3	1336.4	1337.4	1338.4	1337.7	1337.0
140°	1403.6	1404.0	1404.3	1404.5	1404.7	1405.0	1405.3	1405.7	1406.0	1406.0	1406.0
142.5°	1470.5	1470.5	1470.5	1470.5	1470.5	1470.5	1470.5	1470.5	1470.5	1470.9	1471.2
145°	1532.5	1533.6	1534.6	1535.1	1535.3	1535.6	1535.9	1536.3	1536.6	1536.3	1535.9
147.5°	1594.2	1594.5	1594.8	1595.0	1595.2	1595.5	1595.8	1596.2	1596.5	1596.9	1597.2
150°	1651.0	1651.4	1651.7	1651.9	1651.9	1651.9	1651.9	1651.9	1651.9	1651.9	1651.9
152.5°	1704.6	1705.7	1706.7	1707.2	1706.7	1705.7	1704.6	1703.6	1702.6	1702.2	1701.9
155°	1752.9	1754.3	1755.6	1756.3	1755.6	1754.3	1752.9	1751.6	1750.2	1750.5	1750.9
157.5°	1796.8	1797.9	1798.9	1799.4	1798.9	1797.9	1796.8	1795.8	1794.8	1794.8	1794.8
160°	1835.0	1836.7	1838.4	1839.3	1838.8	1837.8	1836.7	1835.7	1834.7	1835.1	1835.4
162.5°	1873.5	1875.2	1876.9	1877.7	1876.7	1874.6	1872.6	1870.5	1868.5	1868.9	1869.2
165°	1905.1	1906.4	1907.8	1908.5	1907.5	1905.4	1903.4	1901.3	1899.3	1900.0	1900.6
167.5°	1931.0	1933.0	1935.1	1936.1	1935.1	1933.0	1931.0	1928.9	1926.9	1926.9	1926.9
170°	1951.7	1954.0	1956.4	1957.6	1956.6	1954.5	1952.5	1950.4	1948.4	1948.1	1947.7
172.5°	1968.6	1970.9	1973.3	1974.5	1973.3	1970.9	1968.6	1966.2	1963.8	1963.8	1963.8
175°	1979.3	1981.7	1984.1	1985.3	1984.1	1981.7	1979.3	1976.9	1974.5	1974.9	1975.2
177.5°	1986.2	1988.9	1991.6	1993.0	1991.8	1989.4	1987.0	1984.6	1982.2	1982.2	1982.2
180°	1986.8	1986.8	1986.8	1986.8	1986.8	1986.8	1986.8	1986.8	1986.8	1986.8	1986.8

TEST NUMBER: P1033162

CATALOG NUMBER: S124DIW-B1020D1560UB35-4F0-XX-W2A-A1

CANDELA DISTRIBUTION (continued):

	150°	155°	157.5°	160°	165°	170°	175°	180°	185°	190°	195°
0°	1665.9	1665.9	1665.9	1665.9	1665.9	1665.9	1665.9	1665.9	1665.9	1665.9	1665.9
2.5°	1718.4	1712.9	1708.7	1708.7	1696.3	1683.9	1677.0	1674.2	1671.4	1660.4	1645.2
5°	1788.8	1770.8	1758.4	1746.0	1725.3	1703.2	1681.1	1668.7	1650.7	1625.9	1608.0
7.5°	1867.4	1824.7	1810.8	1795.7	1754.3	1717.0	1686.6	1660.4	1631.4	1599.7	1567.9
10°	1933.7	1888.1	1857.8	1831.6	1777.7	1728.0	1682.5	1643.8	1606.6	1565.2	1526.5
12.5°	1997.2	1932.3	1900.6	1861.9	1805.3	1733.6	1674.2	1625.9	1570.7	1527.9	1481.0
15°	2085.5	1976.5	1924.0	1899.2	1823.3	1739.1	1667.3	1595.5	1550.0	1485.1	1443.7
17.5°	2099.3	2011.0	1976.5	1913.0	1821.9	1726.7	1643.8	1572.1	1503.1	1445.1	1391.3
20°	2147.6	2031.7	1976.5	1936.4	1816.4	1719.8	1628.7	1536.2	1469.9	1407.8	1347.1
22.5°	2178.0	2046.9	1988.9	1925.4	1810.8	1694.9	1587.3	1507.2	1425.8	1362.3	1314.0
25°	2169.7	2038.6	1973.7	1914.4	1775.0	1659.0	1562.4	1460.3	1384.4	1315.3	1251.9
27.5°	2165.6	2017.9	1948.9	1882.6	1751.5	1630.0	1508.6	1425.8	1341.6	1261.5	1214.6
30°	2154.5	1991.7	1911.6	1839.8	1703.2	1576.2	1472.7	1376.1	1291.9	1218.7	1156.6
32.5°	2117.3	1947.5	1870.2	1792.9	1650.7	1523.8	1418.9	1329.2	1245.0	1169.0	1109.7
35°	2067.6	1895.0	1810.8	1729.4	1587.3	1458.9	1362.3	1268.4	1189.7	1116.6	1060.0
37.5°	2017.9	1834.3	1755.6	1661.8	1530.7	1396.8	1297.4	1213.2	1140.1	1064.1	1002.0
40°	1946.1	1762.5	1675.6	1595.5	1442.3	1316.7	1225.6	1149.7	1078.0	1006.2	953.7
42.5°	1848.1	1683.9	1594.2	1505.8	1362.3	1238.1	1149.7	1082.1	1014.5	955.1	897.1
45°	1748.7	1588.6	1508.6	1429.9	1273.9	1156.6	1075.2	1013.1	956.5	891.6	844.7
47.5°	1628.7	1493.4	1413.3	1336.1	1188.4	1071.1	996.5	938.5	886.1	832.3	788.1
50°	1505.8	1388.5	1315.3	1235.3	1094.5	988.2	915.1	866.8	824.0	772.9	737.0
52.5°	1373.3	1271.2	1209.1	1131.8	1007.6	909.6	835.0	786.7	750.8	713.6	681.8
55°	1232.5	1158.0	1091.8	1029.6	912.3	824.0	757.7	715.0	690.1	655.6	628.0
57.5°	1105.6	1033.8	993.8	923.4	821.2	734.3	681.8	645.9	617.0	596.3	574.2
60°	973.1	915.1	870.9	819.9	730.1	657.0	601.8	581.1	550.7	535.5	525.9
62.5°	846.1	804.7	763.3	724.6	644.6	575.6	534.1	507.9	490.0	474.8	466.5
65°	726.0	687.3	658.4	623.9	557.6	502.4	463.8	443.1	425.1	421.0	411.3
67.5°	608.7	592.1	560.4	532.8	476.2	433.4	404.4	378.2	368.5	364.4	356.1
70°	509.3	490.0	465.1	441.7	398.9	361.6	335.4	325.7	311.9	310.5	300.9
72.5°	419.6	396.1	378.2	360.2	328.5	295.4	281.6	267.8	260.9	255.3	251.2
75°	332.6	316.1	303.6	288.5	260.9	238.8	219.5	213.9	209.8	208.4	205.7
77.5°	248.4	237.4	231.9	216.7	197.4	178.0	169.8	161.5	161.5	158.7	160.1
80°	176.7	169.8	162.9	154.6	138.0	129.7	122.8	117.3	114.6	113.2	114.6
82.5°	111.8	107.7	106.3	100.8	89.7	85.6	80.1	75.9	75.9	75.9	75.9
85°	62.1	62.1	62.1	53.8	49.7	45.5	42.8	41.4	41.4	41.4	42.8
87.5°	26.2	26.2	22.1	22.1	20.7	17.9	16.6	16.6	17.9	17.9	19.3
90°	25.6	22.9	21.5	19.6	15.9	12.1	8.4	4.6	8.4	12.1	15.9
92.5°	62.5	60.8	59.9	57.7	53.3	48.8	44.4	40.0	44.4	48.8	53.3
95°	109.6	107.2	106.0	104.5	101.4	98.3	95.3	92.2	95.3	98.3	101.4
97.5°	163.9	161.2	159.8	158.4	155.7	153.0	150.2	147.5	150.2	153.0	155.7
100°	225.9	222.8	221.3	220.6	219.2	217.9	216.5	215.1	216.5	217.9	219.2
102.5°	291.4	288.7	287.3	287.1	286.8	286.5	286.1	285.8	286.1	286.5	286.8
105°	361.6	360.3	359.6	359.4	359.1	358.7	358.4	358.0	358.4	358.7	359.1
107.5°	435.4	435.1	434.9	434.7	434.4	434.0	433.7	433.3	433.7	434.0	434.4
110°	512.7	513.0	513.2	512.9	512.2	511.5	510.9	510.2	510.9	511.5	512.2

TEST NUMBER: P1033162

CATALOG NUMBER: S124DIW-B1020D1560UB35-4F0-XX-W2A-A1

CANDELA DISTRIBUTION (continued):

	150°	155°	157.5°	160°	165°	170°	175°	180°	185°	190°	195°
112.5°	589.1	589.8	590.1	590.1	590.1	590.1	590.1	590.1	590.1	590.1	590.1
115°	669.0	669.7	670.0	670.0	670.0	670.0	670.0	670.0	670.0	670.0	670.0
117.5°	744.8	745.1	745.3	745.3	745.3	745.3	745.3	745.3	745.3	745.3	745.3
120°	825.2	826.2	826.7	826.0	824.7	823.3	822.0	820.6	822.0	823.3	824.7
122.5°	900.0	900.3	900.5	900.3	900.0	899.6	899.3	898.9	899.3	899.6	900.0
125°	975.2	975.5	975.7	975.7	975.7	975.7	975.7	975.7	975.7	975.7	975.7
127.5°	1048.5	1049.2	1049.5	1049.0	1048.0	1046.9	1045.9	1044.9	1045.9	1046.9	1048.0
130°	1123.3	1123.3	1123.3	1122.8	1121.8	1120.7	1119.7	1118.7	1119.7	1120.7	1121.8
132.5°	1196.5	1196.8	1197.0	1196.7	1196.0	1195.3	1194.6	1193.9	1194.6	1195.3	1196.0
135°	1267.7	1267.7	1267.7	1266.7	1264.6	1262.6	1260.5	1258.5	1260.5	1262.6	1264.6
137.5°	1336.3	1335.6	1335.3	1334.8	1333.8	1332.7	1331.7	1330.7	1331.7	1332.7	1333.8
140°	1406.0	1406.0	1406.0	1405.7	1405.0	1404.3	1403.6	1402.9	1403.6	1404.3	1405.0
142.5°	1471.6	1471.9	1472.1	1471.8	1471.1	1470.4	1469.7	1469.0	1469.7	1470.4	1471.1
145°	1535.6	1535.3	1535.1	1534.4	1533.0	1531.7	1530.3	1528.9	1530.3	1531.7	1533.0
147.5°	1597.6	1597.9	1598.1	1597.2	1595.5	1593.8	1592.1	1590.4	1592.1	1593.8	1595.5
150°	1651.9	1651.9	1651.9	1651.2	1649.8	1648.5	1647.1	1645.7	1647.1	1648.5	1649.8
152.5°	1701.5	1701.2	1701.0	1700.7	1700.0	1699.3	1698.7	1698.0	1698.7	1699.3	1700.0
155°	1751.2	1751.5	1751.7	1751.7	1751.7	1751.7	1751.7	1751.7	1751.7	1751.7	1751.7
157.5°	1794.8	1794.8	1794.8	1795.1	1795.8	1796.5	1797.1	1797.8	1797.1	1796.5	1795.8
160°	1835.8	1836.1	1836.3	1836.5	1836.8	1837.1	1837.5	1837.8	1837.5	1837.1	1836.8
162.5°	1869.6	1869.9	1870.1	1870.6	1871.6	1872.7	1873.7	1874.7	1873.7	1872.7	1871.6
165°	1901.3	1902.0	1902.3	1902.8	1903.8	1904.9	1905.9	1906.9	1905.9	1904.9	1903.8
167.5°	1926.9	1926.9	1926.9	1927.6	1929.0	1930.3	1931.7	1933.1	1931.7	1930.3	1929.0
170°	1947.4	1947.1	1946.9	1947.8	1949.5	1951.2	1952.9	1954.6	1952.9	1951.2	1949.5
172.5°	1963.8	1963.8	1963.8	1964.5	1965.8	1967.2	1968.5	1969.9	1968.5	1967.2	1965.8
175°	1975.6	1975.9	1976.1	1977.0	1978.7	1980.4	1982.1	1983.8	1982.1	1980.4	1978.7
177.5°	1982.2	1982.2	1982.2	1983.1	1984.8	1986.5	1988.2	1989.9	1988.2	1986.5	1984.8
180°	1986.8	1986.8	1986.8	1986.8	1986.8	1986.8	1986.8	1986.8	1986.8	1986.8	1986.8

TEST NUMBER: P1033162

CATALOG NUMBER: S124DIW-B1020D1560UB35-4F0-XX-W2A-A1

CANDELA DISTRIBUTION (continued):

	200°	202.5°	205°	210°	215°	220°	225°	230°	235°	240°	245°
0°	1665.9	1665.9	1665.9	1665.9	1665.9	1665.9	1665.9	1665.9	1665.9	1665.9	1665.9
2.5°	1641.1	1635.6	1638.3	1624.5	1612.1	1594.2	1579.0	1576.2	1573.5	1581.7	1576.2
5°	1594.2	1587.3	1580.4	1563.8	1538.9	1523.8	1501.7	1500.3	1492.0	1479.6	1482.4
7.5°	1543.1	1538.9	1529.3	1503.1	1481.0	1454.8	1436.8	1421.6	1414.7	1403.7	1399.5
10°	1501.7	1486.5	1478.2	1449.2	1423.0	1395.4	1371.9	1360.9	1348.5	1338.8	1331.9
12.5°	1445.1	1440.9	1417.5	1394.0	1371.9	1340.2	1322.3	1290.5	1273.9	1282.2	1279.5
15°	1407.8	1388.5	1383.0	1349.9	1312.6	1291.9	1258.8	1238.1	1231.2	1218.7	1203.6
17.5°	1358.1	1345.7	1326.4	1296.0	1253.2	1224.3	1200.8	1181.5	1173.2	1156.6	1144.2
20°	1311.2	1290.5	1275.3	1247.7	1206.3	1169.0	1140.1	1127.6	1106.9	1093.1	1086.2
22.5°	1268.4	1253.2	1231.2	1189.7	1153.9	1118.0	1083.5	1065.5	1046.2	1037.9	1026.9
25°	1216.0	1191.1	1175.9	1130.4	1091.8	1062.8	1031.0	1007.6	996.5	982.7	980.0
27.5°	1164.9	1141.4	1123.5	1083.5	1036.5	999.3	980.0	963.4	944.1	944.1	937.2
30°	1113.8	1097.3	1069.7	1031.0	986.9	951.0	928.9	913.7	906.8	901.3	899.9
32.5°	1062.8	1040.7	1024.1	971.7	938.5	905.4	888.9	876.4	868.2	866.8	868.2
35°	1010.3	985.5	968.9	922.0	888.9	858.5	851.6	840.6	836.4	835.0	841.9
37.5°	955.1	935.8	915.1	876.4	839.2	821.2	807.4	803.3	801.9	810.2	812.9
40°	904.0	887.5	868.2	826.8	799.1	779.8	772.9	768.8	774.3	782.6	786.7
42.5°	855.7	832.3	817.1	779.8	755.0	743.9	735.7	735.7	741.2	750.8	757.7
45°	804.7	786.7	771.5	738.4	716.3	703.9	702.5	703.9	710.8	717.7	726.0
47.5°	755.0	737.0	720.5	692.9	673.5	666.6	665.3	666.6	677.7	687.3	697.0
50°	709.4	690.1	674.9	648.7	633.5	625.2	626.6	633.5	641.8	655.6	668.0
52.5°	655.6	641.8	628.0	604.5	590.7	585.2	589.4	594.9	610.1	619.7	634.9
55°	603.2	590.7	579.7	561.7	550.7	546.6	549.3	557.6	570.0	586.6	604.5
57.5°	554.8	541.0	530.0	517.6	505.2	506.5	507.9	519.0	534.1	549.3	570.0
60°	501.0	492.7	483.1	467.9	462.4	462.4	466.5	478.9	492.7	517.6	535.5
62.5°	452.7	441.7	434.8	425.1	416.8	418.2	427.9	438.9	455.5	476.2	499.6
65°	403.0	390.6	385.1	376.8	374.0	375.4	382.3	398.9	416.8	434.8	456.9
67.5°	347.8	343.7	338.2	329.9	332.6	334.0	340.9	354.7	374.0	392.0	416.8
70°	300.9	292.6	291.2	284.3	284.3	288.5	302.3	311.9	329.9	349.2	375.4
72.5°	251.2	244.3	244.3	238.8	242.9	247.1	254.0	267.8	284.3	303.6	325.7
75°	200.1	197.4	200.1	197.4	197.4	204.3	212.6	223.6	241.5	262.2	280.2
77.5°	154.6	154.6	153.2	157.3	157.3	161.5	172.5	183.6	197.4	213.9	233.3
80°	113.2	113.2	113.2	117.3	121.5	121.5	128.4	142.2	154.6	165.6	183.6
82.5°	77.3	77.3	77.3	80.1	85.6	85.6	93.9	102.1	115.9	125.6	133.9
85°	46.9	46.9	45.5	48.3	49.7	53.8	60.7	66.3	73.2	81.4	89.7
87.5°	20.7	20.7	22.1	23.5	24.8	27.6	30.4	33.1	40.0	42.8	46.9
90°	19.6	21.5	22.9	25.6	28.3	31.1	33.8	35.8	37.9	39.9	42.0
92.5°	57.7	59.9	60.8	62.5	64.2	65.9	67.6	68.6	69.6	70.7	71.7
95°	104.5	106.0	107.2	109.6	112.0	114.4	116.8	117.8	118.8	119.9	120.9
97.5°	158.4	159.8	161.2	163.9	166.6	169.4	172.1	173.5	174.8	176.2	177.5
100°	220.6	221.3	222.8	225.9	229.0	232.0	235.1	235.8	236.5	237.2	237.9
102.5°	287.1	287.3	288.7	291.4	294.1	296.9	299.6	300.6	301.6	302.7	303.7
105°	359.4	359.6	360.3	361.6	363.0	364.3	365.7	366.7	367.7	368.8	369.8
107.5°	434.7	434.9	435.1	435.4	435.7	436.1	436.4	437.8	439.1	440.5	441.8
110°	512.9	513.2	513.0	512.7	512.4	512.0	511.7	511.0	510.3	509.6	508.9

TEST NUMBER: P1033162

CATALOG NUMBER: S124DIW-B1020D1560UB35-4F0-XX-W2A-A1

CANDELA DISTRIBUTION (continued):

	200°	202.5°	205°	210°	215°	220°	225°	230°	235°	240°	245°
112.5°	590.1	590.1	589.8	589.1	588.4	587.7	587.0	587.0	587.0	587.0	587.0
115°	670.0	670.0	669.7	669.0	668.3	667.6	666.9	666.6	666.2	665.9	665.6
117.5°	745.3	745.3	745.1	744.8	744.4	744.1	743.7	742.7	741.7	740.6	739.6
120°	826.0	826.7	826.2	825.2	824.1	823.1	822.1	820.4	818.7	817.0	815.3
122.5°	900.3	900.5	900.3	900.0	899.6	899.3	898.9	897.9	896.9	895.8	894.8
125°	975.7	975.7	975.5	975.2	974.9	974.5	974.2	973.5	972.8	972.1	971.4
127.5°	1049.0	1049.5	1049.2	1048.5	1047.8	1047.1	1046.4	1045.7	1045.1	1044.4	1043.7
130°	1122.8	1123.3	1123.3	1123.3	1123.3	1123.3	1123.3	1122.6	1121.9	1121.2	1120.5
132.5°	1196.7	1197.0	1196.8	1196.5	1196.2	1195.8	1195.5	1194.8	1194.1	1193.4	1192.7
135°	1266.7	1267.7	1267.7	1267.7	1267.7	1267.7	1267.7	1267.0	1266.3	1265.6	1264.9
137.5°	1334.8	1335.3	1335.6	1336.3	1337.0	1337.7	1338.4	1337.4	1336.4	1335.3	1334.3
140°	1405.7	1406.0	1406.0	1406.0	1406.0	1406.0	1406.0	1405.7	1405.3	1405.0	1404.7
142.5°	1471.8	1472.1	1471.9	1471.6	1471.2	1470.9	1470.5	1470.5	1470.5	1470.5	1470.5
145°	1534.4	1535.1	1535.3	1535.6	1535.9	1536.3	1536.6	1536.3	1535.9	1535.6	1535.3
147.5°	1597.2	1598.1	1597.9	1597.6	1597.2	1596.9	1596.5	1596.2	1595.8	1595.5	1595.2
150°	1651.2	1651.9	1651.9	1651.9	1651.9	1651.9	1651.9	1651.9	1651.9	1651.9	1651.9
152.5°	1700.7	1701.0	1701.2	1701.5	1701.9	1702.2	1702.6	1703.6	1704.6	1705.7	1706.7
155°	1751.7	1751.7	1751.5	1751.2	1750.9	1750.5	1750.2	1751.6	1752.9	1754.3	1755.6
157.5°	1795.1	1794.8	1794.8	1794.8	1794.8	1794.8	1794.8	1795.8	1796.8	1797.9	1798.9
160°	1836.5	1836.3	1836.1	1835.8	1835.4	1835.1	1834.7	1835.7	1836.7	1837.8	1838.8
162.5°	1870.6	1870.1	1869.9	1869.6	1869.2	1868.9	1868.5	1870.5	1872.6	1874.6	1876.7
165°	1902.8	1902.3	1902.0	1901.3	1900.6	1900.0	1899.3	1901.3	1903.4	1905.4	1907.5
167.5°	1927.6	1926.9	1926.9	1926.9	1926.9	1926.9	1926.9	1928.9	1931.0	1933.0	1935.1
170°	1947.8	1946.9	1947.1	1947.4	1947.7	1948.1	1948.4	1950.4	1952.5	1954.5	1956.6
172.5°	1964.5	1963.8	1963.8	1963.8	1963.8	1963.8	1963.8	1966.2	1968.6	1970.9	1973.3
175°	1977.0	1976.1	1975.9	1975.6	1975.2	1974.9	1974.5	1976.9	1979.3	1981.7	1984.1
177.5°	1983.1	1982.2	1982.2	1982.2	1982.2	1982.2	1982.2	1984.6	1987.0	1989.4	1991.8
180°	1986.8	1986.8	1986.8	1986.8	1986.8	1986.8	1986.8	1986.8	1986.8	1986.8	1986.8

TEST NUMBER: P1033162

CATALOG NUMBER: S124DIW-B1020D1560UB35-4F0-XX-W2A-A1

CANDELA DISTRIBUTION (continued):

	247.5°	250°	255°	260°	265°	270°	275°	280°	285°	290°	292.5°
0°	1665.9	1665.9	1665.9	1665.9	1665.9	1665.9	1665.9	1665.9	1665.9	1665.9	1665.9
2.5°	1572.1	1570.7	1563.8	1566.5	1558.3	1561.0	1565.2	1566.5	1572.1	1567.9	1566.5
5°	1475.5	1472.7	1468.6	1464.4	1463.0	1468.6	1458.9	1461.7	1464.4	1468.6	1474.1
7.5°	1396.8	1395.4	1391.3	1384.4	1381.6	1378.8	1380.2	1389.9	1388.5	1387.1	1396.8
10°	1325.0	1326.4	1318.1	1316.7	1308.4	1307.1	1308.4	1311.2	1315.3	1320.9	1322.3
12.5°	1250.5	1268.4	1253.2	1247.7	1235.3	1242.2	1245.0	1232.5	1239.4	1243.6	1264.3
15°	1203.6	1195.3	1185.6	1185.6	1180.1	1177.3	1170.4	1180.1	1185.6	1193.9	1191.1
17.5°	1138.7	1124.9	1119.4	1113.8	1115.2	1120.7	1105.6	1127.6	1127.6	1131.8	1124.9
20°	1082.1	1071.1	1064.1	1061.4	1057.2	1054.5	1053.1	1058.6	1066.9	1069.7	1076.6
22.5°	1022.7	1022.7	1011.7	1007.6	1004.8	1000.7	1007.6	1003.4	1008.9	1014.5	1025.5
25°	973.1	973.1	968.9	963.4	959.3	956.5	960.6	959.3	963.4	970.3	973.1
27.5°	933.0	928.9	927.5	926.1	924.7	926.1	924.7	928.9	933.0	934.4	931.6
30°	898.5	894.4	895.8	895.8	897.1	895.8	894.4	898.5	899.9	897.1	898.5
32.5°	866.8	866.8	869.5	870.9	870.9	872.3	873.7	870.9	872.3	868.2	869.5
35°	840.6	843.3	846.1	847.5	848.8	847.5	850.2	848.8	846.1	843.3	841.9
37.5°	814.3	817.1	822.6	824.0	828.1	829.5	826.8	826.8	825.4	819.9	817.1
40°	786.7	789.5	796.4	800.5	803.3	807.4	804.7	804.7	799.1	793.6	789.5
42.5°	760.5	766.0	772.9	777.1	782.6	782.6	782.6	779.8	772.9	767.4	763.3
45°	734.3	735.7	745.3	752.2	757.7	757.7	757.7	753.6	749.5	738.4	732.9
47.5°	705.3	709.4	720.5	727.4	732.9	734.3	734.3	730.1	721.9	712.2	705.3
50°	673.5	680.4	692.9	702.5	709.4	712.2	708.1	705.3	695.6	684.6	676.3
52.5°	643.2	651.5	666.6	674.9	684.6	686.0	684.6	680.4	669.4	654.2	647.3
55°	612.8	619.7	636.3	650.1	658.4	661.1	658.4	651.5	637.7	622.5	615.6
57.5°	579.7	589.4	607.3	621.1	630.8	632.1	629.4	622.5	611.4	592.1	582.5
60°	545.2	557.6	575.6	589.4	601.8	603.2	600.4	590.7	576.9	557.6	549.3
62.5°	510.7	520.3	541.0	556.2	565.9	572.8	567.3	557.6	543.8	524.5	512.1
65°	470.7	484.5	502.4	516.2	527.2	528.6	525.9	517.6	502.4	481.7	472.0
67.5°	432.0	441.7	459.6	477.6	481.7	485.8	481.7	473.4	461.0	443.1	429.2
70°	385.1	393.4	415.4	427.9	433.4	437.5	434.8	426.5	415.4	398.9	387.8
72.5°	338.2	345.1	365.8	375.4	386.5	385.1	383.7	378.2	363.0	352.0	345.1
75°	288.5	296.7	310.5	323.0	327.1	327.1	327.1	323.0	313.3	295.4	288.5
77.5°	242.9	247.1	258.1	265.0	269.1	270.5	269.1	262.2	256.7	244.3	240.2
80°	186.3	197.4	205.7	207.0	212.6	212.6	212.6	209.8	204.3	191.9	190.5
82.5°	140.8	143.5	151.8	156.0	158.7	157.3	157.3	151.8	150.4	143.5	140.8
85°	95.2	99.4	98.0	103.5	104.9	102.1	102.1	104.9	98.0	99.4	95.2
87.5°	52.4	52.4	55.2	53.8	59.3	59.3	56.6	58.0	55.2	53.8	52.4
90°	43.0	43.3	44.0	44.7	45.4	46.1	45.4	44.7	44.0	43.3	43.0
92.5°	72.2	72.4	72.7	73.1	73.4	73.8	73.4	73.1	72.7	72.4	72.2
95°	121.4	121.4	121.4	121.4	121.4	121.4	121.4	121.4	121.4	121.4	121.4
97.5°	178.2	178.2	178.2	178.2	178.2	178.2	178.2	178.2	178.2	178.2	178.2
100°	238.2	238.2	238.2	238.2	238.2	238.2	238.2	238.2	238.2	238.2	238.2
102.5°	304.2	304.4	304.7	305.1	305.4	305.8	305.4	305.1	304.7	304.4	304.2
105°	370.3	370.8	371.8	372.9	373.9	374.9	373.9	372.9	371.8	370.8	370.3
107.5°	442.5	442.3	442.0	441.7	441.3	441.0	441.3	441.7	442.0	442.3	442.5
110°	508.6	509.1	510.1	511.2	512.2	513.2	512.2	511.2	510.1	509.1	508.6

TEST NUMBER: P1033162

CATALOG NUMBER: S124DIW-B1020D1560UB35-4F0-XX-W2A-A1

CANDELA DISTRIBUTION (continued):

	247.5°	250°	255°	260°	265°	270°	275°	280°	285°	290°	292.5°
112.5°	587.0	587.0	587.0	587.0	587.0	587.0	587.0	587.0	587.0	587.0	587.0
115°	665.4	665.2	664.9	664.5	664.2	663.8	664.2	664.5	664.9	665.2	665.4
117.5°	739.1	738.6	737.6	736.5	735.5	734.5	735.5	736.5	737.6	738.6	739.1
120°	814.4	814.7	815.4	816.1	816.8	817.5	816.8	816.1	815.4	814.7	814.4
122.5°	894.3	893.4	891.7	890.0	888.3	886.6	888.3	890.0	891.7	893.4	894.3
125°	971.1	970.8	970.1	969.4	968.8	968.1	968.8	969.4	970.1	970.8	971.1
127.5°	1043.4	1043.2	1042.9	1042.5	1042.2	1041.8	1042.2	1042.5	1042.9	1043.2	1043.4
130°	1120.2	1119.5	1118.1	1116.8	1115.4	1114.0	1115.4	1116.8	1118.1	1119.5	1120.2
132.5°	1192.4	1192.2	1191.9	1191.6	1191.2	1190.9	1191.2	1191.6	1191.9	1192.2	1192.4
135°	1264.6	1264.1	1263.1	1262.0	1261.0	1260.0	1261.0	1262.0	1263.1	1264.1	1264.6
137.5°	1333.8	1334.0	1334.3	1334.6	1335.0	1335.3	1335.0	1334.6	1334.3	1334.0	1333.8
140°	1404.5	1404.3	1404.0	1403.6	1403.3	1402.9	1403.3	1403.6	1404.0	1404.3	1404.5
142.5°	1470.5	1470.5	1470.5	1470.5	1470.5	1470.5	1470.5	1470.5	1470.5	1470.5	1470.5
145°	1535.1	1534.6	1533.6	1532.5	1531.5	1530.5	1531.5	1532.5	1533.6	1534.6	1535.1
147.5°	1595.0	1594.8	1594.5	1594.2	1593.8	1593.5	1593.8	1594.2	1594.5	1594.8	1595.0
150°	1651.9	1651.7	1651.4	1651.0	1650.7	1650.3	1650.7	1651.0	1651.4	1651.7	1651.9
152.5°	1707.2	1706.7	1705.7	1704.6	1703.6	1702.6	1703.6	1704.6	1705.7	1706.7	1707.2
155°	1756.3	1755.6	1754.3	1752.9	1751.6	1750.2	1751.6	1752.9	1754.3	1755.6	1756.3
157.5°	1799.4	1798.9	1797.9	1796.8	1795.8	1794.8	1795.8	1796.8	1797.9	1798.9	1799.4
160°	1839.3	1838.4	1836.7	1835.0	1833.3	1831.6	1833.3	1835.0	1836.7	1838.4	1839.3
162.5°	1877.7	1876.9	1875.2	1873.5	1871.8	1870.1	1871.8	1873.5	1875.2	1876.9	1877.7
165°	1908.5	1907.8	1906.4	1905.1	1903.7	1902.3	1903.7	1905.1	1906.4	1907.8	1908.5
167.5°	1936.1	1935.1	1933.0	1931.0	1928.9	1926.9	1928.9	1931.0	1933.0	1935.1	1936.1
170°	1957.6	1956.4	1954.0	1951.7	1949.3	1946.9	1949.3	1951.7	1954.0	1956.4	1957.6
172.5°	1974.5	1973.3	1970.9	1968.6	1966.2	1963.8	1966.2	1968.6	1970.9	1973.3	1974.5
175°	1985.3	1984.1	1981.7	1979.3	1976.9	1974.5	1976.9	1979.3	1981.7	1984.1	1985.3
177.5°	1993.0	1991.6	1988.9	1986.2	1983.4	1980.7	1983.4	1986.2	1988.9	1991.6	1993.0
180°	1986.8	1986.8	1986.8	1986.8	1986.8	1986.8	1986.8	1986.8	1986.8	1986.8	1986.8

TEST NUMBER: P1033162

CATALOG NUMBER: S124DIW-B1020D1560UB35-4F0-XX-W2A-A1

CANDELA DISTRIBUTION (continued):

	295°	300°	305°	310°	315°	320°	325°	330°	335°	337.5°	340°
0°	1665.9	1665.9	1665.9	1665.9	1665.9	1665.9	1665.9	1665.9	1665.9	1665.9	1665.9
2.5°	1566.5	1574.8	1566.5	1572.1	1574.8	1581.7	1584.5	1596.9	1601.1	1610.7	1610.7
5°	1472.7	1476.8	1478.2	1483.7	1489.3	1503.1	1512.7	1530.7	1551.4	1554.1	1566.5
7.5°	1396.8	1403.7	1414.7	1410.6	1420.2	1440.9	1453.4	1475.5	1496.2	1507.2	1522.4
10°	1329.2	1337.4	1341.6	1345.7	1363.7	1381.6	1400.9	1416.1	1443.7	1460.3	1472.7
12.5°	1273.9	1267.0	1275.3	1290.5	1311.2	1322.3	1348.5	1371.9	1392.6	1410.6	1421.6
15°	1202.2	1207.7	1216.0	1242.2	1247.7	1275.3	1285.0	1311.2	1349.9	1366.4	1380.2
17.5°	1133.2	1151.1	1167.7	1177.3	1193.9	1216.0	1243.6	1272.6	1297.4	1316.7	1333.3
20°	1078.0	1095.9	1105.6	1112.5	1129.0	1159.4	1185.6	1221.5	1253.2	1268.4	1290.5
22.5°	1033.8	1033.8	1047.6	1068.3	1078.0	1106.9	1129.0	1167.7	1202.2	1221.5	1242.2
25°	978.6	986.9	997.9	1015.8	1029.6	1053.1	1084.9	1118.0	1155.2	1171.8	1198.0
27.5°	933.0	942.7	957.9	962.0	975.8	996.5	1029.6	1065.5	1104.2	1122.1	1144.2
30°	898.5	904.0	909.6	917.8	930.3	948.2	975.8	1007.6	1054.5	1068.3	1095.9
32.5°	868.2	870.9	873.7	880.6	887.5	905.4	927.5	962.0	1000.7	1021.4	1046.2
35°	840.6	837.8	839.2	843.3	850.2	857.1	880.6	909.6	945.5	970.3	989.6
37.5°	814.3	808.8	807.4	807.4	810.2	818.5	836.4	861.3	899.9	920.6	939.9
40°	785.3	779.8	777.1	775.7	774.3	779.8	793.6	818.5	848.8	868.2	890.2
42.5°	757.7	752.2	745.3	743.9	741.2	743.9	753.6	777.1	803.3	822.6	840.6
45°	730.1	720.5	712.2	706.7	708.1	703.9	710.8	728.8	759.1	771.5	789.5
47.5°	699.8	688.7	677.7	672.2	666.6	669.4	672.2	687.3	713.6	726.0	743.9
50°	670.8	655.6	643.2	636.3	632.1	629.4	632.1	647.3	666.6	677.7	692.9
52.5°	637.7	622.5	610.1	599.0	593.5	589.4	590.7	604.5	622.5	633.5	648.7
55°	607.3	588.0	571.4	557.6	553.5	552.1	550.7	560.4	575.6	586.6	599.0
57.5°	572.8	553.5	535.5	519.0	510.7	509.3	509.3	512.1	531.4	539.7	546.6
60°	538.3	517.6	498.3	483.1	470.7	466.5	465.1	470.7	480.3	488.6	498.3
62.5°	499.6	478.9	455.5	441.7	429.2	418.2	422.3	423.7	437.5	441.7	450.0
65°	462.4	438.9	419.6	397.5	383.7	376.8	374.0	376.8	387.8	389.2	394.7
67.5°	419.6	397.5	374.0	358.9	346.4	334.0	331.3	331.3	336.8	340.9	347.8
70°	378.2	356.1	329.9	313.3	300.9	289.8	285.7	284.3	288.5	291.2	298.1
72.5°	329.9	307.8	288.5	270.5	255.3	247.1	242.9	240.2	244.3	247.1	248.4
75°	278.8	260.9	241.5	223.6	213.9	205.7	200.1	196.0	198.8	198.8	198.8
77.5°	230.5	212.6	197.4	184.9	172.5	162.9	158.7	154.6	156.0	156.0	158.7
80°	179.4	167.0	154.6	143.5	132.5	124.2	121.5	117.3	114.6	113.2	113.2
82.5°	132.5	122.8	111.8	102.1	96.6	88.3	85.6	80.1	80.1	78.7	78.7
85°	88.3	82.8	71.8	64.9	60.7	56.6	53.8	51.1	46.9	46.9	45.5
87.5°	46.9	44.2	41.4	33.1	33.1	29.0	27.6	26.2	22.1	23.5	23.5
90°	42.0	39.9	37.9	35.8	33.8	31.1	28.3	25.6	22.9	21.5	19.6
92.5°	71.7	70.7	69.6	68.6	67.6	65.9	64.2	62.5	60.8	59.9	57.7
95°	120.9	119.9	118.8	117.8	116.8	114.4	112.0	109.6	107.2	106.0	104.5
97.5°	177.5	176.2	174.8	173.5	172.1	169.4	166.6	163.9	161.2	159.8	158.4
100°	237.9	237.2	236.5	235.8	235.1	232.0	229.0	225.9	222.8	221.3	220.6
102.5°	303.7	302.7	301.6	300.6	299.6	296.9	294.1	291.4	288.7	287.3	287.1
105°	369.8	368.8	367.7	366.7	365.7	364.3	363.0	361.6	360.3	359.6	359.4
107.5°	441.8	440.5	439.1	437.8	436.4	436.1	435.7	435.4	435.1	434.9	434.7
110°	508.9	509.6	510.3	511.0	511.7	512.0	512.4	512.7	513.0	513.2	512.9

TEST NUMBER: P1033162

CATALOG NUMBER: S124DIW-B1020D1560UB35-4F0-XX-W2A-A1

CANDELA DISTRIBUTION (continued):

	295°	300°	305°	310°	315°	320°	325°	330°	335°	337.5°	340°
112.5°	587.0	587.0	587.0	587.0	587.0	587.7	588.4	589.1	589.8	590.1	590.1
115°	665.6	665.9	666.2	666.6	666.9	667.6	668.3	669.0	669.7	670.0	670.0
117.5°	739.6	740.6	741.7	742.7	743.7	744.1	744.4	744.8	745.1	745.3	745.3
120°	815.3	817.0	818.7	820.4	822.1	823.1	824.1	825.2	826.2	826.7	826.0
122.5°	894.8	895.8	896.9	897.9	898.9	899.3	899.6	900.0	900.3	900.5	900.3
125°	971.4	972.1	972.8	973.5	974.2	974.5	974.9	975.2	975.5	975.7	975.7
127.5°	1043.7	1044.4	1045.1	1045.7	1046.4	1047.1	1047.8	1048.5	1049.2	1049.5	1049.0
130°	1120.5	1121.2	1121.9	1122.6	1123.3	1123.3	1123.3	1123.3	1123.3	1123.3	1122.8
132.5°	1192.7	1193.4	1194.1	1194.8	1195.5	1195.8	1196.2	1196.5	1196.8	1197.0	1196.7
135°	1264.9	1265.6	1266.3	1267.0	1267.7	1267.7	1267.7	1267.7	1267.7	1267.7	1266.7
137.5°	1334.3	1335.3	1336.4	1337.4	1338.4	1337.7	1337.0	1336.3	1335.6	1335.3	1334.8
140°	1404.7	1405.0	1405.3	1405.7	1406.0	1406.0	1406.0	1406.0	1406.0	1406.0	1405.7
142.5°	1470.5	1470.5	1470.5	1470.5	1470.5	1470.9	1471.2	1471.6	1471.9	1472.1	1471.8
145°	1535.3	1535.6	1535.9	1536.3	1536.6	1536.3	1535.9	1535.6	1535.3	1535.1	1534.4
147.5°	1595.2	1595.5	1595.8	1596.2	1596.5	1596.9	1597.2	1597.6	1597.9	1598.1	1597.2
150°	1651.9	1651.9	1651.9	1651.9	1651.9	1651.9	1651.9	1651.9	1651.9	1651.9	1651.2
152.5°	1706.7	1705.7	1704.6	1703.6	1702.6	1702.2	1701.9	1701.5	1701.2	1701.0	1700.7
155°	1755.6	1754.3	1752.9	1751.6	1750.2	1750.5	1750.9	1751.2	1751.5	1751.7	1751.7
157.5°	1798.9	1797.9	1796.8	1795.8	1794.8	1794.8	1794.8	1794.8	1794.8	1794.8	1795.1
160°	1838.8	1837.8	1836.7	1835.7	1834.7	1835.1	1835.4	1835.8	1836.1	1836.3	1836.5
162.5°	1876.7	1874.6	1872.6	1870.5	1868.5	1868.9	1869.2	1869.6	1869.9	1870.1	1870.6
165°	1907.5	1905.4	1903.4	1901.3	1899.3	1900.0	1900.6	1901.3	1902.0	1902.3	1902.8
167.5°	1935.1	1933.0	1931.0	1928.9	1926.9	1926.9	1926.9	1926.9	1926.9	1926.9	1927.6
170°	1956.6	1954.5	1952.5	1950.4	1948.4	1948.1	1947.7	1947.4	1947.1	1946.9	1947.8
172.5°	1973.3	1970.9	1968.6	1966.2	1963.8	1963.8	1963.8	1963.8	1963.8	1963.8	1964.5
175°	1984.1	1981.7	1979.3	1976.9	1974.5	1974.9	1975.2	1975.6	1975.9	1976.1	1977.0
177.5°	1991.8	1989.4	1987.0	1984.6	1982.2	1982.2	1982.2	1982.2	1982.2	1982.2	1983.1
180°	1986.8	1986.8	1986.8	1986.8	1986.8	1986.8	1986.8	1986.8	1986.8	1986.8	1986.8

TEST NUMBER: P1033162

CATALOG NUMBER: S124DIW-B1020D1560UB35-4F0-XX-W2A-A1

CANDELA DISTRIBUTION (continued):

	345°	350°	355°	360°
0°	1665.9	1665.9	1665.9	1665.9
2.5°	1620.4	1634.2	1646.6	1665.9
5°	1584.5	1603.8	1630.0	1659.0
7.5°	1543.1	1573.5	1608.0	1648.0
10°	1504.4	1538.9	1583.1	1631.4
12.5°	1464.4	1505.8	1554.1	1606.6
15°	1418.9	1460.3	1514.1	1584.5
17.5°	1377.5	1427.1	1485.1	1559.6
20°	1329.2	1376.1	1439.6	1525.1
22.5°	1286.4	1340.2	1410.6	1485.1
25°	1239.4	1286.4	1356.8	1446.5
27.5°	1192.5	1250.5	1318.1	1405.1
30°	1147.0	1195.3	1268.4	1359.5
32.5°	1097.3	1155.2	1222.9	1308.4
35°	1043.4	1098.7	1162.1	1254.6
37.5°	995.1	1049.0	1113.8	1195.3
40°	941.3	997.9	1057.2	1138.7
42.5°	888.9	939.9	999.3	1073.8
45°	837.8	882.0	935.8	1000.7
47.5°	785.3	822.6	872.3	930.3
50°	728.8	768.8	806.0	854.4
52.5°	676.3	710.8	741.2	781.2
55°	625.2	648.7	673.5	703.9
57.5°	571.4	589.4	607.3	639.0
60°	517.6	534.1	543.8	564.5
62.5°	465.1	472.0	484.5	496.9
65°	407.2	416.8	423.7	438.9
67.5°	354.7	358.9	365.8	375.4
70°	299.5	309.2	311.9	318.8
72.5°	252.6	256.7	259.5	260.9
75°	200.1	204.3	207.0	215.3
77.5°	157.3	156.0	161.5	162.9
80°	115.9	111.8	113.2	118.7
82.5°	75.9	77.3	75.9	75.9
85°	46.9	45.5	42.8	44.2
87.5°	20.7	20.7	19.3	19.3
90°	15.9	12.1	8.4	4.6
92.5°	53.3	48.8	44.4	40.0
95°	101.4	98.3	95.3	92.2
97.5°	155.7	153.0	150.2	147.5
100°	219.2	217.9	216.5	215.1
102.5°	286.8	286.5	286.1	285.8
105°	359.1	358.7	358.4	358.0
107.5°	434.4	434.0	433.7	433.3
110°	512.2	511.5	510.9	510.2

TEST NUMBER: P1033162

CATALOG NUMBER: S124DIW-B1020D1560UB35-4F0-XX-W2A-A1

CANDELA DISTRIBUTION (continued):

	345°	350°	355°	360°
112.5°	590.1	590.1	590.1	590.1
115°	670.0	670.0	670.0	670.0
117.5°	745.3	745.3	745.3	745.3
120°	824.7	823.3	822.0	820.6
122.5°	900.0	899.6	899.3	898.9
125°	975.7	975.7	975.7	975.7
127.5°	1048.0	1046.9	1045.9	1044.9
130°	1121.8	1120.7	1119.7	1118.7
132.5°	1196.0	1195.3	1194.6	1193.9
135°	1264.6	1262.6	1260.5	1258.5
137.5°	1333.8	1332.7	1331.7	1330.7
140°	1405.0	1404.3	1403.6	1402.9
142.5°	1471.1	1470.4	1469.7	1469.0
145°	1533.0	1531.7	1530.3	1528.9
147.5°	1595.5	1593.8	1592.1	1590.4
150°	1649.8	1648.5	1647.1	1645.7
152.5°	1700.0	1699.3	1698.7	1698.0
155°	1751.7	1751.7	1751.7	1751.7
157.5°	1795.8	1796.5	1797.1	1797.8
160°	1836.8	1837.1	1837.5	1837.8
162.5°	1871.6	1872.7	1873.7	1874.7
165°	1903.8	1904.9	1905.9	1906.9
167.5°	1929.0	1930.3	1931.7	1933.1
170°	1949.5	1951.2	1952.9	1954.6
172.5°	1965.8	1967.2	1968.5	1969.9
175°	1978.7	1980.4	1982.1	1983.8
177.5°	1984.8	1986.5	1988.2	1989.9
180°	1986.8	1986.8	1986.8	1986.8

(END OF REPORT)