

Scaled data based on original data using
LM-79-2019 Approved Method: Electrical and Photometric Measurements of Solid-
State Lighting Products

Test Report Prepared for
Cooper Lighting Solutions

Brand: NEO-RAY

Report Number: P1033351

Luminaire Tested: S124DIW-B1195D470UB50-4F0-XX-W2A-F

Issue Date: 5/6/2025

Test Information

Test Method: LM-79-2019
Report Number: P1033351
REPORT IS A COMBINATION OF REPORTS P997210 AND P1007351
Test Lab: INNOVATION CENTER
Issue Date: 5/6/2025
Manufacturer: COOPER LIGHTING SOLUTIONS
Product Line: NEO-RAY
Catalog Number: S124DIW-B1195D470UB50-4F0-XX-W2A-F
Description: Define 4 Direct/Indirect Wall Mount with 5000K BioUP LEDs {m-DER=1.015} {m-EER=1.115}
Light Source: -
Ballast/Driver: -

Summary


Lumens per Lamp: N/A
Luminaire Lumens: 6753.0 lumens
Efficiency: N/A
Efficacy: 90.6 lumens/watt
Spacing Criteria (0/90/45): 1.2 / 1.17 / 1.29
Luminous Opening: Rectangular w/ Sides (W: 0.33' x L: 4' x H: 0.1')
CIE Type: Semi-Direct

Input Watts (W): 74.5
Input Voltage (V):
Input Current (Ain): NR
Voltage Rise (V): NR
Power Factor: NR
Total Harmonic Distortion (THDi): NR
Frequency (hertz): 60
Stabilization Time: NR
Operation Time: NR
Ambient Temperature (°C): NR
Test Distance: 24 FT

TEST NUMBER: P1033351

CATALOG NUMBER: S124DIW-B1195D470UB50-4F0-XX-W2A-F

Luminous Intensity Polar Plot



TEST NUMBER: P1033351

CATALOG NUMBER: S124DIW-B1195D470UB50-4F0-XX-W2A-F

COEFFICIENT OF UTILIZATION - ZONAL CAVITY METHOD:

RF	20				20				20				20				20
RC	80				70				50				30				10
RW	70	50	30	10	70	50	30	10	50	30	10	50	30	10	50	30	10
RCR																	
0	113	113	113	113	107	107	107	107	96	96	96	86	86	86	77	77	77
1	103	98	94	91	97	94	90	87	84	82	79	76	74	72	68	67	65
2	94	86	80	74	89	82	76	71	74	69	66	67	63	60	60	57	55
3	86	76	68	62	81	72	65	60	65	60	55	59	55	51	53	50	47
4	78	67	59	52	74	64	56	51	58	52	47	53	48	44	48	44	40
5	72	60	51	45	68	57	49	44	52	46	41	47	42	38	43	39	35
6	66	54	45	39	63	52	44	38	47	41	36	43	37	33	39	35	31
7	62	49	40	35	58	47	39	34	43	36	32	39	34	30	36	31	28
8	57	44	36	31	54	43	35	30	39	33	28	36	30	26	33	28	25
9	53	41	33	28	51	39	32	27	36	30	25	33	28	24	30	26	22
10	50	37	30	25	47	36	29	24	33	27	23	31	25	22	28	24	20

AVERAGE LUMINANCE (cd/sqm):

	0°	45°	90°
0°	15660	15660	15660
5°	15672	15209	15228
10°	15540	14787	14684
15°	15317	14285	14069
20°	15032	13742	13434
25°	14712	13168	12749
30°	14326	12548	11998
35°	13926	11912	11272
40°	13508	11229	10500
45°	13071	10544	9778
50°	12586	9879	8978
55°	12060	9104	8184
60°	11522	8254	7356
65°	10906	7376	6424
70°	10196	6318	5425
75°	9135	5093	4345
80°	7786	3683	3057
85°	6047	2050	1645

MAXIMUM LUMINANCE 45°-90°:

Horizontal Angle: 0°

Vertical Angle: 45°

Luminance: 13071 cd/sqm

TEST NUMBER: P1033351

CATALOG NUMBER: S124DIW-B1195D470UB50-4F0-XX-W2A-F

ZONAL LUMENS:

Zone	Lumens	% Fixture
0°-10°	181.0	2.7
10°-20°	509.9	7.6
20°-30°	750.5	11.1
30°-40°	872.4	12.9
40°-50°	872.3	12.9
50°-60°	763.0	11.3
60°-70°	566.4	8.4
70°-80°	321.4	4.8
80°-90°	93.3	1.4
90°-100°	19.6	0.3
100°-110°	128.8	1.9
110°-120°	245.9	3.6
120°-130°	312.2	4.6
130°-140°	333.9	4.9
140°-150°	312.3	4.6
150°-160°	251.8	3.7
160°-170°	162.4	2.4
170°-180°	56.0	0.8
0°-30°	1441.4	21.3
0°-40°	2313.8	34.3
0°-60°	3949.1	58.5
0°-90°	4930.2	73.0
90°-120°	394.2	5.8
90°-150°	1352.6	20.0
90°-180°	1823.0	27.0
0°-180°	6753.0	100.0

CANDELA DISTRIBUTION:

	0°	22.5°	45°	67.5°	90°	Flux
0°	1920	1920	1920	1920	1920	
5°	1919	1913	1896	1913	1910	182
15°	1826	1820	1797	1806	1802	515
25°	1654	1643	1622	1623	1617	761
35°	1423	1413	1391	1380	1373	890
45°	1162	1151	1126	1109	1105	896
55°	879	874	852	834	825	787
65°	596	588	572	557	549	589
75°	317	309	302	295	294	336
85°	83	83	80	80	78	89
90°	1	6	10	12	13	7
95°	24	9	10	12	13	30
105°	133	135	138	141	126	139
115°	248	249	248	249	249	244
125°	348	350	349	350	351	311
135°	432	431	433	434	435	333
145°	498	499	499	500	500	311
155°	546	546	545	547	545	252
165°	576	574	574	577	573	163
175°	589	586	587	591	586	56
180°	589	589	589	589	589	

TEST NUMBER: P1033351

CATALOG NUMBER: S124DIW-B1195D470UB50-4F0-XX-W2A-F

CANDELA DISTRIBUTION (FULL):

	0°	22.5°	45°	67.5°	90°
0°	1920.4	1920.4	1920.4	1920.4	1920.4
2.5°	1926.5	1921.9	1905.0	1920.4	1918.8
5°	1918.8	1912.7	1895.7	1912.7	1909.6
7.5°	1905.0	1898.8	1880.4	1894.2	1892.7
10°	1885.0	1878.8	1858.8	1871.1	1868.1
12.5°	1858.8	1852.7	1831.1	1845.0	1840.4
15°	1826.5	1820.3	1797.3	1806.5	1801.9
17.5°	1789.6	1781.9	1760.3	1766.5	1763.4
20°	1748.0	1740.3	1717.3	1721.9	1718.8
22.5°	1703.4	1692.6	1669.6	1678.8	1672.6
25°	1654.2	1643.4	1621.8	1623.4	1617.2
27.5°	1598.8	1588.0	1568.0	1564.9	1557.2
30°	1543.4	1531.1	1511.1	1504.9	1497.2
32.5°	1484.9	1474.1	1452.6	1444.9	1437.2
35°	1423.4	1412.6	1391.0	1380.3	1372.6
37.5°	1358.7	1349.5	1326.4	1315.6	1304.9
40°	1295.6	1283.3	1260.2	1244.9	1237.2
42.5°	1227.9	1221.8	1195.6	1177.1	1172.5
45°	1161.8	1151.0	1126.4	1109.4	1104.8
47.5°	1092.5	1084.8	1061.7	1043.3	1031.0
50°	1021.7	1015.6	994.0	972.5	963.3
52.5°	952.5	944.8	921.7	903.3	890.9
55°	878.6	874.0	852.5	834.0	824.8
57.5°	809.4	804.8	783.2	764.8	755.5
60°	737.1	729.4	709.4	695.5	687.8
62.5°	666.3	660.1	638.6	626.3	618.6
65°	595.5	587.8	572.4	557.0	549.3
67.5°	523.2	517.0	501.6	486.2	484.7
70°	457.0	446.2	433.9	421.6	417.0
72.5°	386.2	375.5	366.2	357.0	352.4
75°	317.0	309.3	301.6	295.4	293.9
77.5°	249.3	246.2	238.5	237.0	232.4
80°	189.3	184.7	181.6	178.5	177.0
82.5°	130.8	129.3	129.3	127.7	126.2
85°	83.1	83.1	80.0	80.0	78.5
87.5°	40.0	38.5	36.9	36.9	36.9
90°	1.3	6.2	9.7	12.3	13.2
92.5°	6.6	5.7	9.3	11.9	11.9
95°	24.2	9.3	9.7	12.3	12.8
97.5°	46.3	56.0	9.7	11.9	12.3
100°	72.3	80.2	19.4	11.9	12.3
102.5°	101.3	106.6	111.9	12.8	12.8
105°	132.6	135.3	137.5	141.4	125.6
107.5°	161.3	162.6	165.7	167.9	169.6
110°	190.3	191.7	194.3	195.2	196.5



TEST NUMBER: P1033351

CATALOG NUMBER: S124DIW-B1195D470UB50-4F0-XX-W2A-F

CANDELA DISTRIBUTION (continued):

	0°	22.5°	45°	67.5°	90°
112.5°	218.5	221.2	222.1	221.6	223.4
115°	247.6	248.9	248.5	249.4	249.4
117.5°	273.6	275.4	276.7	276.2	276.2
120°	300.0	301.8	301.4	302.2	301.4
122.5°	324.7	325.6	326.5	326.9	326.0
125°	348.1	349.8	348.9	350.3	350.7
127.5°	370.5	371.0	373.2	372.7	372.3
130°	392.1	392.6	393.9	394.3	394.3
132.5°	412.0	412.8	414.6	415.0	414.6
135°	431.8	431.3	433.1	434.0	434.9
137.5°	449.4	449.4	451.6	452.5	452.0
140°	466.6	467.5	468.3	469.7	470.1
142.5°	482.0	483.8	484.2	485.1	485.1
145°	497.9	499.2	499.2	499.6	500.5
147.5°	510.2	512.8	512.4	512.8	513.3
150°	523.9	525.6	525.2	525.2	525.6
152.5°	535.3	536.6	535.8	536.6	536.2
155°	545.9	546.3	545.0	546.8	545.4
157.5°	555.1	555.1	553.4	555.6	553.4
160°	563.1	561.8	561.3	564.0	561.3
162.5°	570.1	568.4	567.9	570.6	567.5
165°	575.9	573.6	573.6	577.2	573.2
167.5°	580.7	578.5	578.1	582.0	577.6
170°	584.7	582.0	582.5	586.0	581.6
172.5°	587.3	584.7	585.1	588.6	583.8
175°	589.1	586.4	586.9	590.8	585.5
177.5°	590.4	587.3	588.2	591.7	586.4
180°	589.1	589.1	589.1	589.1	589.1

(END OF REPORT)