

Scaled data based on original data using
LM-79-2019 Approved Method: Electrical and Photometric Measurements of Solid-
State Lighting Products

Test Report Prepared for
Cooper Lighting Solutions

Brand: NEO-RAY

Report Number: P1034000

Luminaire Tested: S124RDIW-B1195D770UB27-4F0-XX-W2A-A

Issue Date: 5/7/2025

Test Information

Test Method: LM-79-2019
Report Number: P1034000
REPORT IS A COMBINATION OF REPORTS P1000215 AND P1007351
Test Lab: INNOVATION CENTER
Issue Date: 5/7/2025
Manufacturer: COOPER LIGHTING SOLUTIONS
Product Line: NEO-RAY
Catalog Number: S124RDIW-B1195D770UB27-4F0-XX-W2A-A
Description: Define 4 Regressed Direct/Indirect Wall Mount with 2700K BioUP LEDs {m-DER=0.473}
{m-EER=0.52}
Light Source: -
Ballast/Driver: -

Summary


Lumens per Lamp: N/A
Luminaire Lumens: 8076.0 lumens
Efficiency: N/A
Efficacy: 95.6 lumens/watt
Spacing Criteria (0/90/45): 1.22 / 1.27 / 1.38
Luminous Opening: Rectangular w/ Sides (W: 0.33' x L: 4' x H: 0.1')
CIE Type: Semi-Direct

Input Watts (W): 84.5
Input Voltage (V):
Input Current (Ain): NR
Voltage Rise (V): NR
Power Factor: NR
Total Harmonic Distortion (THDi): NR
Frequency (hertz): 60
Stabilization Time: NR
Operation Time: NR
Ambient Temperature (°C): NR
Test Distance: 24 FT

TEST NUMBER: P1034000

CATALOG NUMBER: S124RDIW-B1195D770UB27-4F0-XX-W2A-A

Luminous Intensity Polar Plot



TEST NUMBER: P1034000

CATALOG NUMBER: S124RDIW-B1195D770UB27-4F0-XX-W2A-A

COEFFICIENT OF UTILIZATION - ZONAL CAVITY METHOD:

RF	20				20				20				20				20
RC	80				70				50				30				10
RW	70	50	30	10	70	50	30	10	50	30	10	50	30	10	50	30	10
RCR																	
0	110	110	110	110	103	103	103	103	90	90	90	78	78	78	67	67	67
1	101	97	93	90	94	91	88	85	80	77	75	69	68	66	60	59	58
2	92	85	79	74	86	80	75	70	71	67	63	62	59	56	53	51	49
3	85	75	68	63	79	71	65	60	63	58	54	55	51	48	48	45	43
4	78	67	59	53	73	63	56	51	56	51	46	49	45	42	43	40	37
5	72	60	52	46	67	57	50	44	50	45	40	45	40	36	39	36	33
6	66	54	46	40	62	51	44	39	46	40	35	40	36	32	36	32	29
7	61	49	41	36	57	46	39	34	42	36	31	37	32	29	33	29	26
8	57	45	37	32	53	42	35	30	38	32	28	34	29	26	30	26	23
9	53	41	33	28	50	39	32	27	35	29	25	31	27	23	28	24	21
10	50	38	30	26	47	36	29	25	32	27	23	29	24	21	26	22	19

AVERAGE LUMINANCE (cd/sqm):

	0°	90°	180°	270°
0°	16055	16055	16055	16055
5°	16055	18141	16081	13866
10°	15969	20913	15956	12058
15°	15779	23536	15779	10096
20°	15581	25519	15499	8890
25°	15337	25627	15267	8029
30°	15080	21792	14962	7438
35°	14714	16443	14529	6996
40°	14308	11916	14026	6651
45°	13637	9056	13297	6347
50°	12840	7319	12489	5900
55°	11978	6061	11585	5305
60°	11111	5124	10614	4412
65°	10023	4175	9704	3506
70°	9027	3385	8600	2848
75°	7910	2440	7360	2088
80°	6523	1617	5939	1534
85°	4730	832	3922	832

MAXIMUM LUMINANCE 45°-90°:

Horizontal Angle: 35°

Vertical Angle: 45°

Luminance: 20099 cd/sqm

TEST NUMBER: P1034000

CATALOG NUMBER: S124RDIW-B1195D770UB27-4F0-XX-W2A-A

ZONAL LUMENS:

Zone	Lumens	% Fixture
0°-10°	190.6	2.4
10°-20°	575.7	7.1
20°-30°	901.8	11.2
30°-40°	1001.4	12.4
40°-50°	887.4	11.0
50°-60°	691.6	8.6
60°-70°	452.4	5.6
70°-80°	222.0	2.7
80°-90°	56.1	0.7
90°-100°	33.2	0.4
100°-110°	218.8	2.7
110°-120°	417.8	5.2
120°-130°	530.4	6.6
130°-140°	567.4	7.0
140°-150°	530.5	6.6
150°-160°	427.8	5.3
160°-170°	275.9	3.4
170°-180°	95.1	1.2
0°-30°	1668.2	20.7
0°-40°	2669.6	33.1
0°-60°	4248.6	52.6
0°-90°	4979.1	61.7
90°-120°	669.8	8.3
90°-150°	2298.1	28.5
90°-180°	3097.0	38.3
0°-180°	8076.0	100.0

CANDELA DISTRIBUTION:

	0°	90°	180°	270°	360°	Flux
0°	1969	1969	1969	1969	1969	
5°	1966	2275	1969	1739	1966	187
15°	1882	3014	1882	1293	1882	531
25°	1724	3251	1717	1018	1724	795
35°	1504	2002	1485	852	1504	940
45°	1212	1023	1182	717	1212	935
55°	873	611	844	535	873	780
65°	547	357	530	300	547	546
75°	274	165	255	141	274	291
85°	65	40	54	40	65	73
90°	2	22	2	22	2	6
95°	41	22	41	22	41	51
105°	225	213	225	213	225	236
115°	421	424	421	424	421	414
125°	591	596	591	596	591	528
135°	734	739	734	739	734	565
145°	846	850	846	850	846	529
155°	928	927	928	927	928	428
165°	978	974	978	974	978	276
175°	1001	995	1001	995	1001	95
180°	1001	1001	1001	1001	1001	

TEST NUMBER: P1034000

CATALOG NUMBER: S124RDIW-B1195D770UB27-4F0-XX-W2A-A

CANDELA DISTRIBUTION (FULL):

	0°	5°	10°	15°	20°	22.5°	25°	30°	35°	40°	45°
0°	1968.8	1968.8	1968.8	1968.8	1968.8	1968.8	1968.8	1968.8	1968.8	1968.8	1968.8
2.5°	1972.0	1989.5	1999.0	2006.9	2022.8	2029.1	2041.8	2045.0	2057.7	2056.1	2051.3
5°	1965.7	1995.8	2018.0	2041.8	2070.4	2086.2	2103.7	2129.1	2141.8	2159.2	2170.3
7.5°	1954.6	1995.8	2032.3	2068.8	2114.8	2140.2	2162.4	2202.1	2235.4	2263.9	2295.7
10°	1937.1	1989.5	2043.4	2092.6	2156.0	2186.2	2219.5	2278.2	2324.2	2363.9	2414.6
12.5°	1910.1	1983.1	2043.4	2110.0	2191.0	2232.2	2276.6	2346.4	2400.4	2465.4	2528.9
15°	1881.6	1962.5	2041.8	2129.1	2221.1	2268.7	2313.1	2406.7	2489.2	2563.8	2633.6
17.5°	1849.9	1938.7	2026.0	2122.7	2233.8	2292.5	2344.8	2457.5	2547.9	2644.7	2714.5
20°	1811.8	1908.6	2008.5	2116.4	2241.7	2306.8	2365.5	2494.0	2593.9	2698.6	2785.9
22.5°	1770.5	1875.2	1984.7	2102.1	2232.2	2303.6	2371.8	2509.8	2625.7	2722.4	2839.8
25°	1724.5	1835.6	1948.2	2072.0	2217.9	2295.7	2365.5	2501.9	2625.7	2752.6	2866.8
27.5°	1676.9	1791.2	1908.6	2038.6	2187.8	2263.9	2343.3	2474.9	2619.3	2757.3	2873.1
30°	1624.6	1735.6	1859.4	1983.1	2141.8	2217.9	2298.8	2441.6	2598.7	2736.7	2862.0
32.5°	1567.5	1681.7	1799.1	1927.6	2083.1	2165.6	2240.1	2402.0	2562.2	2698.6	2816.0
35°	1504.0	1611.9	1722.9	1854.6	2008.5	2083.1	2171.9	2340.1	2501.9	2646.3	2722.4
37.5°	1435.8	1538.9	1642.0	1772.1	1919.7	2010.1	2097.3	2267.1	2438.4	2535.2	2574.9
40°	1372.3	1462.7	1553.2	1678.5	1827.6	1921.2	2010.1	2186.2	2336.9	2411.5	2381.3
42.5°	1291.4	1385.0	1465.9	1581.7	1732.5	1819.7	1910.1	2092.6	2214.7	2244.9	2170.3
45°	1212.1	1289.8	1367.6	1480.2	1638.9	1713.4	1810.2	1979.9	2081.5	2054.5	1945.0
47.5°	1134.3	1197.8	1270.8	1380.3	1523.0	1611.9	1702.3	1849.9	1921.2	1883.2	1730.9
50°	1042.3	1105.8	1181.9	1277.1	1415.2	1500.8	1572.2	1708.7	1762.6	1669.0	1485.0
52.5°	955.1	1010.6	1075.6	1164.5	1296.2	1373.9	1451.6	1569.0	1586.5	1478.6	1285.1
55°	872.6	917.0	985.2	1056.6	1177.2	1259.7	1313.6	1413.6	1408.8	1274.0	1107.4
57.5°	786.9	828.2	874.2	948.7	1063.0	1124.8	1183.5	1270.8	1224.8	1110.5	945.6
60°	710.8	734.5	780.6	851.9	948.7	1002.7	1048.7	1096.3	1056.6	932.9	805.9
62.5°	626.7	653.6	687.0	744.1	829.7	880.5	913.8	934.4	893.2	798.0	682.2
65°	547.3	571.1	606.0	656.8	721.9	759.9	777.4	791.7	769.5	661.6	569.6
67.5°	475.9	491.8	523.5	556.9	626.7	636.2	660.0	666.3	621.9	539.4	466.4
70°	404.6	420.4	434.7	474.4	506.1	523.5	528.3	528.3	483.9	429.9	369.7
72.5°	337.9	347.4	361.7	388.7	406.1	418.8	425.2	417.2	376.0	331.6	287.2
75°	274.5	279.2	291.9	309.4	323.6	318.9	317.3	307.8	277.6	245.9	220.5
77.5°	211.0	214.2	228.5	233.2	233.2	238.0	231.6	222.1	196.7	172.9	161.8
80°	158.6	163.4	165.0	168.2	165.0	165.0	160.2	144.4	131.7	120.6	112.6
82.5°	109.5	112.6	114.2	109.5	112.6	107.9	99.9	88.8	80.9	79.3	76.2
85°	65.0	66.6	65.0	65.0	60.3	58.7	52.4	50.8	47.6	47.6	46.0
87.5°	31.7	30.1	27.0	23.8	23.8	22.2	23.8	20.6	23.8	22.2	20.6
90°	2.2	4.0	5.9	7.7	9.6	10.5	11.2	12.5	13.8	15.2	16.5
92.5°	11.2	10.9	10.5	10.2	9.9	9.7	10.4	11.7	13.0	14.4	15.7
95°	41.2	35.5	29.9	24.2	18.5	15.7	15.8	16.0	16.1	16.3	16.5
97.5°	78.6	82.3	85.9	89.6	93.3	95.1	86.4	68.9	51.4	34.0	16.5
100°	122.8	125.8	128.8	131.7	134.7	136.2	124.7	101.8	78.8	55.9	32.9
102.5°	172.2	174.2	176.2	178.2	180.2	181.2	182.2	184.2	186.1	188.1	190.1
105°	225.3	226.3	227.3	228.3	229.3	229.8	230.2	231.1	231.9	232.8	233.6
107.5°	274.0	274.5	275.0	275.5	276.0	276.2	276.8	278.0	279.1	280.3	281.5
110°	323.4	323.9	324.4	324.9	325.4	325.6	326.1	327.1	328.1	329.1	330.1

TEST NUMBER: P1034000

CATALOG NUMBER: S124RDIW-B1195D770UB27-4F0-XX-W2A-A

CANDELA DISTRIBUTION (continued):

	0°	5°	10°	15°	20°	22.5°	25°	30°	35°	40°	45°
112.5°	371.3	372.3	373.3	374.3	375.3	375.8	376.0	376.3	376.6	377.0	377.3
115°	420.7	421.2	421.7	422.2	422.7	422.9	422.8	422.7	422.5	422.4	422.2
117.5°	464.9	465.6	466.2	466.9	467.6	467.9	468.1	468.6	469.1	469.6	470.1
120°	509.8	510.5	511.1	511.8	512.5	512.8	512.7	512.5	512.4	512.2	512.0
122.5°	551.7	552.0	552.4	552.7	553.0	553.2	553.4	553.7	554.0	554.4	554.7
125°	591.4	592.1	592.7	593.4	594.1	594.4	594.2	593.9	593.6	593.2	592.9
127.5°	629.5	629.7	629.9	630.0	630.2	630.3	630.7	631.5	632.4	633.2	634.0
130°	666.2	666.4	666.6	666.7	666.9	667.0	667.2	667.7	668.2	668.7	669.2
132.5°	699.9	700.2	700.6	700.9	701.2	701.4	701.7	702.4	703.1	703.7	704.4
135°	733.6	733.4	733.2	733.1	732.9	732.8	733.1	733.8	734.5	735.1	735.8
137.5°	763.5	763.5	763.5	763.5	763.5	763.5	763.9	764.8	765.6	766.5	767.3
140°	792.7	793.0	793.4	793.7	794.0	794.2	794.4	794.7	795.0	795.4	795.7
142.5°	818.9	819.6	820.2	820.9	821.6	821.9	822.0	822.2	822.3	822.5	822.7
145°	845.9	846.4	846.9	847.4	847.9	848.1	848.1	848.1	848.1	848.1	848.1
147.5°	866.8	867.8	868.8	869.8	870.8	871.3	871.2	871.1	870.9	870.8	870.6
150°	890.0	890.7	891.3	892.0	892.7	893.0	892.9	892.8	892.6	892.5	892.3
152.5°	909.5	910.0	910.5	911.0	911.5	911.8	911.6	911.3	911.0	910.6	910.3
155°	927.5	927.7	927.8	928.0	928.1	928.2	928.0	927.5	927.0	926.5	926.0
157.5°	943.2	943.2	943.2	943.2	943.2	943.2	942.9	942.2	941.5	940.9	940.2
160°	956.7	956.2	955.7	955.2	954.7	954.4	954.3	954.2	954.0	953.9	953.7
162.5°	968.6	968.0	967.3	966.7	966.0	965.7	965.6	965.4	965.3	965.1	964.9
165°	978.4	977.6	976.7	975.9	975.0	974.6	974.6	974.6	974.6	974.6	974.6
167.5°	986.6	985.8	985.0	984.1	983.3	982.9	982.8	982.6	982.5	982.3	982.1
170°	993.3	992.3	991.3	990.4	989.4	988.9	989.0	989.1	989.3	989.4	989.6
172.5°	997.8	996.8	995.8	994.8	993.8	993.3	993.4	993.6	993.7	993.9	994.1
175°	1000.8	999.8	998.8	997.8	996.8	996.3	996.4	996.6	996.7	996.9	997.1
177.5°	1003.1	1001.9	1000.7	999.6	998.4	997.8	998.0	998.3	998.6	999.0	999.3
180°	1000.8	1000.8	1000.8	1000.8	1000.8	1000.8	1000.8	1000.8	1000.8	1000.8	1000.8

TEST NUMBER: P1034000

CATALOG NUMBER: S124RDIW-B1195D770UB27-4F0-XX-W2A-A

CANDELA DISTRIBUTION (continued):

	50°	55°	60°	65°	67.5°	70°	75°	80°	85°	90°	95°
0°	1968.8	1968.8	1968.8	1968.8	1968.8	1968.8	1968.8	1968.8	1968.8	1968.8	1968.8
2.5°	2064.0	2081.5	2083.1	2098.9	2094.2	2086.2	2100.5	2091.0	2110.0	2103.7	2111.6
5°	2184.6	2208.4	2229.0	2241.7	2263.9	2259.2	2283.0	2275.0	2292.5	2275.0	2297.2
7.5°	2325.8	2365.5	2386.1	2419.4	2428.9	2430.5	2459.1	2465.4	2476.5	2465.4	2478.1
10°	2463.8	2511.4	2559.0	2586.0	2603.4	2627.2	2652.6	2663.7	2671.7	2660.6	2668.5
12.5°	2589.2	2663.7	2716.1	2770.0	2782.7	2803.3	2830.3	2827.1	2858.9	2852.5	2866.8
15°	2705.0	2787.5	2850.9	2893.8	2928.7	2946.1	2996.9	3000.1	2998.5	3014.3	3004.8
17.5°	2808.1	2877.9	2968.3	3023.9	3066.7	3066.7	3095.3	3154.0	3149.2	3147.6	3157.1
20°	2892.2	2971.5	3055.6	3149.2	3184.1	3190.4	3230.1	3260.2	3265.0	3265.0	3265.0
22.5°	2955.6	3049.2	3139.7	3206.3	3233.3	3255.5	3290.4	3309.4	3315.8	3312.6	3315.8
25°	2987.4	3076.2	3168.2	3228.5	3244.4	3257.1	3260.2	3271.4	3269.8	3250.7	3261.8
27.5°	2993.7	3079.4	3139.7	3155.5	3147.6	3139.7	3088.9	3093.7	3079.4	3050.8	3061.9
30°	2965.2	3011.2	3009.6	2960.4	2946.1	2912.8	2866.8	2798.6	2743.1	2719.3	2727.2
32.5°	2862.0	2862.0	2804.9	2693.9	2644.7	2584.4	2501.9	2440.0	2367.1	2351.2	2381.3
35°	2719.3	2638.3	2533.6	2387.7	2313.1	2268.7	2125.9	2081.5	2019.6	2002.2	2016.4
37.5°	2497.1	2362.3	2210.0	2073.6	2010.1	1930.8	1805.4	1742.0	1697.6	1667.4	1681.7
40°	2248.1	2084.7	1926.0	1757.8	1688.0	1623.0	1529.4	1472.3	1400.9	1404.0	1408.8
42.5°	2010.1	1818.1	1640.4	1485.0	1418.3	1364.4	1299.3	1229.5	1204.2	1196.2	1188.3
45°	1757.8	1553.2	1386.6	1270.8	1210.5	1159.7	1099.4	1059.8	1029.6	1023.3	1031.2
47.5°	1519.9	1346.9	1188.3	1080.4	1031.2	1005.8	958.2	921.8	902.7	886.9	896.4
50°	1304.1	1142.3	1015.4	924.9	890.0	872.6	828.2	809.1	790.1	785.3	783.7
52.5°	1126.4	988.4	878.9	805.9	779.0	769.5	736.1	709.2	693.3	698.1	701.2
55°	964.6	847.2	761.5	702.8	680.6	669.5	645.7	626.7	615.6	610.8	614.0
57.5°	821.8	720.3	658.4	610.8	593.3	588.6	563.2	556.9	548.9	544.2	544.2
60°	691.7	620.3	563.2	536.2	517.2	512.4	493.4	485.5	483.9	479.1	475.9
62.5°	582.2	523.5	483.9	455.3	447.4	445.8	433.1	423.6	418.8	415.7	415.7
65°	487.1	444.2	410.9	390.3	383.9	380.8	366.5	363.3	360.1	357.0	355.4
67.5°	406.1	368.1	344.3	330.0	322.1	323.6	315.7	309.4	309.4	307.8	306.2
70°	328.4	304.6	284.0	276.1	272.9	269.7	266.5	261.8	260.2	260.2	260.2
72.5°	258.6	242.7	231.6	226.9	223.7	220.5	217.3	217.3	217.3	215.8	215.8
75°	198.3	192.0	184.0	179.3	179.3	182.4	177.7	172.9	168.2	165.0	166.6
77.5°	149.1	146.0	141.2	133.3	134.9	131.7	131.7	128.5	130.1	130.1	126.9
80°	109.5	104.7	103.1	98.4	99.9	98.4	96.8	96.8	93.6	93.6	93.6
82.5°	76.2	71.4	71.4	69.8	68.2	68.2	66.6	66.6	68.2	65.0	65.0
85°	46.0	44.4	44.4	41.2	41.2	41.2	41.2	42.8	41.2	39.7	39.7
87.5°	20.6	22.2	20.6	19.0	19.0	19.0	17.5	17.5	15.9	17.5	17.5
90°	17.5	18.5	19.5	20.5	21.0	21.2	21.5	21.8	22.2	22.5	22.2
92.5°	16.7	17.7	18.7	19.7	20.2	20.2	20.2	20.2	20.2	20.2	20.2
95°	17.5	18.5	19.5	20.5	21.0	21.1	21.2	21.4	21.5	21.7	21.5
97.5°	17.3	18.1	19.0	19.8	20.2	20.3	20.5	20.6	20.8	21.0	20.8
100°	30.1	27.3	24.4	21.6	20.2	20.3	20.5	20.6	20.8	21.0	20.8
102.5°	152.7	115.3	77.8	40.4	21.7	21.7	21.7	21.7	21.7	21.7	21.7
105°	235.1	236.6	238.1	239.6	240.3	237.3	231.3	225.3	219.3	213.3	219.3
107.5°	282.3	283.1	284.0	284.8	285.2	285.5	286.2	286.9	287.5	288.2	287.5
110°	330.4	330.8	331.1	331.4	331.6	331.9	332.4	332.9	333.4	333.9	333.4

TEST NUMBER: P1034000

CATALOG NUMBER: S124RDIW-B1195D770UB27-4F0-XX-W2A-A

CANDELA DISTRIBUTION (continued):

	50°	55°	60°	65°	67.5°	70°	75°	80°	85°	90°	95°
112.5°	377.1	376.9	376.8	376.6	376.5	376.8	377.5	378.2	378.8	379.5	378.8
115°	422.5	422.9	423.2	423.5	423.7	423.7	423.7	423.7	423.7	423.7	423.7
117.5°	469.9	469.8	469.6	469.5	469.4	469.4	469.4	469.4	469.4	469.4	469.4
120°	512.3	512.7	513.0	513.3	513.5	513.3	513.0	512.7	512.3	512.0	512.3
122.5°	554.9	555.0	555.2	555.3	555.4	555.2	554.9	554.6	554.2	553.9	554.2
125°	593.4	593.9	594.4	594.9	595.1	595.2	595.4	595.5	595.7	595.9	595.7
127.5°	633.8	633.7	633.5	633.4	633.3	633.2	633.0	632.9	632.7	632.5	632.7
130°	669.4	669.6	669.7	669.9	670.0	670.0	670.0	670.0	670.0	670.0	670.0
132.5°	704.6	704.8	704.9	705.1	705.2	705.1	704.9	704.8	704.6	704.4	704.6
135°	736.1	736.5	736.8	737.1	737.3	737.5	737.8	738.1	738.5	738.8	738.5
137.5°	767.6	768.0	768.3	768.6	768.8	768.7	768.5	768.4	768.2	768.0	768.2
140°	796.2	796.7	797.2	797.7	798.0	798.1	798.2	798.4	798.5	798.7	798.5
142.5°	823.0	823.4	823.7	824.0	824.2	824.2	824.2	824.2	824.2	824.2	824.2
145°	848.3	848.5	848.6	848.8	848.9	849.1	849.4	849.7	850.1	850.4	850.1
147.5°	870.8	870.9	871.1	871.2	871.3	871.4	871.6	871.7	871.9	872.1	871.9
150°	892.3	892.3	892.3	892.3	892.3	892.4	892.5	892.7	892.8	893.0	892.8
152.5°	910.6	911.0	911.3	911.6	911.8	911.7	911.5	911.4	911.2	911.0	911.2
155°	926.7	927.3	928.0	928.7	929.0	928.7	928.2	927.7	927.2	926.7	927.2
157.5°	941.0	941.8	942.7	943.5	943.9	943.5	942.7	941.8	941.0	940.2	941.0
160°	954.7	955.7	956.7	957.7	958.2	957.7	956.7	955.7	954.7	953.7	954.7
162.5°	965.9	966.9	967.9	968.9	969.4	968.8	967.7	966.5	965.4	964.2	965.4
165°	975.9	977.3	978.6	979.9	980.6	979.9	978.4	976.9	975.4	973.9	975.4
167.5°	983.6	985.1	986.6	988.1	988.9	988.1	986.4	984.7	983.1	981.4	983.1
170°	990.9	992.3	993.6	994.9	995.6	994.8	993.1	991.4	989.8	988.1	989.8
172.5°	995.4	996.8	998.1	999.4	1000.1	999.2	997.4	995.5	993.7	991.9	993.7
175°	998.6	1000.1	1001.6	1003.1	1003.8	1002.8	1000.8	998.8	996.8	994.8	996.8
177.5°	1000.6	1002.0	1003.3	1004.6	1005.3	1004.3	1002.3	1000.3	998.3	996.3	998.3
180°	1000.8	1000.8	1000.8	1000.8	1000.8	1000.8	1000.8	1000.8	1000.8	1000.8	1000.8

TEST NUMBER: P1034000

CATALOG NUMBER: S124RDIW-B1195D770UB27-4F0-XX-W2A-A

CANDELA DISTRIBUTION (continued):

	100°	105°	110°	112.5°	115°	120°	125°	130°	135°	140°	145°
0°	1968.8	1968.8	1968.8	1968.8	1968.8	1968.8	1968.8	1968.8	1968.8	1968.8	1968.8
2.5°	2116.4	2105.3	2103.7	2103.7	2086.2	2095.8	2076.7	2056.1	2046.6	2046.6	2029.1
5°	2292.5	2281.4	2270.3	2252.8	2252.8	2243.3	2213.2	2183.0	2160.8	2141.8	2121.1
7.5°	2473.3	2462.2	2430.5	2413.1	2422.6	2403.5	2363.9	2313.1	2275.0	2244.9	2202.1
10°	2670.1	2639.9	2624.1	2614.5	2581.2	2560.6	2514.6	2440.0	2392.4	2352.8	2297.2
12.5°	2830.3	2839.8	2779.5	2784.3	2751.0	2722.4	2651.0	2579.6	2508.2	2452.7	2370.2
15°	3003.2	2974.7	2938.2	2909.6	2898.5	2863.6	2803.3	2708.1	2630.4	2543.2	2449.5
17.5°	3139.7	3117.5	3082.6	3055.6	3031.8	2947.7	2896.9	2812.9	2706.6	2620.9	2506.7
20°	3255.5	3234.9	3185.7	3168.2	3125.4	3065.1	2992.1	2862.0	2766.8	2673.2	2562.2
22.5°	3304.7	3284.0	3241.2	3219.0	3192.0	3133.3	3063.5	2939.8	2822.4	2705.0	2587.6
25°	3263.4	3263.4	3242.8	3234.9	3211.1	3158.7	3087.3	2982.6	2857.3	2730.4	2590.7
27.5°	3063.5	3103.2	3117.5	3125.4	3125.4	3127.0	3077.8	2976.3	2854.1	2730.4	2584.4
30°	2774.8	2841.4	2900.1	2917.6	2947.7	2981.0	3001.7	2952.5	2843.0	2712.9	2567.0
32.5°	2411.5	2497.1	2606.6	2633.6	2674.8	2774.8	2830.3	2850.9	2790.6	2676.4	2520.9
35°	2049.8	2157.6	2224.3	2306.8	2344.8	2492.4	2616.1	2690.7	2676.4	2608.2	2467.0
37.5°	1734.0	1795.9	1876.8	1964.1	2040.2	2181.4	2335.3	2479.7	2538.4	2505.1	2398.8
40°	1431.0	1504.0	1600.8	1672.2	1724.5	1865.7	2056.1	2213.2	2341.7	2362.3	2297.2
42.5°	1216.8	1289.8	1348.5	1426.3	1467.5	1603.9	1772.1	1968.8	2121.1	2202.1	2173.5
45°	1051.8	1096.3	1143.9	1188.3	1239.1	1359.6	1515.1	1730.9	1902.2	2016.4	2027.5
47.5°	907.5	947.1	988.4	1029.6	1058.2	1151.8	1294.6	1470.7	1657.9	1815.0	1876.8
50°	805.9	825.0	855.1	878.9	912.2	993.1	1107.4	1259.7	1458.0	1627.7	1708.7
52.5°	706.0	729.8	753.6	774.2	796.4	853.5	958.2	1089.9	1261.3	1435.8	1535.7
55°	621.9	640.9	663.2	677.4	690.1	740.9	820.2	921.8	1069.3	1234.3	1358.0
57.5°	553.7	561.6	580.7	588.6	602.9	644.1	701.2	791.7	910.6	1070.9	1172.4
60°	479.1	495.0	509.3	515.6	526.7	555.3	594.9	679.0	782.1	899.5	1015.4
62.5°	418.8	425.2	436.3	444.2	452.2	482.3	515.6	579.1	656.8	755.2	861.5
65°	363.3	366.5	372.8	383.9	388.7	410.9	429.9	475.9	548.9	623.5	729.8
67.5°	306.2	309.4	317.3	323.6	328.4	342.7	363.3	396.6	436.3	518.8	577.5
70°	261.8	261.8	266.5	269.7	274.5	280.8	291.9	317.3	353.8	406.1	460.1
72.5°	218.9	218.9	218.9	223.7	223.7	228.5	234.8	252.3	277.6	318.9	353.8
75°	169.8	171.3	174.5	174.5	176.1	182.4	187.2	192.0	204.7	231.6	263.4
77.5°	128.5	131.7	133.3	130.1	133.3	133.3	139.6	146.0	152.3	160.2	184.0
80°	95.2	96.8	93.6	95.2	95.2	98.4	101.5	99.9	103.1	112.6	119.0
82.5°	63.5	65.0	65.0	65.0	65.0	69.8	69.8	68.2	69.8	71.4	73.0
85°	39.7	38.1	38.1	39.7	38.1	38.1	39.7	41.2	39.7	41.2	42.8
87.5°	17.5	17.5	17.5	17.5	15.9	15.9	17.5	15.9	17.5	15.9	14.3
90°	21.8	21.5	21.2	21.0	20.5	19.5	18.5	17.5	16.5	15.2	13.8
92.5°	20.2	20.2	20.2	20.2	19.7	18.7	17.7	16.7	15.7	14.4	13.0
95°	21.4	21.2	21.1	21.0	20.5	19.5	18.5	17.5	16.5	16.3	16.1
97.5°	20.6	20.5	20.3	20.2	19.8	19.0	18.1	17.3	16.5	34.0	51.4
100°	20.6	20.5	20.3	20.2	21.6	24.4	27.3	30.1	32.9	55.9	78.8
102.5°	21.7	21.7	21.7	21.7	40.4	77.8	115.3	152.7	190.1	188.1	186.1
105°	225.3	231.3	237.3	240.3	239.6	238.1	236.6	235.1	233.6	232.8	231.9
107.5°	286.9	286.2	285.5	285.2	284.8	284.0	283.1	282.3	281.5	280.3	279.1
110°	332.9	332.4	331.9	331.6	331.4	331.1	330.8	330.4	330.1	329.1	328.1

TEST NUMBER: P1034000

CATALOG NUMBER: S124RDIW-B1195D770UB27-4F0-XX-W2A-A

CANDELA DISTRIBUTION (continued):

	100°	105°	110°	112.5°	115°	120°	125°	130°	135°	140°	145°
112.5°	378.2	377.5	376.8	376.5	376.6	376.8	376.9	377.1	377.3	377.0	376.6
115°	423.7	423.7	423.7	423.7	423.5	423.2	422.9	422.5	422.2	422.4	422.5
117.5°	469.4	469.4	469.4	469.4	469.5	469.6	469.8	469.9	470.1	469.6	469.1
120°	512.7	513.0	513.3	513.5	513.3	513.0	512.7	512.3	512.0	512.2	512.4
122.5°	554.6	554.9	555.2	555.4	555.3	555.2	555.0	554.9	554.7	554.4	554.0
125°	595.5	595.4	595.2	595.1	594.9	594.4	593.9	593.4	592.9	593.2	593.6
127.5°	632.9	633.0	633.2	633.3	633.4	633.5	633.7	633.8	634.0	633.2	632.4
130°	670.0	670.0	670.0	670.0	669.9	669.7	669.6	669.4	669.2	668.7	668.2
132.5°	704.8	704.9	705.1	705.2	705.1	704.9	704.8	704.6	704.4	703.7	703.1
135°	738.1	737.8	737.5	737.3	737.1	736.8	736.5	736.1	735.8	735.1	734.5
137.5°	768.4	768.5	768.7	768.8	768.6	768.3	768.0	767.6	767.3	766.5	765.6
140°	798.4	798.2	798.1	798.0	797.7	797.2	796.7	796.2	795.7	795.4	795.0
142.5°	824.2	824.2	824.2	824.2	824.0	823.7	823.4	823.0	822.7	822.5	822.3
145°	849.7	849.4	849.1	848.9	848.8	848.6	848.5	848.3	848.1	848.1	848.1
147.5°	871.7	871.6	871.4	871.3	871.2	871.1	870.9	870.8	870.6	870.8	870.9
150°	892.7	892.5	892.4	892.3	892.3	892.3	892.3	892.3	892.3	892.5	892.6
152.5°	911.4	911.5	911.7	911.8	911.6	911.3	911.0	910.6	910.3	910.6	911.0
155°	927.7	928.2	928.7	929.0	928.7	928.0	927.3	926.7	926.0	926.5	927.0
157.5°	941.8	942.7	943.5	943.9	943.5	942.7	941.8	941.0	940.2	940.9	941.5
160°	955.7	956.7	957.7	958.2	957.7	956.7	955.7	954.7	953.7	953.9	954.0
162.5°	966.5	967.7	968.8	969.4	968.9	967.9	966.9	965.9	964.9	965.1	965.3
165°	976.9	978.4	979.9	980.6	979.9	978.6	977.3	975.9	974.6	974.6	974.6
167.5°	984.7	986.4	988.1	988.9	988.1	986.6	985.1	983.6	982.1	982.3	982.5
170°	991.4	993.1	994.8	995.6	994.9	993.6	992.3	990.9	989.6	989.4	989.3
172.5°	995.5	997.4	999.2	1000.1	999.4	998.1	996.8	995.4	994.1	993.9	993.7
175°	998.8	1000.8	1002.8	1003.8	1003.1	1001.6	1000.1	998.6	997.1	996.9	996.7
177.5°	1000.3	1002.3	1004.3	1005.3	1004.6	1003.3	1002.0	1000.6	999.3	999.0	998.6
180°	1000.8	1000.8	1000.8	1000.8	1000.8	1000.8	1000.8	1000.8	1000.8	1000.8	1000.8

TEST NUMBER: P1034000

CATALOG NUMBER: S124RDIW-B1195D770UB27-4F0-XX-W2A-A

CANDELA DISTRIBUTION (continued):

	150°	155°	157.5°	160°	165°	170°	175°	180°	185°	190°	195°
0°	1968.8	1968.8	1968.8	1968.8	1968.8	1968.8	1968.8	1968.8	1968.8	1968.8	1968.8
2.5°	2019.6	2011.7	2006.9	2005.3	1991.1	1983.1	1978.4	1975.2	1970.4	1957.7	1946.6
5°	2095.8	2073.6	2062.4	2049.8	2027.5	2002.2	1981.5	1968.8	1953.0	1927.6	1903.8
7.5°	2167.2	2133.8	2111.6	2094.2	2056.1	2014.8	1981.5	1954.6	1924.4	1889.5	1856.2
10°	2241.7	2187.8	2159.2	2132.3	2076.7	2022.8	1975.2	1935.5	1892.7	1846.7	1810.2
12.5°	2300.4	2229.0	2197.3	2159.2	2091.0	2027.5	1967.3	1913.3	1857.8	1808.6	1756.3
15°	2368.6	2279.8	2243.3	2194.1	2100.5	2018.0	1940.3	1881.6	1824.5	1751.5	1696.0
17.5°	2408.3	2305.2	2252.8	2210.0	2108.5	2008.5	1918.1	1845.1	1778.5	1705.5	1646.8
20°	2448.0	2330.6	2271.9	2211.6	2091.0	1984.7	1889.5	1802.3	1732.5	1653.1	1592.8
22.5°	2460.7	2324.2	2262.3	2206.8	2079.9	1960.9	1851.4	1762.6	1681.7	1602.4	1534.1
25°	2460.7	2322.6	2249.7	2178.3	2045.0	1922.8	1813.4	1716.6	1626.2	1546.8	1478.6
27.5°	2435.3	2290.9	2214.7	2149.7	2011.7	1880.0	1767.4	1661.1	1573.8	1494.5	1416.7
30°	2403.5	2244.9	2168.7	2091.0	1957.7	1832.4	1710.2	1611.9	1519.9	1429.4	1359.6
32.5°	2363.9	2195.7	2111.6	2032.3	1891.1	1761.0	1648.4	1551.6	1464.3	1370.7	1293.0
35°	2306.8	2122.7	2029.1	1959.3	1822.9	1688.0	1580.1	1485.0	1400.9	1304.1	1220.0
37.5°	2233.8	2056.1	1960.9	1875.2	1734.0	1610.3	1508.8	1416.7	1334.2	1245.4	1151.8
40°	2148.1	1962.5	1880.0	1789.6	1640.4	1523.0	1427.8	1345.3	1262.9	1178.8	1088.3
42.5°	2051.3	1867.3	1775.3	1688.0	1545.2	1429.4	1340.6	1266.0	1189.9	1112.1	1015.4
45°	1935.5	1762.6	1673.8	1591.3	1453.2	1334.2	1253.3	1181.9	1116.9	1037.6	951.9
47.5°	1805.4	1654.7	1564.3	1475.4	1340.6	1237.5	1158.1	1097.9	1042.3	963.0	885.3
50°	1678.5	1529.4	1456.4	1366.0	1242.2	1145.5	1064.5	1013.8	970.9	893.2	823.4
52.5°	1518.3	1405.6	1335.8	1258.1	1139.1	1040.7	977.3	932.9	882.1	821.8	759.9
55°	1377.1	1272.4	1216.8	1143.9	1026.5	939.2	885.3	844.0	804.4	750.4	701.2
57.5°	1216.8	1151.8	1096.3	1032.8	917.0	842.4	794.8	759.9	723.4	679.0	639.4
60°	1048.7	1018.5	964.6	913.8	815.5	750.4	710.8	679.0	644.1	607.6	574.3
62.5°	899.5	882.1	850.4	810.7	718.7	663.2	623.5	599.7	574.3	541.0	509.3
65°	758.3	750.4	720.3	691.7	628.3	579.1	544.2	529.9	501.3	475.9	447.4
67.5°	633.0	623.5	606.0	593.3	539.4	493.4	475.9	456.9	433.1	414.1	390.3
70°	506.1	504.5	493.4	477.5	449.0	415.7	398.2	385.5	361.7	347.4	330.0
72.5°	393.5	401.4	391.9	385.5	366.5	342.7	326.8	318.9	299.8	288.7	276.1
75°	293.5	299.8	304.6	293.5	288.7	277.6	263.4	255.4	245.9	230.0	225.3
77.5°	199.9	214.2	214.2	217.3	218.9	212.6	201.5	195.1	184.0	180.9	174.5
80°	131.7	144.4	146.0	149.1	153.9	153.9	146.0	144.4	133.3	131.7	126.9
82.5°	76.2	87.3	93.6	98.4	96.8	103.1	96.8	95.2	88.8	88.8	85.7
85°	41.2	42.8	46.0	49.2	52.4	55.5	55.5	53.9	52.4	50.8	47.6
87.5°	15.9	15.9	17.5	15.9	17.5	20.6	22.2	22.2	20.6	19.0	15.9
90°	12.5	11.2	10.5	9.6	7.7	5.9	4.0	2.2	4.0	5.9	7.7
92.5°	11.7	10.4	9.7	9.9	10.2	10.5	10.9	11.2	10.9	10.5	10.2
95°	16.0	15.8	15.7	18.5	24.2	29.9	35.5	41.2	35.5	29.9	24.2
97.5°	68.9	86.4	95.1	93.3	89.6	85.9	82.3	78.6	82.3	85.9	89.6
100°	101.8	124.7	136.2	134.7	131.7	128.8	125.8	122.8	125.8	128.8	131.7
102.5°	184.2	182.2	181.2	180.2	178.2	176.2	174.2	172.2	174.2	176.2	178.2
105°	231.1	230.2	229.8	229.3	228.3	227.3	226.3	225.3	226.3	227.3	228.3
107.5°	278.0	276.8	276.2	276.0	275.5	275.0	274.5	274.0	274.5	275.0	275.5
110°	327.1	326.1	325.6	325.4	324.9	324.4	323.9	323.4	323.9	324.4	324.9

TEST NUMBER: P1034000

CATALOG NUMBER: S124RDIW-B1195D770UB27-4F0-XX-W2A-A

CANDELA DISTRIBUTION (continued):

	150°	155°	157.5°	160°	165°	170°	175°	180°	185°	190°	195°
112.5°	376.3	376.0	375.8	375.3	374.3	373.3	372.3	371.3	372.3	373.3	374.3
115°	422.7	422.8	422.9	422.7	422.2	421.7	421.2	420.7	421.2	421.7	422.2
117.5°	468.6	468.1	467.9	467.6	466.9	466.2	465.6	464.9	465.6	466.2	466.9
120°	512.5	512.7	512.8	512.5	511.8	511.1	510.5	509.8	510.5	511.1	511.8
122.5°	553.7	553.4	553.2	553.0	552.7	552.4	552.0	551.7	552.0	552.4	552.7
125°	593.9	594.2	594.4	594.1	593.4	592.7	592.1	591.4	592.1	592.7	593.4
127.5°	631.5	630.7	630.3	630.2	630.0	629.9	629.7	629.5	629.7	629.9	630.0
130°	667.7	667.2	667.0	666.9	666.7	666.6	666.4	666.2	666.4	666.6	666.7
132.5°	702.4	701.7	701.4	701.2	700.9	700.6	700.2	699.9	700.2	700.6	700.9
135°	733.8	733.1	732.8	732.9	733.1	733.2	733.4	733.6	733.4	733.2	733.1
137.5°	764.8	763.9	763.5	763.5	763.5	763.5	763.5	763.5	763.5	763.5	763.5
140°	794.7	794.4	794.2	794.0	793.7	793.4	793.0	792.7	793.0	793.4	793.7
142.5°	822.2	822.0	821.9	821.6	820.9	820.2	819.6	818.9	819.6	820.2	820.9
145°	848.1	848.1	848.1	847.9	847.4	846.9	846.4	845.9	846.4	846.9	847.4
147.5°	871.1	871.2	871.3	870.8	869.8	868.8	867.8	866.8	867.8	868.8	869.8
150°	892.8	892.9	893.0	892.7	892.0	891.3	890.7	890.0	890.7	891.3	892.0
152.5°	911.3	911.6	911.8	911.5	911.0	910.5	910.0	909.5	910.0	910.5	911.0
155°	927.5	928.0	928.2	928.1	928.0	927.8	927.7	927.5	927.7	927.8	928.0
157.5°	942.2	942.9	943.2	943.2	943.2	943.2	943.2	943.2	943.2	943.2	943.2
160°	954.2	954.3	954.4	954.7	955.2	955.7	956.2	956.7	956.2	955.7	955.2
162.5°	965.4	965.6	965.7	966.0	966.7	967.3	968.0	968.6	968.0	967.3	966.7
165°	974.6	974.6	974.6	975.0	975.9	976.7	977.6	978.4	977.6	976.7	975.9
167.5°	982.6	982.8	982.9	983.3	984.1	985.0	985.8	986.6	985.8	985.0	984.1
170°	989.1	989.0	988.9	989.4	990.4	991.3	992.3	993.3	992.3	991.3	990.4
172.5°	993.6	993.4	993.3	993.8	994.8	995.8	996.8	997.8	996.8	995.8	994.8
175°	996.6	996.4	996.3	996.8	997.8	998.8	999.8	1000.8	999.8	998.8	997.8
177.5°	998.3	998.0	997.8	998.4	999.6	1000.7	1001.9	1003.1	1001.9	1000.7	999.6
180°	1000.8	1000.8	1000.8	1000.8	1000.8	1000.8	1000.8	1000.8	1000.8	1000.8	1000.8

TEST NUMBER: P1034000

CATALOG NUMBER: S124RDIW-B1195D770UB27-4F0-XX-W2A-A

CANDELA DISTRIBUTION (continued):

	200°	202.5°	205°	210°	215°	220°	225°	230°	235°	240°	245°
0°	1968.8	1968.8	1968.8	1968.8	1968.8	1968.8	1968.8	1968.8	1968.8	1968.8	1968.8
2.5°	1937.1	1933.9	1930.8	1918.1	1907.0	1887.9	1872.1	1865.7	1864.1	1865.7	1861.0
5°	1881.6	1880.0	1868.9	1846.7	1826.1	1803.8	1788.0	1772.1	1762.6	1762.6	1751.5
7.5°	1829.2	1818.1	1808.6	1780.0	1756.3	1726.1	1702.3	1688.0	1680.1	1662.6	1662.6
10°	1773.7	1757.8	1745.1	1718.2	1683.3	1653.1	1623.0	1605.5	1591.3	1578.6	1573.8
12.5°	1718.2	1705.5	1681.7	1653.1	1618.2	1580.1	1548.4	1535.7	1502.4	1475.4	1477.0
15°	1665.8	1637.3	1626.2	1584.9	1543.7	1507.2	1461.2	1424.7	1397.7	1380.3	1358.0
17.5°	1607.1	1578.6	1557.9	1523.0	1469.1	1412.0	1367.6	1318.4	1291.4	1261.3	1247.0
20°	1542.1	1518.3	1502.4	1446.9	1381.8	1313.6	1264.4	1234.3	1204.2	1181.9	1169.2
22.5°	1486.5	1456.4	1437.4	1362.8	1291.4	1223.2	1185.1	1159.7	1134.3	1115.3	1109.0
25°	1415.2	1397.7	1351.7	1286.6	1199.4	1153.4	1120.1	1086.7	1072.5	1059.8	1045.5
27.5°	1356.5	1313.6	1281.9	1196.2	1142.3	1089.9	1056.6	1031.2	1013.8	1001.1	990.0
30°	1283.5	1243.8	1199.4	1128.0	1078.8	1029.6	999.5	978.9	959.8	951.9	942.4
32.5°	1207.3	1170.8	1128.0	1070.9	1010.6	972.5	948.7	926.5	913.8	905.9	894.8
35°	1139.1	1093.1	1064.5	1010.6	961.4	918.6	896.4	877.3	863.1	859.9	858.3
37.5°	1066.1	1031.2	1004.3	948.7	907.5	871.0	850.4	829.7	821.8	820.2	813.9
40°	1002.7	972.5	947.1	894.8	850.4	817.0	801.2	788.5	780.6	780.6	779.0
42.5°	947.1	915.4	890.0	842.4	802.8	772.6	755.2	742.5	739.3	740.9	739.3
45°	885.3	858.3	832.9	783.7	750.4	728.2	709.2	702.8	698.1	699.6	701.2
47.5°	826.6	804.4	779.0	739.3	701.2	677.4	666.3	660.0	660.0	660.0	663.2
50°	774.2	748.8	726.6	685.4	650.5	631.4	621.9	614.0	615.6	617.1	618.7
52.5°	712.3	690.1	674.3	633.0	607.6	583.8	572.7	574.3	572.7	572.7	575.9
55°	658.4	636.2	620.3	582.2	556.9	541.0	531.5	526.7	528.3	525.1	531.5
57.5°	598.1	579.1	568.0	531.5	509.3	495.0	487.1	479.1	482.3	480.7	479.1
60°	545.8	523.5	506.1	480.7	461.7	444.2	439.5	431.5	434.7	431.5	429.9
62.5°	485.5	468.0	455.3	429.9	414.1	399.8	388.7	383.9	382.3	377.6	372.8
65°	425.2	415.7	403.0	377.6	361.7	350.6	344.3	339.5	337.9	325.2	311.0
67.5°	369.7	363.3	350.6	331.6	317.3	306.2	296.7	288.7	279.2	269.7	261.8
70°	317.3	307.8	299.8	282.4	269.7	258.6	249.1	239.6	234.8	225.3	222.1
72.5°	266.5	257.0	249.1	233.2	222.1	211.0	207.8	196.7	192.0	190.4	190.4
75°	214.2	206.2	201.5	187.2	177.7	169.8	165.0	161.8	158.6	155.5	150.7
77.5°	163.4	158.6	155.5	146.0	138.0	133.3	131.7	120.6	117.4	114.2	111.1
80°	119.0	117.4	114.2	106.3	103.1	92.0	92.0	88.8	87.3	87.3	87.3
82.5°	80.9	77.7	76.2	68.2	66.6	65.0	63.5	61.9	63.5	61.9	63.5
85°	42.8	41.2	39.7	39.7	39.7	39.7	39.7	39.7	39.7	38.1	39.7
87.5°	15.9	15.9	15.9	15.9	14.3	15.9	15.9	14.3	15.9	15.9	15.9
90°	9.6	10.5	11.2	12.5	13.8	15.2	16.5	17.5	18.5	19.5	20.5
92.5°	9.9	9.7	10.4	11.7	13.0	14.4	15.7	16.7	17.7	18.7	19.7
95°	18.5	15.7	15.8	16.0	16.1	16.3	16.5	17.5	18.5	19.5	20.5
97.5°	93.3	95.1	86.4	68.9	51.4	34.0	16.5	17.3	18.1	19.0	19.8
100°	134.7	136.2	124.7	101.8	78.8	55.9	32.9	30.1	27.3	24.4	21.6
102.5°	180.2	181.2	182.2	184.2	186.1	188.1	190.1	152.7	115.3	77.8	40.4
105°	229.3	229.8	230.2	231.1	231.9	232.8	233.6	235.1	236.6	238.1	239.6
107.5°	276.0	276.2	276.8	278.0	279.1	280.3	281.5	282.3	283.1	284.0	284.8
110°	325.4	325.6	326.1	327.1	328.1	329.1	330.1	330.4	330.8	331.1	331.4

TEST NUMBER: P1034000

CATALOG NUMBER: S124RDIW-B1195D770UB27-4F0-XX-W2A-A

CANDELA DISTRIBUTION (continued):

	200°	202.5°	205°	210°	215°	220°	225°	230°	235°	240°	245°
112.5°	375.3	375.8	376.0	376.3	376.6	377.0	377.3	377.1	376.9	376.8	376.6
115°	422.7	422.9	422.8	422.7	422.5	422.4	422.2	422.5	422.9	423.2	423.5
117.5°	467.6	467.9	468.1	468.6	469.1	469.6	470.1	469.9	469.8	469.6	469.5
120°	512.5	512.8	512.7	512.5	512.4	512.2	512.0	512.3	512.7	513.0	513.3
122.5°	553.0	553.2	553.4	553.7	554.0	554.4	554.7	554.9	555.0	555.2	555.3
125°	594.1	594.4	594.2	593.9	593.6	593.2	592.9	593.4	593.9	594.4	594.9
127.5°	630.2	630.3	630.7	631.5	632.4	633.2	634.0	633.8	633.7	633.5	633.4
130°	666.9	667.0	667.2	667.7	668.2	668.7	669.2	669.4	669.6	669.7	669.9
132.5°	701.2	701.4	701.7	702.4	703.1	703.7	704.4	704.6	704.8	704.9	705.1
135°	732.9	732.8	733.1	733.8	734.5	735.1	735.8	736.1	736.5	736.8	737.1
137.5°	763.5	763.5	763.9	764.8	765.6	766.5	767.3	767.6	768.0	768.3	768.6
140°	794.0	794.2	794.4	794.7	795.0	795.4	795.7	796.2	796.7	797.2	797.7
142.5°	821.6	821.9	822.0	822.2	822.3	822.5	822.7	823.0	823.4	823.7	824.0
145°	847.9	848.1	848.1	848.1	848.1	848.1	848.1	848.3	848.5	848.6	848.8
147.5°	870.8	871.3	871.2	871.1	870.9	870.8	870.6	870.8	870.9	871.1	871.2
150°	892.7	893.0	892.9	892.8	892.6	892.5	892.3	892.3	892.3	892.3	892.3
152.5°	911.5	911.8	911.6	911.3	911.0	910.6	910.3	910.6	911.0	911.3	911.6
155°	928.1	928.2	928.0	927.5	927.0	926.5	926.0	926.7	927.3	928.0	928.7
157.5°	943.2	943.2	942.9	942.2	941.5	940.9	940.2	941.0	941.8	942.7	943.5
160°	954.7	954.4	954.3	954.2	954.0	953.9	953.7	954.7	955.7	956.7	957.7
162.5°	966.0	965.7	965.6	965.4	965.3	965.1	964.9	965.9	966.9	967.9	968.9
165°	975.0	974.6	974.6	974.6	974.6	974.6	974.6	975.9	977.3	978.6	979.9
167.5°	983.3	982.9	982.8	982.6	982.5	982.3	982.1	983.6	985.1	986.6	988.1
170°	989.4	988.9	989.0	989.1	989.3	989.4	989.6	990.9	992.3	993.6	994.9
172.5°	993.8	993.3	993.4	993.6	993.7	993.9	994.1	995.4	996.8	998.1	999.4
175°	996.8	996.3	996.4	996.6	996.7	996.9	997.1	998.6	1000.1	1001.6	1003.1
177.5°	998.4	997.8	998.0	998.3	998.6	999.0	999.3	1000.6	1002.0	1003.3	1004.6
180°	1000.8	1000.8	1000.8	1000.8	1000.8	1000.8	1000.8	1000.8	1000.8	1000.8	1000.8

TEST NUMBER: P1034000

CATALOG NUMBER: S124RDIW-B1195D770UB27-4F0-XX-W2A-A

CANDELA DISTRIBUTION (continued):

	247.5°	250°	255°	260°	265°	270°	275°	280°	285°	290°	292.5°
0°	1968.8	1968.8	1968.8	1968.8	1968.8	1968.8	1968.8	1968.8	1968.8	1968.8	1968.8
2.5°	1861.0	1867.3	1859.4	1864.1	1853.0	1851.4	1853.0	1853.0	1854.6	1856.2	1857.8
5°	1756.3	1754.7	1745.1	1738.8	1734.0	1738.8	1742.0	1745.1	1742.0	1745.1	1746.7
7.5°	1657.9	1653.1	1648.4	1637.3	1640.4	1637.3	1646.8	1642.0	1642.0	1650.0	1656.3
10°	1570.6	1561.1	1557.9	1545.2	1535.7	1534.1	1545.2	1550.0	1554.8	1557.9	1570.6
12.5°	1458.0	1443.7	1432.6	1437.4	1410.4	1421.5	1424.7	1418.3	1437.4	1459.6	1446.9
15°	1337.4	1339.0	1316.8	1308.9	1286.6	1293.0	1294.6	1310.4	1326.3	1324.7	1343.8
17.5°	1248.6	1239.1	1220.0	1218.4	1208.9	1213.7	1212.1	1224.8	1220.0	1227.9	1243.8
20°	1166.1	1159.7	1143.9	1137.5	1140.7	1137.5	1139.1	1140.7	1145.5	1162.9	1159.7
22.5°	1101.0	1093.1	1093.1	1085.2	1075.6	1072.5	1080.4	1085.2	1091.5	1094.7	1102.6
25°	1043.9	1037.6	1029.6	1024.9	1016.9	1018.5	1023.3	1029.6	1034.4	1040.7	1047.1
27.5°	985.2	985.2	977.3	975.7	972.5	970.9	977.3	980.5	980.5	985.2	991.6
30°	939.2	939.2	931.3	929.7	928.1	928.1	932.9	934.4	936.0	940.8	944.0
32.5°	894.8	893.2	890.0	891.6	890.0	891.6	891.6	893.2	896.4	898.0	904.3
35°	853.5	855.1	851.9	851.9	850.4	851.9	855.1	856.7	858.3	861.5	861.5
37.5°	813.9	817.0	815.5	820.2	820.2	820.2	820.2	823.4	823.4	823.4	821.8
40°	779.0	779.0	777.4	780.6	783.7	783.7	785.3	785.3	786.9	786.9	785.3
42.5°	739.3	742.5	747.2	748.8	752.0	750.4	755.2	753.6	755.2	752.0	748.8
45°	702.8	702.8	709.2	715.5	717.1	717.1	717.1	720.3	717.1	712.3	710.8
47.5°	663.2	666.3	669.5	677.4	679.0	679.0	679.0	679.0	675.8	675.8	675.8
50°	623.5	625.1	626.7	629.8	634.6	633.0	633.0	633.0	639.4	633.0	634.6
52.5°	575.9	577.5	579.1	585.4	583.8	583.8	585.4	585.4	590.2	588.6	585.4
55°	528.3	528.3	531.5	531.5	531.5	534.6	536.2	539.4	537.8	539.4	541.0
57.5°	480.7	477.5	475.9	475.9	480.7	479.1	480.7	480.7	487.1	490.2	491.8
60°	425.2	425.2	423.6	414.1	414.1	412.5	417.2	420.4	423.6	437.9	436.3
62.5°	368.1	361.7	355.4	357.0	347.4	352.2	349.0	352.2	361.7	372.8	374.4
65°	311.0	306.2	299.8	298.3	295.1	299.8	298.3	299.8	304.6	311.0	318.9
67.5°	260.2	258.6	255.4	253.8	253.8	253.8	257.0	257.0	258.6	263.4	268.1
70°	222.1	220.5	222.1	218.9	220.5	218.9	220.5	222.1	223.7	225.3	230.0
72.5°	187.2	187.2	187.2	184.0	187.2	185.6	185.6	187.2	188.8	190.4	193.6
75°	149.1	146.0	142.8	139.6	138.0	141.2	142.8	141.2	146.0	152.3	152.3
77.5°	112.6	111.1	111.1	111.1	112.6	111.1	114.2	112.6	114.2	114.2	117.4
80°	87.3	85.7	87.3	87.3	85.7	88.8	87.3	87.3	88.8	90.4	88.8
82.5°	63.5	65.0	63.5	63.5	63.5	66.6	63.5	63.5	63.5	65.0	65.0
85°	39.7	39.7	39.7	39.7	41.2	39.7	41.2	39.7	42.8	41.2	41.2
87.5°	14.3	15.9	17.5	17.5	17.5	17.5	15.9	17.5	19.0	17.5	19.0
90°	21.0	21.2	21.5	21.8	22.2	22.5	22.2	21.8	21.5	21.2	21.0
92.5°	20.2	20.2	20.2	20.2	20.2	20.2	20.2	20.2	20.2	20.2	20.2
95°	21.0	21.1	21.2	21.4	21.5	21.7	21.5	21.4	21.2	21.1	21.0
97.5°	20.2	20.3	20.5	20.6	20.8	21.0	20.8	20.6	20.5	20.3	20.2
100°	20.2	20.3	20.5	20.6	20.8	21.0	20.8	20.6	20.5	20.3	20.2
102.5°	21.7	21.7	21.7	21.7	21.7	21.7	21.7	21.7	21.7	21.7	21.7
105°	240.3	237.3	231.3	225.3	219.3	213.3	219.3	225.3	231.3	237.3	240.3
107.5°	285.2	285.5	286.2	286.9	287.5	288.2	287.5	286.9	286.2	285.5	285.2
110°	331.6	331.9	332.4	332.9	333.4	333.9	333.4	332.9	332.4	331.9	331.6

TEST NUMBER: P1034000

CATALOG NUMBER: S124RDIW-B1195D770UB27-4F0-XX-W2A-A

CANDELA DISTRIBUTION (continued):

	247.5°	250°	255°	260°	265°	270°	275°	280°	285°	290°	292.5°
112.5°	376.5	376.8	377.5	378.2	378.8	379.5	378.8	378.2	377.5	376.8	376.5
115°	423.7	423.7	423.7	423.7	423.7	423.7	423.7	423.7	423.7	423.7	423.7
117.5°	469.4	469.4	469.4	469.4	469.4	469.4	469.4	469.4	469.4	469.4	469.4
120°	513.5	513.3	513.0	512.7	512.3	512.0	512.3	512.7	513.0	513.3	513.5
122.5°	555.4	555.2	554.9	554.6	554.2	553.9	554.2	554.6	554.9	555.2	555.4
125°	595.1	595.2	595.4	595.5	595.7	595.9	595.7	595.5	595.4	595.2	595.1
127.5°	633.3	633.2	633.0	632.9	632.7	632.5	632.7	632.9	633.0	633.2	633.3
130°	670.0	670.0	670.0	670.0	670.0	670.0	670.0	670.0	670.0	670.0	670.0
132.5°	705.2	705.1	704.9	704.8	704.6	704.4	704.6	704.8	704.9	705.1	705.2
135°	737.3	737.5	737.8	738.1	738.5	738.8	738.5	738.1	737.8	737.5	737.3
137.5°	768.8	768.7	768.5	768.4	768.2	768.0	768.2	768.4	768.5	768.7	768.8
140°	798.0	798.1	798.2	798.4	798.5	798.7	798.5	798.4	798.2	798.1	798.0
142.5°	824.2	824.2	824.2	824.2	824.2	824.2	824.2	824.2	824.2	824.2	824.2
145°	848.9	849.1	849.4	849.7	850.1	850.4	850.1	849.7	849.4	849.1	848.9
147.5°	871.3	871.4	871.6	871.7	871.9	872.1	871.9	871.7	871.6	871.4	871.3
150°	892.3	892.4	892.5	892.7	892.8	893.0	892.8	892.7	892.5	892.4	892.3
152.5°	911.8	911.7	911.5	911.4	911.2	911.0	911.2	911.4	911.5	911.7	911.8
155°	929.0	928.7	928.2	927.7	927.2	926.7	927.2	927.7	928.2	928.7	929.0
157.5°	943.9	943.5	942.7	941.8	941.0	940.2	941.0	941.8	942.7	943.5	943.9
160°	958.2	957.7	956.7	955.7	954.7	953.7	954.7	955.7	956.7	957.7	958.2
162.5°	969.4	968.8	967.7	966.5	965.4	964.2	965.4	966.5	967.7	968.8	969.4
165°	980.6	979.9	978.4	976.9	975.4	973.9	975.4	976.9	978.4	979.9	980.6
167.5°	988.9	988.1	986.4	984.7	983.1	981.4	983.1	984.7	986.4	988.1	988.9
170°	995.6	994.8	993.1	991.4	989.8	988.1	989.8	991.4	993.1	994.8	995.6
172.5°	1000.1	999.2	997.4	995.5	993.7	991.9	993.7	995.5	997.4	999.2	1000.1
175°	1003.8	1002.8	1000.8	998.8	996.8	994.8	996.8	998.8	1000.8	1002.8	1003.8
177.5°	1005.3	1004.3	1002.3	1000.3	998.3	996.3	998.3	1000.3	1002.3	1004.3	1005.3
180°	1000.8	1000.8	1000.8	1000.8	1000.8	1000.8	1000.8	1000.8	1000.8	1000.8	1000.8

TEST NUMBER: P1034000

CATALOG NUMBER: S124RDIW-B1195D770UB27-4F0-XX-W2A-A

CANDELA DISTRIBUTION (continued):

	295°	300°	305°	310°	315°	320°	325°	330°	335°	337.5°	340°
0°	1968.8	1968.8	1968.8	1968.8	1968.8	1968.8	1968.8	1968.8	1968.8	1968.8	1968.8
2.5°	1864.1	1872.1	1868.9	1857.8	1862.5	1872.1	1881.6	1894.3	1902.2	1908.6	1911.7
5°	1754.7	1768.9	1765.8	1765.8	1772.1	1788.0	1803.8	1830.8	1840.3	1851.4	1867.3
7.5°	1657.9	1669.0	1678.5	1681.7	1691.2	1711.8	1732.5	1762.6	1786.4	1799.1	1808.6
10°	1572.2	1580.1	1594.4	1602.4	1611.9	1637.3	1667.4	1699.1	1722.9	1745.1	1757.8
12.5°	1462.7	1494.5	1513.5	1526.2	1538.9	1577.0	1600.8	1635.7	1664.2	1684.9	1703.9
15°	1340.6	1378.7	1389.8	1439.0	1470.7	1500.8	1537.3	1578.6	1605.5	1629.3	1654.7
17.5°	1237.5	1264.4	1277.1	1329.5	1356.5	1404.0	1456.4	1508.8	1550.0	1567.5	1592.8
20°	1172.4	1186.7	1212.1	1229.5	1258.1	1313.6	1370.7	1434.2	1496.1	1513.5	1538.9
22.5°	1105.8	1124.8	1142.3	1166.1	1188.3	1226.4	1283.5	1353.3	1419.9	1451.6	1481.8
25°	1045.5	1064.5	1075.6	1101.0	1121.7	1159.7	1199.4	1270.8	1350.1	1377.1	1424.7
27.5°	997.9	1009.0	1028.0	1039.2	1063.0	1097.9	1134.3	1188.3	1266.0	1312.0	1358.0
30°	950.3	958.2	974.1	990.0	1007.4	1031.2	1072.5	1124.8	1196.2	1235.9	1281.9
32.5°	902.7	915.4	924.9	936.0	955.1	983.6	1012.2	1063.0	1120.1	1164.5	1210.5
35°	863.1	867.8	880.5	893.2	905.9	931.3	961.4	1010.6	1061.4	1096.3	1137.5
37.5°	820.2	828.2	837.7	842.4	863.1	878.9	910.6	948.7	1009.0	1031.2	1072.5
40°	786.9	785.3	794.8	802.8	812.3	837.7	856.7	898.0	945.6	980.5	1005.8
42.5°	745.7	745.7	748.8	758.3	771.0	786.9	809.1	844.0	893.2	918.6	948.7
45°	712.3	707.6	709.2	715.5	723.4	739.3	761.5	791.7	840.8	861.5	893.2
47.5°	672.7	667.9	667.9	674.3	680.6	691.7	709.2	744.1	783.7	810.7	834.5
50°	628.3	629.8	628.3	633.0	636.2	647.3	666.3	694.9	731.4	753.6	780.6
52.5°	587.0	583.8	582.2	585.4	591.8	599.7	620.3	645.7	680.6	702.8	726.6
55°	536.2	539.4	539.4	539.4	548.9	552.1	568.0	593.3	628.3	645.7	667.9
57.5°	490.2	488.6	491.8	490.2	498.2	509.3	522.0	541.0	575.9	593.3	614.0
60°	439.5	441.0	442.6	442.6	449.0	460.1	474.4	491.8	520.4	537.8	556.9
62.5°	377.6	385.5	393.5	396.6	406.1	414.1	423.6	442.6	468.0	480.7	498.2
65°	318.9	330.0	341.1	349.0	355.4	363.3	376.0	393.5	414.1	426.8	444.2
67.5°	268.1	276.1	290.3	298.3	311.0	320.5	328.4	342.7	368.1	372.8	387.1
70°	231.6	234.8	241.1	247.5	261.8	269.7	279.2	293.5	312.5	323.6	331.6
72.5°	195.1	196.7	199.9	206.2	212.6	222.1	233.2	245.9	263.4	268.1	279.2
75°	155.5	165.0	165.0	169.8	174.5	179.3	188.8	201.5	212.6	220.5	226.9
77.5°	115.8	120.6	123.7	131.7	138.0	142.8	149.1	158.6	165.0	171.3	176.1
80°	90.4	92.0	93.6	93.6	96.8	103.1	109.5	115.8	123.7	126.9	131.7
82.5°	66.6	66.6	66.6	69.8	71.4	73.0	73.0	76.2	84.1	87.3	92.0
85°	42.8	42.8	42.8	42.8	44.4	46.0	47.6	49.2	49.2	49.2	52.4
87.5°	17.5	20.6	19.0	20.6	20.6	20.6	20.6	22.2	22.2	23.8	23.8
90°	20.5	19.5	18.5	17.5	16.5	15.2	13.8	12.5	11.2	10.5	9.6
92.5°	19.7	18.7	17.7	16.7	15.7	14.4	13.0	11.7	10.4	9.7	9.9
95°	20.5	19.5	18.5	17.5	16.5	16.3	16.1	16.0	15.8	15.7	18.5
97.5°	19.8	19.0	18.1	17.3	16.5	34.0	51.4	68.9	86.4	95.1	93.3
100°	21.6	24.4	27.3	30.1	32.9	55.9	78.8	101.8	124.7	136.2	134.7
102.5°	40.4	77.8	115.3	152.7	190.1	188.1	186.1	184.2	182.2	181.2	180.2
105°	239.6	238.1	236.6	235.1	233.6	232.8	231.9	231.1	230.2	229.8	229.3
107.5°	284.8	284.0	283.1	282.3	281.5	280.3	279.1	278.0	276.8	276.2	276.0
110°	331.4	331.1	330.8	330.4	330.1	329.1	328.1	327.1	326.1	325.6	325.4

TEST NUMBER: P1034000

CATALOG NUMBER: S124RDIW-B1195D770UB27-4F0-XX-W2A-A

CANDELA DISTRIBUTION (continued):

	295°	300°	305°	310°	315°	320°	325°	330°	335°	337.5°	340°
112.5°	376.6	376.8	376.9	377.1	377.3	377.0	376.6	376.3	376.0	375.8	375.3
115°	423.5	423.2	422.9	422.5	422.2	422.4	422.5	422.7	422.8	422.9	422.7
117.5°	469.5	469.6	469.8	469.9	470.1	469.6	469.1	468.6	468.1	467.9	467.6
120°	513.3	513.0	512.7	512.3	512.0	512.2	512.4	512.5	512.7	512.8	512.5
122.5°	555.3	555.2	555.0	554.9	554.7	554.4	554.0	553.7	553.4	553.2	553.0
125°	594.9	594.4	593.9	593.4	592.9	593.2	593.6	593.9	594.2	594.4	594.1
127.5°	633.4	633.5	633.7	633.8	634.0	633.2	632.4	631.5	630.7	630.3	630.2
130°	669.9	669.7	669.6	669.4	669.2	668.7	668.2	667.7	667.2	667.0	666.9
132.5°	705.1	704.9	704.8	704.6	704.4	703.7	703.1	702.4	701.7	701.4	701.2
135°	737.1	736.8	736.5	736.1	735.8	735.1	734.5	733.8	733.1	732.8	732.9
137.5°	768.6	768.3	768.0	767.6	767.3	766.5	765.6	764.8	763.9	763.5	763.5
140°	797.7	797.2	796.7	796.2	795.7	795.4	795.0	794.7	794.4	794.2	794.0
142.5°	824.0	823.7	823.4	823.0	822.7	822.5	822.3	822.2	822.0	821.9	821.6
145°	848.8	848.6	848.5	848.3	848.1	848.1	848.1	848.1	848.1	848.1	847.9
147.5°	871.2	871.1	870.9	870.8	870.6	870.8	870.9	871.1	871.2	871.3	870.8
150°	892.3	892.3	892.3	892.3	892.3	892.5	892.6	892.8	892.9	893.0	892.7
152.5°	911.6	911.3	911.0	910.6	910.3	910.6	911.0	911.3	911.6	911.8	911.5
155°	928.7	928.0	927.3	926.7	926.0	926.5	927.0	927.5	928.0	928.2	928.1
157.5°	943.5	942.7	941.8	941.0	940.2	940.9	941.5	942.2	942.9	943.2	943.2
160°	957.7	956.7	955.7	954.7	953.7	953.9	954.0	954.2	954.3	954.4	954.7
162.5°	968.9	967.9	966.9	965.9	964.9	965.1	965.3	965.4	965.6	965.7	966.0
165°	979.9	978.6	977.3	975.9	974.6	974.6	974.6	974.6	974.6	974.6	975.0
167.5°	988.1	986.6	985.1	983.6	982.1	982.3	982.5	982.6	982.8	982.9	983.3
170°	994.9	993.6	992.3	990.9	989.6	989.4	989.3	989.1	989.0	988.9	989.4
172.5°	999.4	998.1	996.8	995.4	994.1	993.9	993.7	993.6	993.4	993.3	993.8
175°	1003.1	1001.6	1000.1	998.6	997.1	996.9	996.7	996.6	996.4	996.3	996.8
177.5°	1004.6	1003.3	1002.0	1000.6	999.3	999.0	998.6	998.3	998.0	997.8	998.4
180°	1000.8	1000.8	1000.8	1000.8	1000.8	1000.8	1000.8	1000.8	1000.8	1000.8	1000.8

TEST NUMBER: P1034000

CATALOG NUMBER: S124RDIW-B1195D770UB27-4F0-XX-W2A-A

CANDELA DISTRIBUTION (continued):

	345°	350°	355°	360°
0°	1968.8	1968.8	1968.8	1968.8
2.5°	1924.4	1933.9	1949.8	1972.0
5°	1880.0	1907.0	1932.4	1965.7
7.5°	1840.3	1872.1	1907.0	1954.6
10°	1794.3	1834.0	1878.4	1937.1
12.5°	1740.4	1795.9	1846.7	1910.1
15°	1700.7	1742.0	1807.0	1881.6
17.5°	1645.2	1700.7	1765.8	1849.9
20°	1592.8	1651.5	1724.5	1811.8
22.5°	1537.3	1603.9	1676.9	1770.5
25°	1480.2	1551.6	1624.6	1724.5
27.5°	1427.8	1492.9	1575.4	1676.9
30°	1364.4	1439.0	1518.3	1624.6
32.5°	1302.5	1380.3	1461.2	1567.5
35°	1235.9	1313.6	1402.5	1504.0
37.5°	1170.8	1256.5	1337.4	1435.8
40°	1099.4	1188.3	1272.4	1372.3
42.5°	1029.6	1121.7	1205.7	1291.4
45°	964.6	1055.0	1131.2	1212.1
47.5°	902.7	983.6	1061.4	1134.3
50°	842.4	910.6	982.0	1042.3
52.5°	779.0	844.0	901.1	955.1
55°	721.9	772.6	823.4	872.6
57.5°	653.6	704.4	748.8	786.9
60°	596.5	628.3	671.1	710.8
62.5°	531.5	568.0	601.3	626.7
65°	468.0	499.7	525.1	547.3
67.5°	414.1	433.1	452.2	475.9
70°	349.0	364.9	387.1	404.6
72.5°	293.5	306.2	317.3	337.9
75°	238.0	249.1	255.4	274.5
77.5°	184.0	195.1	199.9	211.0
80°	141.2	142.8	149.1	158.6
82.5°	96.8	99.9	101.5	109.5
85°	55.5	63.5	61.9	65.0
87.5°	23.8	25.4	28.6	31.7
90°	7.7	5.9	4.0	2.2
92.5°	10.2	10.5	10.9	11.2
95°	24.2	29.9	35.5	41.2
97.5°	89.6	85.9	82.3	78.6
100°	131.7	128.8	125.8	122.8
102.5°	178.2	176.2	174.2	172.2
105°	228.3	227.3	226.3	225.3
107.5°	275.5	275.0	274.5	274.0
110°	324.9	324.4	323.9	323.4

TEST NUMBER: P1034000

CATALOG NUMBER: S124RDIW-B1195D770UB27-4F0-XX-W2A-A

CANDELA DISTRIBUTION (continued):

	345°	350°	355°	360°
112.5°	374.3	373.3	372.3	371.3
115°	422.2	421.7	421.2	420.7
117.5°	466.9	466.2	465.6	464.9
120°	511.8	511.1	510.5	509.8
122.5°	552.7	552.4	552.0	551.7
125°	593.4	592.7	592.1	591.4
127.5°	630.0	629.9	629.7	629.5
130°	666.7	666.6	666.4	666.2
132.5°	700.9	700.6	700.2	699.9
135°	733.1	733.2	733.4	733.6
137.5°	763.5	763.5	763.5	763.5
140°	793.7	793.4	793.0	792.7
142.5°	820.9	820.2	819.6	818.9
145°	847.4	846.9	846.4	845.9
147.5°	869.8	868.8	867.8	866.8
150°	892.0	891.3	890.7	890.0
152.5°	911.0	910.5	910.0	909.5
155°	928.0	927.8	927.7	927.5
157.5°	943.2	943.2	943.2	943.2
160°	955.2	955.7	956.2	956.7
162.5°	966.7	967.3	968.0	968.6
165°	975.9	976.7	977.6	978.4
167.5°	984.1	985.0	985.8	986.6
170°	990.4	991.3	992.3	993.3
172.5°	994.8	995.8	996.8	997.8
175°	997.8	998.8	999.8	1000.8
177.5°	999.6	1000.7	1001.9	1003.1
180°	1000.8	1000.8	1000.8	1000.8

(END OF REPORT)