

Scaled data based on original data using

LM-41-14 Approved Method for Photometric Testing Of Indoor Fluorescent Luminaires

Test Report Prepared for

Cooper Lighting Solutions

(formerly Eaton)

Brand: io LED

Report Number: P225426

Luminaire Tested: **LSSQ2B10FL409727D010 2LBDLC*MB**

Issue Date: 3/3/2020

Test Information

Test Method: LM-41-14
Report Number: P225426
TEST IS SCALED FROM IESNA LM-79-08 TEST DATA (P14833)
Test Lab: INNOVATION CENTER (G1)
Issue Date: 3/3/2020
Manufacturer: COOPER LIGHTING SOLUTIONS (FORMERLY EATON)
Product Line: io LED
Catalog Number: LSSQ2B10FL409727D010 2LBDLC*MB
Description: 1000 Lumen, 2inch Portfolio LED Cylinder
FLOOD OPTIC
LENSED CAST ROUND TRIM WITH MATTE BLACK FINISH
Light Source: -
Ballast/Driver: -

Summary

Lumens per Lamp: N/A
Luminaire Lumens: 651.1 lumens
Efficiency: N/A
Efficacy: 63.2 lumens/watt
Spacing Criteria (0/90/45): 0.6 / 0.6 / 0.6
Luminous Opening: Rectangular (W 0.17' x L: 0.17' x H: 0')
CIE Type: Direct


Input Watts (W): 10.3
Input Voltage (V): NR
Input Current (Ain): NR
Voltage Rise (V): NR
Power Factor: NR
Total Harmonic Distortion (THDi): NR
Frequency (hertz): 60
Stabilization Time: NR
Operation Time: NR
Ambient Temperature (°C): NR
Test Distance: 25 FT



TEST NUMBER: P225426

CATALOG NUMBER: LSSQ2B10FL409727D010 2LBDLC*MB

Luminous Intensity Polar Plot





TEST NUMBER: P225426

CATALOG NUMBER: LSSQ2B10FL409727D010 2LBDLC*MB

COEFFICIENT OF UTILIZATION - ZONAL CAVITY METHOD:

RF	20				20					20					20					20
RC	80				70					50					30					10
RW	70	50	30	10	70	50	30	10		50	30	10			50	30	10			50
RCR																				
0	119	119	119	119	116	116	116	116		111	111	111			106	106	106			102
1	114	112	110	108	112	110	108	106		106	104	103			102	101	100			99
2	110	105	102	99	107	104	101	98		101	98	96			98	96	94			95
3	105	100	95	92	103	98	94	91		96	92	90			93	91	88			91
4	101	94	90	86	99	93	89	86		91	87	85			89	86	84			88
5	97	90	85	81	95	89	84	81		87	83	80			85	82	79			84
6	93	85	80	77	92	85	80	76		83	79	76			82	78	75			81
7	89	81	76	73	88	81	76	73		80	75	72			79	75	72			78
8	86	78	73	69	85	77	73	69		76	72	69			75	72	69			75
9	83	75	70	66	82	74	69	66		73	69	66			72	69	66			72
10	80	72	67	63	79	71	66	63		70	66	63			70	66	63			69

AVERAGE LUMINANCE (cd/sqm):

	0°
0°	566184
5°	545872
10°	480127
15°	376308
20°	260637
25°	160570
30°	89364
35°	47665
40°	23614
45°	12051
50°	6629
55°	4322
60°	2092
65°	0
70°	0
75°	0
80°	0
85°	0



TEST NUMBER: P225426

CATALOG NUMBER: LSSQ2B10FL409727D010 2LBDLC*MB

ZONAL LUMENS:

Zone	Lumens	% Fixture
0°-10°	128.0	19.7
10°-20°	256.3	39.4
20°-30°	175.1	26.9
30°-40°	66.7	10.3
40°-50°	18.5	2.8
50°-60°	5.8	0.9
60°-70°	0.5	0.1
70°-80°	0.0	0.0
80°-90°	0.0	0.0
90°-100°	0.0	0.0
100°-110°	0.0	0.0
110°-120°	0.0	0.0
120°-130°	0.0	0.0
130°-140°	0.0	0.0
140°-150°	0.0	0.0
150°-160°	0.0	0.0
160°-170°	0.0	0.0
170°-180°	0.0	0.0
0°-30°	559.5	85.9
0°-40°	626.2	96.2
0°-60°	650.5	99.9
0°-90°	651.1	100.0
90°-120°	0.0	0.0
90°-150°	0.0	0.0
90°-180°	0.0	0.0
0°-180°	651.1	100.0

CANDELA DISTRIBUTION:

	0°	Flux
0°	1462	
5°	1404	128
15°	938	256
25°	376	175
35°	101	67
45°	22	19
55°	6	6
65°	0	1
75°	0	0
85°	0	0
90°	0	



TEST NUMBER: P225426

CATALOG NUMBER: LSSQ2B10FL409727D010 2LBDLC*MB

CANDELA DISTRIBUTION (FULL):

	0°
0°	1461.7
2.5°	1446.1
5°	1403.9
7.5°	1325.1
10°	1220.7
12.5°	1087.8
15°	938.4
17.5°	785.4
20°	632.3
22.5°	496.7
25°	375.7
27.5°	275.8
30°	199.8
32.5°	142.0
35°	100.8
37.5°	70.6
40°	46.7
42.5°	31.2
45°	22.0
47.5°	15.6
50°	11.0
52.5°	8.2
55°	6.4
57.5°	4.6
60°	2.7
62.5°	0.9
65°	0.0
67.5°	0.0
70°	0.0
72.5°	0.0
75°	0.0
77.5°	0.0
80°	0.0
82.5°	0.0
85°	0.0
87.5°	0.0
90°	0.0



Report Generated By E9808895 / USPTCWHP6082093





— 0°-180°







(END OF REPORT)